


Indianapolis International Airport –  
Midfield Terminal  
Indianapolis, IN



## Appendix A

### Ballast Schedule

Lamp Type	Ballast Catalog	Ballast Type	Lamp Watts	Lamp #	Ballast Watts	Power Factor	Ballast Factor
<b>F28T5</b>	VCN-132-MC	Electronic Instant Start	28	1	30	0.99	0.98
<b>F24T5HO</b>	ICN-2S24	Electronic Instant Start	24	2	52	0.98	1
<b>F32 T8</b>	VCN-2M32-MC	Electronic Instant Start	32	2	59	0.99	0.88
<b>F32 T8</b>	VCN-132-MC	Electronic Instant Start	32	1	30	0.98	0.98
<b>MH70 T6</b>	71A5237J	M98/M143	70	1	85	0.9	0.8
<b>MH150 T6</b>	71A5437J	M102	150	1	173	0.9	0.8
<b>MH250 ED28</b>	71A5730	M58	250	1	291	0.9	0.8

### Lamp Schedule

Lamp Label	Brand	Catalog #	Lamp Type	Lamp Watts	CCT (x100k)
<b>F28T5</b>	Philips	28W/835 Min Bipin T5 UNP	Linear Fluorescent T5 High Output	28	35
<b>F24T5HO</b>	Philips	24W/835 WH Min Bipin HO UNP	Linear Fluorescent T5 High Output	24	35
<b>F32 T8</b>	Philips	F32T8 ADV830 48 ALTO 1LP	Linear Fluorescent T8	32	35
<b>MH70 T6</b>	Philips	MasterColor CDM-T 70W/830 G12 T6 1CT	Metal Halide T6	70	30
<b>MH150 T6</b>	Philips	MasterColor CDM-T 150W/830 G12 T6 1CT	Metal Halide T6	150	30
<b>MH250 ED28</b>	GE	MVR250/SP30/U	Metal Halide ED 28	250	30