

VIMS Seawater Research Laboratory

Dan DiCriscio
AE Senior Thesis
Mechanical Option
2007



Outline

Background

Existing Conditions

Redesign Goals

System Redesign

Redesign Analysis

Conclusions

Acknowledgements

Questions

© Photo courtesy of Virginia Institute of Marine Science



Background-Building Stats

Outline

Background

Existing Conditions

Redesign Goals

System Redesign

Redesign Analysis

Conclusions

Acknowledgements

Questions

Building Size:

40,000 ft²

Building Type/Occupancy:

Laboratory

Construction Dates:

2005 - 2007

© Photo courtesy of Virginia Institute of Marine Science



Background-Project Team

Outline

Background

Existing Conditions

Redesign Goals

System Redesign

Redesign Analysis

Conclusions

Acknowledgements

Questions

Owner:

Virginia Institute of Marine Science

Architects & Engineers:

Clark Nexsen, Norfolk, VA

Lab Consultants:

RMF, Mt. Pleasant, SC

Contractor:

W. M. Jordan, Hampton Roads, VA

© Photo courtesy of Virginia Institute of Marine Science



Background-Location

Outline

Background

Existing Conditions

Redesign Goals


System Redesign

Redesign Analysis

Conclusions

Acknowledgements

Questions



Background-Location

Outline

Background

Existing Conditions

Redesign Goals

System Redesign

Redesign Analysis

Conclusions

Acknowledgements

Questions



Existing Conditions

Outline

Background

Existing Conditions

Redesign Goals

System Redesign

Redesign Analysis

Conclusions

Acknowledgements

Questions

The mechanical system supplies 100% OA to the entire building.

Administration spaces to be converted to Lab spaces

Additional plant source components (chillers & boilers) will be required, but the existing distribution system is sized for a 25% increase in load.

Mechanical equipment is necessary for laboratory process purposes.

© Photo courtesy of Virginia Institute of Marine Science



Existing Conditions

Calculated Building Loads & Load Profile

Outline

Background

(based on typical medium commercial load profile data from Pacific Electric & Gas Company)

Existing Conditions

Redesign Goals


System Redesign

Redesign Analysis

Conclusions

Acknowledgements

Questions



Existing Conditions

Outline

Background

Existing Conditions

Redesign Goals

System Redesign

Redesign Analysis

Conclusions

Acknowledgements

Questions

Run Around Energy Recovery Loop is already utilized

Distributed Pump System is already utilized

Enthalpy wheels cannot be utilized because of the risk of cross contamination of the supply air

© Photo courtesy of Virginia Institute of Marine Science



Redesign Goals

Outline

Background

Existing Conditions

Redesign Goals

System Redesign

Redesign Analysis

Conclusions

Acknowledgements

Questions

Reduce Building Energy Cost

High energy consumption

Required mechanical equipment

Reduce Emissions Generated by Building

VA utilities 43% coal

LEED

High pollution generation

High energy cost

© Photo courtesy of Virginia Institute of Marine Science



System Redesign

Outline

Background

Existing Conditions

Redesign Goals

System Redesign

Redesign Analysis

Conclusions

Acknowledgements

Questions

Initial System Resign

Thermal & electrical energy storage

Energy stored as hydrogen

Generate hydrogen through electrolysis powered by renewable energy sources

Hydrogen to be used as fuel for cogeneration system

© Photo courtesy of Virginia Institute of Marine Science



System Redesign

Outline

Background

Existing Conditions

Redesign Goals

System Redesign

Redesign Analysis

Conclusions

Acknowledgements

Questions

Initial System Resign Problems

On-site renewable energy sources are not adequate for system

Hydrogen generators don't meet required specifications

© Photo courtesy of Virginia Institute of Marine Science



System Redesign

Outline

Background

Existing Conditions

Redesign Goals

System Redesign

Redesign Analysis

Conclusions

Acknowledgements

Questions

Adjusted Redesign

Cogeneration

What is it?

On-site power generation in which the waste heat created by the power generator is recovered and used to heat and cool the building as needed.

© Photo courtesy of Virginia Institute of Marine Science



System Redesign - Equipment

Outline

Background

Existing Conditions

Redesign Goals

System Redesign

Redesign Analysis

Conclusions

Acknowledgements

Questions

Cogeneration

Equipment Options?

Typically the 4 most common types of generators are:

I.C.R. Engines Too Noisy

Fuel Cells Too Expensive

MicroTurbines Lacks Adequate Thermal Capacity For District Applications

Gas Turbines Good Fit For Design

© Photo courtesy of Virginia Institute of Marine Science



System Redesign - Equipment

Outline Cogeneration - Generator Equipment Used

Background

Existing Conditions

CAT Solar Centaur 40 Gas Turbine

Redesign Goals


System Redesign

Redesign Analysis

Conclusions

Acknowledgements

Questions



PA6877545



System Redesign - Equipment

Outline Cogeneration – Generator Equipment Used

Background

Existing Conditions

CAT Solar Centaur 40 Gas Turbine

Redesign Goals

System Redesign


	e ⁻ Output (MW)	Fuel (MMBTU/hr)
ISO (59°F)	3.53	48.64
Design (99°F)	2.59	42.01

Redesign Analysis

Conclusions

Acknowledgements

Questions



System Redesign - Equipment

Outline

Background

Existing Conditions

Redesign Goals

System Redesign

Redesign Analysis

Conclusions

Acknowledgements

Questions

Cogeneration

Heat Recovery

The CAT Centaur 40 Generator Set includes a HRSG

The HRSG generates steam by recovering the waste heat in the exhaust stream of the gas turbine

Steam is used to drive the absorption chillers

© Photo courtesy of Virginia Institute of Marine Science

System Redesign - Equipment

Outline

Background

Existing Conditions

Redesign Goals

System Redesign

Redesign Analysis

Conclusions

Acknowledgements

Questions

Cogeneration

Additional Equipment

To get the most use of the recovered heat from the generator Absorption Chillers should be used.

Absorption Chillers use steam created from the HRSG and can be used to heat and cool a building.

The absorption chillers require a condenser water loop

© Photo courtesy of Virginia Institute of Marine Science



System Redesign - Equipment

Outline

Background

Existing Conditions

Redesign Goals

System Redesign

Redesign Analysis

Conclusions

Acknowledgements

Questions

Cogeneration

Additional Equipment

Equipment required with the condenser water loop:

Condenser Water Pumps

Cooling Towers

© Photo courtesy of Virginia Institute of Marine Science



System Redesign - Equipment

Outline Cogeneration - Absorption Chiller Equipment Used

Background

Existing Conditions York YIA-ST-2A3 Single Stage Absorption Chiller

Redesign Goals

System Redesign

Redesign Analysis

Conclusions

Acknowledgements

Questions

	Condenser	Evaporator
Flow Rate (gpm)	620	413
Temperature (°F)	101.4 - 85	54 - 44
Pressure Drop (ft)	13	12
Input Electrical (kW)	5.9	
Input Steam (lbm/hr)	3140	
Output (tons)	172	
Rated COP	0.72	



System Redesign - Equipment

Outline Cogeneration - Condenser Water Pump Equipment Used

Background

Existing Conditions

Bell & Gossett

Redesign Goals

DETAIL SUMMARY			
Pump Series:	1510	Pump Size:	6G
Flow Rate: (USGPM)	620	Total Head: (ft.)	50
Pump Speed (RPM)	1150	NPSH req (ft)	3.5
Weight: (lbs)	970	Cost Index:	185
Suction Size: (in)	8	Suction Velocity (fps)	4
Discharge Size: (in)	6	Discharge Velocity: (fps)	6.9
Impeller Diameter: (in)	11.125	Efficiency: (%)	75.32
Max Impeller Dia (in)	13.5		
Max Flow (USGPM)	1491	Duty Flow/Max Flow (%)	0.42
Flow @ BEP (USGPM)	1010	Min. Rec. Flow: (USGPM)	400
Motor Power, HP:	15	Frame Size:	284T
Pump Power (BHP)	10.58		
Max Power (BHP)	15.49		

System Redesign

Redesign Analysis

Conclusions

Acknowledgements

Questions



System Redesign - Equipment

Outline Cogeneration - Cooling Tower Equipment Used

Background

Existing Conditions Marley NC8303FL1 Cooling Tower

Redesign Goals

System Redesign

Redesign Analysis

Conclusions

Acknowledgements

Questions

Flow Rate (gpm)	620
Temperature (°F)	101.4 - 85
Wet Bulb (°F)	76
Range (°F)	16.4
RPM	356
Fan Motor Output (BHP)	15



Redesign Analysis

Outline

Background

Existing Conditions

Redesign Goals

System Redesign

Redesign Analysis

Conclusions

Acknowledgements

Questions

Reduced Emissions

Reduced Energy Cost

Pay Back

LEED Credits

© Photo courtesy of Virginia Institute of Marine Science



Redesign Analysis - Emissions

Outline Emissions Generated by Existing Building and Surrounding Buildings

Background

Existing Conditions

Redesign Goals

System Redesign

Redesign Analysis

Conclusions

Acknowledgements

Questions

Building	MWh	Tons CO ₂	Tons SO ₂	Tons NO _x
Seawater Research Lab Daily	26.37	63.98	0.290139	0.084729
Seawater Research Lab Yearly	9387.94	22777.43	103.2895	30.16346
Watermen's Hall Daily	4.70	11.40	0.051706	0.0151
Watermen's Hall Yearly	1715.33	4059.18	18.40729	5.375447
Nunnally Hall Daily	5.22	12.66	0.057398	0.016762
Nunnally Hall Yearly	1904.17	4506.06	20.43378	5.96724
Wetlands Facility Daily	0.22	0.54	0.002431	0.00071
Wetlands Facility Yearly	80.64	190.83	0.865366	0.252711
Chesapeake Bay Hall Daily	18.67	45.31	0.205452	0.059998
Chesapeake Bay Hall Yearly	6815.80	16129.02	73.14078	21.35917
Geddings House Daily	0.17	0.41	0.00186	0.000543
Geddings House Yearly	61.70	146.01	0.662109	0.193354
Wilson House (CBNERR) Daily	1.17	2.84	0.012878	0.003761
Wilson House (CBNERR) Yearly	427.24	1011.02	4.584706	1.338864
DCOP Facility Daily	0.22	0.53	0.0024	0.000701
DCOP Facility Yearly	79.62	188.42	0.854412	0.249512
CBNERRVA Annex Daily	1.60	3.89	0.017628	0.005148
CBNERRVA Annex Yearly	584.82	1383.93	6.27573	1.83269



Redesign Analysis - Emissions

Outline Emissions Generated by Buildings serviced by CHP System

	Building	MWh	Tons CO ₂	Tons SO ₂	Tons NO _x
Background	Seawater Research Lab Daily	23.44	7.52	5.47E-08	0.002244
Existing Conditions	Seawater Research Lab Yearly	8556.87	2743.11	1.99E-05	0.819087
	Watermen's Hall Daily	4.70	1.51	1.1E-08	0.00045
Redesign Goals	Watermen's Hall Yearly	1715.33	549.89	4E-06	0.164196
	Nunnally Hall Daily	5.22	1.67	1.22E-08	0.000499
System Redesign	Nunnally Hall Yearly	1904.17	610.43	4.44E-06	0.182272
	Wetlands Facility Daily	0.22	0.07	5.15E-10	2.11E-05
Redesign Analysis	Wetlands Facility Yearly	80.64	25.85	1.88E-07	0.007719
	Chesapeake Bay Hall Daily	18.67	5.99	4.35E-08	0.001787
Conclusions	Chesapeake Bay Hall Yearly	6815.80	2184.97	1.59E-05	0.652427
	Geddings House Daily	0.17	0.05	3.94E-10	1.62E-05
Acknowledgements	Geddings House Yearly	61.70	19.78	1.44E-07	0.005906
	Wilson House (CBNERR) Daily	1.17	0.38	2.73E-09	0.000112
Questions	Wilson House (CBNERR) Yearly	427.24	136.96	9.96E-07	0.040896
	DCOP Facility Daily	0.22	0.07	5.09E-10	2.09E-05
	DCOP Facility Yearly	79.62	25.52	1.86E-07	0.007621
	CBNERRVA Annex Daily	1.60	0.51	3.74E-09	0.000153
	CBNERRVA Annex Yearly	584.82	187.48	1.36E-06	0.05598



Redesign Analysis - Emissions

Outline Emissions Reduction

	Building	% Decrease CO2	% Decrease SOx	% Decrease NOx
Background	Seawater Research Lab Daily	88.25	100.00	97.35
Existing Conditions	Seawater Research Lab Yearly	87.96	100.00	97.28
	Watermen's Hall Daily	86.79	100.00	97.02
Redesign Goals	Watermen's Hall Yearly	86.45	100.00	96.95
	Nunnally Hall Daily	86.79	100.00	97.02
System Redesign	Nunnally Hall Yearly	86.45	100.00	96.95
	Wetlands Facility Daily	86.79	100.00	97.02
Redesign Analysis	Wetlands Facility Yearly	86.45	100.00	96.95
	Chesapeake Bay Hall Daily	86.79	100.00	97.02
Conclusions	Chesapeake Bay Hall Yearly	86.45	100.00	96.95
	Geddings House Daily	86.79	100.00	97.02
Acknowledgements	Geddings House Yearly	86.45	100.00	96.95
	Wilson House (CBNERR) Daily	86.79	100.00	97.02
Questions	Wilson House (CBNERR) Yearly	86.45	100.00	96.95
	DCOP Facility Daily	86.79	100.00	97.02
	DCOP Facility Yearly	86.45	100.00	96.95
	CBNERRVA Annex Daily	86.79	100.00	97.02
	CBNERRVA Annex Yearly	86.45	100.00	96.95



Redesign Analysis – Energy Costs

Outline

Background

Existing Conditions

Redesign Goals

System Redesign

Redesign Analysis

Conclusions

Acknowledgements

Questions

Reduced Energy Costs

Spark Gap = Cost/MMBTU_e – Cost/MMBTU_{thermal}

Spark Gap ~ \$15

Energy Savings

Average Annual Savings: \$876,739

Lifetime Savings: \$20,165,001

© Photo courtesy of Virginia Institute of Marine Science



Redesign Analysis – Pay Back

Outline

Background

Existing Conditions

Redesign Goals

System Redesign

Redesign Analysis

Conclusions

Acknowledgements

Questions

Equipment First Cost:

\$6,020,920

Simple Pay Back Period (without power sell back to the utilities):

10 Years

Total savings over 22 years:

\$13,837,958

© Photo courtesy of Virginia Institute of Marine Science



Redesign Analysis – LEED

Outline

Background

Existing Conditions

Redesign Goals

System Redesign

Redesign Analysis

Conclusions

Acknowledgements

Questions

LEED Requirements

Annual Efficiency: 70% > 60%

Annual Energy Cost Reduction: 46% > 42%

Absorption Chillers reduce CFC refrigerants

Add Building systems commissioning to construction schedule

© Photo courtesy of Virginia Institute of Marine Science



Redesign Analysis – LEED

Outline

Background

Existing Conditions

Redesign Goals

System Redesign

Redesign Analysis

Conclusions

Acknowledgements

Questions

LEED Credits

LEED EA Credit 1

42% Energy Cost Reduction = 10 points

LEED EA Credit 4

No Refrigerants Used = 1 point

LEED Total = 11 points

© Photo courtesy of Virginia Institute of Marine Science



Conclusions

Outline

Background

Existing Conditions

Redesign Goals

System Redesign

Redesign Analysis

Conclusions

Acknowledgements

Questions

CHP systems can significantly reduce emissions

CHP systems can reduce energy costs

This is a system the should be considered by VIMS

Recommend further analysis of CHP system with actual energy loads of the surrounding buildings

© Photo courtesy of Virginia Institute of Marine Science



Acknowledgements

Outline

Background

Existing Conditions

Redesign Goals

System Redesign

Redesign Analysis

Conclusions

Acknowledgements

Questions

Thank You!

Clark Nexsen

Virginia Institute of Marine Science

AE Faculty

AE Peers

Mom, Neil, Tony, and Ashley

© Photo courtesy of Virginia Institute of Marine Science



Questions?

Outline

Background

Existing Conditions

Redesign Goals


System Redesign

Redesign Analysis

Conclusions

Acknowledgements

Questions



© Photo courtesy of Virginia Institute of Marine Science

