
Condenser Water Loop

# MILTON HERSHEY SCHOOL

**FOUNDED 1909** 



#### Owner

- The Milton Hershey School Location
- Hershey, PA Project Size
- 110,000 sq ft
- Total Cost
- \$23,500,000

Design-Bid-Build Contract **Under Construction** 

## **EXISTING CONDITIONS**

### The Supply Center

- General Office and Conference Rooms
- Kitchen and Bakery
- Clothing Store
- Alterations Seamstress
- Mail Distribution Center
- General Building Storage

#### Existing Mechanical Systems AIR SIDE

- 14 Total Air Handling Units
  - 10 VAV Units General Office Space
  - 4 CAV Units 100% OA Make-Up Units
- Housed in Elevated Mezzanine Floor Water Side
- (2) 270 Ton Water Cooled Centrifugal Chillers - 45 degree Chilled Water
- (3) Natural Gas Fired Steam Boilers Walk-In-Freezer Condenser Water Loop
- Rejected Heat From Condenser Met Directly by Chilled Water

## MECHANICAL SYSTEM REDESIGN

#### Dedicated Outdoor Air Systems


- Replace 10 VAV AHUs with 2 DOAS Units
  - Saves in First and Operating Costs
- Water Source Heat Pumps
  - Parallel Cooling System
  - Integration of Water Source Loop with Condenser Water Loop

#### Direct Fired Absorption Chiller-Heater

- Single Effect LiBr Absorption Cycle
- Heat Exchanger in High Temperature Generator
- Simultaneous Cooling and Hot Water Production
- (2) 240 Cooling Ton Chiller-**Heaters Selected**
- Meets Cooling Load, HVAC Heating, and Domestic Hot Water Heating
- Redundancy for Continuous Condenser Water Loop Heat Rejection


## Walk-In-Freezer Condenser Water Loop Heat Recovery

- 1282 MBH of Possible Heat Recovery
  - 84 degree Leaving Water Temperature
  - 65 degree Operating Temperature
- Water Source Loop Winter Time Heat Addition Source
- Domestic Hot Water Preheat



### RELOCATION OF AHUS TO ROOF

- Eliminates Need for Mezzanine Floor
- Requires Structural Adjustments



#### **ECONOMIC ANALYSIS**

	Existing System	Redesigned System	
Cooling Cost	\$67,577	N/A	
HVAC Heating Cost	\$23,016	N/A	
Hot Water Heating Cost	\$58,371	N/A	
Combined Heating and Cooling Cost	N/A	\$117,370	
Air System Fan Cost	\$21,303	\$12,318	
Pump Cost	\$29,274	\$20,480	
Cooling Tower Cost	\$9,920	\$16,440	
Total Operating Cost	\$209,461	\$166,608	
Mechancial First Cost	\$622,840	\$682,885	
Mezzanine Floor Cost	\$154,458	N/A	
Total First Cost	\$777,298	\$683,173	
20 Year Life Cycle Cost	\$3,043,808	\$2,512,748	

Redesign Saves: Energy Initial Cost Operating Cost

Redesign is \$530,000 Less Over 20 Years Redesign Integrates Multiple Building Systems Redesign is Benificial for MHS New Supply Center