

BUILDING AND PLANT ENERGY ANALYSIS REPORT



UNIVERSITY RIDGE AT EAST STROUDSBURG UNIVERSITY EAST STROUDSBURG, PA

PREPARED FOR:
JAE-WEON JEONG, PH.D.

BY:
MATTHEW CARR
MECHANICAL OPTION
OCTOBER 27, 2006

Table of Contents

Executive Summary	3
ASHRAE Standard 90.1 Compliance	4
Lost Rentable Space Comparison	9
Mechanical System First Cost	9
LEED-NC Version 2.2 Analysis	10
Energy Utilization Data	11
TRANE TRACE 700 Energy & Load	12
TRACE 700 Energy Consumption & Operating Cost	13
Appendix A	14
Appendix B	16
Appendix C	17
Appendix D	20
Appendix E	33
References	39

Executive Summary

This report is intended to analyze the building and plant energy for the University Ridge student housing complex at East Stroudsburg. The building is analyzed using ASHRAE's Standard 90.1-2004 Energy Standard and the LEED-NC Green Building Rating System. These two guides analyze the energy use and compliance for green and sustainable buildings. This report also looks at the impact of mechanical space which results in a loss of rentable space and the mechanical system first cost. Moreover, an energy and design load estimates were calculated using Trace 700 which is a readily used design and analysis program used by designers. Energy consumption and cost data using utility rates associated with the mechanical system were also determined using this program.

The degree of University Ridge's compliance for energy efficient design was demonstrated using ASHRAE Standard 90.1. This guide is the latest update and most acceptable design standard for energy efficient design. The buildings envelope, HVAC system, service water heating, and lighting were all analyzed to determine its degree of compliance.

The LEED Green Building Rating System was used to measure its degree of sustainability and environmentally friendliness. The system consists of 6 categories in which points can be earned towards a certification. For the intents and purposes of this report, only the topics concerning mechanical systems were analyzed.

The mechanical spaces comprise only 2% of lost rentable space of the buildings gross square footage. The first cost of the mechanical systems came in at \$3.4 million dollars or about 21.6% of the buildings total cost.

TRANE TRACE 700 was used to calculate the design load for the spaces using design conditions from the design documents. From these design calculations, energy and utility cost information was obtained. Utility rates were based on an actual utility bill from June of 2006.

ASHRAE Standard 90.1 Compliance

Building Envelope – Section 5

In determining the buildings envelope compliance, sections 5.1, 5.4, 5.5, 5.7, and 5.8 of Standard 90.1 must be met in order for the building to be considered acceptable. It is assumed that the buildings pass sections 5.1, 5.4, 5.7, and 5.8 as they cannot be verified with given information.

5.5 Prescriptive Path

Given the location and occupancy of the buildings, the envelope must comply with the non-residential section of Climate Zone 5A. These requirements are stated in table 5.5-5 of Standard 90.1 as follows:

**TABLE 5.5-5
Building Envelope Requirements For Climate Zone 5 (A,B,C)**

	Residential	
	Assembly Maximum	Insulation Min. R-Value
Opaque Elements		
<i>Roofs</i>		
Insulation Entirely above Deck	U-0.063	R-15.0 ci
Metal Building	U-0.065	R-19.0
Attic and Other	U-0.027	R-38.0
<i>Walls, Above Grade</i>		
Mass	U-0.090	R-11.4 ci
Metal Building	U-0.057	R-13.0 + R-13.0
Steel Framed	U-0.064	R-13.0 + R-7.5 ci
Wood Framed and Other	U-0.089	R-13.0
<i>Wall, Below Grade</i>		
Below Grade Wall	C-1.140	NR
<i>Floors</i>		
Mass	U-0.074	R-10.4 ci
Steel Joist	U-0.038	R-30.0
Wood Framed and Other	U-0.033	R-30.0
<i>Slab-On-Grade Floors</i>		
Unheated	F-0.730	NR
Heated	F-0.840	R-10 for 36 in.
<i>Opaque Doors</i>		
Swinging	U-0.700	
Non-Swinging	U-0.500	
	Assembly Max. U (Fixed/ Operable)	Assembly Max. SHGC (All Orientations/ North-Oriented)
Fenestration		

<i>Vertical Glazing, % of Wall</i>		
0-10.0%	ufixed-0.57	SHGcall-0.49
	uoper -0.67	SHGCnorth-0.49
10.1-20.0%	ufixed-0.57	SHGcall-0.39
	uoper -0.67	SHGCnorth-0.49
20.1-30.0%	ufixed-0.57	SHGcall-0.39
	uoper -0.67	SHGCnorth-0.49
30.1-40.0%	ufixed-0.57	SHGcall-0.39
	uoper -0.67	SHGCnorth-0.49
40.1-50.0%	ufixed-0.46	SHGcall-0.26
	uoper -0.47	SHGCnorth-0.49
<i>Skylight with Curb, Glass, % of Roof</i>		
0-2.0%	uall-1.17	SHGcall-0.49
2.1-5.0%	uall-1.17	SHGcall-0.39
<i>Skylight with Curb, Plastic, % of Roof</i>		
0-2.0%	uall-1.10	SHGcall-0.77
2.1-5.0%	uall-1.10	SHGcall-0.62
<i>Skylight without Curb, All, % of Roof</i>		
0-2.0%	uall-0.69	SHGcall-0.49
2.1-5.0%	uall-0.69	SHGcall-0.39

Opaque Elements

Roofs

The buildings utilize an attic system with R-30 insulation. This R-value does not meet the required value for residential construction. However, this value does meet the required value for non-residential construction. The overall assembly U value does not meet 90.1 with a value of 0.030, as seen in Appendix A, compared to a required value of 0.027. Moreover, the assembly U-factor will not meet because of this shortfall in insulation. A value of 0.0355 was calculated and does not meet the required value of 0.027.

Walls, Above Grade

For assemblies listed on the design documents, exterior walls above grade call for 2x6 wood construction with R-13 insulation and an assembly U-Value of 0.086 as calculated in Appendix A. These values exceed the maximum and minimum thus beating the standard.

Walls, Below Grade

Below grade walls need to meet a maximum assembly factor of C-1.14. The below grade 10" concrete walls with 1.5" insulation at an R-value of 7.5 have a C-value of 0.147 found in Table A4.2 in Appendix A

of Standard 90.1 thus meeting Standard 90.1. No required minimum R-value of insulation is needed.

Slab-On-Grade Floors

For an unheated slab-on-grade floor, no maximum required R-value of insulation is needed. An F-value of 0.7 for 4" concrete floors with R-10 24" horizontal insulation can be found in Table A6.3 in Appendix A of 90.1 which meets the maximum of 0.730.

Opaque Doors

The buildings do not utilize opaque doors for entry ways.

Fenestration

Vertical Glazing % of Wall

It was determined from the architectural design elevations that the window to wall area ratio falls between 10-20%. Therefore, the maximum U-value for operable windows is 0.67 and inoperable windows requiring a value of 0.57. The manufacturer's data that has been provided beats both of these values with a U-value of 0.49, thus beating both of the requirements, see Appendix A. The Solar Heat Gain Coefficient, SHGC, for the windows used has a value of 0.65 which does not meet the required SHGC of 0.39 for all orientations or 0.49 for north orientations. All of the above values were obtained from Silver Line Windows.

Heating, Ventilating, and Air Conditioning – Section 6

After reviewing the requirements as stated in Standard 90.1 Section 6.3.2 Criteria, it is found that the mechanical system meets the standards stated in that section. The air conditionings condensing unit meets the standard as stated in Table 6.8.1A for a split system under 65,000 Btu/h having a Seasonal Energy Efficiency Rating (SEER) of 10.0 where 10.0 is the minimum for being installed before 1/23/06. Given the size of the systems for climate zone 5A, 30.7-70.1 MBH, an economizer is not required per Table 6.5.1.

The duct furnaces that supply conditioned air to spaces are supplied with hot water from exclusive water heaters and shall be considered as gas fired boilers. Therefore, at an input of 65,000 Btu/h, an AFUE of 80% is required for a minimum efficiency. However, the water heaters

supplied do not have an AFUE rating since they run year round and cannot be compared to the table.

The duct furnace fans meet the required horse power values of Table 6.5.3.1 since the duct furnace fans are 1 hp or below and range from 1225-1700 cfm. The maximum allowable motor power is 1.2 hp/1000 cfm. Duct located in the ceiling can be considered indirectly conditioned spaces and do not require insulation per Table 6.8.2B. However, it is stated that in the specifications under section 15081 that supply ducts are rigid fiber board and have an R-value of 4.3, thus meeting 90.1.

It is assumed that all other sections of 6.3.2 Criteria are satisfied in the design documents and by commissioning.

Service Water Heating – Section 7

A single type of gas storage water heater is utilized for service water heating throughout the buildings at a capacity of 65,000 Btu/h and 50 gallons. This rating puts it in the category of 0.62-0.0019V EF for Required Performance according to Table 7.8 of Standard 90.1. The listed Energy Factor (EF) from design data is 0.58 thus meeting the required value in the Standard.

Lighting – Section 9

Interior Space Lighting

The lighting section of ASHRAE Standard 90.1 deals with the maximum allowable power density per floor area for a building. I utilized the building area method to yield the following results for a dormitory.

Building Area Method

Building Type:	Dormitory
Allowed Lighting Power Density:	1.0 W/ft ²
Gross Lighted Floor Area:	140,000 ft ²
Total Lighting Power:	64,956 W

Actual Lighting Power Density: 0.464 W/ft²

The design of the building used compact fluorescents and regular fluorescence for all spaces, thus yielding a very low power density and increased energy savings both through power use and decreased load to internal spaces.

Conclusion

In conclusion, most of the service elements meet or exceed the requirements for ASHRAE Standard 90.1. The only areas that are lacking are the use of R-30 insulation in the attic and the solar heat gain coefficient of the windows. The R-30 insulation, which is located in the attic, can be argued that it is an unoccupied space and can therefore be considered for a non-residential application and would then pass. The SHGC is high for the windows because it is clear glass. If a tinted glass or low emittance glass was used, the windows would beat the SHGC.

Lost Rentable Space Comparison

The designers took into consideration the fact that lost rentable space due to the mechanical systems greatly impacts the cost of construction. Using space to the most efficient way possible increases the amount of usable space and dictates the type of mechanical system which can be used. There was very insignificant loss of space with the current system as it is located in a mechanical closet local to the each residence.

A total of 2,787 ft² of space in the buildings is utilized for mechanical space. This equates to about 2% of the 140,000 gross square footage in lost rentable space.

Mechanical System First Cost

As this project was completed in September of 2005, the actual mechanical costs were obtained. The HVAC cost equates to \$2.1 million of the project. The other components of the mechanical first cost include plumbing at \$1.0 million and fire protection at \$300,000. This mechanical system first cost then sums to the amount of \$3.4 million or \$24.29 per square feet which is about 21.6% of the building cost.

LEED-NC Version 2.2 Analysis

The Leadership in Energy and Environmental Design (LEED) provides the basic guidelines for building designers to design to green, environmentally friendly, and sustainable standards. This standard was created and is maintained by the United States Green Building Council (USGBC) which is the nation's foremost association of professionals from the building industry in order to promote the design and implementation of environmentally friendly buildings. LEED consists of a point system with different levels of certification depending on how environmentally friendly a building is. Ratings, which can be attained, range from an accredited building to silver, gold, and platinum, where a platinum rating is the highest attainable.

The Sustainable Sites category does not contain any mechanically related points which can be obtained.

The buildings and site do not utilize any Water Efficiency techniques to reduce the amount of water consumed and therefore earns no points.

In the Energy and Atmosphere category, no outside commissioning authority was hired to inspect the systems and therefore does not pass EA Prerequisite 1. For EA Prerequisite 2, no minimum energy level was established and the buildings were designed to ASHRAE Standard 90.1-2004 and as a result do not pass. As for EA Prerequisite 3, CFC refrigerants in the form of R-22 and does not pass the ozone depletion requirement. None of the following Credits for this section are achieved as a result of failure to meet the above prerequisites.

The Materials and Resources Category does not apply to the mechanical system and is not analyzed.

For Indoor Air Quality, EQ Prerequisite 1 is met as seen in Technical Assignment 1 which found the buildings to be in compliance with ASHRAE Standard 62.1. Prerequisite 2 is met since the buildings are smoke free and smoking areas are assumed to be compliant. EQ Credit 1 is not received because CO₂ sensors are not used. Credit 2 cannot be determined with the information at hand. The techniques recommended for Credit 3.1 and 3.2 were not implemented during construction and earn no point. Low-emitting materials were not used for construction and finishes and therefore Credit 4.1 to 4.4 are not earned. Credit 5 is not earned because required systems are not

used. Credit 6.1 is earned as the multi-occupant zones contain light switches for each space and therefore have a high level of control. Credit 6.2 is a possible earned point as each multi-occupant space has its own thermostat for control. Credit 7.1 and 7.2 are not earned as it is not designed to ASHRAE 55 with proper documentation. Credit 8.1 and 8.2 cannot be determined.

There is no credit earned for the final category, Innovation and Design process.

Refer to Appendix B for a spreadsheet breakdown.

Energy Utilization Data

Since this project has been completed for well over a year at the time of this writing, an energy bill from PP&L and Met-Ed was obtained. PP&L is the supplier of gas while Met-Ed supplies electricity. Refer to Appendix C for the bill.

TRANE TRACE 700 Energy & Load Analysis

The following calculations and results were obtained using TRACE 700, which is a simulation of HVAC systems and energy usage. The main sources of load for the spaces were people, lighting, and small appliances. Medium sedentary occupants were assumed along with the previously calculated lighting power density and miscellaneous load of 0.5 – 1.0 W/ft² to account for appliances. A schedule was created for the occupants where it is assumed that 20 percent of the occupants are not in the building between 8-5. Also for the intents of this report, the floor multiplier was used where typical apartments are stacked. The results for the calculated design load can be found in Appendix D. The values that were found using the program are going to differ from design document values. This is because of the fact that in order to save time, the design was simplified to four typical spaces so accurate loads for each space was not found. The difference comes from the change in direction in which the spaces face.

TRACE 700 Energy Consumption & Operating Cost

Energy consumption and the utility operating cost of equipment were found for University Ridge using TRACE 700. Gas and electric rates from PP&L and Met-Ed were obtained for the building as stated previously. These rates were then put into the simulation to yield utility costs as seen in Appendix E.

An energy analysis was not performed by Greenman-Pedersen Inc. Engineers because it is not a requirement. The delivery method was one of a Design-Build structure and the extra time and cost required to perform an energy analysis may have hindered the projects cost and schedule.

The yearly energy utilization data which was obtained from a single months meter bill cannot be accurately compared to the actual bill. However, the values for the summer months which were calculated cannot be accurately be determined because the buildings are not fully occupied and therefore the calculated values seem high. Winter values for comparison cannot be accurately compared because of unavailable data. Refer to data in Appendix C and E.

Appendix A

R-13 2x4 Stud Wall U-Value

Material	Insulation	Wood Stud
OA Film	0.17	0.17
Sheathing	1.57	1.57
Insulation	13	-
Wood Stud	-	3.5
5/8 Gypsum Board	0.56	0.56
IA Film	0.68	0.68

R-Value	15.96	6.48
U-Value	0.0626	0.1543

$$U_{tot} = 0.75(0.0626) + 0.25(0.155) = 0.086$$

Attic Roof U-Value

Material	Insulation	Wood Stud
OA Film	0.17	0.17
Asphalt Shingles	0.21	0.21
1/2" OSB	0.5	0.5
2x4 Truss	-	3.9
0.5" Air Gap	1.88	1.88
Insulation	30	-
Wood Stud	-	3.9
1/2 Gypsum Board	0.32	0.32
IA Film	0.68	0.68

R-Value	33.76	11.56
U-Value	0.0296	0.0865

$$U_{tot} = 0.75(0.0296) + 0.25(0.0865) = 0.0354$$



NEW CONSTRUCTION WINDOW THERMAL PERFORMANCE

THERMAL TEST INFORMATION

Windows are tested and certified to the NFRC 100-97 specification for the thermal performance of the entire window unit.

WINDOW SERIES	TEST METHOD	GLAZING TYPE	U VALUE	SHGC	VISIBLE LIGHT TRANSMITTANCE	ENERGY STAR COMPLIANCE
1400 Double Hung	NFRC 100-97	Clear I.G.*	0.49	0.63	0.66	-
		LoE ² I.G.*	0.35	0.34	0.58	
		LoE ² / Argon I.G.*	0.32	0.33	0.58	
		Clear I.G. with Contour Grille**	0.51	0.56	0.59	-
		LoE ² I.G. with Contour Grille**	0.38	0.30	0.52	
1450 / 1460 Fixed Lite	NFRC 100-97	Clear I.G.*	0.50	0.67	0.71	-
		LoE ² I.G.*	0.35	0.36	0.61	
		LoE ² / Argon I.G.*	0.30	0.35	0.61	
		Clear I.G. with Contour Grille**	0.51	0.61	0.63	-
		LoE ² I.G. with Contour Grille**	0.37	0.32	0.55	
2110 / 2160 Single Hung	NFRC 100-97	Clear I.G.	0.49	0.65	0.69	-
		LoE ² I.G.	0.35	0.35	0.60	
		LoE ² / Argon I.G.	0.30	0.35	0.60	
		Clear I.G. with Flat Grille	0.49	0.59	0.61	-
		LoE ² I.G. with Flat Grille	0.35	0.31	0.54	
2130 / 2135 2180 / 2185 Fixed Lite	NFRC 100-97	Clear I.G.	0.49	0.67	0.71	-
		LoE ² I.G.	0.34	0.36	0.61	
		LoE ² / Argon I.G.	0.29	0.35	0.61	
		Clear I.G. with Flat Grille	0.49	0.61	0.63	-
		LoE ² I.G. with Flat Grille	0.34	0.32	0.55	
2710 / 2760 Single Hung	NFRC 100-97	Clear I.G.	0.52	0.60	0.62	-
		LoE ² I.G.	0.38	0.33	0.54	
		LoE ² / Argon I.G.	0.34	0.33	0.54	
		Clear I.G. with Flat Grille	0.52	0.55	0.55	-
		LoE ² I.G. with Flat Grille	0.38	0.30	0.49	
2800 Slider	NFRC 100-97	Clear I.G.	0.49	0.62	0.66	-
		LoE ² I.G.	0.35	0.34	0.58	
		LoE ² / Argon I.G.	0.31	0.33	0.58	
		Clear I.G. with Flat Grille	0.49	0.56	0.59	-
		LoE ² I.G. with Flat Grille	0.35	0.30	0.52	
		LoE ² / Argon with Flat Grille	0.31	0.30	0.52	

* Denotes that windows with a 1/1 pattern or flat grilles share the same U-Values.

** Both contour grilles and flat grilles carry the same Solar Heat Gain Coefficient and Visible Light Transmittance performance values.

For more information on Silver Line Windows, visit us at www.silverlinewindows.com or call us at 800-234-4228

Appendix B



LEED-NC

LEED-NC Version 2.2 Registered Project Checklist

University Ridge at East Stroudsburg University
East Stroudsburg, PA,

Yes	?	No			
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Water Efficiency		5 Points
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Credit 1.1	Water Efficient Landscaping, Reduce by 50%	1
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Credit 1.2	Water Efficient Landscaping, No Potable Use or No Irrigation	1
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Credit 2	Innovative Wastewater Technologies	1
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Credit 3.1	Water Use Reduction, 20% Reduction	1
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Credit 3.2	Water Use Reduction, 30% Reduction	1
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Energy & Atmosphere		17 Points
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Prereq 1	Fundamental Commissioning of the Building Energy Systems	Required
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Prereq 2	Minimum Energy Performance	Required
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Prereq 3	Fundamental Refrigerant Management	Required
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Credit 1	Optimize Energy Performance	1 to 10
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Credit 2	On-Site Renewable Energy	1 to 3
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Credit 3	Enhanced Commissioning	1
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Credit 4	Enhanced Refrigerant Management	1
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Credit 5	Measurement & Verification	1
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Credit 6	Green Power	1
					continued...
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Indoor Environmental Quality		15 Points
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Prereq 1	Minimum IAQ Performance	Required
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Prereq 2	Environmental Tobacco Smoke (ETS) Control	Required
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Credit 1	Outdoor Air Delivery Monitoring	1
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Credit 2	Increased Ventilation	1
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Credit 3.1	Construction IAQ Management Plan, During Construction	1
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Credit 3.2	Construction IAQ Management Plan, Before Occupancy	1
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Credit 4.1	Low-Emitting Materials, Adhesives & Sealants	1
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Credit 4.2	Low-Emitting Materials, Paints & Coatings	1
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Credit 4.3	Low-Emitting Materials, Carpet Systems	1
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Credit 4.4	Low-Emitting Materials, Composite Wood & Agrifiber Products	1
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Credit 5	Indoor Chemical & Pollutant Source Control	1
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Credit 6.1	Controllability of Systems, Lighting	1
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Credit 6.2	Controllability of Systems, Thermal Comfort	1
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Credit 7.1	Thermal Comfort, Design	1
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Credit 7.2	Thermal Comfort, Verification	1
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Credit 8.1	Daylight & Views, Daylight 75% of Spaces	1
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Credit 8.2	Daylight & Views, Views for 90% of Spaces	1



Matthew Carr AE 481W October 27, 2006

Appendix C



FAST BILL INFORMATION
 The balance of your last bill 336.37
 Payments Track you 336.37CB
 Balance Before this Bill .00

AUG 07 2006

6535

Account Number: 0798478-0

Bill for Service to:
Capstone Management Corp

F Room- St #BLDG 2
 East Stroudsburg, PA
 Rate Class:
 Landlord/Resiliuous heat
 Statement Date:
 August 02, 2006
 Next Scheduled Meter
 Reading On or About:
 August 31, 2006

If you have any
 questions, please
 call us at:
 (800)652-0550
 or write us at
 PPL Gas Utilities
 PO Box 508
 Lock Haven, Pa 17745-0508


CURRENT BILL
DELIVERY CHARGES
 Delivery Charge 15.00
 Distribution Charge
 -Ret 5.0 DT 4.5089 22.69
 Next 11.5 DT 2.2208 28.57
 Total 18.5 DT 49.26
GAS CHARGES
 Gas Cost Adj. Chg @ 1.4422/DT 29.60
 Gas Supply Charge @11.3997/DT 185.96
TAXES & SUIV-APGFS
 State Tax Agreement Surcharge .6708
 Pennsylvania State Tax 17.02
 Current Charges 301.84
 Balance as of this bill
 due by August 22, 2006 801.84

9:030311305

For Emergency Service
(800)652-0550

Your Gas Usage			Meter Reading Information					
Average	This Year	Last Year	Meter Number	Present Reading	Last Reading	OCF Used	RTU Factor	DeKalb Term
per Day	.6168		0000100098	41904	41700	161	1.0270	15.5
Av. Temperature	50.0° F	50.0° F						

Usage per Month (C)



Actual: 8/31/06
 Actual: 8/10/06
 22 Days in Billing period

Messages from PPL Gas Utilities

SCAN ALERT PPL Gas would like to warn our customers about a potential phone scam. If you fall behind on your gas bill, you will receive one or more written notices BEFORE a PPL Gas representative will phone you. The CSR will NEVER ask for your CREDIT or DEBIT card information. PPL utilizes a secure third party vendor for these payments. You may access this payment option via PPL Gas's automated phone menu - OPTION # 9.

Make checks payable to PPL GAS UTILITIES

Keep this bill for your records

1/1

Met-Ed Basic Charges

When contacting an Electric Generation Supplier, please provide the customer numbers below.
 Call Met-Ed at 1-800-545-7741 with questions on these charges.

Met-Ed Basic Charges			
Customer Number: 0604331178-0006411045 - General Secondary 3 Phase Service - ME_GS3_B1F			
Customer Charge			16.74
Generation Charges	34,050 KWH	x 0.048070	1,638.23
Transmission Charges	32,050 KWH	x 0.000000	0.00
	2,000 KWH	x 0.002800	5.60
	102.5 KW	x 0.780000	79.95
	5.0 KW	x 0.000000	0.00
Total Transmission Charges			85.61
85.61			85.61
Distribution Charges	12,550 KWH	x 0.006600	83.03
	19,500 KWH	x 0.007200	140.40
	2,000 KWH	x 0.038000	76.00
	102.5 KW	x 4.570000	468.43
	5.0 KW	x 0.000000	0.00
Total Distribution Charges			761.86
761.86			761.86
Transition Charges	2,500 KWH	x 0.002010	4.02
	19,500 KWH	x 0.000860	16.77
	12,500 KWH	x -0.000510	-73.09
	5.0 KW	x 0.000000	0.00
	102.5 KW	x 4.610000	472.53
Total Transition Charges			420.23
420.23			420.23
State Tax Surchage			32.44
State Sales Tax			177.91
Total Met-Ed Charges			\$ 3,132.42


Payments and Adjustments

Date	Reference	Amount
Payments:		
08/22/06		-3,280.64
Total Payments		-3,280.64
Total Payments and Adjustments		-3,280.64

General Secondary 3 Phase Service

Meter Number	029337850
Present KWH Reading (Actual)	2,821
Previous KWH Reading (Actual)	2,638
Difference	213
Multiplier	100
Kilowatt Hours Used	34,050
Metered Load in KW	0.672
Billed Load in KWKVA	107.5

Usage Comparison



	Sep 05	Sep 06
Average Daily Use (KWH)	1275	1196
Average Daily Temperature	72	69
Days in Billing Period	33	30
Last 12 Months Use (KWH)		708,250
Average Monthly Use (KWH)		34,107

Generation prices and charges are set by the electric generation supplier you have chosen.
The Public Utility Commission regulates distribution prices and services.
The Federal Energy Regulatory Commission regulates transmission prices and services.



Appendix D

ENGINEERING CHECKS

By ae

Description	Type	COOLING				HEATING			Floor Area ft ²	
		% OA	cfm/ft ²	cfm/ton	ft ³ /ton	Btu/hr-ft ²	% OA	cfm/ft ²		Btu/hr-ft ²
Blgd 1 - NE Apartments	Zone	0.00	1.04	609.2	586.9	20.45	0.00	1.04	-4.76	2,745
Blgd 1 - SE Apartment	Zone	0.00	1.03	608.6	588.4	20.39	0.00	1.03	-4.76	2,745
Blgd 1 - SW Apartment	Zone	0.00	1.35	657.6	487.5	24.62	0.00	1.35	-5.11	1,830
Blgd 1 - NW Apartments	Zone	0.00	1.33	655.2	493.9	24.29	0.00	1.33	-5.11	1,830
Blgd 1 - 2nd SW Apt	Zone	0.00	1.58	687.7	435.3	27.57	0.00	1.58	-6.30	776
Blgd 1 - 2nd NW Apt	Zone	0.00	1.57	707.5	450.7	26.62	0.00	1.57	-6.63	776
Blgd 2 - NE Apt	Zone	0.00	0.59	499.8	852.0	14.09	0.00	0.59	-4.25	3,572
Blgd 2 - SE Apt	Zone	0.00	1.27	738.4	579.6	20.70	0.00	1.27	-4.42	2,679
Blgd 2 - SW Apt	Zone	0.00	1.20	731.4	609.2	19.70	0.00	1.20	-3.43	2,679
Blgd 2 - NW Apt	Zone	0.00	0.56	505.5	905.6	13.25	0.00	0.56	-3.26	3,572
Blgd 3 - NW Apt	Zone	0.00	0.73	556.6	767.1	15.64	0.00	0.73	-4.25	3,572
Blgd 3 - NE Apt	Zone	0.00	0.53	479.4	907.1	13.23	0.00	0.53	-3.26	3,572
Blgd 3 - SE Apt	Zone	0.00	1.22	732.9	602.6	19.91	0.00	1.22	-3.43	2,679
Blgd 3 - SW Apt	Zone	0.00	1.28	738.9	578.3	20.75	0.00	1.28	-4.42	2,679
Blgd 5 - NW Apt	Zone	0.00	0.74	560.3	755.2	15.89	0.00	0.74	-4.42	2,679
Blgd 5 - NE Apt	Zone	0.00	0.54	483.5	893.7	13.43	0.00	0.54	-3.43	2,679
Blgd 5 - SE Apt	Zone	0.00	1.21	732.5	604.3	19.86	0.00	1.21	-3.26	3,572
Blgd 5 - SW Apt	Zone	0.00	1.27	738.2	581.0	20.65	0.00	1.27	-4.25	3,572
Blgd 6 - NE Apt	Zone	0.00	0.60	502.9	842.2	14.25	0.00	0.60	-4.42	2,679
Blgd 6 - SE Apt	Zone	0.00	1.27	738.0	581.4	20.64	0.00	1.27	-4.25	3,572
Blgd 6 - SW Apt	Zone	0.00	1.20	730.9	611.0	19.64	0.00	1.20	-3.26	3,572
Blgd 6 - NW Apt	Zone	0.00	0.57	512.2	892.4	13.45	0.00	0.57	-3.43	2,679
Blgd 7 - NW Apt	Zone	0.00	0.74	560.3	755.2	15.89	0.00	0.74	-4.42	2,679
Blgd 7 - NE Apt	Zone	0.00	0.54	483.5	893.7	13.43	0.00	0.54	-3.43	2,679
Blgd 7 - SE Apt	Zone	0.00	1.21	732.5	604.3	19.86	0.00	1.21	-3.26	3,572
Blgd 7 - SW Apt	Zone	0.00	1.27	738.2	581.0	20.65	0.00	1.27	-4.25	3,572
Blgd 8 - NE Apt	Zone	0.00	0.60	502.9	842.2	14.25	0.00	0.60	-4.42	2,679
Blgd 8 - SE Apt	Zone	0.00	1.27	738.0	581.4	20.64	0.00	1.27	-4.25	3,572
Blgd 8 - SW Apt	Zone	0.00	1.20	730.9	611.0	19.64	0.00	1.20	-3.26	3,572
Blgd 8 - NW Apt	Zone	0.00	0.57	512.2	892.4	13.45	0.00	0.57	-3.43	2,679
Blgd 9 - NW Apt	Zone	0.00	0.74	560.3	755.2	15.89	0.00	0.74	-4.42	2,679
Blgd 9 - NE Apt	Zone	0.00	0.54	483.5	893.7	13.43	0.00	0.54	-3.43	2,679
Blgd 9 - SE Apt	Zone	0.00	1.21	732.5	604.3	19.86	0.00	1.21	-3.26	3,572
Blgd 9 - SW Apt	Zone	0.00	1.27	738.2	581.0	20.65	0.00	1.27	-4.25	3,572
Blgd 10 - NE Apt	Zone	0.00	0.60	502.9	842.2	14.25	0.00	0.60	-4.42	2,679
Blgd 10 - SE Apt	Zone	0.00	1.27	738.0	581.4	20.64	0.00	1.27	-4.25	3,572
Blgd 10 - SW Apt	Zone	0.00	1.20	730.9	611.0	19.64	0.00	1.20	-3.26	3,572
Blgd 10 - NW Apt	Zone	0.00	0.57	512.2	892.4	13.45	0.00	0.57	-3.43	2,679
Blgd 4 - NE Apt	Zone	0.00	0.60	502.9	842.2	14.25	0.00	0.60	-4.42	2,679
Blgd 4 - SE Apt	Zone	0.00	1.27	738.4	579.6	20.70	0.00	1.27	-4.42	2,679

ENGINEERING CHECKS

By ae

Description	Type	COOLING					HEATING			Floor Area ft ²
		% OA	cfm/ft ²	cfm/ton	ft ² /ton	Btu/hr-ft ²	% OA	cfm/ft ²	Btu/hr-ft ²	
Bldg 4 - NW Apt	Zone	0.00	0.74	560.3	755.2	15.89	0.00	0.74	-4.42	2,679
Bldg 4 - SW Apt	Zone	0.00	1.28	738.9	578.3	20.75	0.00	1.28	-4.42	2,679
Terminal A/C	System - Packaged Terminal Air Conditioner	0.00	0.97	650.8	669.3	17.93	0.00	0.97	-3.99	121,434
Bldg 1 - Stairs	Zone	0.00	0.00	0.0	0.0	0.00	0.00	0.22	-15.81	333
Bldg 2 - Stairs	Zone	0.00	0.00	0.0	0.0	0.00	0.00	0.28	-20.03	333
Bldg 3 - Stairs	Zone	0.00	0.00	0.0	0.0	0.00	0.00	0.28	-20.03	333
Bldg 4 - Stairs	Zone	0.00	0.00	0.0	0.0	0.00	0.00	0.24	-17.32	333
Bldg 5 - Stairs	Zone	0.00	0.00	0.0	0.0	0.00	0.00	0.28	-20.03	333
Bldg 6 - Stairs	Zone	0.00	0.00	0.0	0.0	0.00	0.00	0.28	-20.03	333
Bldg 7 - Stairs	Zone	0.00	0.00	0.0	0.0	0.00	0.00	0.28	-20.03	333
Bldg 8 - Stairs	Zone	0.00	0.00	0.0	0.0	0.00	0.00	0.28	-20.03	333
Bldg 9 - Stairs	Zone	0.00	0.00	0.0	0.0	0.00	0.00	0.28	-20.03	333
Bldg 10 - Stairs	Zone	0.00	0.00	0.0	0.0	0.00	0.00	0.28	-20.03	333
Heating only	System - Unit Heaters	0.00	0.00	0.0	0.0	0.00	0.00	0.27	-19.34	3,330
Bldg 1 - Game/TV	Zone	12.24	1.09	638.8	585.6	20.49	12.24	1.09	-10.00	1,123
Bldg 1 - Office/Reception	Zone	18.27	1.17	451.6	386.5	31.05	18.27	1.17	-18.28	281
Bldg 1 - Group Meeting	Zone	27.03	0.70	383.9	547.4	21.92	27.03	0.70	-12.09	633
Bldg 1 - Conference	Zone	93.10	0.74	200.8	272.6	44.02	93.10	0.74	-43.72	175
Bldg 1 - Office - C009	Zone	52.61	0.30	265.7	876.2	13.70	52.61	0.30	-10.21	281
Bldg 1 - File/Closet	Zone	0.00	0.34	1,000.6	2,935.0	4.09	0.00	0.34	-4.67	145
Bldg 1 - Cyber Lounge	Zone	12.24	1.88	983.3	524.2	22.89	12.24	1.88	-14.64	653
Bldg 1 - Corridor/Bathroom	Zone	0.00	4.38	15,381.7	3,515.8	3.41	0.00	4.38	0.00	280
Bldg 1 - Fitness	Zone	7.76	5.78	3,243.4	561.3	21.38	7.76	5.78	-28.57	212
Commons	System - Packaged Terminal Air Conditioner	12.47	1.57	939.5	598.7	20.04	12.47	1.57	-13.44	3,783

System Checksums

By ae

Commons

Packaged Terminal Air Conditioner

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES		
Peaked at Time:		Mo/Hr: 7 / 10		Mo/Hr: 7 / 9		Mo/Hr: 13 / 1						Cooling		Heating
Outside Air:		OADB/WB/HR: 60 / 69 / 92		OADB: 77		OADB: 10						SADB	64.0	68.6
Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent Of Total	Space Sensible	Percent Of Total	Space Peak	Coil Peak	Percent	Space Sens	Tot Sens	Percent	Plenum	72.0	68.0
Btu/h	Btu/h	Btu/h	(%)	Btu/h	(%)	Btu/h	Btu/h	(%)	Btu/h	Btu/h	(%)	Return	72.2	68.0
Envelope Loads														
Skyllite Solar	0	0	0.00	0	0.00	0	0	0.00	0	0	0.00	Rat/OA	73.1	60.8
Skyllite Cond	0	0	0.00	0	0.00	0	0	0.00	0	0	0.00	Fn MtrTD	0.0	0.0
Roof Cond	0	0	0.00	0	0.00	0	0	0.00	0	0	0.00	Fn BldTD	0.0	0.0
Glass Solar	26,071	0	34.38	26,844	51.68	0	0	0.00	0	0	0.00	Fn Fric	0.0	0.0
Glass Cond	593	0	0.78	289	0.56	-7,466	-7,466	15.83	-7,466	-7,466	15.83			
Wall Cond	2,062	0	2.72	1,904	3.67	-4,199	-4,199	8.90	-4,199	-4,199	8.90			
Partition	133	0	0.18	133	0.26	-1,444	-1,444	3.06	-1,444	-1,444	3.06			
Exposed Floor	0	0	0.00	0	0.00	0	0	0.00	0	0	0.00			
Infiltration	0	0	0.00	0	0.00	-1	-1	0.00	-1	-1	0.00			
Sub Total ==>	28,658	0	38.06	29,170	56.16	-13,110	-13,110	27.79	-13,110	-13,110	27.79			
Internal Loads														
Lights	5,165	1,291	8.51	5,165	9.94	0	0	0.00	0	0	0.00			
People	17,120	0	22.58	11,035	21.25	11,035	11,035	-23.39	11,035	11,035	-23.39			
Misc	6,570	0	8.67	6,570	12.65	6,570	6,570	-13.93	6,570	6,570	-13.93			
Sub Total ==>	28,655	1,291	39.76	22,770	43.84	17,605	17,605	-37.32	17,605	17,605	-37.32			
Ceiling Load														
Ventilation Load	0	0	0.00	0	0.00	0	0	0.00	0	0	0.00			
Ov/Undr Sizing	0	0	0.00	0	0.00	0	-47,178	100.00	0	-47,178	100.00			
Exhaust Heat	0	-262	-0.35	0	0.00	0	0	0.00	0	0	0.00			
Sup. Fan Heat	0	0	0.00	0	0.00	0	0	0.00	0	0	0.00			
Ret. Fan Heat	0	0	0.00	0	0.00	0	0	0.00	0	0	0.00			
Duct Heat Pkup	0	0	0.00	0	0.00	0	-4,496	9.53	0	-4,496	9.53			
Reheat at Design	0	0	0.00	0	0.00	0	0	0.00	0	0	0.00			
Grand Total ==>	57,713	1,029	75.820	51,940	100.00	4,495	-47,178	100.00	4,495	-47,178	100.00			

COOLING COIL SELECTION				AREAS				HEATING COIL SELECTION							
Total Capacity	Capacity	Sens Cap.	Coil Airflow	Enter DB/WB/HR		Leave DB/WB/HR		Gross Total	Glass	Capacity		Coil Airflow	Ent	Lvg	
ton	MBh	MBh	cfm	*F	*F	*F	*F		ft² (%)	MBh	cfm	*F	*F	*F	
Main Clg	6.3	75.8	5,936	73.1	63.3	72.7	64.0	59.2	68.7	Floor	3,783				
Aux Clg	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Part	663				
Opt Vent	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	0				
Total	6.3	75.8								Roof	0	0	0		
										Wall	1,027	252	25		

TEMPERATURES				AIRFLOWS				ENGINEERING CKS						
SADB	Plenum	Return	Rat/OA	Fn MtrTD	Fn BldTD	Fn Fric	Vent	Infl	Supply	MinStop/Rh	Return	Exhaust	Rm Exh	Auxiliary
64.0	72.0	72.2	73.1	0.0	0.0	0.0	740	0	5,936	0	5,936	740	0	0
68.6	68.0	68.0	60.8	0.0	0.0	0.0	740	0	5,936	0	5,936	740	0	0

ENGINEERING CKS			
% OA	cfm/ft²	cfm/ton	ft³/ton
12.5	1.57	939.51	598.73
12.5	1.57		
		20.04	-13.44

System Checksums

By ae

Heating only

Unit Heaters

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES		
Peaked at Time:		Mo/Hr: 0 / 0		Mo/Hr: 0 / 0		Mo/Hr: 13 / 1		Mo/Hr: 13 / 1				Cooling		Heating
Outside Air:		OADB/WB/HR: 0 / 0 / 0		OADB: 0		OADB: 10		OADB: 10				SADB	0.0	125.0
Space Sens. + Lat	Plenum Sens. + Lat	Net Total	Percent Of Total	Space Sensible	Percent Of Total	Space Peak	Coil Peak	Percent	Space Sens	Tot Sens	Of Total	Plenum	0.0	60.0
Btu/h	Btu/h	Btu/h	(%)	Btu/h	(%)	Btu/h	Btu/h	(%)	Btu/h	Btu/h	(%)	Return	0.0	60.0
Envelope Loads														
Skyllite Solar	0	0	0	0.00	0	0.00	Skyllite Solar	0	0	0.00	Skyllite Solar	0	0	0.00
Skyllite Cond	0	0	0	0.00	0	0.00	Skyllite Cond	0	0	0.00	Skyllite Cond	0	0	0.00
Roof Cond	0	0	0	0.00	0	0.00	Roof Cond	-5,372	-5,372	8.34	Roof Cond	0	0	0.00
Glass Solar	0	0	0	0.00	0	0.00	Glass Solar	0	0	0.00	Glass Solar	0	0	0.00
Glass Cond	0	0	0	0.00	0	0.00	Glass Cond	-46,316	-46,316	71.92	Glass Cond	0	0	0.00
Wall Cond	0	0	0	0.00	0	0.00	Wall Cond	-12,711	-12,711	19.74	Wall Cond	0	0	0.00
Partition	0	0	0	0.00	0	0.00	Partition	0	0	0.00	Partition	0	0	0.00
Exposed Floor	0	0	0	0.00	0	0.00	Exposed Floor	0	0	0.00	Exposed Floor	0	0	0.00
Infiltration	0	0	0	0.00	0	0.00	Infiltration	-1	-1	0.00	Infiltration	0	0	0.00
Sub Total ==>	0	0	0	0.00	0	0.00	Sub Total ==>	-64,400	-64,400	100.00	Sub Total ==>	0	0	0.00
Internal Loads														
Lights	0	0	0	0.00	0	0.00	Lights	0	0	0.00	Lights	0	0	0.00
People	0	0	0	0.00	0	0.00	People	0	0	0.00	People	0	0	0.00
Misc	0	0	0	0.00	0	0.00	Misc	0	0	0.00	Misc	0	0	0.00
Sub Total ==>	0	0	0	0.00	0	0.00	Sub Total ==>	0	0	0.00	Sub Total ==>	0	0	0.00
Ceiling Load	0	0	0	0.00	0	0.00	Ceiling Load	0	0	0.00	Ceiling Load	0	0	0.00
Ventilation Load	0	0	0	0.00	0	0.00	Ventilation Load	0	0	0.00	Ventilation Load	0	0	0.00
Ov/Undr Sizing	0	0	0	0.00	0	0.00	Ov/Undr Sizing	0	0	0.00	Ov/Undr Sizing	0	0	0.00
Exhaust Heat	0	0	0	0.00	0	0.00	Exhaust Heat	0	0	0.00	Exhaust Heat	0	0	0.00
Sup. Fan Heat	0	0	0	0.00	0	0.00	OA Preheat Diff.	0	0	0.00	OA Preheat Diff.	0	0	0.00
Ret. Fan Heat	0	0	0	0.00	0	0.00	RA Preheat Diff.	0	0	0.00	RA Preheat Diff.	0	0	0.00
Duct Heat Pkup	0	0	0	0.00	0	0.00	Additional Reheat	0	0	0.00	Additional Reheat	0	0	0.00
Reheat at Design	0	0	0	0.00	0	0.00	Grand Total ==>	-64,400	-64,400	100.00	Grand Total ==>	0	0	0.00
Grand Total ==>	0	0	0	100.00	0	100.00	Grand Total ==>	-64,400	-64,400	100.00	Grand Total ==>	0	0	0.00

COOLING COIL SELECTION								AREAS			HEATING COIL SELECTION					
Total Capacity	Sens Cap.	Coil Airflow	Enter DB/WB/HR	Leave DB/WB/HR				Gross Total	Glass	Capacity Coil Airflow Ent Lvg						
ton	MBh	MBh	*F *F gr/h	*F *F gr/h					ft² (%)	MBh	cfm	*F	*F			
Main Clg	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Floor	3,330		Main Htg	-64.4	901	60.0	125.0	
Aux Clg	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Part	0		Aux Htg	0.0	0	0.0	0.0	
Opt Vent	0.0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	0		Preheat	0.0	0	0.0	0.0	
Total	0.0	0.0						Roof	3,330	0	Humidtr	0.0	0	0.0	0.0	
								Wall	4,976	1,853	37	Opt Vent	0.0	0	0.0	0.0
											Total	-64.4				

System Checksums

By ae

Terminal A/C

Packaged Terminal Air Conditioner

COOLING COIL PEAK					CLG SPACE PEAK			HEATING COIL PEAK			TEMPERATURES		
Peaked at Time: Mo/Hr: 7 / 14					Mo/Hr: 9 / 14			Mo/Hr: 13 / 1			Cooling Heating		
Outside Air: OADB/WB/HR: 69 / 73 / 96					OADB: 83			OADB: 10			SADB 56.9 71.7		
Space Sens. + Lat	Plenum Sens. + Lat	Net Total	Percent Of Total		Space Sensible	Percent Of Total	Space Peak	Coil Peak	Percent	Plenum	Return	Ret/OA	
Btu/h	Btu/h	Btu/h	(%)		Btu/h	(%)	Space Sens	Tot Sens	Of Total	72.0	72.3	68.0	
Envelope Loads													
Skyllite Solar	0	0	0.00		0	0.00	Skyllite Solar	0	0	0.00	Fn MtrTD	0.0	0.0
Skyllite Cond	0	0	0.00		0	0.00	Skyllite Cond	0	0	0.00	Fn BldTD	0.0	0.0
Roof Cond	61,774	0	2.84		63,794	3.25	Roof Cond	-76,838	-76,838	15.84	Fn Fric	0.0	0.0
Glass Solar	810,504	0	37.23		811,013	41.35	Glass Solar	0	0	0.00			
Glass Cond	64,437	0	2.96		62,748	3.20	Glass Cond	-302,435	-302,435	62.34			
Wall Cond	225,693	0	10.37		228,954	11.67	Wall Cond	-287,799	-287,799	59.33			
Partition	0	0	0.00		0	0.00	Partition	0	0	0.00			
Exposed Floor	0	0	0.00		0	0.00	Exposed Floor	0	0	0.00			
Infiltration	151,922	0	6.98		79,449	4.05	Infiltration	-367,738	-367,738	75.81			
Sub Total ==>	1,314,330	0	60.37		1,245,957	63.52	Sub Total ==>	-1,034,810	-1,034,810	213.32			
Internal Loads													
Lights	165,782	41,445	9.52		165,782	8.45	Lights	0	0	0.00			
People	243,450	0	11.18		135,250	6.90	People	135,250	135,250	-27.88			
Misc	414,454	0	19.04		414,454	21.13	Misc	414,454	414,454	-85.44			
Sub Total ==>	823,686	41,445	39.73		715,486	36.48	Sub Total ==>	549,704	549,704	-113.32			
Ceiling Load	0	0	0.00		0	0.00	Ceiling Load	0	0	0.00			
Ventilation Load	0	0	0.00		0	0.00	Ventilation Load	0	0	0.00			
Ov/Undr Sizing	0	0	0.00		0	0.00	Ov/Undr Sizing	0	0	0.00			
Exhaust Heat		-2,165	-0.10				Exhaust Heat	0	0	0.00			
Sup. Fan Heat		0	0.00				OA Preheat Diff.	0	0	0.00			
Ret. Fan Heat		0	0.00				RA Preheat Diff.	0	0	0.00			
Duct Heat Pkup		0	0.00				Additional Reheat	0	0	0.00			
Reheat at Design		0	0.00										
Grand Total ==>	2,138,016	39,280	100.00		1,961,444	100.00	Grand Total ==>	-485,106	-485,105	100.00			

AIRFLOWS												
	Cooling	Heating										
Vent	0	0										
Infil	5,768	5,768										
Supply	118,078	118,078										
MinStop/Rh	0	0										
Return	123,846	123,846										
Exhaust	5,768	5,768										
Rm Exh	0	0										
Auxiliary	0	0										

ENGINEERING CKS												
	Cooling	Heating										
% OA	0.0	0.0										
cfm/ft²	0.97	0.97										
cfm/ton	650.78											
ft³/ton	669.27											
Btu/hr-ft²	17.93	-3.99										
No. People	541											

COOLING COIL SELECTION								AREAS			HEATING COIL SELECTION				
	Total Capacity	Sens Cap.	Coil Airflow	Enter DB/WB/HR	Leave DB/WB/HR			Gross Total	Glass	Capacity	Coil Airflow	Ent	Lvg		
	ton	MBh	MBh	*F	*F	gr/lb			ft² (%)	MBh	cfm	*F	*F		
Main Clg	181.4	2,177.3	1,999.0	72.3	60.1	59.5	56.9	53.7	57.3						
Aux Clg	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0						
Opt Vent	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0						
Total	181.4	2,177.3													

HEATING COIL SELECTION												
	Capacity	Coil Airflow	Ent	Lvg								
	MBh	cfm	*F	*F								
Main Htg	-485.1	118,078	68.0	71.7								
Aux Htg	0.0	0	0.0	0.0								
Preheat	0.0	0	0.0	0.0								
Humidif	0.0	0	0.0	0.0								
Opt Vent	0.0	0	0.0	0.0								
Total	-485.1											

**PEAK COOLING LOADS
MAIN SYSTEM**

By ae

Description	Room	Floor Area ft²	SPACE							COIL							
			Peak Time Mo/Hr	OA Cond. DB/WB °F	Room Dry Bulb °F	Supply Dry Bulb °F	Space Air Flow cfm	Space Sensible Load Btu/h	Space Latent Load Btu/h	Peak Time Mo/Hr	OA Cond. DB/WB °F	Supply Dry Bulb °F	Coil Air Flow cfm	Coil Sensible Load Btu/h	Coil Latent Load Btu/h		
Bldg 1 - NE Apartments	Rm/Zn Tot	2,745	7/9	77	68	72	56.1	2,849	49,928	5,302	7/9	77	68	56.1	2,849	50,824	5,302
Bldg 1 - SE Apartment	Rm/Zn Tot	2,745	7/9	77	68	72	56.0	2,839	49,785	5,302	7/9	77	68	56.0	2,839	50,680	5,302
Bldg 1 - SW Apartment	Rm/Zn Tot	1,830	7/17	88	71	72	56.9	2,469	41,100	3,344	7/17	88	71	56.9	2,469	41,704	3,344
Bldg 1 - NW Apartments	Rm/Zn Tot	1,830	7/17	88	71	72	56.8	2,427	40,511	3,344	7/17	88	71	56.8	2,427	41,114	3,344
Bldg 1 - 2nd SW Apt	Rm/Zn Tot	776	7/17	88	71	72	57.3	1,226	19,794	1,340	7/17	88	71	57.3	1,226	20,051	1,340
Bldg 1 - 2nd NW Apt	Rm/Zn Tot	776	7/17	88	71	72	57.6	1,218	19,262	1,140	7/17	88	71	57.6	1,218	19,519	1,140
Bldg 2 - NE Apt	Rm/Zn Tot	3,572	7/14	89	73	72	53.9	2,096	41,739	7,446	7/14	89	73	53.9	2,096	42,867	7,446
Bldg 2 - SE Apt	Rm/Zn Tot	2,679	9/13	81	63	72	58.1	3,412	52,139	2,427	9/13	81	63	58.1	3,412	53,020	2,427
Bldg 2 - SW Apt	Rm/Zn Tot	2,679	9/13	81	63	72	58.0	3,216	49,462	2,427	9/13	81	63	58.0	3,216	50,341	2,427
Bldg 2 - NW Apt	Rm/Zn Tot	3,572	7/18	86	70	72	54.2	1,994	39,089	6,610	7/18	86	70	54.4	1,994	39,795	7,528
Bldg 3 - NW Apt	Rm/Zn Tot	3,572	7/18	86	70	72	55.1	2,592	48,127	6,610	7/18	86	70	55.1	2,592	49,271	6,610
Bldg 3 - NE Apt	Rm/Zn Tot	3,572	7/15	90	73	72	53.4	1,888	38,606	7,528	7/15	90	73	53.4	1,888	39,724	7,528
Bldg 3 - SE Apt	Rm/Zn Tot	2,679	9/13	81	63	72	58.0	3,259	50,043	2,427	9/13	81	63	58.0	3,259	50,923	2,427
Bldg 3 - SW Apt	Rm/Zn Tot	2,679	9/14	83	64	72	58.1	3,423	52,284	2,425	9/14	83	64	58.1	3,423	53,166	2,425
Bldg 5 - NW Apt	Rm/Zn Tot	2,679	7/18	86	70	72	55.2	1,988	36,753	4,958	7/18	86	70	55.2	1,988	37,612	4,958
Bldg 5 - NE Apt	Rm/Zn Tot	2,679	7/15	90	73	72	53.5	1,449	29,486	5,646	7/15	90	73	53.5	1,449	30,326	5,646
Bldg 5 - SE Apt	Rm/Zn Tot	3,572	9/13	81	63	72	58.0	4,330	66,518	3,236	9/13	81	63	58.0	4,330	67,691	3,236
Bldg 5 - SW Apt	Rm/Zn Tot	3,572	9/14	83	64	72	58.1	4,538	69,363	3,233	9/14	83	64	58.1	4,538	70,538	3,233
Bldg 6 - NE Apt	Rm/Zn Tot	2,679	7/14	89	73	72	53.9	1,599	31,739	5,584	7/14	89	73	53.9	1,599	32,586	5,584
Bldg 6 - SE Apt	Rm/Zn Tot	3,572	9/13	81	63	72	58.1	4,534	69,312	3,236	9/13	81	63	58.1	4,534	70,487	3,236
Bldg 6 - SW Apt	Rm/Zn Tot	3,572	9/13	81	63	72	58.0	4,273	65,743	3,236	9/13	81	63	58.0	4,273	66,916	3,236
Bldg 6 - NW Apt	Rm/Zn Tot	2,679	7/18	86	70	72	54.3	1,538	29,974	4,958	7/18	86	70	54.5	1,538	30,379	5,646
Bldg 7 - NW Apt	Rm/Zn Tot	2,679	7/18	86	70	72	55.2	1,988	36,753	4,958	7/18	86	70	55.2	1,988	37,612	4,958
Bldg 7 - NE Apt	Rm/Zn Tot	2,679	7/15	90	73	72	53.5	1,449	29,486	5,646	7/15	90	73	53.5	1,449	30,326	5,646
Bldg 7 - SE Apt	Rm/Zn Tot	3,572	9/13	81	63	72	58.0	4,330	66,518	3,236	9/13	81	63	58.0	4,330	67,691	3,236
Bldg 7 - SW Apt	Rm/Zn Tot	3,572	9/14	83	64	72	58.1	4,538	69,363	3,233	9/14	83	64	58.1	4,538	70,538	3,233
Bldg 8 - NE Apt	Rm/Zn Tot	2,679	7/14	89	73	72	53.9	1,599	31,739	5,584	7/14	89	73	53.9	1,599	32,586	5,584
Bldg 8 - SE Apt	Rm/Zn Tot	3,572	9/13	81	63	72	58.1	4,534	69,312	3,236	9/13	81	63	58.1	4,534	70,487	3,236
Bldg 8 - SW Apt	Rm/Zn Tot	3,572	9/13	81	63	72	58.0	4,273	65,743	3,236	9/13	81	63	58.0	4,273	66,916	3,236
Bldg 8 - NW Apt	Rm/Zn Tot	2,679	7/18	86	70	72	54.3	1,538	29,974	4,958	7/18	86	70	54.5	1,538	30,379	5,646
Bldg 9 - NW Apt	Rm/Zn Tot	2,679	7/18	86	70	72	55.2	1,988	36,753	4,958	7/18	86	70	55.2	1,988	37,612	4,958
Bldg 9 - NE Apt	Rm/Zn Tot	2,679	7/15	90	73	72	53.5	1,449	29,486	5,646	7/15	90	73	53.5	1,449	30,326	5,646

**PEAK COOLING LOADS
MAIN SYSTEM**

By ae

Description	Floor Area ft²	SPACE						COIL					
		Peak Time Mo/Hr	OA Cond. DB/WB °F	Room Dry Bulb °F	Supply Dry Bulb °F	Space Air Flow cfm	Space Sensible Load Btu/h	Space Latent Load Btu/h	Peak Time Mo/Hr	OA Cond. DB/WB °F	Supply Dry Bulb °F	Coil Air Flow cfm	Coil Sensible Load Btu/h
Bldg 9 - SE Apt	Rm/Zn Tot	3,572	9/13 81 63	72	58.0	4,330	66,518	3,236	9/13 81 63	58.0	4,330	67,691	3,236
Bldg 9 - SW Apt	Rm/Zn Tot	3,572	9/14 83 64	72	58.1	4,538	69,363	3,233	9/14 83 64	58.1	4,538	70,538	3,233
Bldg 10 - NE Apt	Rm/Zn Tot	2,679	7/14 89 73	72	53.9	1,599	31,739	5,584	7/14 89 73	53.9	1,599	32,586	5,584
Bldg 10 - SE Apt	Rm/Zn Tot	3,572	9/13 81 63	72	58.1	4,534	69,312	3,236	9/13 81 63	58.1	4,534	70,487	3,236
Bldg 10 - SW Apt	Rm/Zn Tot	3,572	9/13 81 63	72	58.0	4,273	65,743	3,236	9/13 81 63	58.0	4,273	66,916	3,236
Bldg 10 - NW Apt	Rm/Zn Tot	2,679	7/18 86 70	72	54.3	1,538	29,974	4,958	7/15 90 73	54.5	1,538	30,379	5,646
Bldg 4 - NE Apt	Rm/Zn Tot	2,679	7/14 89 73	72	53.9	1,599	31,739	5,584	7/14 89 73	53.9	1,599	32,586	5,584
Bldg 4 - SE Apt	Rm/Zn Tot	2,679	9/13 81 63	72	58.1	3,412	52,139	2,427	9/13 81 63	58.1	3,412	53,020	2,427
Bldg 4 - NW Apt	Rm/Zn Tot	2,679	7/18 86 70	72	55.2	1,988	36,753	4,958	7/18 86 70	55.2	1,988	37,612	4,958
Bldg 4 - SW Apt	Rm/Zn Tot	2,679	9/14 83 64	72	58.1	3,423	52,284	2,425	9/14 83 64	58.1	3,423	53,166	2,425
Terminal A/C	Sys Tot/Ave	121,434	83 64 72	56.9	118,078	1,961,444	175,328		89 73 56.9	118,078	1,998,987	178,309	
Terminal A/C	Sys Block	121,434	9/14 83 64 72	56.9	118,078	1,757,301	109,315		7/14 89 73 59.4	118,078	1,670,815	252,530	
Bldg 1 - Stairs	Rm/Zn Tot	0	0/0 0 0 0	0.0	0	0	0	0	0/0 0 0 0.0	0	0	0	0
Bldg 2 - Stairs	Rm/Zn Tot	0	0/0 0 0 0	0.0	0	0	0	0	0/0 0 0 0.0	0	0	0	0
Bldg 3 - Stairs	Rm/Zn Tot	0	0/0 0 0 0	0.0	0	0	0	0	0/0 0 0 0.0	0	0	0	0
Bldg 4 - Stairs	Rm/Zn Tot	0	0/0 0 0 0	0.0	0	0	0	0	0/0 0 0 0.0	0	0	0	0
Bldg 5 - Stairs	Rm/Zn Tot	0	0/0 0 0 0	0.0	0	0	0	0	0/0 0 0 0.0	0	0	0	0
Bldg 6 - Stairs	Rm/Zn Tot	0	0/0 0 0 0	0.0	0	0	0	0	0/0 0 0 0.0	0	0	0	0
Bldg 7 - Stairs	Rm/Zn Tot	0	0/0 0 0 0	0.0	0	0	0	0	0/0 0 0 0.0	0	0	0	0
Bldg 8 - Stairs	Rm/Zn Tot	0	0/0 0 0 0	0.0	0	0	0	0	0/0 0 0 0.0	0	0	0	0
Bldg 9 - Stairs	Rm/Zn Tot	0	0/0 0 0 0	0.0	0	0	0	0	0/0 0 0 0.0	0	0	0	0
Bldg 10 - Stairs	Rm/Zn Tot	0	0/0 0 0 0	0.0	0	0	0	0	0/0 0 0 0.0	0	0	0	0
Heating only	Sys Tot/Ave	0	0 0 0 0	0.0	0	0	0	0	0 0 0 0.0	0	0	0	0
Heating only	Sys Block	0	0/0 0 0 0	0.0	0	0	0	0	0/0 0 0 0.0	0	0	0	0
Bldg 1 - Game/TV	Rm/Zn Tot	1,123	9/10 71 59	72	58.7	1,225	17,886	1,050	7/9 77 68 58.9	1,225	18,701	4,310	
Bldg 1 - Office/Reception	Rm/Zn Tot	281	7/9 77 68	72	54.3	328	6,374	620	7/9 77 68 54.3	328	6,769	1,955	
Bldg 1 - Group Meeting	Rm/Zn Tot	633	7/9 77 68	72	53.2	444	9,176	1,240	7/9 77 68 53.2	444	9,966	3,911	
Bldg 1 - Conference	Rm/Zn Tot	175	7/15 90 73	72	55.0	129	2,409	1,240	7/15 90 73 55.0	129	4,787	2,917	
Bldg 1 - Office - C009	Rm/Zn Tot	281	7/15 90 73	72	55.0	86	1,598	465	7/15 90 73 55.0	86	2,534	1,315	
Bldg 1 - File/Closet	Rm/Zn Tot	145	7/17 88 71	72	62.0	49	543	0	7/17 88 71 62.0	49	593	0	
Bldg 1 - Cyber Lounge	Rm/Zn Tot	653	7/9 77 68	72	63.6	1,225	11,286	1,050	7/9 77 68 63.6	1,225	12,273	2,676	
Bldg 1 - Corridor/Bathroom	Rm/Zn Tot	280	7/15 90 73	72	71.4	1,225	860	0	7/15 90 73 71.4	1,225	956	0	

**PEAK COOLING LOADS
MAIN SYSTEM**

By ae

Description	Floor Area ft ²	SPACE							COIL						
		Peak Time Mo/Hr	OA Cond. DB/WB °F	Room Dry Bulb °F	Supply Dry Bulb °F	Space Air Flow cfm	Space Sensible Load Btu/h	Space Latent Load Btu/h	Peak Time Mo/Hr	OA Cond. DB/WB °F	Supply Dry Bulb °F	Coil Air Flow cfm	Coil Sensible Load Btu/h	Coil Latent Load Btu/h	
Bldg 1 - Fitness	Rm/Zn Tot	212	7/15	90 73	72	70.7	1,225	1,809	420	7/15	90 73	70.7	1,225	3,755	777
Commons	Sys Tot/Ave	3,783		77 68	72	64.0	5,936	51,940	6,085		80 69	64.1	5,936	57,959	17,862
Commons	Sys Block	3,783	7/9	77 68	72	64.0	5,936	51,425	6,085	7/10	80 69	64.4	5,936	56,637	16,981

**PEAK HEATING LOADS
MAIN SYSTEM**

By ae

Description		Floor Area ft²	SPACE						COIL				
			Peak Time Mo/Hr	OA Cond. DB/WB °F	Room Dry Bulb °F	Supply Dry Bulb °F	Space Air Flow cfm	Space Sensible Load Btu/h	Peak Time Mo/Hr	OA Cond. DB/WB °F	Supply Dry Bulb °F	Coll Air Flow cfm	Coll Sensible Load Btu/h
Bldg 1 - NE Apartments	Rm/Zn Tot	2,745	13 / 1	10 6	68	72.2	2,849	-13,072	13 / 1	10 6	72.2	2,849	-13,072
Bldg 1 - SE Apartment	Rm/Zn Tot	2,745	13 / 1	10 6	68	72.2	2,839	-13,072	13 / 1	10 6	72.2	2,839	-13,072
Bldg 1 - SW Apartment	Rm/Zn Tot	1,830	13 / 1	10 6	68	71.4	2,469	-9,342	13 / 1	10 6	71.4	2,469	-9,342
Bldg 1 - NW Apartments	Rm/Zn Tot	1,830	13 / 1	10 6	68	71.5	2,427	-9,342	13 / 1	10 6	71.5	2,427	-9,342
Bldg 1 - 2nd SW Apt	Rm/Zn Tot	776	13 / 1	10 6	68	71.6	1,226	-4,892	13 / 1	10 6	71.6	1,226	-4,892
Bldg 1 - 2nd NW Apt	Rm/Zn Tot	776	13 / 1	10 6	68	71.8	1,218	-5,142	13 / 1	10 6	71.8	1,218	-5,142
Bldg 2 - NE Apt	Rm/Zn Tot	3,572	13 / 1	10 6	68	74.6	2,096	-15,175	13 / 1	10 6	74.6	2,096	-15,175
Bldg 2 - SE Apt	Rm/Zn Tot	2,679	13 / 1	10 6	68	71.2	3,412	-11,840	13 / 1	10 6	71.2	3,412	-11,840
Bldg 2 - SW Apt	Rm/Zn Tot	2,679	13 / 1	10 6	68	70.6	3,216	-9,196	13 / 1	10 6	70.6	3,216	-9,196
Bldg 2 - NW Apt	Rm/Zn Tot	3,572	13 / 1	10 6	68	73.3	1,994	-11,649	13 / 1	10 6	73.3	1,994	-11,649
Bldg 3 - NW Apt	Rm/Zn Tot	3,572	13 / 1	10 6	68	73.3	2,592	-15,175	13 / 1	10 6	73.3	2,592	-15,175
Bldg 3 - NE Apt	Rm/Zn Tot	3,572	13 / 1	10 6	68	73.6	1,888	-11,649	13 / 1	10 6	73.6	1,888	-11,649
Bldg 3 - SE Apt	Rm/Zn Tot	2,679	13 / 1	10 6	68	70.6	3,259	-9,196	13 / 1	10 6	70.6	3,259	-9,196
Bldg 3 - SW Apt	Rm/Zn Tot	2,679	13 / 1	10 6	68	71.1	3,423	-11,840	13 / 1	10 6	71.1	3,423	-11,840
Bldg 5 - NW Apt	Rm/Zn Tot	2,679	13 / 1	10 6	68	73.4	1,988	-11,840	13 / 1	10 6	73.4	1,988	-11,840
Bldg 5 - NE Apt	Rm/Zn Tot	2,679	13 / 1	10 6	68	73.8	1,449	-9,196	13 / 1	10 6	73.8	1,449	-9,196
Bldg 5 - SE Apt	Rm/Zn Tot	3,572	13 / 1	10 6	68	70.4	4,330	-11,649	13 / 1	10 6	70.4	4,330	-11,649
Bldg 5 - SW Apt	Rm/Zn Tot	3,572	13 / 1	10 6	68	71.0	4,538	-15,175	13 / 1	10 6	71.0	4,538	-15,175
Bldg 6 - NE Apt	Rm/Zn Tot	2,679	13 / 1	10 6	68	74.7	1,599	-11,840	13 / 1	10 6	74.7	1,599	-11,840
Bldg 6 - SE Apt	Rm/Zn Tot	3,572	13 / 1	10 6	68	71.0	4,534	-15,175	13 / 1	10 6	71.0	4,534	-15,175
Bldg 6 - SW Apt	Rm/Zn Tot	3,572	13 / 1	10 6	68	70.5	4,273	-11,649	13 / 1	10 6	70.5	4,273	-11,649
Bldg 6 - NW Apt	Rm/Zn Tot	2,679	13 / 1	10 6	68	73.4	1,538	-9,196	13 / 1	10 6	73.4	1,538	-9,196
Bldg 7 - NW Apt	Rm/Zn Tot	2,679	13 / 1	10 6	68	73.4	1,988	-11,840	13 / 1	10 6	73.4	1,988	-11,840
Bldg 7 - NE Apt	Rm/Zn Tot	2,679	13 / 1	10 6	68	73.8	1,449	-9,196	13 / 1	10 6	73.8	1,449	-9,196
Bldg 7 - SE Apt	Rm/Zn Tot	3,572	13 / 1	10 6	68	70.4	4,330	-11,649	13 / 1	10 6	70.4	4,330	-11,649
Bldg 7 - SW Apt	Rm/Zn Tot	3,572	13 / 1	10 6	68	71.0	4,538	-15,175	13 / 1	10 6	71.0	4,538	-15,175
Bldg 8 - NE Apt	Rm/Zn Tot	2,679	13 / 1	10 6	68	74.7	1,599	-11,840	13 / 1	10 6	74.7	1,599	-11,840
Bldg 8 - SE Apt	Rm/Zn Tot	3,572	13 / 1	10 6	68	71.0	4,534	-15,175	13 / 1	10 6	71.0	4,534	-15,175
Bldg 8 - SW Apt	Rm/Zn Tot	3,572	13 / 1	10 6	68	70.5	4,273	-11,649	13 / 1	10 6	70.5	4,273	-11,649
Bldg 8 - NW Apt	Rm/Zn Tot	2,679	13 / 1	10 6	68	73.4	1,538	-9,196	13 / 1	10 6	73.4	1,538	-9,196
Bldg 9 - NW Apt	Rm/Zn Tot	2,679	13 / 1	10 6	68	73.4	1,988	-11,840	13 / 1	10 6	73.4	1,988	-11,840
Bldg 9 - NE Apt	Rm/Zn Tot	2,679	13 / 1	10 6	68	73.8	1,449	-9,196	13 / 1	10 6	73.8	1,449	-9,196

**PEAK HEATING LOADS
MAIN SYSTEM**

By ae

Description		Floor Area ft²	SPACE						COIL				
			Peak Time Mo/Hr	OA Cond. DB/WB °F	Room Dry Bulb °F	Supply Dry Bulb °F	Space Air Flow cfm	Space Sensible Load Btu/h	Peak Time Mo/Hr	OA Cond. DB/WB °F	Supply Dry Bulb °F	Coll Air Flow cfm	Coll Sensible Load Btu/h
Bldg 9 - SE Apt	Rm/Zn Tot	3,572	13 / 1	10 6	68	70.4	4,330	-11,649	13 / 1	10 6	70.4	4,330	-11,649
Bldg 9 - SW Apt	Rm/Zn Tot	3,572	13 / 1	10 6	68	71.0	4,538	-15,175	13 / 1	10 6	71.0	4,538	-15,175
Bldg 10 - NE Apt	Rm/Zn Tot	2,679	13 / 1	10 6	68	74.7	1,599	-11,840	13 / 1	10 6	74.7	1,599	-11,840
Bldg 10 - SE Apt	Rm/Zn Tot	3,572	13 / 1	10 6	68	71.0	4,534	-15,175	13 / 1	10 6	71.0	4,534	-15,175
Bldg 10 - SW Apt	Rm/Zn Tot	3,572	13 / 1	10 6	68	70.5	4,273	-11,649	13 / 1	10 6	70.5	4,273	-11,649
Bldg 10 - NW Apt	Rm/Zn Tot	2,679	13 / 1	10 6	68	73.4	1,538	-9,196	13 / 1	10 6	73.4	1,538	-9,196
Bldg 4 - NE Apt	Rm/Zn Tot	2,679	13 / 1	10 6	68	74.7	1,599	-11,840	13 / 1	10 6	74.7	1,599	-11,840
Bldg 4 - SE Apt	Rm/Zn Tot	2,679	13 / 1	10 6	68	71.2	3,412	-11,840	13 / 1	10 6	71.2	3,412	-11,840
Bldg 4 - NW Apt	Rm/Zn Tot	2,679	13 / 1	10 6	68	73.4	1,988	-11,840	13 / 1	10 6	73.4	1,988	-11,840
Bldg 4 - SW Apt	Rm/Zn Tot	2,679	13 / 1	10 6	68	71.1	3,423	-11,840	13 / 1	10 6	71.1	3,423	-11,840
Terminal A/C	Sys Tot/Ave	121,434		10 6	68	71.7	118,078	-485,106	10 6	71.7	118,078	-485,106	
Terminal A/C	Sys Block	121,434	13 / 1	10 6	68	71.7	118,078	-485,106	13 / 1	10 6	71.7	118,078	-485,106
Bldg 1 - Stairs	Rm/Zn Tot	333	13 / 1	10 6	60	125.0	74	-5,266	13 / 1	10 6	125.0	74	-5,266
Bldg 2 - Stairs	Rm/Zn Tot	333	13 / 1	10 6	60	125.0	93	-6,671	13 / 1	10 6	125.0	93	-6,671
Bldg 3 - Stairs	Rm/Zn Tot	333	13 / 1	10 6	60	125.0	93	-6,671	13 / 1	10 6	125.0	93	-6,671
Bldg 4 - Stairs	Rm/Zn Tot	333	13 / 1	10 6	60	125.0	81	-5,769	13 / 1	10 6	125.0	81	-5,769
Bldg 5 - Stairs	Rm/Zn Tot	333	13 / 1	10 6	60	125.0	93	-6,671	13 / 1	10 6	125.0	93	-6,671
Bldg 6 - Stairs	Rm/Zn Tot	333	13 / 1	10 6	60	125.0	93	-6,671	13 / 1	10 6	125.0	93	-6,671
Bldg 7 - Stairs	Rm/Zn Tot	333	13 / 1	10 6	60	125.0	93	-6,671	13 / 1	10 6	125.0	93	-6,671
Bldg 8 - Stairs	Rm/Zn Tot	333	13 / 1	10 6	60	125.0	93	-6,671	13 / 1	10 6	125.0	93	-6,671
Bldg 9 - Stairs	Rm/Zn Tot	333	13 / 1	10 6	60	125.0	93	-6,671	13 / 1	10 6	125.0	93	-6,671
Bldg 10 - Stairs	Rm/Zn Tot	333	13 / 1	10 6	60	125.0	93	-6,671	13 / 1	10 6	125.0	93	-6,671
Heating only	Sys Tot/Ave	3,330		10 6	60	125.0	901	-64,400	10 6	125.0	901	-64,400	
Heating only	Sys Block	3,330	13 / 1	10 6	60	125.0	901	-64,400	13 / 1	10 6	125.0	901	-64,400
Bldg 1 - Game/TV	Rm/Zn Tot	1,123	13 / 1	10 6	68	69.2	1,225	-1,662	13 / 1	10 6	69.2	1,225	-11,225
Bldg 1 - Office/Reception	Rm/Zn Tot	281	13 / 1	10 6	68	71.6	328	-1,312	13 / 1	10 6	71.6	328	-5,137
Bldg 1 - Group Meeting	Rm/Zn Tot	633	13 / 1	10 6	68	68.0	444	1,616	13 / 1	10 6	68.0	444	-7,650
Bldg 1 - Conference	Rm/Zn Tot	175	13 / 1	10 6	68	68.0	129	2,093	13 / 1	10 6	68.0	129	-7,650
Bldg 1 - Office - C009	Rm/Zn Tot	281	13 / 1	10 6	68	68.0	86	1,214	13 / 1	10 6	68.0	86	-2,869
Bldg 1 - File/Closet	Rm/Zn Tot	145	13 / 1	10 6	68	80.5	49	-677	13 / 1	10 6	80.5	49	-677
Bldg 1 - Cyber Lounge	Rm/Zn Tot	653	13 / 1	10 6	68	68.0	1,225	1,462	13 / 1	10 6	68.0	1,225	-9,563
Bldg 1 - Corridor/Bathroom	Rm/Zn Tot	280	13 / 1	10 6	68	68.0	1,225	478	13 / 1	10 6	68.0	1,225	0

**PEAK HEATING LOADS
MAIN SYSTEM**

By ae

Description	Floor Area ft ²	SPACE							COIL				
		Peak Time Mo/Hr	OA Cond. DB/WB °F	Room Dry Bulb °F	Supply Dry Bulb °F	Space Air Flow cfm	Space Sensible Load Btu/h	Peak Time Mo/Hr	OA Cond. DB/WB °F	Supply Dry Bulb °F	Coil Air Flow cfm	Coil Sensible Load Btu/h	
Bldg 1 - Fitness	Rm/Zn Tot	212	13 / 1	10 6	68	68.0	1,225	1,282	13 / 1	10 6	68.0	1,225	-6,057
Commons	Sys Tot/Ave	3,783		10 6	68	68.6	5,936	4,495		10 6	68.6	5,936	-50,828
Commons	Sys Block	3,783	13 / 1	10 6	68	68.0	5,936	0	13 / 1	10 6	68.0	5,936	-47,178

Load / Airflow Summary

By ae

Description **		Floor Area ft²	People #	Coil Cooling Sensible Btu/h	Coil Cooling Total Btu/h	Space Design Max SA cfm	Air Changes ach/hr	VAV Minimum SA cfm	Main Coil Heating Sensible Btu/h	Heating Fan Max SA cfm	Percent OA Clg	Htg	ASHRAE 62-89 OA fraction
Bldg 1 - NE Apartments	Rm/Zn Tot	2,745	12.0	50,824	56,126	2,849	6.56	0	-13,072	2,849	0.0	0.0	
Bldg 1 - SE Apartment	Rm/Zn Tot	2,745	12.0	50,680	55,982	2,839	6.53	0	-13,072	2,839	0.0	0.0	
Bldg 1 - SW Apartment	Rm/Zn Tot	1,830	8.0	41,704	45,048	2,469	6.52	0	-9,342	2,469	0.0	0.0	
Bldg 1 - NW Apartments	Rm/Zn Tot	1,830	8.0	41,114	44,458	2,427	8.38	0	-9,342	2,427	0.0	0.0	
Bldg 1 - 2nd SW Apt	Rm/Zn Tot	776	3.0	20,051	21,390	1,226	9.98	0	-4,892	1,226	0.0	0.0	
Bldg 1 - 2nd NW Apt	Rm/Zn Tot	776	2.0	19,519	20,659	1,218	9.91	0	-5,142	1,218	0.0	0.0	
Bldg 2 - NE Apt	Rm/Zn Tot	3,572	16.0	42,867	50,313	2,096	3.71	0	-15,175	2,096	0.0	0.0	
Bldg 2 - SE Apt	Rm/Zn Tot	2,679	12.0	53,020	55,447	3,412	8.04	0	-11,840	3,412	0.0	0.0	
Bldg 2 - SW Apt	Rm/Zn Tot	2,679	12.0	50,341	52,769	3,216	7.58	0	-9,196	3,216	0.0	0.0	
Bldg 2 - NW Apt	Rm/Zn Tot	3,572	16.0	39,795	47,322	1,994	3.53	0	-11,649	1,994	0.0	0.0	
Bldg 3 - NW Apt	Rm/Zn Tot	3,572	16.0	49,271	55,882	2,592	4.58	0	-15,175	2,592	0.0	0.0	
Bldg 3 - NE Apt	Rm/Zn Tot	3,572	16.0	39,724	47,252	1,888	3.34	0	-11,649	1,888	0.0	0.0	
Bldg 3 - SE Apt	Rm/Zn Tot	2,679	12.0	50,923	53,350	3,259	7.68	0	-9,196	3,259	0.0	0.0	
Bldg 3 - SW Apt	Rm/Zn Tot	2,679	12.0	53,166	55,590	3,423	8.07	0	-11,840	3,423	0.0	0.0	
Bldg 5 - NW Apt	Rm/Zn Tot	2,679	12.0	37,612	42,570	1,988	4.69	0	-11,840	1,988	0.0	0.0	
Bldg 5 - NE Apt	Rm/Zn Tot	2,679	12.0	30,326	35,972	1,449	3.42	0	-9,196	1,449	0.0	0.0	
Bldg 5 - SE Apt	Rm/Zn Tot	3,572	16.0	67,691	70,928	4,330	7.66	0	-11,649	4,330	0.0	0.0	
Bldg 5 - SW Apt	Rm/Zn Tot	3,572	16.0	70,538	73,771	4,538	8.02	0	-15,175	4,538	0.0	0.0	
Bldg 6 - NE Apt	Rm/Zn Tot	2,679	12.0	32,586	38,170	1,599	3.77	0	-11,840	1,599	0.0	0.0	
Bldg 6 - SE Apt	Rm/Zn Tot	3,572	16.0	70,487	73,724	4,534	8.02	0	-15,175	4,534	0.0	0.0	
Bldg 6 - SW Apt	Rm/Zn Tot	3,572	16.0	66,916	70,152	4,273	7.56	0	-11,649	4,273	0.0	0.0	
Bldg 6 - NW Apt	Rm/Zn Tot	2,679	12.0	30,379	36,025	1,538	3.63	0	-9,196	1,538	0.0	0.0	
Bldg 7 - NW Apt	Rm/Zn Tot	2,679	12.0	37,612	42,570	1,988	4.69	0	-11,840	1,988	0.0	0.0	
Bldg 7 - NE Apt	Rm/Zn Tot	2,679	12.0	30,326	35,972	1,449	3.42	0	-9,196	1,449	0.0	0.0	
Bldg 7 - SE Apt	Rm/Zn Tot	3,572	16.0	67,691	70,928	4,330	7.66	0	-11,649	4,330	0.0	0.0	
Bldg 7 - SW Apt	Rm/Zn Tot	3,572	16.0	70,538	73,771	4,538	8.02	0	-15,175	4,538	0.0	0.0	
Bldg 8 - NE Apt	Rm/Zn Tot	2,679	12.0	32,586	38,170	1,599	3.77	0	-11,840	1,599	0.0	0.0	
Bldg 8 - SE Apt	Rm/Zn Tot	3,572	16.0	70,487	73,724	4,534	8.02	0	-15,175	4,534	0.0	0.0	
Bldg 8 - SW Apt	Rm/Zn Tot	3,572	16.0	66,916	70,152	4,273	7.56	0	-11,649	4,273	0.0	0.0	
Bldg 8 - NW Apt	Rm/Zn Tot	2,679	12.0	30,379	36,025	1,538	3.63	0	-9,196	1,538	0.0	0.0	
Bldg 9 - NW Apt	Rm/Zn Tot	2,679	12.0	37,612	42,570	1,988	4.69	0	-11,840	1,988	0.0	0.0	

** This report does not display heating only systems.

Project Name: University Ridge at East Stroudsburg
 Dataset Name: C:\CDS\TRACE700\Projects\ESU-AQUATHERM.TRC

TRACE® 700 v4.1 calculated at 11:54 AM on 10/27/2006
 Alternative - 1 Load/Airflow Summary report page 1

Load / Airflow Summary

By ae

Description **		Floor Area ft²	People #	Coil Cooling Sensible Btu/h	Coil Cooling Total Btu/h	Space Design Max SA cfm	Air Changes ach/hr	VAV Minimum SA cfm	Main Coil Heating Sensible Btu/h	Heating Fan Max SA cfm	Percent OA Clg	ASHRAE 62-89 Htg OA fraction
Bldg 9 - NE Apt	Rm/Zn Tot	2,679	12.0	30,326	35,972	1,449	3.42	0	-9,196	1,449	0.0	0.0
Bldg 9 - SE Apt	Rm/Zn Tot	3,572	16.0	67,691	70,928	4,330	7.66	0	-11,649	4,330	0.0	0.0
Bldg 9 - SW Apt	Rm/Zn Tot	3,572	16.0	70,538	73,771	4,538	8.02	0	-15,175	4,538	0.0	0.0
Bldg 10 - NE Apt	Rm/Zn Tot	2,679	12.0	32,586	38,170	1,599	3.77	0	-11,840	1,599	0.0	0.0
Bldg 10 - SE Apt	Rm/Zn Tot	3,572	16.0	70,487	73,724	4,534	8.02	0	-15,175	4,534	0.0	0.0
Bldg 10 - SW Apt	Rm/Zn Tot	3,572	16.0	66,916	70,152	4,273	7.56	0	-11,649	4,273	0.0	0.0
Bldg 10 - NW Apt	Rm/Zn Tot	2,679	12.0	30,379	36,025	1,538	3.63	0	-9,196	1,538	0.0	0.0
Bldg 4 - NE Apt	Rm/Zn Tot	2,679	12.0	32,586	38,170	1,599	3.77	0	-11,840	1,599	0.0	0.0
Bldg 4 - SE Apt	Rm/Zn Tot	2,679	12.0	53,020	55,447	3,412	8.04	0	-11,840	3,412	0.0	0.0
Bldg 4 - NW Apt	Rm/Zn Tot	2,679	12.0	37,612	42,570	1,988	4.69	0	-11,840	1,988	0.0	0.0
Bldg 4 - SW Apt	Rm/Zn Tot	2,679	12.0	53,166	55,590	3,423	8.07	0	-11,840	3,423	0.0	0.0
Terminal A/C	Sys Tot/Ave	121,434	541.0	1,998,987	2,177,296	118,078			-485,106	118,078	0.0	0.0
Terminal A/C	Sys Block	121,434	541.0	1,670,815	1,923,345	118,078			-485,106	118,078	0.0	0.0
Bldg 1 - Game/TV	Rm/Zn Tot	1,123	10.0	18,701	23,012	1,225	6.89	0	-11,225	1,225	12.2	12.2
Bldg 1 - Office/Reception	Rm/Zn Tot	281	4.0	6,769	8,724	328	7.38	0	-5,137	328	18.3	18.3
Bldg 1 - Group Meeting	Rm/Zn Tot	633	8.0	9,966	13,877	444	4.43	0	-7,650	444	27.0	27.0
Bldg 1 - Conference	Rm/Zn Tot	175	8.0	4,787	7,704	129	4.65	0	-7,650	129	93.1	93.1
Bldg 1 - Office - C009	Rm/Zn Tot	281	3.0	2,534	3,849	86	1.92	0	-2,869	86	52.6	52.6
Bldg 1 - File/Closet	Rm/Zn Tot	145	0.0	593	593	49	2.15	0	-677	49	0.0	0.0
Bldg 1 - Cyber Lounge	Rm/Zn Tot	653	10.0	12,273	14,950	1,225	11.85	0	-9,563	1,225	12.2	12.2
Bldg 1 - Corridor/Bathroom	Rm/Zn Tot	280	0.0	956	956	1,225	27.63	0	0	1,225	0.0	0.0
Bldg 1 - Fitness	Rm/Zn Tot	212	4.0	3,755	4,532	1,225	36.49	0	-6,057	1,225	7.8	7.8
Commons	Sys Tot/Ave	3,783	47.0	57,959	75,820	5,936			-50,828	5,936	12.5	12.5
Commons	Sys Block	3,783	47.0	56,637	73,618	5,936			-47,178	5,936	12.5	12.5

** This report does not display heating only systems.

Project Name: University Ridge at East Stroudsburg
 Dataset Name: C:\CDS\TRACE700\Projects\ESU-AQUATHERM.TRC

TRACE® 700 v4.1 calculated at 11:54 AM on 10/27/2006
 Alternative - 1 Load/Airflow Summary report page 2

Appendix E

MONTHLY ENERGY CONSUMPTION

By ae

Alternative: 1 University Ridge

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (kWh)	61,646	55,288	72,480	69,062	82,871	88,862	84,584	94,726	78,781	77,104	69,513	60,591	895,507
Off-Pk Cons. (kWh)	83,482	75,260	79,528	83,862	89,152	88,251	108,611	91,561	91,389	84,425	80,879	86,920	1,043,321
On-Pk Demand (kW)	322	321	348	355	374	390	398	394	385	351	347	346	398
Off-Pk Demand (kW)	346	346	371	366	353	365	375	366	358	352	358	366	375
Gas													
On-Pk Cons. (therms)	64	59	20	4	0	0	0	0	0	4	10	40	201
Off-Pk Cons. (therms)	28	28	14	1	0	0	0	0	0	0	9	19	99
On-Pk Demand (therms/hr)	3	1	0	0	0	0	0	0	0	0	0	0	3
Off-Pk Demand (therms/hr)	5	1	0	0	0	0	0	0	0	0	0	1	5

Building Energy Consumption = 51,711 Btu/(ft2-year)
 Source Energy Consumption = 154,893 Btu/(ft2-year)
 Floor Area = 128,647 ft2

ENERGY CONSUMPTION SUMMARY

By ae

	Elect Cons. (kWh)	Gas Cons. (therms)	Percent of Total Energy	Total Source Energy* (kBtu/yr)
Primary heating				
Primary heating	6,003.1	300.3	0.8 %	930.9
Primary cooling				
Cooling Compressor	313,170.7		16.1 %	32,068.8
Tower/Cond Fans	44,656.4		2.3 %	4,572.8
Condenser Pump			0.0 %	0.0
Other CLG Accessories	1,204.5		0.1 %	123.3
Cooling Subtotal....	359,031.5		18.4 %	36,764.9
Auxiliary				
Supply Fans			0.0 %	0.0
Circ Pumps	5,036.0		0.3 %	515.7
Base Utilities			0.0 %	0.0
Aux Subtotal....	5,036.0		0.3 %	515.7
Lighting				
Lighting	563,035.6		28.9 %	57,655.0
Receptacle				
Receptacles	1,005,722.6		51.6 %	102,966.2
Heating plant load				
Base Utilities			0.0 %	0.0
Cogeneration				
Cogeneration			0.0 %	0.0
Totals				
Totals**	1,938,828.9	300.3	100.0 %	198,852.7

* Note: Resource Utilization factors are included in the Total Source Energy value.

** Note: This report can display a maximum of 6 utilities. If additional utilities are used, they will be included in the total.

MONTHLY UTILITY COSTS

By ae

Alternative: 1

Utility	----- Monthly Utility Costs -----												Total
	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	
Electric													
On-Pk Cons. (\$)	5,965	5,350	7,013	6,682	8,019	8,598	8,184	9,166	7,623	7,461	6,726	5,863	86,649
On-Pk Demand (\$)	3,156	3,151	3,413	3,487	3,677	3,833	3,918	3,872	3,782	3,451	3,405	3,400	42,544
Total (\$):	9,121	8,501	10,426	10,169	11,695	12,431	12,102	13,038	11,405	10,912	10,131	9,262	129,193
Gas													
On-Pk Cons. (\$)	257	246	92	18	0	0	0	0	0	18	47	182	861
Monthly Total (\$):	9,378	8,747	10,519	10,187	11,695	12,431	12,102	13,038	11,405	10,930	10,178	9,444	130,054

TRACE® 700 Economic Summary

By ae

Project Information

Weather file Allentown, Pennsylvania
 Project Name University Ridge at East Stroudsburg
 Location East Stroudsburg, PA
 Building Owner
 User Matthew Carr
 Company
 Comments


Alternative 1 - - University Ridge

Economic Summary

Alternative Number	Installed Cost	First Year Util. Cost	Final Year Util. Cost	First Year MaInt. Cost	Final Year MaInt. Cost	Life Cycle Cost
1	0.00	130053.89	130053.89	0.00	0.00	1107222.09

Monthly Utility Costs per Utility

(1 alternative)



Equipment Energy Consumption by Alternative

	Elect Conc. (kWh)	Gas Conc. (therms)	Percent of Total Energy	Total Source Energy* (kBtu/yr)
Alternative: 1 - University Ridge				
Primary heating	6,003.1	300.3	0.8%	930.9
Cooling Compressor	313,170.7		16.1%	32,068.8
Tower/Cond Fans	44,656.4		2.3%	4,572.8
Other CLG Accessories	1,204.5		0.1%	123.3
Circ Pumps	5,036.0		0.3%	515.7
Lighting	563,035.8		28.9%	57,655.0
Totals	1,938,628.9	300.3	100.0%	198,852.7

* Note: Resource Utilization factors are included in the Total Source Energy value.

References

1. ASHRAE. 2004. *ANSI/ASHRAE Standard 90.1-2004 – Energy Standard*. American Society of Heating, Refrigerating, and Air-Conditioning Engineers, Inc.
2. LEED-NC Green Building Rating System: Version 2.2. United States Green Building Council, 2005.
3. TRANE TRACE 700 v 4.1.1 2001.