



Mechanical Breadth

Breadth Overview

My mechanical depth was designed to explore the affect of the architectural implications of the new façade designs in the capital market classroom, the designs that can be found on the cd attached to this book. The addition of the light shelf and the use of more efficient solar glazing windows will affect the mechanical design to the room. Solar gains through the windows can potentially cause significant loses and gains to the systems serving the room, and through these gains will directly affect the operation cost of the system. To explore how the design will affect the mechanical system in the capital market classroom, a program called Hourly Analysis Program was used.

The primary goal of this depth study is to examine the affect the solar heat gains or loses have on the mechanical systems, and to determine if the existing system is adequate. The secondary goal of the study is to analyze emissions and energy gains or loses.

Existing System Narrative –

The existing design utilizes two blower coil units, which are located on floor P1 below the classroom on floor. These two units only supply the capital market classroom. The existing system and the inputs placed into the HAP analysis are contained below.

<p>1. General Details: Air System Name BCU1 Equipment Class Chilled Water AHU Air System Type Single Zone CAV Number of zones 1</p> <p>2. System Components: Ventilation Air Data: Airflow Control Constant Ventilation Airflow Ventilation Sizing Method ASHRAE Std 62-2001 Unocc. Damper Position Closed Damper Leak Rate 0 % Outdoor Air CO2 Level 400 ppm</p> <p>Preheat Coil Data: Setpoint 56.0 °F Heating Source Hot Water Schedule JFMAMJJASOND Coil position Downstream of Mixing Point</p> <p>Central Cooling Data: Supply Airflow Rate 2700.0 CFM Coil Bypass Factor 0.100 Cooling Source Chilled Water Schedule JFMAMJJASOND Capacity Control ... Constant Temperature - Fan Cycled</p> <p>Supply Fan Data: Fan Type Forward Curved Configuration Draw-thru Fan Performance 3.00 in wg Overall Efficiency 54 %</p>	<p>1. General Details: Air System Name BCU2 Equipment Class Chilled Water AHU Air System Type Single Zone CAV Number of zones 1</p> <p>2. System Components: Ventilation Air Data: Airflow Control Constant Ventilation Airflow Ventilation Sizing Method ASHRAE Std 62-2001 Unocc. Damper Position Closed Damper Leak Rate 0 % Outdoor Air CO2 Level 400 ppm</p> <p>Preheat Coil Data: Setpoint 56.0 °F Heating Source Hot Water Schedule JFMAMJJASOND Coil position Downstream of Mixing Point</p> <p>Central Cooling Data: Supply Airflow Rate 1200.0 CFM Coil Bypass Factor 0.100 Cooling Source Chilled Water Schedule JFMAMJJASOND Capacity Control ... Constant Temperature - Fan Cycled</p> <p>Supply Fan Data: Fan Type Forward Curved Configuration Draw-thru Fan Performance 2.70 in wg Overall Efficiency 54 %</p>
---	---



<p>3. Zone Components: Space Assignments:</p> <table border="1" style="margin-left: 20px;"> <thead> <tr> <th colspan="2">Zone 1: Zone 1</th> </tr> </thead> <tbody> <tr> <td>Capital Market</td> <td style="text-align: center;">x1</td> </tr> </tbody> </table> <p>Thermostats and Zone Data:</p> <p>Zone All Cooling T-stat: Occ. 75.0 °F Cooling T-stat: Unocc. 85.0 °F Heating T-stat: Occ. 70.0 °F Heating T-stat: Unocc. 60.0 °F T-stat Throttling Range 3.00 °F Diversity Factor 100 % Direct Exhaust Airflow 0.0 CFM Direct Exhaust Fan kW 0.0 kW</p>		Zone 1: Zone 1		Capital Market	x1
Zone 1: Zone 1					
Capital Market	x1				
<p>Supply Terminals Data:</p> <p>Zone All Terminal Type Diffuser Minimum Airflow 2700.0 CFM</p> <p>Zone Heating Units:</p> <p>Zone All Zone Heating Unit Type Baseboard, room T-stat control</p> <p>4. Sizing Data (Computer-Generated): System Sizing Data:</p> <p>Cooling Supply Temperature 61.2 °F Supply Fan Airflow 2700.0 CFM Ventilation Fan Airflow 495.0 CFM</p> <p>Hydronic Sizing Specifications:</p> <p>Chilled Water Delta-T 10.0 °F Hot Water Delta-T 20.0 °F</p>	<p>Supply Terminals Data:</p> <p>Zone All Terminal Type Diffuser Minimum Airflow 1200.0 CFM</p> <p>Zone Heating Units:</p> <p>Zone All Zone Heating Unit Type Baseboard, room T-stat control</p> <p>4. Sizing Data (Computer-Generated): System Sizing Data:</p> <p>Cooling Supply Temperature 43.9 °F Supply Fan Airflow 1200.0 CFM Ventilation Fan Airflow 495.0 CFM</p> <p>Hydronic Sizing Specifications:</p> <p>Chilled Water Delta-T 10.0 °F Hot Water Delta-T 20.0 °F</p>				

Input data for the chiller plant and the boiler plant are contained in the appendix. Data for the chiller and boiler plants was taken from the existing mechanical plans, but sized down. The two plants were sized down to eliminate any portion of the system not feeding the room. With that portion of the system eliminate, it was easier to compare the systems that were just serving the classroom. All other results were placed with the HAP files with the CD contained.

System Analysis

The existing design of the two blowing coil units has already been included in this report; however, with the changes made to the exterior portion of the room, the system will operate at a separate design level. After running an analysis of the room with the addition of a light shelf, and then again with different windows, the system operated under different design loads each time. Displayed below is a comparison of the blowing coil unit one in its existing condition, with the light shelf added to the space, and with the addition of the light shelf and the new glass.



Information on blowing coil unit 2 can be found on the CD attached with the book.

BCU1 - Central Cooling Coil Size Data – Existing Data

Total coil load	7.3 Tons	Load occurs at	Jul 1100
Total coil load	88.2 MBH	OA DB / WB	88.5 / 74.3 °F
Sensible coil load	68.5 MBH	Entering DB / WB	79.9 / 66.0 °F
Coil CFM at Jul 1100	2700 CFM	Leaving DB / WB	56.4 / 55.1 °F
Max block CFM	2700 CFM	Coil ADP	53.8 °F
Sum of peak zone CFM	2700 CFM	Bypass Factor	0.100
Sensible heat ratio	0.778	Resulting RH	46 %
ft ² /Ton	195.1	Design supply temp.	58.5 °F
BTU/(hr-ft ²)	61.5	Zone T-stat Check	1 of 1 OK
Water flow @ 10.0 °F rise	17.64 gpm	Max zone temperature deviation	0.0 °F

BCU1 - Central Cooling Coil Size Data – Lightshef only

Total coil load	7.4 Tons	Load occurs at	Jul 1100
Total coil load	89.2 MBH	OA DB / WB	88.5 / 74.3 °F
Sensible coil load	69.4 MBH	Entering DB / WB	80.0 / 65.9 °F
Coil CFM at Jul 1100	2700 CFM	Leaving DB / WB	56.1 / 54.9 °F
Max block CFM	2700 CFM	Coil ADP	53.5 °F
Sum of peak zone CFM	2700 CFM	Bypass Factor	0.100
Sensible heat ratio	0.778	Resulting RH	46 %
ft ² /Ton	192.7	Design supply temp.	58.2 °F
BTU/(hr-ft ²)	62.3	Zone T-stat Check	1 of 1 OK
Water flow @ 10.0 °F rise	17.86 gpm	Max zone temperature deviation	0.1 °F

BCU1 - Central Cooling Coil Size Data – Lightshef with new glass

Total coil load	6.0 Tons	Load occurs at	Jul 1100
Total coil load	72.2 MBH	OA DB / WB	88.5 / 74.3 °F
Sensible coil load	56.3 MBH	Entering DB / WB	79.9 / 67.8 °F
Coil CFM at Jul 1100	2685 CFM	Leaving DB / WB	60.4 / 59.3 °F
Max block CFM	2700 CFM	Coil ADP	58.3 °F
Sum of peak zone CFM	2700 CFM	Bypass Factor	0.100
Sensible heat ratio	0.780	Resulting RH	54 %
ft ² /Ton	238.0	Design supply temp.	62.5 °F
BTU/(hr-ft ²)	50.4	Zone T-stat Check	1 of 1 OK
Water flow @ 10.0 °F rise	14.46 gpm	Max zone temperature deviation	0.0 °F

As expected, total coil loads and the sensible coil load decreased as the changes were made to the space, and the BTU value and water flow rate also lowered in the final situation. The glazing on the window blocks a solid portion of the heat gain from solar means. Making changes to an isolated system such as this one would not necessarily produce savings that would be noticeable among the costs of an entire building. However, if these changes were to be implemented throughout the building, cost savings would be more significant, and it would be easy to replace the existing system with a smaller, less expensive system.



System Analysis


The advantages to the changes in the façade design are not limited to sizing down the blower coils units to a cheaper system. With the elimination of a portion of the solar loads, the mechanical equipment in the room will operate in a different way. In some cases there will be a decrease in certain cooling because a portion of the direct gains will be eliminated, and it will also affect heating loads in the opposite manner. Design for the capital market room was made with three different systems; however, due to the length of the study and the amount of data contained in each of the studies, only the data from two situations is contained below. An analysis of the existing condition has been run for comparison purposes, and then a direct indirect lighting system with a light shelf added to the space and a lighting system with a light shelf and new glass. The cases for the remaining lighting systems and blower coil units can be found in on the CD with the rest of the HAP files.

Component Costs Analysis


The pie charts that on the next page give a breakdown of how the total cost is divided between the varying system components. The charts show that the cost of the varying system components is spread in a uniform fashion for the different situations. Changes between the existing system and the system with the light shelf is not very different, but when the low-e windows are added, the system changes dramatically. By adding the windows, a very large portion of the cooling cost is eliminated. The other systems vary in only one and two percent increments. Small changes in the data are hard to judge however, as the values can remain the same, but the data can be affected by the other changes to the system. The pie charts showing these changes are shown on the next page, followed by the actual cost break down of each of the components.




Existing System



Light Shelf Design



Light Shelf and Window Design





Component Cost Analysis

Existing System				Light Shelf			
Component	Annual Cost (\$)	(\$/ft ²)	Percent of Total (%)	Component	Annual Cost (\$)	(\$/ft ²)	Percent of Total (%)
Air System Fans	514	0.179	6.5	Air System Fans	530	0.185	6.6
Cooling	1,810	0.632	22.9	Cooling	1,880	0.656	23.5
Heating	458	0.160	5.8	Heating	457	0.160	5.7
Pumps	223	0.078	2.8	Pumps	230	0.080	2.9
Cooling Tower Fans	702	0.245	8.9	Cooling Tower Fans	729	0.255	9.1
HVAC Sub-Total	3,707	1.293	46.9	HVAC Sub-Total	3,826	1.335	47.8
Lights	1,248	0.436	15.8	Lights	1,245	0.434	15.5
Electric Equipment	2,947	1.028	37.3	Electric Equipment	2,939	1.025	36.7
Misc. Electric	0	0.000	0.0	Misc. Electric	0	0.000	0.0
Misc. Fuel Use	0	0.000	0.0	Misc. Fuel Use	0	0.000	0.0
Non-HVAC Sub-Total	4,195	1.464	53.1	Non-HVAC Sub-Total	4,184	1.460	52.2
Grand Total	7,902	2.757	100.0	Grand Total	8,009	2.795	100.0

Light Shelf and Windows			
Component	Annual Cost (\$)	(\$/ft ²)	Percent of Total (%)
Air System Fans	568	0.198	7.6
Cooling	1,467	0.512	19.6
Heating	457	0.160	6.1
Pumps	213	0.074	2.8
Cooling Tower Fans	571	0.199	7.6
HVAC Sub-Total	3,276	1.143	43.7
Lights	1,257	0.439	16.8
Electric Equipment	2,967	1.035	39.6
Misc. Electric	0	0.000	0.0
Misc. Fuel Use	0	0.000	0.0
Non-HVAC Sub-Total	4,224	1.474	56.3
Grand Total	7,500	2.617	100.0


As you can see from viewing the charts above, the cost of the system components increases slightly with the addition of the light shelf, and then decreases significantly when the glazing windows are added to the façade. The savings found in this room may seem to be significant, but the savings of five hundred dollars in a single room can be very small compared to the cost of the upkeep of the entire building. However, if the new windows are placed throughout the entire building, the savings would multiply and the building would see substantial savings.




Annual Energy Costs

The annual energy cost utilized the information from the system components and applied it to the cost of the system as opposed to the singular components. The data is displayed in the same manner as the previous section. H.A.P. provided a pie chart to show the breakdown of the cost on the entire system, and then numerical charts to give raw cost data on the systems.


Existing System



Light Shelf



Light Shelf and Windows





Annual Energy Costs

Existing System				Light Shelf			
Component	Annual Cost (\$/yr)	(\$/ft ²)	Percent of Total (%)	Component	Annual Cost (\$/yr)	(\$/ft ²)	Percent of Total (%)
HVAC Components				HVAC Components			
Electric	3,249	1.134	41.1	Electric	3,368	1.175	42.1
Natural Gas	458	0.160	5.8	Natural Gas	457	0.160	5.7
HVAC Sub-Total	3,707	1.293	46.9	HVAC Sub-Total	3,826	1.335	47.8
Non-HVAC Components				Non-HVAC Components			
Electric	4,195	1.464	53.1	Electric	4,184	1.460	52.2
Natural Gas	0	0.000	0.0	Natural Gas	0	0.000	0.0
Non-HVAC Sub-Total	4,195	1.464	53.1	Non-HVAC Sub-Total	4,184	1.460	52.2
Grand Total	7,902	2.757	100.0	Grand Total	8,009	2.795	100.0

Light Shelf and Glass			
Component	Annual Cost (\$/yr)	(\$/ft ²)	Percent of Total (%)
HVAC Components			
Electric	2,819	0.984	37.6
Natural Gas	457	0.160	6.1
HVAC Sub-Total	3,276	1.143	43.7
Non-HVAC Components			
Electric	4,224	1.474	56.3
Natural Gas	0	0.000	0.0
Non-HVAC Sub-Total	4,224	1.474	56.3
Grand Total	7,500	2.617	100.0

The results from the annual energy costs mirror the results from the component costs. As before, the cost of the system with the light shelf and the low-e glass windows provided the most cost saving. Although there was an increase in the cost of the non HVAC electrical equipment, there was a very large saving in the actual HVAC systems.



Energy Emissions

Existing System

Light Shelf

Light Shelf and Windows

Table 1. Annual Costs

Component	duques hall (\$)
HVAC Components	
Electric	3,249
Natural Gas	458
HVAC Sub-Total	3,707
Non-HVAC Components	
Electric	4,195
Natural Gas	0
Non-HVAC Sub-Total	4,195
Grand Total	7,902

Table 1. Annual Costs

Component	duques hall (\$)
HVAC Components	
Electric	3,368
Natural Gas	457
HVAC Sub-Total	3,826
Non-HVAC Components	
Electric	4,184
Natural Gas	0
Non-HVAC Sub-Total	4,184
Grand Total	8,009

Table 1. Annual Costs

Component	duques hall (\$)
HVAC Components	
Electric	2,819
Natural Gas	457
HVAC Sub-Total	3,276
Non-HVAC Components	
Electric	4,224
Natural Gas	0
Non-HVAC Sub-Total	4,224
Grand Total	7,500

The annual savings for the space are shown in the tables above. The biggest savings is electrical savings for the HVAC components when the Solarban windows are utilized in the design. Overall totals do not differ very much between the existing system and the light shelf study, while the study with the glazing and the light shelf gives the biggest savings.

Table 2. Annual Energy Consumption

Component	duques hall
HVAC Components	
Electric (kWh)	26,253
Natural Gas (Therm)	3
Non-HVAC Components	
Electric (kWh)	32,644
Natural Gas (Therm)	0
Totals	
Electric (kWh)	58,897
Natural Gas (Therm)	3

Table 2. Annual Energy Consumption

Component	duques hall
HVAC Components	
Electric (kWh)	27,280
Natural Gas (Therm)	2
Non-HVAC Components	
Electric (kWh)	32,644
Natural Gas (Therm)	0
Totals	
Electric (kWh)	59,924
Natural Gas (Therm)	2

Table 2. Annual Energy Consumption

Component	duques hall
HVAC Components	
Electric (kWh)	22,430
Natural Gas (Therm)	1
Non-HVAC Components	
Electric (kWh)	32,644
Natural Gas (Therm)	0
Totals	
Electric (kWh)	55,074
Natural Gas (Therm)	1

The energy consumption tables follow the same trend. Values for the existing system and the system with the light shelf are rather similar; however, cost savings occur in the HVAC components of the final study.

Table 3. Annual Emissions

Component	duques hall
CO2 (lb)	81,282
SO2 (kg)	201
NOx (kg)	118

Table 3. Annual Emissions

Component	duques hall
CO2 (lb)	82,699
SO2 (kg)	205
NOx (kg)	120

Table 3. Annual Emissions

Component	duques hall
CO2 (lb)	76,004
SO2 (kg)	188
NOx (kg)	111

The savings in the HVAC systems carriers over into the emissions categories. This is clear because the light shelf and windows system has the least amount of emissions.



Table 4. Annual Cost per Unit Floor Area		Table 4. Annual Cost per Unit Floor Area		Table 4. Annual Cost per Unit Floor Area	
Component	duques hall (\$/ft ²)	Component	duques hall (\$/ft ²)	Component	duques hall (\$/ft ²)
HVAC Components		HVAC Components		HVAC Components	
Electric	1.134	Electric	1.175	Electric	0.984
Natural Gas	0.160	Natural Gas	0.160	Natural Gas	0.160
HVAC Sub-Total	1.293	HVAC Sub-Total	1.335	HVAC Sub-Total	1.143
Non-HVAC Components		Non-HVAC Components		Non-HVAC Components	
Electric	1.464	Electric	1.460	Electric	1.474
Natural Gas	0.000	Natural Gas	0.000	Natural Gas	0.000
Non-HVAC Sub-Total	1.464	Non-HVAC Sub-Total	1.460	Non-HVAC Sub-Total	1.474
Grand Total	2.757	Grand Total	2.795	Grand Total	2.617
Gross Floor Area (ft ²)	2866.0	Gross Floor Area (ft ²)	2866.0	Gross Floor Area (ft ²)	2866.0
Conditioned Floor Area (ft ²)	2866.0	Conditioned Floor Area (ft ²)	2866.0	Conditioned Floor Area (ft ²)	2866.0

The same conclusions made in the other categories follow through to this one as well.

Table 5. Component Cost as a Percentage of Total Cost		Table 5. Component Cost as a Percentage of Total Cost		Table 5. Component Cost as a Percentage of Total Cost	
Component	duques hall (%)	Component	duques hall (%)	Component	duques hall (%)
HVAC Components		HVAC Components		HVAC Components	
Electric	41.1	Electric	42.1	Electric	37.6
Natural Gas	5.8	Natural Gas	5.7	Natural Gas	6.1
HVAC Sub-Total	46.9	HVAC Sub-Total	47.8	HVAC Sub-Total	43.7
Non-HVAC Components		Non-HVAC Components		Non-HVAC Components	
Electric	53.1	Electric	52.2	Electric	56.3
Natural Gas	0.0	Natural Gas	0.0	Natural Gas	0.0
Non-HVAC Sub-Total	53.1	Non-HVAC Sub-Total	52.2	Non-HVAC Sub-Total	56.3
Grand Total	100.0	Grand Total	100.0	Grand Total	100.0

The break down of cost percentage varies so much across the three categories because of the difference in total cost.

Conclusion

From the breakdown of the different sections, it is quite apparent that the implementation of the solarban glass cuts significant portions out of the heating and cooling loads to the capital market classroom. The light shelf seems to have little affect on the room, and if anything, seems to cause higher heating costs to supplement the light it prevents from entering the space. More efficient glazing is an excellent addition to any space to aide of the HVAC systems. Cost data might not reach a pay back for a few years do to the smaller scale of this situation, but if implemented to an entire building, the money saved would slowly start adding up in the bank.