

# Building Systems Integration - Energy and Cost Analysis

## The Milton Hershey School New Supply Center

Justin Bem  
AE Senior Thesis – Spring 2007  
Mechanical Option  
Penn State University



## Presentation Outline

Project and Building Background

Existing Conditions

Mechanical System Redesign

- DOAS/ Water Source Heat Pumps

- Condenser Loop Heat Recovery System

- Absorption Chiller-Heater Technology

- Redesigned Chiller/Boiler Plants

- Life Cycle Cost Analysis and Payback

Structural/Construction Breadth

- AHU Relocation Roof Structure Impact

- Mezzanine Floor Detailed Cost Estimate

Electrical Breadth

- Redesign's effect on Power Systems

Conclusions and Recommendations



# Presentation Outline

## **Project and Building Background**

Existing Conditions

Mechanical System Redesign

- DOAS/ Water Source Heat Pumps

- Condenser Loop Heat Recovery System

- Absorption Chiller-Heater Technology

- Redesigned Chiller/Boiler Plants

- Life Cycle Cost Analysis and Payback

Structural/Construction Breadth

- AHU Relocation Roof Structure Impact

- Mezzanine Floor Detailed Cost Estimate

Electrical Breadth

- Redesign's effect on Power Systems

Conclusions and Recommendations



# Project and Building Background

## Owner

- The Milton Hershey School

## Location

- The Milton Hershey School Campus, Hershey, PA

## Project Size

- 110,000 square feet

## Total Cost

- \$23,500,000

## Design-Bid-Build Contract

## Construction Dates

- July 2006 – July 2007



# Project and Building Background

## The Supply Center

- General Office and Conference Rooms
- Kitchen/Food Preparation Center
- Bakery
- Clothing Store and Alterations Seamstress
- Mail Distribution Center
- General Building and MHS Campus Storage



## Presentation Outline

Project and Building Background

### **Existing Conditions**

Mechanical System Redesign

- DOAS/ Water Source Heat Pumps

- Condenser Loop Heat Recovery System

- Absorption Chiller-Heater Technology

- Redesigned Chiller/Boiler Plants

- Life Cycle Cost Analysis and Payback

Structural/Construction Breadth

- AHU Relocation Roof Structure Impact

- Mezzanine Floor Detailed Cost Estimate

Electrical Breadth

- Redesign's effect on Power Systems

Conclusions and Recommendations



## Existing Conditions

### Air Side Mechanical System

#### 14 Total Air Handling Units

- 10 VAV Units – Serving General Office and Clothing Areas
- 4 CAV Units – 100% Outdoor Air Make-Up Units for Kitchen/Bakery
- Chilled/Hot Water Coils
- Housed in Elevated Mechanical Mezzanine Floor



McQuay Custom Air Handling Unit



## Existing Conditions

### Existing Chiller Plant

#### (2) 270 ton Water Cooled Centrifugal Chillers

- Primary-Secondary Pumping
- 45°F Chilled Water Serves AHU Coils and Walk-in Freezer Condenser
- Electric Driven Vapor Compression Machines
- Housed in 1<sup>st</sup> Floor Mechanical Room

### Existing Boiler Plant

#### (3) Natural Gas Fired Steam Boilers

- Handles All Building HVAC Heating Demands
- Meets Domestic Hot Water Heating Demands



Trane Centrifugal Chiller






## Existing Conditions

### Walk-in Freezer Condenser Water Loop

Rejected Heat from Condenser to water loop

- Removes Additional Heating Load from Kitchen Space
- Load Is Met Directly By Chilled Water Plant Via Plate-Frame HX's
- Water Side "Free" Cooling Is Utilized in the Winter for Heat Rejection



## Presentation Outline

Project and Building Background

Existing Conditions

### **Mechanical System Redesign**

DOAS/ Water Source Heat Pumps

Condenser Loop Heat Recovery System

Absorption Chiller-Heater Technology

Redesigned Chiller/Boiler Plants

Life Cycle Cost Analysis and Payback

Structural/Construction Breadth

AHU Relocation Roof Structure Impact

Mezzanine Floor Detailed Cost Estimate

Electrical Breadth

Redesign's effect on Power Systems

Conclusions and Recommendations



# Mechanical System Redesign

## Goals and Objectives

- Increase Energy Efficiency
- Low Life Cycle Cost
- Affordable – (Low First Cost or 2-4 Year Payback Period)

## Integration of All Building Systems with HVAC System

- Recover Waste Heat
- Perform Multiple Functions from One Fuel Source



## Presentation Outline

Project and Building Background

Existing Conditions

### **Mechanical System Redesign**

#### **DOAS/ Water Source Heat Pumps**

Condenser Loop Heat Recovery System

Absorption Chiller-Heater Technology

Redesigned Chiller/Boiler Plants

Life Cycle Cost Analysis and Payback

Structural/Construction Breadth

AHU Relocation Roof Structure Impact

Mezzanine Floor Detailed Cost Estimate

Electrical Breadth

Redesign's effect on Power Systems

Conclusions and Recommendations



# Mechanical System Redesign DOAS/ Water Source Heat Pumps

## DOAS at The Supply Center

- 10 Existing VAV Air Handling Units Replaced with 2 DOAS Units
- Saves in First Cost
- Saves in Fan and Chiller Energy

## Water Source Heat Pumps at The Supply Center

- Water Source Loop Integrates Other Building Systems
  - Condenser Water Loop Heat Recovery
- Gives Ability to Heat and Cool Simultaneously



## Presentation Outline

Project and Building Background

Existing Conditions

### **Mechanical System Redesign**

DOAS/ Water Source Heat Pumps

### **Condenser Loop Heat Recovery System**

Absorption Chiller-Heater Technology

Redesigned Chiller/Boiler Plants

Life Cycle Cost Analysis and Payback

Structural/Construction Breadth

AHU Relocation Roof Structure Impact

Mezzanine Floor Detailed Cost Estimate

Electrical Breadth

Redesign's effect on Power Systems

Conclusions and Recommendations



# Mechanical System Redesign Condenser Loop Heat Recovery

## Walk-in Freezer's Reject Heat to a Condenser Water Loop

- Must Be Cooled for Continues Operation of Freezers
- Potential for a Large Amount of Energy Recovery

135gpm Flow Rate

84°F Hot Temperature

65°F Operating Temperature


1282 MBH of Possible Heat Recovery



# Mechanical System Redesign Condenser Loop Heat Recovery

## Heat Recovery In Water Source Loop

- Water Source Heat Pump Loop Requires Winter Time Heat Addition
- Operating Temperature of 68°F
- Condenser Water Loop Serves as Heat Source Via Heat Exchanger






# Mechanical System Redesign Condenser Loop Heat Recovery

## Heat Recovery In Domestic Hot Water Pre-Heat

- High Domestic Hot Water Demand at The Supply Center
- Condenser Loop Pre-Heats Water to 76-81°F (Saves 35% Heating Energy)



## Presentation Outline

Project and Building Background

Existing Conditions

### **Mechanical System Redesign**

DOAS/ Water Source Heat Pumps

Condenser Loop Heat Recovery System

### **Absorption Chiller-Heater Technology**

Redesigned Chiller/Boiler Plants

Life Cycle Cost Analysis and Payback

Structural/Construction Breadth

AHU Relocation Roof Structure Impact

Mezzanine Floor Detailed Cost Estimate

Electrical Breadth

Redesign's effect on Power Systems


Conclusions and Recommendations



# Mechanical System Redesign Absorption Chiller-Heater Technology

## Direct Natural Gas Fired Absorption Chiller-Heaters


- Utilizes Natural Gas Service at The Supply Center
- Typical Single Effect LiBr/Water Absorption Cycle
- Includes Heat Exchanger in High Temperature Generator for Simultaneous Cooling and Hot Water Production (Up to 210°F)



# Mechanical System Redesign Absorption Chiller-Heater Technology

## Direct Natural Gas Fired Absorption Chiller-Heaters

- Simultaneous Heating Comes at the Expense of Cooling Production
- Chiller-Heater Must Run at 30% Cooling Capacity Minimum



## Presentation Outline

Project and Building Background

Existing Conditions

### **Mechanical System Redesign**

DOAS/ Water Source Heat Pumps

Condenser Loop Heat Recovery System

Absorption Chiller-Heater Technology

### **Redesigned Chiller/Boiler Plants**

Life Cycle Cost Analysis and Payback

Structural/Construction Breadth

AHU Relocation Roof Structure Impact

Mezzanine Floor Detailed Cost Estimate

Electrical Breadth

Redesign's effect on Power Systems

Conclusions and Recommendations



# Mechanical System Redesign Redesigned Chiller/Boiler Plants

## Chiller-Heater Selection

- Sized to Meet Cooling and HVAC/Domestic Hot Water Needs
- (2) 240 ton Chiller-Heaters Used
- Meets Cooling Load with Enough Capacity to Produce Hot Water


## Redundancy

- If one Chiller-Heater Is Off Line, Second Meets Critical Load
  - Walk-in Freezer's Condenser System
- Back-up Boiler to Meet Heating Demand in This Situation

**INTEGRATES HEATING, COOLING, CONDENSER WATER, AND DOMESTIC WATER SYSTEMS!**



# Mechanical System Redesign Redesigned Chiller/Boiler Plants



## Presentation Outline

Project and Building Background

Existing Conditions

### **Mechanical System Redesign**

DOAS/ Water Source Heat Pumps

Condenser Loop Heat Recovery System

Absorption Chiller-Heater Technology

Redesigned Chiller/Boiler Plants

### **Life Cycle Cost Analysis and Payback**

Structural/Construction Breadth

AHU Relocation Roof Structure Impact

Mezzanine Floor Detailed Cost Estimate

Electrical Breadth

Redesign's effect on Power Systems

Conclusions and Recommendations





# Mechanical System Redesign Life Cycle Cost Analysis

## Annual Operating Cost Comparison

	Existing System	Redesign w/ Chiller-Heater
Cooling Cost	\$67,577	N/A
HVAC Heating Cost	\$23,016	N/A
Hot Water Heating Cost	\$58,371	N/A
Combined Heating and Cooling Cost	N/A	\$117,370
Air System Fan Cost	\$21,303	\$12,318
Pump Cost	\$29,274	\$20,480
Cooling Tower Cost	\$9,920	\$16,440
<b>Total</b>	<b>\$209,461</b>	<b>\$166,608</b>

**\$42,800 Annual Cost Savings!**



# Mechanical System Redesign Life Cycle Cost Analysis

## Initial Cost Comparison

Equipment (Quantity and Type)	Existing System	Redesign Chiller-heater Option
Chillers (2 Centrifugal)	178,000	-
Chiller-Heaters (2)	-	450,000
HVAC Boiler (1 4500 MBH)	21,800	-
HW Boiler (2 6500 MBH)	61,000	-
Supplemental Boiler (1 9000 MBH)	-	85,000
Heat Exchangers (for HW system)	10,000	-
DOAS AHUs (2)	-	47,840
VAV AHUs (10)	309,310	-
Plate-Frame HX	10,000	20,000
VAV Boxes w/reheat	32,730	-
Heat Pumps	-	60,045
<b>TOTAL</b>	<b>\$622,840</b>	<b>\$682,885</b>

**\$60,000 More Expensive**



# Mechanical System Redesign Life Cycle Cost Analysis

## 20 Year Life Cycle Cost Comparison

	Existing System	Redesign System
<b>NPW</b>	<b>\$2,266,510</b>	<b>\$1,829,863</b>
Initial Cost	\$622,840	\$682,885
<b>20 Yr LCC</b>	<b>\$2,889,350</b>	<b>\$2,512,748</b>

**\$376,600 Savings Over 20 Years!**



# Mechanical System Redesign Life Cycle Cost Analysis

## Mechanical Redesign Conclusions

- Integrates Multiple Building Systems
- More Expensive Up Front
- Cheaper to Operate
- Least Expensive 20 Year Life Cycle Cost

**Payback In Just Under 2 Years!**



## Presentation Outline

Project and Building Background

Existing Conditions

Mechanical System Redesign

- DOAS/ Water Source Heat Pumps

- Condenser Loop Heat Recovery System

- Absorption Chiller-Heater Technology

- Redesigned Chiller/Boiler Plants

- Life Cycle Cost Analysis and Payback

**Structural/Construction Breadth**

- AHU Relocation Roof Structure Impact**

- Mezzanine Floor Detailed Cost Estimate

Electrical Breadth

- Redesign's effect on Power Systems

Conclusions and Recommendations



# Structural/Construction Breadth AHU Relocation

Existing System

**Creates Wasted Space in Mezzanine Floor**

10 VAV                      4 CAV

Redesigned System


6 Total AHUs

2 DOAS                      4 CAV

**Move AHUs to Roof**


- **Creates Structural Work**

- **Potential to Save Initial Cost**



# Structural/Construction Breadth AHU Relocation

## Steel K-Series Joist are Replaced with W-flanged Beams



# Structural/Construction Breadth AHU Relocation

**Additional Cost of Redesign Is Small!**

BEAM/JOIST	LENGTH	AMOUNT	\$COST/LF	TOTAL COST
28KCS5	37	14	11	\$5,698
26K7	37	8	6.35	\$1,879.6
JOIST TOTAL COST				\$7,577.6
W 8x10	37	22	9.65	\$7,855.1
<b>Difference</b>				<b>\$277.5</b>





## Presentation Outline

Project and Building Background

Existing Conditions

Mechanical System Redesign

- DOAS/ Water Source Heat Pumps

- Condenser Loop Heat Recovery System

- Absorption Chiller-Heater Technology

- Redesigned Chiller/Boiler Plants

- Life Cycle Cost Analysis and Payback

### **Structural/Construction Breadth**

- AHU Relocation Roof Structure Impact

- Mezzanine Floor Detailed Cost Estimate**

Electrical Breadth


- Redesign's effect on Power Systems

Conclusions and Recommendations



# Structural/Construction Breadth Mezzanine Floor Cost

No Need to Construct Mezzanine Floor  
Only Held Air Handling Units



# Structural/Construction Breadth Mezzanine Floor Cost

## Large First Cost Savings for Not Construction Mezzanine Floor

	Total Construction Cost
Steel Members	\$122,986.1
1-1/2" Steel Decking	\$19,762.75
139 C.Y. of 4000psi Concrete	\$11,709.6
<b>TOTAL FLOOR COST</b>	<b>\$154,458.45</b>



## Presentation Outline

Project and Building Background

Existing Conditions

Mechanical System Redesign

- DOAS/ Water Source Heat Pumps

- Condenser Loop Heat Recovery System

- Absorption Chiller-Heater Technology

- Redesigned Chiller/Boiler Plants

- Life Cycle Cost Analysis and Payback

Structural/Construction Breadth

- AHU Relocation Roof Structure Impact

- Mezzanine Floor Detailed Cost Estimate

**Electrical Breadth**

- Redesign's effect on Power Systems**

Conclusions and Recommendations



# Electrical Breadth Power System Alterations

## Less Electric Driven Mechanical Equipment

- Chillers, 8 AHUs, Boiler Accessories
- Changes Load on Distribution Panels
- Saves Cost on Feeder and Wire Sizes



# Electrical Breadth Power System Alterations

## Electrical Cost Savings

Electrical Cost Savings	\$9,189
New Equipment Electrical Cost	\$5,534
<b>Total Electrical Cost Savings</b>	<b>\$3,600</b>

Mechanical Redesign Creates Electrical Cost Savings!



## Presentation Outline

Project and Building Background

Existing Conditions

Mechanical System Redesign

- DOAS/ Water Source Heat Pumps

- Condenser Loop Heat Recovery System

- Absorption Chiller-Heater Technology

- Redesigned Chiller/Boiler Plants

- Life Cycle Cost Analysis and Payback

Structural/Construction Breadth

- AHU Relocation Roof Structure Impact

- Mezzanine Floor Detailed Cost Estimate

Electrical Breadth

- Redesign's effect on Power Systems

**Conclusions and Recommendations**



# Conclusions and Recommendations

## Final Cost Analysis

### Overall Building System Redesign Cost Analysis

	Existing System	Redesign
Mechanical 1 <sup>st</sup> Cost	\$622,840	\$682,885
Mezzanine Cost	\$154,458	N/A
Additional Structural Cost	N/A	\$277
Additional Electrical Cost	\$3,600	N/A
Total 1 <sup>st</sup> Cost	\$780,898	\$683,173





# Conclusions and Recommendations

## Final Cost Analysis

### Conclusions Compared to Existing System

- Mechanical Redesign Saves Energy and Cost Over 20 Years
- Integrates Other Building Systems
- Creates Overall First Cost Savings!

**\$ 97,725 Less Upfront!**

**\$ 42,800 Less Per Year!**

**\$ 531,000 Saved Over 20 Years!**

**Redesign Is Beneficial**



# Acknowledgments

**Thank You!**

**AE Department**

- Advisor Dr. Bahnfleth

**H.F. Lenz Company**

- Tom Hovan, P.E.

**Structural Help**

- Brian Barna & Cynthia Milinichik

**Construction Help**

- Kyle Conrad

**My Great Friends for Their Support!**


- Andy, Jess, Kyle, Kevin



# Building Systems Integration

## The Milton Hershey School Supply Center

# Questions?



# Mechanical System Redesign Redesigned Chiller/Boiler Plants


## Plant Load Analysis

- Walk-in Freezer's Heat Rejection Creates 106 ton Base Load
- Peak Cooling Load at 390 tons
- High Hot Domestic Hot Water Demand
  - Excellent Opportunity for Simultaneous Heating and Cooling!



# Existing System Chiller Plant Load Profile

Daily Cooling Load Profile



# New System Chiller Plant Load Profile

Redesign Plant Load Profile

