

## Electrical Depth

### Introduction

The existing electrical system for each space redesigned in my lighting depth had to be adjusted accordingly to the new design. The following electrical depth will illustrate how these modifications were accommodated.

In addition to adjusting the existing electrical distribution to these spaces, a study was done to evaluate the determine feasibility of implementing a photo voltaic array on the roof of this building. A second study was done to compare standard transformers versus energy efficient ones.

### Existing System

The Art & Visual Technology Building utilizes simple radial distribution at 480Y/277V, 3 $\phi$ , 4W. It originates at the 2000A switchboard, which is located in the lower level main electrical room. The main switchboard has ten internal circuit breakers; two are dedicated to the automatic transfer switches, six go to distribution panels throughout the building and the final two are dedicated to each elevator. There are also four spaces left open in the switchboard with frame sizes ranging from 250A to 600A. Distribution is divided into panels that feed the North end of the building and those that feed the South. On the lower level, the main electric room feeds the South end of the building, while there is an electrical closet that feeds the North. On the floors above, electrical closets located in North and South ends of building feed their respective end. Each closet contains 480Y/277V 3 $\phi$ , 4W panels, transformers and 208Y/120 3 $\phi$ , 4W panels. Emergency power is supplied from an 80kW diesel generator and is integrated into normal building power thru automatic transfer switches

### Main Entrance Courtyard

Fed from the same panel as the entry lobby, the lighting circuits at the main entrance façade also have a great distance for the conductors to run. One of the LED fixtures and recessed step lights both are low-voltage, with integral transformers, and require 120v power.

### Branch Circuit Redesign

Please refer to the proceeding panelboard and power plan for additional information.

#### Panel L2N Circuit 6

6 “G” fixtures \* 118 input watts/fixture = 708 W  
 2 “H” fixtures \* 54 input watts/fixture = 108 W  
 4 “P” Fixtures \* 13 input watts/fixture = 52W  
 Total watts = 868W/ .9PF = 964VA

964VA/277V = 3.5A -> 2#12 Copper THWN  
 20A single pole breaker  
 ¾” Conduit EMT

*\*Note: 20A\*277V \* 80% de-rating = 4,432 W Maximum allowed*

### Voltage Drop Calculation

$$V_{\text{drop}(l-n)} = A \cdot \text{ft} * V_{\text{drop}} / (1000 A \cdot \text{ft}) * 2(\text{if single phase})$$

$$\% V_{\text{drop}} = V_{\text{drop}(l-n)} / V$$

<b>Circuit Voltage</b>	277
<b>power factor</b>	0.9
<b>Length (ft)</b>	220
<b>Wire Size</b>	#12
<b>V<sub>drop</sub>/(1000 A ft)</b>	1.749
<b>Current (A)</b>	3.5
<b>1φ Multiplier</b>	2
<b>V<sub>drop</sub>(l-n)</b>	2.693
<b>% V<sub>drop</sub></b>	<b>0.972</b>

0.972% < 3% maximum per NEC recommendations

**Panel R2NA Circuit 45**

6 “I” fixtures \* 20 input watts/fixture = 120 W

43 “J” fixtures \* 6 input watts/fixture = 258 W

3 “O” Fixtures \* 280 input watts/fixture = 840W

1029W/1.0 PF = 1029VA

1029VA/120 V = 8.58A -> 2#12 Copper THWN

20A single pole breaker

¾” Conduit

*\*Note: 20A\*120V \* 80% de-rating = 1,920 W Maximum allowed*

**Voltage Drop Calculation**

$$V_{\text{drop}(l-n)} = A \cdot \text{ft} \cdot V_{\text{drop}} / (1000 \text{ A} \cdot \text{ft}) \cdot 2 (\text{if single phase})$$

$$\% V_{\text{drop}} = V_{\text{drop}(l-n)} / V$$

<b>Circuit Voltage</b>	120
<b>power factor</b>	1
<b>Length (ft)</b>	205
<b>Wire Size</b>	#12
<b>V<sub>drop</sub>/(1000 A ft)</b>	1.917
<b>Current (A)</b>	8.6
<b>1φ Multiplier</b>	2
<b>V<sub>drop</sub>(l-n)</b>	6.759
<b>% V<sub>drop</sub></b>	<b>5.633</b>

3.177% > 3% maximum per NEC recommendations

**Resize to #10**

<b>Circuit Voltage</b>	120
<b>power factor</b>	1
<b>Length (ft)</b>	205
<b>Wire Size</b>	#10
<b>V<sub>drop</sub>/(1000 A ft)</b>	1.2
<b>Current (A)</b>	8.6
<b>1φ Multiplier</b>	2
<b>V<sub>drop</sub>(l-n)</b>	4.231
<b>% V<sub>drop</sub></b>	<b>3.526</b>

3.526% > 3% maximum per NEC recommendations


**Resize to #10**

<b>Circuit Voltage</b>	120
<b>power factor</b>	1
<b>Length (ft)</b>	205
<b>Wire Size</b>	#8
<b>V<sub>drop/(1000 A ft)</sub></b>	0.75
<b>Current (A)</b>	8.6
<b>1<math>\phi</math> Multiplier</b>	2
<b>V<sub>drop(l-n)</sub></b>	2.645
<b>% V<sub>drop</sub></b>	<b>2.204</b>

2.204% < 3% maximum per NEC recommendations

-> **2#8 Copper THWN, 20A single pole breaker, 3/4" conduit**

**New Lighting Power Plan**



*\* Note: See Appendix G for a 1/8" = 1'-0" Plan*

**Existing L2N Panelboard**

PANELBOARD: L2N		BUS RATING:		60 A			MAIN OCP OR			
MIN AIC:		VOLTAGE:		208 120 V			PHASE(S): 3			
NEMA 1 ENCLOSURE		MOUNTING:		SURFACE			WIRES: 5			
LOCATION:		NOTES:								
				LOAD, VA						
BRANCH CIRCUIT DESIGNATION	P	TRIP	CKT#	φA	φB	φC	CKT#	TRIP	P	CIRCUIT DESIGNATION
West Corridor	1	20	1	1100						
West Corridor	1	20	2		1000					
East Corridor & Elevator Lobby	1	20	3			900				
East Corridor	1	20	4	700						
Student Lounge	1	20	5		300					
Exterior Lighting	1	20	6			600				
Exterior Lighting	1	20	7	600						
LTGRM 1001	1	20	8		775					
	1	20	9							
	1	20	10							
	1	20	11							
	1	20	12							
	1	20	13							
	1	20	14							
	1	20	15							
	1	20	16							
	1	20	17							
	1	20	18							
	1	20	19							
	1	20	20							
	1	20	21							
PHASE CONNECTED LOAD, VA				2400	2075	1500				
PHASE BALANCE				20.50%	4.18%	-24.69%				
TOTAL CONNECTED LOAD, VA		5975								
FUTURE GROWTH - 25%		1494								
TOTAL + FUTURE LOAD, VA		7469								
TOTAL CURRENT, A		21								
DESIGN CURRENT, A		26								
MINIMUM MAIN OCP		100								

**Existing R2NA Panelboard**

PANELBOARD: R2NA		BUS RATING:		400 A		MAIN OCP OR MLO					
MIN AIC:		VOLTAGE:		208 120 V		PHASE(S): 3					
NEMA 1 ENCLOSURE		MOUNTING:		SURFACE		WIRES: 4					
LOCATION:		NOTES:		200% NEUTRAL							
		LOAD, VA									
BRANCH CIRCUIT DESIGNATION	P	TRIP	CKT	φA	φB	φC	CKT#	TRIP	P	CH CIRCUIT DESIGNATION	
Recept - WC	1	20	1	720	784		2	20	1	SOUND BOOTH	
Recept - RM 1126 / 1127	1	20	3			1080	4	20	1	SPARE	
Recept - WC	1	20	5				6	20	1	SPARE	
Recept - Corridor (Flat Panel Display)	1	20	7	600			8	20	1	SPARE	
Recept - Corridor	1	20	9		900	660	10	20	1	Recept - RM 1006	
Recept - RM 1004	1	20	11				12	20	1	Recept - RM 1006	
Recept - RM 1004	1	20	13	720	600		14	20	1	Recept - RM 1006	
Recept - RM 1004	1	20	15		720	600	16	20	1	Recept - RM 1006	
Recept - RM 1004 (AV)	1	20	17				18	20	1	Recept - RM 1006	
Projector - RM 1004	1	20	19	300	360		20	20	1	Recept - RM 1006	
Recept - Corridor (Flat Panel Display)	1	20	21		600	1200	22	20	1	Recept - RM 1006	
Recept - Corridor	1	20	23				24	20	1	Recept - RM 1006	
EF-4	1	20	25	528	912		26	20	1	Recept - RM 1006	
Recept - Proj. RM 1007	1	20	27		300	912	28	20	1	Recept - RM 1006	
Recept - Proj. RM 1007	1	20	29				30	20	1	Recept - RM 1005	
Recept - RM 1007	1	20	31	360	900		32	20	1	Recept - RM 1005	
Recept - RM 1007	1	20	33		540	360	34	20	1	Recept - RM 1005	
Recept - RM 1007	1	20	35				36	20	1	Projector - RM 1005	
Recept - RM 1007	1	20	37	540	750		38	20	1	LTG - RM 1005	
Recept - RM 1007 (AV)	1	20	39		840	1875	40	20	1	LTG - RM 1021	
Recept - RM 1125	1	20	41				42	20	1	LTG - RM 1022	
Recept - RM 1007 (AV)	1	20	43	840	1875		44	20	1	LTG - RM 1023	
	1	20	45			0	46	20	1	SPARE	
	1	20	47				48	20	1	LTG - RM 1004	
	1	20	49	180			50	20	1	Trap Priming Cabinet	
	1	20	51				52	20	1		
	1	20	53				54	20	1		
	1	20	55				56	20	1		
	1	20	57				58	20	1		
	1	20	59				60	20	1		
	1	20	61				62	20	1		
	1	20	63				64	20	1		
	1	20	65				66	20	1		
	1	20	67				68	20	1		
	1	20	69				70	20	1		
	1	20	71				72	20	1		
	1	20	73		5260		74				
	1	20	75			4792	76	150	3	PNL R2NF	
	1	20	77				78				
	1	20	79	7050			80				
	1	20	81			6450	82	80	3	PNL R2ND	
	1	20	83				84				
PHASE CONNECTED LOAD, VA				23279	21829	19578					
PHASE BALANCE				7.96%	1.24%	-9.20%					
TOTAL CONNECTED LOAD, VA		64686									
FUTURE GROWTH - 25%		16172									
TOTAL + FUTURE LOAD, VA		80858									
TOTAL CURRENT, A		224									
DESIGN CURRENT, A		281									
MINIMUM MAIN OCP		400									

**Redesigned L2N Panelboard**

PANELBOARD: L2N			BUS RATING:				60	A			MAIN OCP	60A MCB
MIN AIC:			VOLTAGE:				208	120	V	PHASE(S):	3	
NEMA 1 ENCLOSURE			MOUNTING:				SURFACE		WIRES:	5		
LOCATION:			NOTES:									
				LOAD, VA								
BRANCH CIRCUIT DESIGNATION	P	TRIP	CKT#	φA	φB	φC	CKT#	TRIP	P	CIRCUIT DESIGNATION		
West Corridor	1	20	1	747								
West Corridor	1	20	2		952							
East Corridor & Elevator Lobby	1	20	3			644						
East Corridor	1	20	4	652								
Lobby Lighting	1	20	5		1317							
Exterior Lighting	1	20	6			964						
Spare	1	20	7	0								
Lobby Cove Lighting	1	20	8		348							
	1	20	9									
	1	20	10									
	1	20	11									
	1	20	12									
	1	20	13									
	1	20	14									
	1	20	15									
	1	20	16									
	1	20	17									
	1	20	18									
	1	20	19									
	1	20	20									
	1	20	21									
PHASE CONNECTED LOAD, VA				1399	2617	1608						
PHASE BALANCE				-25.37%	39.60%	-14.22%						
TOTAL CONNECTED LOAD, VA	5624											
FUTURE GROWTH - 25%	1406											
TOTAL + FUTURE LOAD, VA	7030											
TOTAL CURRENT, A	20											
DESIGN CURRENT 1.25 CONT. Factor	24											
MINIMUM MAIN OCP	60											

\*Note red highlighted circuits correspond to the lobby and blue highlighted correspond to the main façade.

**Main Overcurrent Protection**

60A breaker

**New Feeder Size**

(4) #6 and (1) #10 ground in 1” Conduit

*Based per NEC 2005. Tables 310-16, Table C.2, Table 250.122. THWN Copper wire rated for 75°C.*



**Redesigned L2N Panelboard**

PANELBOARD: R2NA		BUS RATING:		400 A		MAIN OCP: 3P 300A MCI					
MIN AIC:		VOLTAGE:		208 120 V		PHASE(S): 3					
NEMA 1 ENCLOSURE		MOUNTING:		SURFACE		WIRES: 4					
LOCATION:		NOTES:									
		LOAD, VA									
BRANCH CIRCUIT DESIGNATION	P	TRIP	CKT	φA	φB	φC	CKT#	TRIP	P	NCH CIRCUIT DESIGNATION	
Recept - WC	1	20	1	720	784		2	20	1	SOUND BOOTH	
Recept - RM 1126 / 1127	1	20	3		1080		4	20	1	SPARE	
Recept - WC	1	20	5			720	6	20	1	SPARE	
Recept - Corridor (Flat Panel Display)	1	20	7	600			8	20	1	SPARE	
Recept - Corridor	1	20	9		900	660	10	20	1	Recept - RM 1006	
Recept - RM 1004	1	20	11			360	12	20	1	Recept - RM 1006	
Recept - RM 1004	1	20	13	720	600		14	20	1	Recept - RM 1006	
Recept - RM 1004	1	20	15		720	600	16	20	1	Recept - RM 1006	
Recept - RM 1004 (AV)	1	20	17			840	18	20	1	Recept - RM 1006	
Projector - RM 1004	1	20	19	300	360		20	20	1	Recept - RM 1006	
Recept - Corridor (Flat Panel Display)	1	20	21		600	1200	22	20	1	Recept - RM 1006	
Recept - Corridor	1	20	23			360	24	20	1	Recept - RM 1006	
EF-4	1	20	25	528	912		26	20	1	Recept - RM 1006	
Recept - Proj. RM 1007	1	20	27		300	912	28	20	1	Recept - RM 1006	
Recept - Proj. RM 1007	1	20	29			300	30	20	1	Recept - RM 1005	
Recept - RM 1007	1	20	31	360	900		32	20	1	Recept - RM 1005	
Recept - RM 1007	1	20	33		540	360	34	20	1	Recept - RM 1005	
Recept - RM 1007	1	20	35			540	36	20	1	Projector - RM 1005	
Recept - RM 1007	1	20	37	540	750		38	20	1	LTG - RM 1005	
Recept - RM 1007 (AV)	1	20	39		840	1875	40	20	1	LTG - RM 1021	
Recept - RM 1125	1	20	41			180	42	20	1	LTG - RM 1022	
Recept - RM 1007 (AV)	1	20	43	840	1875		44	20	1	LTG - RM 1023	
Exterior Lighting	1	20	45		1030	0	46	20	1	SPARE	
	1	20	47				48	20	1	LTG - RM 1004	
	1	20	49	180			50	20	1	Trap Priming Cabinet	
	1	20	51				52	20	1		
	1	20	53				54	20	1		
	1	20	55				56	20	1		
	1	20	57				58	20	1		
	1	20	59				60	20	1		
	1	20	61				62	20	1		
	1	20	63				64	20	1		
	1	20	65				66	20	1		
	1	20	67				68	20	1		
	1	20	69				70	20	1		
	1	20	71				72	20	1		
	1	20	73		5260		74				
	1	20	75			4792	76	150	3	PNL R2NF	
	1	20	77				78				
	1	20	79		7050		80				
	1	20	81			6450	82	80	3	PNL R2ND	
	1	20	83				84				
PHASE CONNECTED LOAD, VA				23279	22859	19578					
PHASE BALANCE				6.27%	4.35%	-10.62%					
TOTAL CONNECTED LOAD, VA		65716									
FUTURE GROWTH - 25%		16429									
TOTAL + FUTURE LOAD, VA		82145									
TOTAL CURRENT, A		228									
DESIGN CURRENT, A (1.0 Demand Fac)		228									
MINIMUM MAIN OCP		300									

**Main Overcurrent Protection**

300A breaker

**New Feeder Size**

(4) #350 MCM and (1) #4 ground in 3" Conduit

*Based per NEC 2005. Tables 310-16, Table C.2, Table 250.122. THWN Copper wire rated for 75°C.*

### **Entry Lobby**

The entry lobby was divided into two circuits on the basis of constructability. The main circuit feeds all the fixtures on the entry level and the continuous wall sconce on the stairwell column. The second circuit feeds the stairwell cove for the all three levels of the building. One important issue electrically with the lobby was the long length of conductors for each of the circuits. However, by each circuit being at 277V, voltage drop turned out to be not become an issue. Since this is a public space, the primary control for lighting will be done via a time-clock while a manual switch is located remotely by the gallery support area in the NW corner of the lobby.

### **Branch Circuit Redesign**

Please refer to the proceeding panelboard and power plan for additional information.

#### **Panel L2N Circuit 5**

21 "C" fixtures * 33 input watts/fixture	= 693 W
8 "D" fixtures * 33 input watts/fixture	= 264 W
10 "E" fixtures * 36 input watts/fixture	= 360 W
Total Watts = 1,317 W/.90PF	= 1463VA
1463VA/277V = 5.3A -> 2#12 Copper THWN	
20A single pole breaker	
¾" Conduit EMT	

*\*Note: 20A\*277V \* 80% de-rating = 4,432 W Maximum allowed*

### Voltage Drop Calculation

$$V_{\text{drop}(l-n)} = A \cdot \text{ft} * V_{\text{drop}} / (1000 \text{ A} \cdot \text{ft}) * 2(\text{if single phase})$$

$$\% V_{\text{drop}} = V_{\text{drop}(l-n)} / V$$

<b>Circuit Voltage</b>	277
<b>power factor</b>	0.9
<b>Length (ft)</b>	165
<b>Wire Size</b>	#12
<b>V<sub>drop</sub>/(1000 A ft)</b>	1.749
<b>Current (A)</b>	5.3
<b>1φ Multiplier</b>	2
<b>V<sub>drop</sub>(l-n)</b>	3.059
<b>% V<sub>drop</sub></b>	<b>1.104</b>

1.104% < 3% maximum per NEC recommendations

### Panel L2N Circuit 8

$$12 \text{ "F" fixtures} * 29 \text{ input watts/fixture} = 348 \text{ W}$$

$$348\text{W} / .90 \text{ PF} = 387\text{VA}$$

$$387\text{VA} / 277 \text{ V} = 1.4\text{A} \rightarrow 2\#12 \text{ Copper THWN}$$

20A single pole breaker

3/4" Conduit

*\*Note: 20A \* 277V \* 80% de-rating = 4,432 W Maximum allowed*

### Voltage Drop Calculation


$$V_{\text{drop}(l-n)} = A \cdot \text{ft} * V_{\text{drop}} / (1000 \text{ A} \cdot \text{ft}) * 2(\text{if single phase})$$

$$\% V_{\text{drop}} = V_{\text{drop}(l-n)} / V$$

<b>Circuit Voltage</b>	277
<b>power factor</b>	0.9
<b>Length (ft)</b>	140
<b>Wire Size</b>	#12
<b>V<sub>drop</sub>/(1000 A ft)</b>	1.749
<b>Current (A)</b>	1.4
<b>1φ Multiplier</b>	2
<b>V<sub>drop</sub>(l-n)</b>	0.686
<b>% V<sub>drop</sub></b>	<b>0.248</b>

0.248% < 3% maximum per NEC recommendations

**New Lighting Power Plan**



\* Note: See Appendix H for a 1/8" = 1'-0" Plan

**Existing L2N Panelboard**

PANELBOARD: L2N		BUS RATING:					60 A		MAIN OCP OR		
MIN AIC:		VOLTAGE:					208 120 V		PHASE(S): 3		
NEMA 1 ENCLOSURE		MOUNTING:					SURFACE		WIRES: 5		
LOCATION:		NOTES:									
				LOAD, VA							
BRANCH CIRCUIT DESIGNATION	P	TRIP	CKT#	φA	φB	φC	CKT#	TRIP	P	CIRCUIT DESIGNATION	
West Corridor	1	20	1	1100							
West Corridor	1	20	2		1000						
East Corridor & Elevator Lobby	1	20	3			900					
East Corridor	1	20	4	700							
Student Lounge	1	20	5		300						
Exterior Lighting	1	20	6			600					
Exterior Lighting	1	20	7	600							
LTGRM 1001	1	20	8		775						
	1	20	9								
	1	20	10								
	1	20	11								
	1	20	12								
	1	20	13								
	1	20	14								
	1	20	15								
	1	20	16								
	1	20	17								
	1	20	18								
	1	20	19								
	1	20	20								
	1	20	21								
PHASE CONNECTED LOAD, VA				2400	2075	1500					
PHASE BALANCE				20.50%	4.18%	-24.69%					
TOTAL CONNECTED LOAD, VA		5975									
FUTURE GROWTH - 25%		1494									
TOTAL + FUTURE LOAD, VA		7469									
TOTAL CURRENT, A		21									
DESIGN CURRENT, A		26									
MINIMUM MAIN OCP		100									

**Redesigned L2N Panelboard**

PANELBOARD: L2N	BUS RATING:			60 A			MAIN OCP	60A MCB		
MIN AIC:	VOLTAGE:			208	120	V	PHASE(S):	3		
NEMA 1 ENCLOSURE	MOUNTING:			SURFACE			WIRES:	5		
LOCATION:	NOTES:									
				LOAD, VA						
BRANCH CIRCUIT DESIGNATION	P	TRIP	CKT#	φA	φB	φC	CKT#	TRIP	P	CIRCUIT DESIGNATION
West Corridor	1	20	1	747						
West Corridor	1	20	2		952					
East Corridor & Elevator Lobby	1	20	3			644				
East Corridor	1	20	4	652						
Lobby Lighting	1	20	5		1317					
Exterior Lighting	1	20	6			660				
Spare	1	20	7	0						
Lobby Cove Lighting	1	20	8		348					
	1	20	9							
	1	20	10							
	1	20	11							
	1	20	12							
	1	20	13							
	1	20	14							
	1	20	15							
	1	20	16							
	1	20	17							
	1	20	18							
	1	20	19							
	1	20	20							
	1	20	21							
PHASE CONNECTED LOAD, VA				1399	2617	1304				
PHASE BALANCE				-21.11%	47.58%	-26.47%				
TOTAL CONNECTED LOAD, VA	5320									
FUTURE GROWTH - 25%	1330									
TOTAL + FUTURE LOAD, VA	6650									
TOTAL CURRENT, A	18									
DESIGN CURRENT 1.25 CONT. Factor	23									
MINIMUM MAIN OCP	60									

*\*Note Red Highlighted circuits correspond to the entry lobby while blue highlighted circuits correspond to the main courtyard.*

**Main Overcurrent Protection**

60A breaker

**New Feeder Size**

(4) #6 and (1) #10 ground in 1" Conduit

*Based per NEC 2005. Tables 310-16, Table C.2, Table 250.122. THWN Copper wire rated for 75°C.*

### Painting Studio

The modification of the existing artificial and natural lighting systems led to necessary changes for the electrical demands for this space. Most notably is the added load of the motorized shades. The motors were estimated of having an electrical load of 150kW since electrical specifications were unavailable.

### Branch Circuit Redesign

Please refer to the proceeding panelboards and power plan for additional information.

#### Max Dimmer panel load

$$9 \text{ Type "A" fixtures} * 62\text{W/fixture} = 558\text{W}$$

$$558\text{W}/1.00 \text{ PF} = 558\text{VA}$$

$$558\text{VA}/277 \text{ V} = 2.1\text{A} \rightarrow 2\#12 \text{ Copper THWN}$$

20A single pole breaker

3/4" Conduit EMT

*\*Note: 20A\*120V \* 80% de-rating = 1,920 W Maximum allowed*

#### Voltage Drop Calculation

$$V_{\text{drop}(l-n)} = A \cdot \text{ft} * V_{\text{drop}} / (1000 \text{ A} \cdot \text{ft}) * 2(\text{if single phase})$$

$$\%V_{\text{drop}} = V_{\text{drop}(l-n)} / V$$

<b>Circuit Voltage</b>	120
<b>power factor</b>	0.9
<b>Length (ft)</b>	85
<b>Wire Size</b>	#12
<b>V<sub>drop</sub>/(1000 A ft)</b>	1.749
<b>Current (A)</b>	2.1
<b>1φ Multiplier</b>	2
<b>V<sub>drop</sub>(l-n)</b>	0.624
<b>% V<sub>drop</sub></b>	<b>0.520</b>

0.520% < 3% maximum per NEC recommendations



**Motor Load R3SA Circuit 46**

9 Motors \* 150W/motor = 1450W

1450W/.80 PF = 1813VA

1813VA/120 V =15.1A -> 2#12 Copper THWN

20A single pole breaker

¾” Conduit EMT

*\*Note: 20A\*120V \* 80% de-rating = 1,920 W Maximum allowed*

**Voltage Drop Calculation**

$$V_{\text{drop}(l-n)} = A \cdot \text{ft} * V_{\text{drop}} / (1000 A \cdot \text{ft}) * 2(\text{if single phase})$$

$$\% V_{\text{drop}} = V_{\text{drop}(l-n)} / V$$

<b>Circuit Voltage</b>	120
<b>power factor</b>	0.8
<b>Length (ft)</b>	85
<b>Wire Size</b>	#12
<b>V<sub>drop</sub>/(1000 A ft)</b>	1.57
<b>Current (A)</b>	15.1
<b>1φ Multiplier</b>	2
<b>V<sub>drop</sub>(l-n)</b>	4.030
<b>% V<sub>drop</sub></b>	<b>3.358</b>

3.358% > 3% maximum per NEC recommendations


Resize using #10 Wire

<b>Circuit Voltage</b>	120
<b>power factor</b>	0.8
<b>Length (ft)</b>	85
<b>Wire Size</b>	#10
<b>V<sub>drop</sub>/(1000 A ft)</b>	0.993
<b>Current (A)</b>	15.1
<b>1φ Multiplier</b>	2
<b>V<sub>drop</sub>(l-n)</b>	2.549
<b>% V<sub>drop</sub></b>	<b>2.124</b>

2.124% < 3% maximum per NEC recommendations


**->2#12 Copper THWN, 20A single pole breaker, ¾” Conduit EMT**

**New Lighting Plan**



*\* Note: See Appendix I for a 1/8" = 1'-0" Plan*

**New Power Plan**



*\* Note: See Appendix I for a 1/8" = 1'-0" Plan*



**Existing R3SA Panelboard**

PANELBOARD: R3SA			BUS RATING:						400 A			MAIN OCP OR MLO: 3P250A MCB			
MIN AIC:			VOLTAGE:						208 120 V			PHASE(S):			3
NEMA 1 ENCLOSURE			MOUNTING:						SURFACE			WIRES:			5
LOCATION:			NOTES:						200% NEUTRAL						
			LOAD, VA												
BRANCH CIRCUIT DESIGNATION	P	TRIP	CKT#	φ A	φ B	φ C	CKT#	TRIP	P	BRANCH CIRCUIT DESIGNATION					
Recept - RM 2041	1	20	1	720	600		2	20	1	Recept - RM 2034					
Recept - RM 2040	1	20	3		720	600	4	20	1	Recept - RM 2034					
Recept - Corridor	1	20	5				6	20	1	Recept - RM 2034					
Recept - RM 2039	1	20	7	720	840		8	20	1	Recept - RM 2033					
Recept - RM 2038	1	20	9		720	840	10	20	1	Recept - RM 2031					
Recept - RM 2036	1	20	11			720	12	20	1	Recept - RM 2029					
Recept - RM 2035	1	20	13	780	840		14	20	1	Recept - RM 2032					
Recept - RM 2035	1	20	15			480	16	20	1	Recept - RM 2030					
Recept - RM 2035	1	20	17				18	20	1	Recept - RM 2028					
Recept - RM 2035	1	20	19	780	1140		20	20	1	Recept - RM 2027					
Recept - Corridor	1	20	21		540	840	22	20	1	Recept - RM 2025					
Recept - RM 2037/2154	1	20	23			720	24	20	1	Recept - RM 2023					
Recept - RM 2041	1	20	25	540	840		26	20	1	Recept - RM 2021					
Recept - RM 2040	1	20	27		540	840	28	20	1	Recept - RM 2024					
Recept - RM 2039	1	20	29			540	30	20	1	Recept - RM 2022					
Recept - RM 2038	1	20	31	540	300		32	20	1	Projector - RM 2026					
Recept - RM 2036	1	20	33		540	840	34	20	1	Recept - RM 2026					
Motorized Proj. Screen	1	20	35			300	36	20	1	Recept - RM 2020					
Recept - RM 2026 (AV)	1	20	37	840	300		38	20	1	Projector - RM 2026					
LTG - RM 2044	1	20	39		1500	540	40	20	1	Recept - RM 2026					
LTG - RM 2044	1	20	41			1500	42	20	1	Recept - RM 2026					
LTG - RM 2044	1	20	43	1500	840		44	20	1	Recept - RM 2026 (AV)					
Recept - Roof	1	20	45		180	938	46	20	1	LTG - RM 2044					
SPARE	1	20	47			0	48	20	1	LTG - RM 2046					
LTG - RM 2045	1	20	49	750	938		50	20	1	LTG - RM 2046					
LTG - RM 2045	1	20	51		750	938	52	20	1	LTG - RM 2044					
LTG - RM 2045	1	20	53			750	54	20	1	LTG - RM 2046					
LTG - RM 2044	1	20	55	938	1125		56	20	1	LTG - RM 2046					
LTG - RM 2044	1	20	57		938	1125	58	20	1	LTG - RM 2046					
LTG - RM 2046	1	20	59			938	60	20	1	Recept - RM 2045					
LTG - RM 2046	1	20	61	938	720		62	20	1	Recept - RM 2045					
SPARE	1	20	63		0	864	64	20	1	CUH-7					
SPARE	1	20	65			0	66	20	1	Recept - Roof					
Recept - Flat Panel Display	1	20	67	600			68	20	1						
	1	20	69				70	20	1						
	1	20	71				72	20	1						
	1	20	73				74	20	1						
	1	20	75				76	20	1						
	1	20	77				78	20	1						
			79	3060			80	20	1						
PNL R3SB	3	100	81		2340		82	20	1						
			83			2460	84	20	1						
PHASE CONNECTED LOAD, VA				21188		18452		17430							
PHASE BALANCE				11.38%		-3.00%		-8.37%							
TOTAL CONNECTED LOAD, VA		57069													
FUTURE GROWTH - 25%		14267													
TOTAL + FUTURE LOAD, VA		71336													
TOTAL CURRENT, A		198													
DESIGN CURRENT, A		248													
MINIMUM MAIN OCP		250													

**Redesigned H3SB Panelboard**

PANELBOARD: H3SB		BUS RATING:		100		A	MAIN OCP OR MLO: <b>60A MCB</b>			
MIN AIC:		VOLTAGE:		480		277	V	PHASE(S): 3		
NEMA 1 ENCLOSURE		MOUNTING:		SURFACE		WIRES: 4				
LOCATION:		NOTES:								
				LOAD, VA						
BRANCH CIRCUIT DESIGNATION	P	TRIP	CKT#	φA	φB	φC	CKT#	TRIP	P	BRANCH CIRCUIT DESIGNATION
LTG - Offices	1	20	1	2150			2	20	1	
LTG - RM 2037 & 2045	1	20	3		400		4	20	1	
Spare	1	20	5			0	6	20	1	
LTG - RM 2046	1	20	7	1300			8	20	1	
LTG - RM 2035	1	20	9		2050		10	20	1	
	1	20	11				12	20	1	
	1	20	13				14	20	1	
	1	20	15				16	20	1	
	1	20	17				18	20	1	
	1	20	19				20	20	1	
	1	20	21				22	20	1	
	1	20	23				24	20	1	
	1	20	25				26	20	1	
	1	20	27				28	20	1	
	1	20	29				30	20	1	
PHASE CONNECTED LOAD, VA				3450	2450	0				
PHASE BALANCE				75.42%	24.58%	-100.00%				
TOTAL CONNECTED LOAD, VA		5900								
FUTURE GROWTH - 25%		1475								
TOTAL + FUTURE LOAD, VA		7375								
TOTAL CURRENT, A		11								
DESIGN CURRENT, A (1.25 Cont. Factor)		14								
MINIMUM MAIN OCP		60								

**Main Overcurrent Protection**

60A breaker

**New Feeder Size**

(4) #6 and (1) #10 ground in 1" Conduit

*Based per NEC 2005. Tables 310-16, Table C.2, Table 250.122. THWN Copper wire rated for 75°C.*

### Redesigned R3SA Panelboard

PANELBOARD: R3SA			BUS RATING:			400 A			MAIN OCP OR MLO: <b>3P200A MCB</b>			
MIN AIC:			VOLTAGE:			208 120 V			PHASE(S): 3			
NEMA 1 ENCLOSURE			MOUNTING:			SURFACE			WIRES: 5			
LOCATION:			NOTES:			200% NEUTRAL						
BRANCH CIRCUIT DESIGNATION		P	TRIP	CKT#	LOAD, VA				CKT#	TRIP	P	BRANCH CIRCUIT DESIGNATION
					φ A	φ B	φ C					
Recept - RM 2041	1	20	1	720	600			2	20	1	Recept - RM 2034	
Recept - RM 2040	1	20	3			720	600	4	20	1	Recept - RM 2034	
Recept - Corridor	1	20	5					6	20	1	Recept - RM 2034	
Recept - RM 2039	1	20	7	720	840			8	20	1	Recept - RM 2033	
Recept - RM 2038	1	20	9			720	840	10	20	1	Recept - RM 2031	
Recept - RM 2036	1	20	11					12	20	1	Recept - RM 2029	
Recept - RM 2035	1	20	13	780	840			14	20	1	Recept - RM 2032	
Recept - RM 2035	1	20	15			480	840	16	20	1	Recept - RM 2030	
Recept - RM 2035	1	20	17					18	20	1	Recept - RM 2028	
Recept - RM 2035	1	20	19	780	1140			20	20	1	Recept - RM 2027	
Recept - Corridor	1	20	21			540	840	22	20	1	Recept - RM 2025	
Recept - RM 2037/2154	1	20	23					24	20	1	Recept - RM 2023	
Recept - RM 2041	1	20	25	540	840			26	20	1	Recept - RM 2021	
Recept - RM 2040	1	20	27			540	840	28	20	1	Recept - RM 2024	
Recept - RM 2039	1	20	29					30	20	1	Recept - RM 2022	
Recept - RM 2038	1	20	31	540	300			32	20	1	Projector - RM 2026	
Recept - RM 2036	1	20	33			540	840	34	20	1	Recept - RM 2026	
Motorized Proj. Screen	1	20	35					36	20	1	Recept - RM 2020	
Recept - RM 2026 (AV)	1	20	37	840	300			38	20	1	Projector - RM 2026	
-----	-	-	39			696	540	40	20	1	Recept - RM 2026	
Dimmer Panel D3S2	3	20	41					42	20	1	Recept - RM 2026	
-----	-	-	43	696	840			44	20	1	Recept - RM 2026 (AV)	
Recept - Roof	1	20	45			180	1688	46	20	1	Shade Motors RM 2044	
SPARE	1	20	47					48	20	1	LTG - RM 2046	
LTG - RM 2045	1	20	49	750	938			50	20	1	LTG - RM 2046	
LTG - RM 2045	1	20	51			750	0	52	20	1	Spare	
LTG - RM 2045	1	20	53					54	20	1	LTG - RM 2046	
Spare	1	20	55	0	1125			56	20	1	LTG - RM 2046	
Spare	1	20	57			0	1125	58	20	1	LTG - RM 2046	
LTG - RM 2046	1	20	59					60	20	1	Recept - RM 2045	
LTG - RM 2046	1	20	61	938	720			62	20	1	Recept - RM 2045	
SPARE	1	20	63			0	864	64	20	1	CUH-7	
SPARE	1	20	65					66	20	1	Recept - Roof	
Recept - Flat Panel Display	1	20	67	600				68	20	1		
	1	20	69					70	20	1		
	1	20	71					72	20	1		
	1	20	73					74	20	1		
	1	20	75					76	20	1		
	1	20	77					78	20	1		
			79	3060				80	20	1		
PNL R3SB	3	100	81			2340		82	20	1		
			83					84	20	1		
PHASE CONNECTED LOAD, VA					19446		16523		16626			
PHASE BALANCE					10.92%		-5.75%		-5.17%			
TOTAL CONNECTED LOAD, VA			52595									
FUTURE GROWTH - 25%			13149									
TOTAL + FUTURE LOAD, VA			65744									
TOTAL CURRENT, A			182									
DESIGN CURRENT, A			182									
MINIMUM MAIN OCP			200A									

### Main Overcurrent Protection

200A Main circuit breaker

**New Feeder Size**

(4) #3/0 and (1) #6 ground in 2" Conduit

*Based per NEC 2005. Tables 310-16, Table C.2, Table 250.122. Copper wire rated for 75 °*

C.

**New Dimmer Panel D3S2**

NEMA 1 ENCLOSURE		MOUNTING:		SURFACE		WIRES:		5			
LOCATION:		NOTES:									
				LOAD, VA							
RANCH CIRCUIT DESIGNATIO	P	TRIP	CK	φA	φB	φC	CKT#	TRIP	P	NCH CIRCUIT DESIGNATION	
LTG - RM 2044	1	20	1	558			2	20	1	Space	
LTG - RM 2044	1	20	3		558		4	20	1	Space	
LTG - RM 2044	1	20	5			372	6	20	1	Space	
LTG - RM 2044	1	20	7	150			8	20	1	Space	
LTG - RM 2044	1	20	9		150		10	20	1	Space	
LTG - RM 2044	1	20	11			150	12	20	1	Space	
LTG - RM 2044	1	20	13	150			14	20	1	Space	
Spare	1	20	15				16	20	1	Space	
Spare	1	20	17				18	20	1	Space	
Space	1	-	19				20	20	1	Space	
Space	1	-	21				22	20	1	Space	
Space	1	-	23				24	20	1	Space	
PHASE CONNECTED LOAD, VA				858	708	522					
PHASE BALANCE				23.28%	1.72%	-25.00%					
TOTAL CONNECTED LOAD, VA				2088							
FUTURE GROWTH - 10%				209							
TOTAL + FUTURE LOAD, VA				2297							
TOTAL CURRENT, A				6							
DESIGN CURRENT, A (*1.25)				8							
MINIMUM MAIN OCP				20							

**Main Overcurrent Protection**

20A Main circuit breaker

**New Feeder Size**

(4) #12 and (1) #12 ground in 1" Conduit

*Based per NEC 2005. Tables 310-16, Table C.2, Table 250.122. Copper wire rated for 75 °*

C.



### Exhibit Gallery

The existing design utilized a dimmer panel for the control of the 120V track lighting while the suspended direct/indirect fixtures provided ambient light for the space were fed on 277V. Upon redesign, recessed low profile louvered fixtures provide ambient light and were added to the 120V dimmer panel with the redesigned track lighting. The dimming panel was resized for the existing design.

### Branch Circuit Redesign

Please refer to the proceeding panelboard and power plan for additional information.

### Dimmer Panel D2N1 Circuit 12

12 “K” fixtures \* 62 input watts/fixture = 744 W  
 Total watts = 744W/ .9PF = 827VA  
 827VA/120V = 6.9A -> 2#12 Copper THWN  
 20A single pole breaker  
 3/4” Conduit EMT

*\*Note: 20A \* 120V \* 80% de-rating = 1,920 W Maximum allowed*

### Voltage Drop Calculation


$$V_{\text{drop(l-n)}} = A \cdot \text{ft} \cdot V_{\text{drop}} / (1000 \text{ A} \cdot \text{ft}) \cdot 2 (\text{if single phase})$$

$$\% V_{\text{drop}} = V_{\text{drop(l-n)}} / V$$

<b>Circuit Voltage</b>	120
<b>power factor</b>	0.9
<b>Length (ft)</b>	75
<b>Wire Size</b>	#12
<b>V<sub>drop/(1000 A ft)</sub></b>	1.749
<b>Current (A)</b>	6.9
<b>1φ Multiplier</b>	2
<b>V<sub>drop(l-n)</sub></b>	1.810
<b>% V<sub>drop</sub></b>	<b>1.509</b>

1.509% < 3% maximum per NEC recommendations

**New Lighting Power Plan**



\* Note: See Appendix J for a 1/8" = 1'-0" Plan

**Existing R2NF Panelboard**

PANELBOARD: R2NF		BUS RATING:		225 A		MAIN OCP						
MIN AIC:		VOLTAGE:		208 120 V		PHASE(S):				3		
NEMA 1 ENCLOSURE		MOUNTING:		SURFACE		WIRES:				5		
LOCATION:		NOTES:		200% NEUTRAL								
				LOAD, VA								
CH	CIRCUIT DESIGNN	P	TRIP	CKT	φA	φB	φC	CKT#	TRIP	P	CH CIRCUIT DESIGNATION	
	Recept - RM 1001	1	20	1	720 840			2	20	1	Recept - RM 1003	
	Recept - RM 1001	1	20	3		720 720		4	20	1	Recept - WC	
	Recept - RM 1001	1	20	5			720 300	6	20	1	Recept - RM 1002	
	Recept - RM 1001	1	20	7	720 900			8	20	1	Recept - RM 1002	
	Recept - RM 1001	1	20	9		720 1000		10	20	1	Recept - RM 1002	
	Recept - RM 1001	1	20	11			720 300	12	20	1	Recept - RM 1002	
	Recept - RM 1001	1	20	13	720 1000			14	20	1	Recept - RM 1002	
	Recept - RM 1001	1	20	15		720 528		16	20	1	CUH -6	
	Recept - RM 1001	1	20	17			720 864	18	20	1	CUH-1	
	Recept - Exterior	1	20	19	180			20	20	1		
	Power Door	1	20	21		384		22	20	1		
	Power Door	1	20	23			384	24	20	1		
	Recept - Exterior	1	20	25	180			26	20	1		
		1	20	27				28	20	1		
		1	20	29				30	20	1		
		1	20	31				32	20	1		
		1	20	33				34	20	1		
		1	20	35				36	20	1		
				37				38				
	PNL D2N1	3	60	39				40	60	3	PNL D2N2	
				41				42				
PHASE CONNECTED LOAD, VA					5260	4792	4008					
PHASE BALANCE					12.23%	2.25%	-14.48%					
TOTAL CONNECTED L 14060												
FUTURE GROWTH - 25 3515												
TOTAL + FUTURE LOA 17575												
TOTAL CURRENT, A 49												
DESIGN CURRENT, A 61												
MINIMUM MAIN OCP 150												

**Existing D2N1 Dimmer Panel**

PANELBOARD: D2N1		BUS RATING:		60 A		MAIN OCP OR MLO: ML(				
MIN AIC:		VOLTAGE:		208 120 V		PHASE(S): 3				
NEMA 1 ENCLOSURE		MOUNTING:		SURFACE		WIRES: 5				
LOCATION:		NOTES:								
		LOAD, VA								
RANCH CIRCUIT DESIGNATIO	P	TRIP	CK	φA	φB	φC	CKT#	TRIP	P	NCH CIRCUIT DESIGNATION
LTG - RM 1001	1	20	1	640	640		2	20	1	LTG - RM 1001
LTG - RM 1001	1	20	3		640	640	4	20	1	LTG - RM 1001
LTG - RM 1001	1	20	5			640	6	20	1	LTG - RM 1001
LTG - RM 1001	1	20	7	640	640		8	20	1	LTG - RM 1001
LTG - RM 1001	1	20	9		640	640	10	20	1	LTG - RM 1001
LTG - RM 1001	1	20	11			640	12	20	1	LTG - RM 1001
LTG - RM 1001	1	20	13	640	640		14	20	1	LTG - RM 1001
LTG - RM 1001	1	20	15		640	640	16	20	1	LTG - RM 1001
LTG - RM 1001	1	20	17			640	18	20	1	LTG - RM 1001
LTG - RM 1001	1	20	19	640	640		20	20	1	LTG - RM 1001
LTG - RM 1001	1	20	21		640	640	22	20	1	LTG - RM 1001
LTG - RM 1001	1	20	23			640	24	20	1	LTG - RM 1001
PHASE CONNECTED LOAD, VA				5120	5120	5120				
PHASE BALANCE				0.00%	0.00%	0.00%				
TOTAL CONNECTED LOAD, VA		15360								
FUTURE GROWTH - 10%		1536								
TOTAL + FUTURE LOAD, VA		16896								
TOTAL CURRENT, A		47								
DESIGN CURRENT, A		59								
MINIMUM MAIN OCP		60								

**Redesigned R2NF Panelboard**

PANELBOARD: R2NF		BUS RATING:		225 A		MAIN OCP							
MIN AIC:		VOLTAGE:		208 120 V		PHASE(S):		3					
NEMA 1 ENCLOSURE		MOUNTING:		SURFACE		WIRES:		5					
LOCATION:		NOTES:		200% NEUTRAL									
				LOAD, VA									
CH	CIRCUIT DESIGN	P	TRIP	CKT	φA	φB	φC	CKT#	TRIP	P	CH	CIRCUIT DESIGNATION	
	Recept - RM 1001	1	20	1	720	840			2	20	1	Recept - RM 1003	
	Recept - RM 1001	1	20	3			720	720	4	20	1	Recept - WC	
	Recept - RM 1001	1	20	5				720	300	6	20	1	Recept - RM 1002
	Recept - RM 1001	1	20	7	720	900			8	20	1	Recept - RM 1002	
	Recept - RM 1001	1	20	9			720	1000	10	20	1	Recept - RM 1002	
	Recept - RM 1001	1	20	11				720	300	12	20	1	Recept - RM 1002
	Recept - RM 1001	1	20	13	720	1000			14	20	1	Recept - RM 1002	
	Recept - RM 1001	1	20	15			720	528	16	20	1	CUH -6	
	Recept - RM 1001	1	20	17				720	864	18	20	1	CUH-1
	Recept - Exterior	1	20	19	180				20	20	1		
	Power Door	1	20	21			384		22	20	1		
	Power Door	1	20	23				384	24	20	1		
	Recept - Exterior	1	20	25	180				26	20	1		
		1	20	27					28	20	1		
		1	20	29					30	20	1		
		1	20	31					32	20	1		
		1	20	33					34	20	1		
		1	20	35					36	20	1		
				37	2344				38				
	PNL D2N1	3	40	39			2344		40	60	3	PNL D2N2	
				41				2344	42				
PHASE CONNECTED LOAD, VA					7604	7136	6352						
PHASE BALANCE					8.15%	1.50%	-9.65%						
TOTAL CONNECTED L 21093													
FUTURE GROWTH - 25 5273													
TOTAL + FUTURE LOA 26366													
TOTAL CURRENT, A 73													
DESIGN CURRENT, A 91													
MINIMUM MAIN OCP 150													

**Main Overcurrent Protection**

300A breaker

**New Feeder Size**

(3) #350 MCM and (1) #4 in 2 1/2" Conduit

*Based per NEC 2005. Tables 310-16, Table C.2, Table 250.122. THWN Copper wire rated for 75°C.*

**Redesigned D2N1 Dimmer Panel**

PANELBOARD: D2N1		BUS RATING:		60 A		MAIN OCP 40A							
MIN AIC:		VOLTAGE:		208 120 V		PHASE(S):		3					
NEMA 1 ENCLOSURE		MOUNTING:		SURFACE		WIRES:		5					
LOCATION:		NOTES:											
				LOAD, VA									
RANCH CIRCUIT DESIGNATION	P	TRIP	CK	φA		φB		φC		CKT#	TRIP	P	RANCH CIRCUIT DESIGNATION
LTG - RM 1001	1	20	1	827	450					2	20	1	LTG - RM 1001
LTG - RM 1001	1	20	3			450	450			4	20	1	LTG - RM 1001
LTG - RM 1001	1	20	5					450	450	6	20	1	LTG - RM 1001
LTG - RM 1001	1	20	7	450	450					8	20	1	LTG - RM 1001
LTG - RM 1001	1	20	9			450	450			10	20	1	LTG - RM 1001
LTG - RM 1001	1	20	11					450	450	12	20	1	LTG - RM 1001
LTG - RM 1001	1	20	13	450	450					14	20	1	LTG - RM 1001
LTG - RM 1001	1	20	15			450	450			16	20	1	LTG - RM 1001
LTG - RM 1001	1	20	17					450	450	18	20	1	LTG - RM 1001
LTG - RM 1001	1	20	19	450	450					20	20	1	LTG - RM 1001
Space	1	20	21							22	20	1	Space
Space	1	20	23							24	-	1	Space
PHASE CONNECTED LOAD, VA				3977		2700		2700					
PHASE BALANCE				27.24%		-13.62%		-13.62%					
TOTAL CONNECTED LOAD, VA		9377											
FUTURE GROWTH - 10%		938											
TOTAL + FUTURE LOAD, VA		10315											
TOTAL CURRENT, A		29											
DESIGN CURRENT, A		36											
MINIMUM MAIN OCP		40											

**Main Overcurrent Protection**

40A breaker

**New Feeder Size**

(3) #8 and (1) #10 in 3/4" Conduit

*Based per NEC 2005. Tables 310-16, Table C.2, Table 250.122. THWN Copper wire rated for 75°C.*

### **Energy Efficient Transformer Study**

The Art & Visual Technology building utilizes 12 transformers throughout the building to supply electricity at either 480/277V or 208/120V power. The following study compares the use of energy efficient transformers versus standard ones.

The cost of the standard transformers was estimated from 2008 RS Means. Additionally, the cost of Powersmith's transformers was estimated to cost an additional 35%. The utility rate of \$0.00272/kWh was used per the utility rate schedule of the building (GS-3 Dominion Virginia Power). This value seems extremely low to me, however I called to verify this information and a representative from Dominion Virginia assured me that all the information provided on their utility rate schedules is accurate. A typical 9 month, 12 hour operating schedule was used to estimate the building electrical usage.

*\*Note: A copy of the utility rate can be found in appendix D*



**The ESP Calculator™**  
Energy Savings Payback Calculator

Toll Free : 1-800-747-9627 or (905) 791-1493

**Project Description**

**Art & Visual Technology Building**

**Date**

**1-Mar-07**

		Transformers on Project		Standard Xfmr Co	PowerSmith Co
		QTY	kVA		
		2	15	\$6,530	\$8,816
		2	30	\$4,385	\$5,920
			45	\$5,110	\$6,899
		5	75	\$7,000	\$9,450
		3	112.5	\$13,439	\$18,143
			150	Total Cost	Total Cost
			225	\$97,147	\$131,148
			300		
			500		
			750		
			1000		
			1500		
			2000		
			7.5		
<b>Available Full Load kW</b>		<b>802.5</b>			
Average kVA (calc)		<b>67</b>			
equipment operating hrs/ day		<b>12</b>			
equipment operating days/yr		<b>270</b>	Calc Load kW	Calc Annual kWh	
Load during normal operating hours		<b>40%</b>	321	1,040,040	
Load outside operating hours		<b>15%</b>	120	664,470	
			<b>Total Annual Load</b>	<b>1,704,510</b>	
<b>Annual Cost to Operate Load Only</b>					
kWh rate		<b>\$ 0.003</b>	Annual Consumption:	\$ 4,636	
demand rate (\$/kW/mo) ex. \$10.00		<b>\$12.15</b>	Annual Demand:	\$ 46,802	
			<b>Total Cost to run load</b>	<b>\$ 51,438</b>	
<b>Annual Cost of Status Quo Transformer Losses &amp; Associated Air Conditioning (A/C) burden</b>					
Status quo Efficiency (Normal Operation)		<b>97.0%</b>			
Transformer kW Losses (Normal Operation)		<b>9.9 kW</b>			
Status quo Efficiency (Outside op. hrs)		<b>92.0%</b>			
Transformer kW Losses (Outside op. hrs)		<b>10.5 kW</b>			
Annual additional kWh from transformers		<b>89,946 kWh</b>			
<b>Annual Cost of Transformer Losses</b>		<b>\$ 1,692</b>			
A/C System Performance (kW/ton)		<b>1.25</b>			
Additional Tons of Cooling (on peak)		<b>2.82 tons</b>			
Annual additional kWh from A/C		<b>31,941 kWh</b>			
<b>Annual Cost of Associated A/C</b>		<b>\$ 601</b>			
<b>Summary with Status Quo Transformer</b>					
Annual Cost of feeding Building Load		<b>\$ 51,438</b>			
Annual Cost of Transformer Losses		<b>\$ 1,692</b>			
Annual Cost of Associated A/C		<b>\$ 601</b>			
<b>Electrical Bill (Status Quo Transformer)</b>		<b>\$ 53,731</b>			



<p>IMPORTANT: By using the ESP Calculator™, you are agreeing the TERMS OF USE section on page 1 of 3. Powersmiths International Corp. is a licensed user. Content subject to change without notice.</p>			
<p>Page 1 of 3 © Power Quality Institute 1998-2006. All rights reserved. doc#807-000440-110-AC</p>		<p>1-Mar-07</p>	
<p><b>POWERSMITHS</b></p>		<p><b>Page 2 The ESP Calculator™</b></p>	
<p>Toll Free : 1-800-747-9627 or (905) 791-1493</p>		<p>Energy Savings Payback Calculator</p>	
<p><b>Using Powersmiths instead of status quo transformers</b></p>			
Powersmiths Efficiency (Normal Operation)	98.2%		
Powersmiths kW Losses (Normal Operation)	5.9 kW		
Powersmiths Efficiency (Outside op. hrs)	97.6%		
Transformer kW Losses (Outside op. hrs)	3.0 kW		
Annual additional kWh from transformers	35,403 kWh		
<b>Annual Cost of Powersmiths Losses</b>	<b>\$ 954</b>		
Additional Tons of Cooling (on peak)	1.67 tons		
Annual additional kWh from A/C	12,572 kWh		
<b>Annual Cost of Associated A/C</b>	<b>\$ 339</b>		
<p><b>Comparing Status Quo &amp; Powersmiths</b></p>			
	<b>Status Quo</b>	<b>Powersmiths</b>	
Annual Cost of feeding Building Load	\$ 51,438	\$ 51,438	
Annual Cost of Transformer Losses	\$ 1,692	\$ 954	
Annual Cost of Associated A/C	\$ 601	\$ 339	<b>Reduction</b>
<b>Annual estimated Electrical Bill</b>	<b>\$ 53,731</b>	<b>\$ 52,731</b>	<b>2%</b>
<b>Peak kW reduction (normal op hours)</b>	<b>4.0 kW</b>		
<b>Annual kWh reduction</b>	<b>73,912 kWh</b>		
<b>Reduction in Air Conditioning Load (on peak)</b>	<b>1.15 tons</b>		
<p><b>Cost Analysis (calc)</b></p>			
Energy Cost Escalation (above inflation)	3.0%		
Annual Power Quality Benefit	\$ -		
	<b>Annual Operating Cost</b>	<b>Life Cycle Operating Cost &amp; Savings</b>	
		<b>20 years</b>	<b>32 years</b>
Status Quo Transformers	\$2,293	\$82,829	\$188,952
Powersmiths Transformers	\$1,293	\$46,706	\$106,547
<b>Savings with Powersmiths</b>	<b>\$1,000</b>	<b>\$36,123</b>	<b>\$82,404</b>
	<b>Cost</b>		
Powersmiths Transformers	\$131,148		
Status Quo Transformers	\$97,147		
	<b>Payback on total cost</b>	<b>34.00 years</b>	current kWh rate:
Cost of Energy Savings	\$ 0.014 /kWh		\$0.003
Cost - Benefit Ratio	0.2	times less to save a kWh than to buy a kWh	
	<b>Leasing Option</b>	<b>60 Month Term</b>	<b>48 Month Term</b>
<b>Total Annual Leasing Payments</b>	<b>\$24,563</b>	<b>\$29,960</b>	<b>\$38,120</b>
<b>Net Annual Cost with savings</b>	<b>\$23,563</b>	<b>\$28,960</b>	<b>\$37,120</b>
<p><b>Summary of Environmental Benefits</b></p>			
<b>Annual Reduction in Greenhouse Gases (per EPA)</b>		<b>Equivalence</b>	
55 tons of CO2		10 Acres trees planted	
177 tons of Coal		7 Car Emissions	
428 kgs of SO2		7 homes heated	
184 kgs of NOx			
<p>IMPORTANT: By using the ESP Calculator™, you are agreeing the TERMS OF USE section on page 1 of 3. Powersmiths International Corp. is a licensed user. Content subject to change without notice.</p>			

## **Conclusion**

Based on Powersmith's ESP calculator, energy efficient transformers will save roughly \$1,000 a year. With the initial increased cost of nearly \$35,000, it will take about 34 years for the energy efficient transformers to pay themselves back. Over the life span of the system (32 years) energy efficient transformers will save roughly \$82,000 in energy savings. In addition to the financial savings, the reduced energy usage equates to roughly 10 acres of trees planted each year. In this instance, due to the extremely low utility rate, I would not recommend the use of energy efficient transformers. However, in other instances where the utility rate is a more typical range \$0.10/kWh energy efficient transformers can be very beneficial.

### **Photovoltaic Array Study**

A relatively attractive climate along with federal and state incentives makes the possibility of a photovoltaic array to be financial feasible for the Art & Visual Technology Building. The following study investigates the use of a photovoltaic array on roof of the Art & Visual Technology building. This study was conducted with the aid of RestScreen® to determine if the proposed system of 170 watt monocrystalline (product number BP 5170) photovoltaic modules produced by BP Solar would be beneficial to implement. The aim of this study was to compare the cost of the solar panels versus the cost savings of energy production. Therefore, the cost of engineering, feasibility studies, and balancing were not included.

*\*See appendix E for the product cut sheet*

The federal and state incentives for the installation of a photovoltaic are integral to the financial success of installing such a system. These incentives help offset the high initial cost of purchasing and installing the system. After research of available state incentives for the production of renewable energy, it was found that no state incentives were applicable for this application. Many federal incentives are available but, are based on federal tax rebates. Since GMU is a university, most of these incentives were not applicable. The only incentive obtainable for this project was:

#### **Federal Renewable Energy Production Incentive (REPI)**

Introduced in the Energy Policy Act of 1992, the federal government provides financial assistance to energy producing facilities at the rate of 1.5 cents per kilowatt hour (1993 dollars, indexed for inflation) for the first ten years of operation. As estimated by [www.moneytimes.com](http://www.moneytimes.com), the average inflation rate over this period was 2.69%, which equates to a rate of 2.22 cents per kilowatt hour.

### **Design Parameters**

To find the potential photovoltaic system size an approximation of available roof square footage was determined. 80% of the available roof area was assumed to be useable for installation of photovoltaic modules.

Available space on roof = 9,775 ft<sup>2</sup>  
Usable space on roof = 7,820 ft<sup>2</sup>  
Module Size (31" x 62.7") = 13.5 ft<sup>2</sup>  
Module Nominal Power = .170kW  
Number of Modules = 7,820 ft<sup>2</sup> / 13.5 ft<sup>2</sup> = 579  
Maximum Nominal Power = **98.4kW**

Weather data for Fairfax, Virginia was not obtainable, however weather data for Washington D.C. was used as it is close in proximity to Fairfax. The avoided cost of energy was \$0.272 which was determined from the utility rate for the campus.

#### **Estimated Initial Cost**

Module Cost 98.4kW \* \$5,750/kW = \$565,800

#### **Estimated intermittent Cost**

Periodic Inverter Replacement\* = \$50,000

Misc. Cost\*\* = \$28,700

Annual Operating & Maintenance = \$880

*\*Note: Per RetScreen recommendations*

*\*\*Note: Includes Training & 5% Contingency*

#### **Federal Renewable Energy Production Incentive (REPI)**

Savings \$0.0222/kWh for the first ten years

## RetScreen Results

### RETScreen® Energy Model - Photovoltaic Project

[Training Calendar](#)

Site Conditions		Estimate	Notes/Range
Project name		Art & Visual Technology	<a href="#">See Online Manual</a>
Project location		Fairfax, VA	
Nearest location for weather data	-	Washington, DC	→ <a href="#">Complete SR&amp;SL sheet</a>
Latitude of project location	°N	38.9	-90.0 to 90.0
Annual solar radiation (tilted surface)	MWh/m <sup>2</sup>	1.52	
Annual average temperature	°C	14.5	-20.0 to 30.0

System Characteristics		Estimate	Notes/Range
Application type	-	On-grid	
Grid type	-	Central-grid	
PV energy absorption rate	%	100.0%	
<b>PV Array</b>			
PV module type	-	mono-Si	
PV module manufacturer / model #		BP Solar/ BP 5170 S	<a href="#">See Product Database</a>
Nominal PV module efficiency	%	13.5%	4.0% to 15.0%
NOCT	°C	45	40 to 55
PV temperature coefficient	% / °C	0.40%	0.10% to 0.50%
Miscellaneous PV array losses	%	5.0%	0.0% to 20.0%
Nominal PV array power	kWp	98.40	
PV array area	m <sup>2</sup>	728.9	
<b>Power Conditioning</b>			
Average inverter efficiency	%	90%	80% to 95%
Suggested inverter (DC to AC) capacity	kW (AC)	88.6	
Inverter capacity	kW (AC)	72.0	
Miscellaneous power conditioning losses	%	0%	0% to 10%

Annual Energy Production (9.19 months analysed)		Estimate	Notes/Range
Specific yield	kWh/m <sup>2</sup>	126.2	
Overall PV system efficiency	%	11.2%	
PV system capacity factor	%	10.7%	
Renewable energy collected	MWh	102.181	
Renewable energy delivered	MWh	91.963	
	kWh	91,963	
Excess RE available	MWh	0.000	

[Complete Cost Analysis sheet](#)

**RETScreen® Solar Resource and System Load Calculation - Photovoltaic Project**

Site Latitude and PV Array Orientation		Estimate	Notes/Range
Nearest location for weather data		Washington, DC	<a href="#">See Weather Database</a>
Latitude of project location	°N	38.9	-90.0 to 90.0
PV array tracking mode	-	Fixed	
Slope of PV array	°	30.0	0.0 to 90.0
Azimuth of PV array	°	0.0	0.0 to 180.0

Monthly Inputs					
Month	Fraction of month used (0 - 1)	Monthly average daily radiation on horizontal surface (kWh/m <sup>2</sup> /d)	Monthly average temperature (°C)	Monthly average daily radiation in plane of PV array (kWh/m <sup>2</sup> /d)	Monthly solar fraction (%)
January	0.60	1.81	1.4	2.61	-
February	1.00	2.57	3.1	3.34	-
March	1.00	3.55	8.4	4.08	-
April	1.00	4.60	13.6	4.79	-
May	1.00	5.42	19.1	5.23	-
June	0.33	5.99	24.2	5.58	-
July	0.33	5.73	26.7	5.42	-
August	0.33	5.10	25.8	5.14	-
September	1.00	4.23	21.8	4.71	-
October	1.00	3.16	15.4	3.97	-
November	1.00	2.05	9.9	2.91	-
December	0.60	1.52	4.1	2.22	-
			<b>Annual</b>	<b>Season of use</b>	
Solar radiation (horizontal)		MWh/m <sup>2</sup>	1.39	1.01	
Solar radiation (tilted surface)		MWh/m <sup>2</sup>	1.52	1.13	
Average temperature		°C	14.5	13.0	

Load Characteristics	Estimate
Application type	On-grid

[Return to Energy Model sheet](#)


**RETScreen® Financial Summary - Photovoltaic Project**

Annual Energy Balance				
Project name	Art & Visual Technology			
Project location	Fairfax, VA	Nominal PV array power	kWp	100.00
Renewable energy delivered	MWh	93.458		
Firm RE capacity	kW	-		
Application type	On-grid			

Financial Parameters					
Avoided cost of energy	\$/kWh	0.003	Debt ratio	%	0.0%
RE production credit	\$/kWh	0.015			
RE production credit duration	yr	20			
RE credit escalation rate	%	2.0%	Income tax analysis?	yes/no	No
Energy cost escalation rate	%	5.0%			
Inflation	%	2.5%			
Discount rate	%	9.0%			
Project life	yr	25			

Project Costs and Savings				
<b>Initial Costs</b>			<b>Annual Costs and Debt</b>	
Feasibility study	0.0%	\$ -	O&M	\$ 880
Development	0.0%	\$ -	Fuel	\$ -
Engineering	0.0%	\$ -		
Energy equipment	95.2%	\$ 575,000	<b>Annual Costs and Debt - Total</b>	<b>\$ 880</b>
Balance of equipment	0.0%	\$ -		
Miscellaneous	4.8%	\$ 29,160	<b>Annual Savings or Income</b>	
<b>Initial Costs - Total</b>	<b>100.0%</b>	<b>\$ 604,160</b>	Energy savings/income	\$ 254
Incentives/Grants		\$ -	RE production credit income - 20 yrs	\$ 1,402
			<b>Annual Savings - Total</b>	<b>\$ 1,656</b>
<b>Periodic Costs (Credits)</b>			Schedule yr # 12,24	
Inverter Repair/Replacement		\$ 50,000		
		\$ -		
		\$ -		
End of project life -		\$ -		

Financial Feasibility					
Pre-tax IRR and ROI	%	negative	Calculate energy production cost?	yes/no	Yes
After-tax IRR and ROI	%	negative	Energy production cost	\$/kWh	0.43
Simple Payback	yr	778.5			
Year-to-positive cash flow	yr	more than 25	Project equity	\$	604,160
Net Present Value - NPV	\$	(631,329)			
Annual Life Cycle Savings	\$	(64,273)			
Benefit-Cost (B-C) ratio	-	(0.04)			




**Photovoltaic Array Conclusion**

The designed photovoltaic system yielded a twenty-five year plus payback period for the owner. The net energy production cost came out to be roughly \$0.43/kWh which is much higher than the utilities’ rate of \$0.00272/kWh. As discussed earlier in this report, I believe that the utility rate is extremely low. This is what drove the payback period to be at least 25 years. I had tested the same setup with using a rate of \$0.10/kWh and got an output of roughly 15 years for the payback period. Since the federal incentive packages are based on federal tax savings and the avoided cost of energy (utility rate), implementing photovoltaic array on the Art & Visual Technology building is not



recommended. However, on a project whose owner pays federal taxes and a higher utility rate, a photovoltaic array could be highly recommended.






**Evaluation**

Upon laying the current trip curves over each other, it was found that the coordination of the chosen path was properly coordinated with the breaker furthest downstream tripping first and each consecutive breaker up stream breaking next.

### Short Circuit Analysis



I was unable to contact Dominion Virginia Power, therefore with the recommendations of Professor Dannerth, the Utility transformer size was estimated at 750kVA. The following is the summary table of the short circuit analysis at each point throughout the system. The calculations used to tabulate the summary are in the following section.

<b>Point</b>	<b>Location</b>	<b>Available Fault</b>	<b>Standard Breaking Rating</b>
A	Utility Transformer Secondary	17,803	25,000
B	SWBD	16,243	25,000
C	Panel H3SA	14,790	25,000
D	T3S	14,408	25,000
E	R3SA	1,425	14,000
F	R3SB	1,400	14,000

<b>Per Unit Method</b>			
<b>BASE kVA</b>	1000		
<b>Utility Company Available Fault</b>	1000000		
<b>System Voltage (kV)</b>	0.48		
<b>Utility Transformer Primary</b>			
Utility Transformer Size	750	X (p.u.)	0.001
<b>Utility Transformer Secondary</b>			
Average % Z.	5	$X(p.u.) = (\%X * \text{base kVA} / 100 * \text{xfmr kVA})$	0.059507777
Average X/R	1.98	$R(p.u.) = (\%R * \text{base KVA} / 100 * \text{xfmr kVA})$	0.030054433
X (%)	4.463		
R (%)	2.254	$\Sigma X(p.u.)$	0.060507777
		$\Sigma R(p.u.)$	0.030054433
		$\Sigma Z(p.u.)$	0.067560787
		$I_{sc \text{ rms sym}}$	17803.4198
<b>Main SwitchBoard</b>			
# of sets	6	X(p.u.)	0.00531684
length	150	R(p.u.)	0.003862847
Wire Size	400kcmil		
$X_L$	0.049	$\Sigma X(p.u.)$	0.065824617
R	0.0356	$\Sigma R(p.u.)$	0.03391728
X	0.001225	$\Sigma Z(p.u.)$	0.074049052
R	0.00089	$I_{sc \text{ rms sym}}$	16243.46331
<b>Panel H3SA</b>			
# of sets	1	X(p.u.)	0.008038194
length	40	R(p.u.)	0.000111545
Wire Size	600kcmil		
$X_L$	0.0463	$\Sigma X(p.u.)$	0.073862812
R	0.0257	$\Sigma R(p.u.)$	0.034028825
X	0.001852	$\Sigma Z(p.u.)$	0.08132451
R	2.57E-05	$I_{sc \text{ rms sym}}$	14790.28972
<b>Transformer T3S</b>			
# of sets	1	X(p.u.)	0.00234375
length	10	R(p.u.)	5.55556E-05
Wire Size	#1/0		
$X_L$	0.054	$\Sigma X(p.u.)$	0.076206562
R	0.0128	$\Sigma R(p.u.)$	0.034084381
X	0.00054	$\Sigma Z(p.u.)$	0.083481645
R	1.28E-05	$I_{sc \text{ rms sym}}$	14408.11404

<b>Secondary T3S</b>			
Transformer Size	75	$X(p.u.) = (\%X * \text{base kVA} / 100 * \text{xfmr kVA})$	0.615409881
Average % Z.	5.7	$R(p.u.) = (\%R * \text{base KVA} / 100 * \text{xfmr kVA})$	0.445949189
Average X/R	1.38		
X (%)	4.616	$\Sigma X(p.u.)$	0.691616442
R (%)	3.345	$\Sigma R(p.u.)$	0.480033569
		$\Sigma Z(p.u.)$	0.841882136
		$I_{sc \text{ rms sym}}$	1428.719068
<b>Panel R3SA</b>			
# of sets	1	$X(p.u.)$	0.002148438
length	10	$R(p.u.)$	0.000239583
Wire Size	250kcmil		
$X_L$	0.0495	$\Sigma X(p.u.)$	0.69376488
R	0.0552	$\Sigma R(p.u.)$	0.480273153
X	0.000495	$\Sigma Z(p.u.)$	0.843784338
R	5.52E-05	$I_{sc \text{ rms sym}}$	1425.498206
<b>Panel R3SB</b>			
# of sets	1	$X(p.u.)$	0.018554688
length	75	$R(p.u.)$	6.94444E-05
Wire Size	#1		
$X_L$	0.057	$\Sigma X(p.u.)$	0.712319567
R	0.016	$\Sigma R(p.u.)$	0.480342597
X	0.004275	$\Sigma Z(p.u.)$	0.859143863
R	0.000016	$I_{sc \text{ rms sym}}$	1400.013564