

Senior Thesis Final Report

Ground-source Gymsnasiums and Satisfactory Stages

Altoona Area Junior High School

Altoona, PA

Christopher G. Conrad

Mechanical Option

Faculty Advisor: James D. Freihaut, Ph.D.

April 9, 2008

Thesis Abstract

ALTOONA AREA JUNIOR HIGH SCHOOL · ALTOONA, PA



BUILDING STATISTICS

Building Occupant: **Altoona Area School District**
 Occupancy Type: **Secondary Education**
 Size: **292,066 SF**
 Number of Stories: **Academic/Fine Arts Building - 4
Physical Education Building - 2**
 Dates of Construction: **April 2006 - August 2008**
 Cost: **\$48 Million**
 Project Delivery Method: **Design-Bid-Build**

STRUCTURAL OVERVIEW

12-26" Reinforced Concrete Footings
8-12" Reinforced CMU Foundation
5" Slab-on-grade with W2.9xW2.9 WWF
5.25" Concrete Floor Slabs on 9/16" Steel Deck
Single Steel Joists on Load-bearing CMU Walls
Single and Double Joists on Steel Columns
1.5" Galvanized Steel Roof Deck

DESIGN & CONSTRUCTION TEAM

Owner: **Altoona Area School District**
 Architects: **L. Robert Kimball and Associates**
 General Contractor: **Leonard S. Fiore, Inc.**
 HVAC: **D. C. Goodman and Sons, Inc.**
 Plumbing: **S. P. McCarl and Company, Inc.**
 Fire Protection: **Interstate Fire Protection Co.**
 Electrical: **G. M. McCrossin, Inc.**
 Food Service: **Commercial Appliance Contracts**
 Auditorium Seating: **Maffei Strayer Furnishings, Inc.**

MECHANICAL OVERVIEW

Modular Indoor and Outdoor CW/HW AHUs
(2) 225-ton Rotary Screw Water Chillers
(2) 3,322-MBH Gas Boilers
(11) Air-cooled Condensing Units
(8) VAV Boxes with Electric Reheat Coil
(1) 41.5-MBH Split-system A/C Unit
(6) Rooftop A/C Units
(12) 14.5-MBH Hydronic Cabinet Unit Heaters
(6) 6,825-BTUH Electrical Wall Heaters
(130) Room Unit Ventilators
(3) 500-BTU/ft Radiant Ceiling Panel Heaters

ARCHITECTURAL SUMMARY

The new Altoona Area Junior High School consists of a 239,434 SF Academic and Fine Arts Building and a 52,632 SF Physical Education Building. The Academic Building houses two cafeterias, an enclosed courtyard, an auditorium, offices, and classrooms. The Physical Education Building houses two gymnasiums, an indoor running track, and locker room facilities. The entire structure is clad in red brick accented with tinted pre-cast concrete elements. The windows and doors are aluminum with decorative pre-cast panels.

LIGHTING/ELECTRICAL OVERVIEW

4000 A, 480/277V Service
Voice and Data Communications
Security Cameras/Alarms
Closed-circuit Television
Auditorium and Gymnasium Sound
Fire Detection and Pumping
600 kW Emergency Generator
Interior Fluorescent Pendant Luminaires
Exterior HID Luminaires
Auditorium Dimming
Theatrical Lighting

CHRISTOPHER G. CONRAD · MECHANICAL OPTION

<http://www.engr.psu.edu/ae/thesis/portfolios/2008/cgc129/>

Acknowledgements

First and foremost, I would like to acknowledge the assistance and cooperation of the Altoona Area School District and their representatives, notably Dr. George Cardone, Assistant Superintendent, and Mr. Tom Bradley, Public Relations Director. Their assistance in granting the go-ahead for this project as well as providing information and photographs of the building construction have been most helpful in the development of the following studies.

Furthermore, much of the accompanying analyses would not have been possible without the construction documents and answers provided by the engineers, designers and contractors involved in the project. Mr. Earl Wong and Mr. Brad Palmisiano of L. Robert Kimball & Associates, Inc. have been of immense help in clarifying the objectives and operation of the existing mechanical systems in the new junior high school. Mr. David Goodman and Mr. Mike Humphreys of D. C. Goodman & Sons, Inc. have also been instrumental in providing a complete set of construction drawings and specifications, much of which provided the inspiration for the following report.

The assistance of my course instructors, faculty advisors, and fellow classmates must also be acknowledged. I would like to give a special thank you to Dr. Jim Freihaut, whose knowledge and constructive criticism over the past school year have most certainly affected the outcome of this report. I would also like to thank Prof. Kevin Parfitt and Prof. Bob Holland for the excellent job they have done in organizing and administrating the Penn State AE Senior Thesis course. I must also give thanks to my fellow peers whose diverse experiences have provided a wealth of knowledge that has enhanced this report.

Finally, I would like to thank my family and friends, whose support over the past five years have made my time at Penn State successful and enjoyable: my mother, Linda; my father, Randy; my sister, Lana; my grandparents, aunts, uncles, and cousins; my roommates, Tom Chirdon, David Miller, and Scott Earley; my bandmates, Thom Fronauer, Ryan Furry, and Michael Furry; and my friends, Paul Conway, Mike Johnson, Jon Reynolds, Andrew Collins, Chris DeStefano, Doug Conrad, Scott Davis and Nick Kutchi.

*Dedicated to my grandmother, Althea M. Chilcote,
who passed away during the compilation of this report.*

Table of Contents

| | |
|--|----|
| Executive Summary | 5 |
| 1. Existing Conditions | 6 |
| 1.1 Building Statistics | 6 |
| 1.2 Existing Mechanical Systems Summary | 7 |
| 1.3 Reduction of Scope | 8 |
| 2. Project Depth Study | 9 |
| 2A.1 Existing Athletic Building Systems Analysis | 9 |
| 2A.2 Considered Alternative Solution | 15 |
| 2A.3 The Ground Source Heat Pump System | 16 |
| 2A.4 Initial Considerations | 17 |
| 2A.5 Designing the System | 19 |
| 2A.6 Modeling the System | 23 |
| 2A.7 Results | 25 |
| 2B.1 Stage Analysis Summary | 28 |
| 3. Lighting Breadth Study | 29 |
| 3A. Designing and Modeling the System | 29 |
| 3B. Results | 32 |
| 4. Acoustics Breadth Study | 35 |
| 5. Project Summary | 36 |
| 6. Conclusions | 38 |
| References & Photo Credits | 39 |
| Appendix A | 40 |
| Appendix B | 49 |

Executive Summary

The primary purpose of the following report is to examine the potential for a proposed HVAC system redesign to reduce energy costs and consumption at the Altoona Area Junior High School. The scope has been reduced to include an examination of seven direct-expansion/gas air handling units that serve the school's athletic facility. Based off of an anticipated high level of efficiency offered by ground source heat pump systems, this option was critically analyzed and selected to serve as the redesign featured in this study.

It has been found that the use of a GSHP system has the potential to reduce annual maintenance and operating costs by as much as 57% in this instance. It was also determined that while a GSHP system figured to increase annual electricity consumption by an estimated 33%, it totally eliminated the need for natural gas. The main drawback for the proposed GSHP system is its high initial cost, costing an estimated \$95,000 more than the traditional existing design.

Furthermore, a proposed gymnasium daylighting system utilizing skylights has been found to increase the thermal loads for the system redesign, as expected, but has demonstrated a potential in decreasing electric lighting costs by as much as 67%.

The conclusions made by this report indicate that a GSHP system with integrated daylighting has the potential to significantly reduce energy costs and consumption and should therefore be considered as a feasible and adequate alternative to the original design.

Additionally, this report has verified the feasibility of diverting outdoor air from an air handling unit serving the school's band room to the school's auditorium, where deficiencies have been noted through previous analysis. This report has also concluded that the use of additional air diffusers to accommodate this diverted outdoor air will not have an adverse effect on background noise if the proper diffuser size is specified. If a diversion of outdoor air meeting the requirements of ASHRAE Std. 62.1 were to be carried out to improve the original design, it is the finding of this report that the acoustic considerations, while critical, are minimal.

1. Existing Conditions

Main aspects of the Altoona Area Junior High School are discussed below. The discussion focuses on the building's mechanical systems and related items. This study's scope is also defined, highlighting which aspects will be further discussed later in this report.

1.1 Building Statistics

The Altoona Area Junior High School building located in Altoona, Pennsylvania is a 292,000 ft², \$48 million educational facility with a variety of mixed-use and single-use spaces. The school will accommodate an estimated 1800 students in grades 7-9. School construction began in the spring of 2006 and will open in time for the 2008-09 school year.

The Altoona Area School District, one of the largest school districts in Pennsylvania, is the owner of the project and will oversee the management and construction of the building. L. Robert Kimball and Associates, of Ebensburg are the architects for the school. L.S. Fiore, Inc., of Altoona will construct this design-bid-build project. For more information on building details including an in-depth listing of the project's subcontractors, please visit the Capstone Project Electronic Portfolio website at <http://www.engr.psu.edu/ae/thesis/portfolios/2008/cgc129>.

Main systems and features of the building are described in detail below. Please note that a mechanical system description has been omitted from this section. A more detailed description of the building's existing mechanical system can be found in **Section 1.2**.

Architecture

The new facility consists of a four-story 239,434 ft² academic and fine arts building and a two-story 52,632 ft² physical education building. The academic building houses two cafeterias, an enclosed courtyard, an auditorium, administrative offices, and classrooms. The physical education building houses two gymnasiums, an indoor running track, and locker room facilities. The entire structure is clad in red brick accented with tinted pre-cast concrete elements. The windows and doors are aluminum with decorative pre-cast panels.



Figure 1-A. A rendered elevation of the Altoona Area Junior High School.

Lighting/Electrical

The Building is fed with 4000A, 480/277V service. The building's backup power is provided by a 600 kW emergency generator. The school features fluorescent pendant luminaires in most of the interior spaces with HID luminaires on the exterior. An auditorium dimming system and theatrical lighting are also included in the overall system.

Structural

The building is supported by reinforced concrete footings ranging from 12-26 inches in size with a foundation of concrete masonry units. The main floor slab is 5-inch slab on grade with W2.9xW2.9 reinforcing steel. The upper floors are 5.25-inch concrete floor slabs on top of 9/16” steel decking. Load-bearing CMU walls are reinforced by steel columns with single steel floor joists. The roof system uses 1.5-inch steel decking as a base.

Fire Protection

Smoke detectors and emergency pull stations are connected to a centralized alert center within the building. Sprinklers are provided throughout the building as is stipulated by the International Building Code. Ceiling-mounted luminaries and exit signs are powered by the backup generator in case of an emergency.

Telecommunications

The building features a voice and data communications system as well as a closed-circuit television system which is accessible in all classrooms and throughout all major assembly spaces in the building. Interior and exterior security cameras providing real-time and recordable video will also be installed throughout the school campus. The auditorium and gymnasiums feature public address systems and interactive scoreboards where needed.

1.2 Existing Mechanical Systems Summary

The Altoona Area Junior High School is served by several different HVAC systems. A two-pipe change over chilled water/hot water system serves a majority of the air handlers and classroom unit ventilators in the building. Several prepackaged rooftop units and DX/gas units were also utilized, mainly in the school’s athletic area.

Due to the building’s size, it would be too tedious to list each space and the system by which it is served. Instead, **Table 1-A**, provided below, makes a listing of the types of spaces in the building and by which type of system these spaces are generally served.

| Table 1-A Building System Summary Organized by Type | |
|--|------------------------------|
| Unit | Space |
| DX/gas AHUs | Gymnasiums/Athletics |
| CW/HW AHUs | Library/Auditorium/Cafeteria |
| VAV Box System | Office Suite |
| Individual Unit Ventilators | Classrooms/Lounges |

The Two-Pipe Change Over System

The obvious characteristic of this system is that only two sets of pipes (one for supply and one for return) serve the units in the building. Chilled water is provided by two 225-ton air-cooled chillers and hot water is provided by two 3,322-MBH natural gas boilers. A three-way mixing valve provides a controlled mixture of return and supply water. Change-over valves control the operation of the system based on seasonal requirements. The chilled water supply temperature is 45°F and the hot water supply temperature is 180°F. Chilled water is returned at 55°F, while hot water is returned at 160°F.

Direct Expansion (DX) Air Handlers

A large portion of the building also uses DX/gas air handling units. These large pre-packaged units utilize direct expansion cooling and gas-fired heating. These single-zone constant air volume (CAV) units are not fed from a centralized boiler/chiller plant and thus operate independently from one another. This offers a high level of controllability for the occupant, and ease of installation for the contractor. The drawback to this system is its inefficiency, which can lead to relatively high electricity costs in the summer and relatively high natural gas costs in the winter. The replacement of this system will serve as the main focus of this report. For further information, please see the following note on scope reduction and **Section 2** of the report.

1.3 Reduction of Scope

Because of the sheer size of the project and the invitation to improve certain aspects of the existing base design, the scope of this study has been reduced significantly. The split-pipe changeover system that occupies a majority of the academic building remains unchanged. Other major systems that have been considered in this report will be discussed below.



Figure 1-B. A majority of the depth study occurs in the building's athletic facility.

In the athletic facility, seven pre-packaged DX/gas air handling units have been replaced by a more energy efficient ground-source heat pump network. This study occupies the majority of the depth work presented in this report. In the academic facility, the delivery of outdoor air has been improved in the auditorium's stage area. Breadth topic selection, and more importantly, their integration with depth topic items are provided in their respective sections in this report. The results of these studies, in detail, have been provided below.

2. Project Depth Study

The project’s depth study is separated into two different sub-projects, each with its own implications which have come to define the non-mechanical breadth studies presented in this report. The first is a redesign of the current systems in the building’s athletic facilities to include a ground-source heat pump network which has been influenced by an accompanying lighting system redesign. The second involves the diversion of outdoor air delivery to the building’s auditorium, where the acoustic effects of such a diversion will be examined. Further breadth study details can be found in **Section 3** and **Section 4** of this report.

The design suggestions provided within these studies are presented as if they had been implemented in the building’s original design and are presented in an “A vs. B” format. Had the building been finished at the time of this study’s conception, a retrofit analysis may have been more effective.

2A.1 Existing Athletic Building Systems Analysis

As part of the preliminary analysis that was conducted before the conception of this report, an annual energy use and cost simulation was performed using Carrier’s *Hourly Analysis Program* (HAP). Without diverging from the primary focus of this report, several tables and screenshots from this program are provided below to give the reader an understanding of how the system was simulated and how the resulting figures will influence the conclusions made by this report. The figures provide a step-by-step progression through the simulation process and aim to logically condense its results.

For purposes of brevity, design parameters and sizing data from *HAP* will not be provided in this report. It is confirmed (from previous observation) that the systems sized using *HAP* closely match those in the design documents and should provide similar simulated results. Therefore, this section of the report will focus on schedules, fuel and electricity rates, and other parameters that will specifically affect the annual simulation. Please reference **Table 2-A**, provided below for design values for mechanical systems in the AAJHS athletic complex.

| Table 2-A Athletic Building Equipment Schedule | | | | | | | | |
|--|-----------|---------------|--------------|------|-----|---------------|------|-----|
| Mark | Total CFM | Min. O.A. CFM | Cooling (DX) | | | Heating (Gas) | | |
| | | | MBH | EAT | LAT | MBH | EAT | LAT |
| AHU A-1 | 7400 | 3875 | 306.3 | 82.3 | 55 | 560 | 35.3 | 100 |
| AHU A-2 | 7400 | 3875 | 306.3 | 82.3 | 55 | 560 | 35.3 | 100 |
| AHU A-3 | 3200 | 1440 | 122.6 | 81.1 | 55 | 200 | 40.5 | 100 |
| AHU A-4 | 3200 | 1440 | 122.6 | 81.1 | 55 | 200 | 40.5 | 100 |
| AHU A-5 | 13150 | 1500 | 378.5 | 76.6 | 55 | 560 | 63.8 | 100 |
| AHU A-6 | 2250 | 1475 | 102.7 | 84.2 | 55 | 200 | 27 | 100 |
| AHU A-7 | 3650 | 1040 | 122 | 79 | 55 | 200 | 51.5 | 100 |

Fractional and Thermostat Schedules

The following screen shots indicate how occupancy schedules were assigned using *HAP*. The schedules were created based off of assumed occupancy over a standard 180-day school year.




Figure 2-A. Occupancy schedule profile 1 used by HAP.




Figure 2-B. Occupancy schedule profile 2 used by HAP.




Figure 2-C. Occupancy schedule profile 3 used by HAP.




Figure 2-D. Occupancy schedule annual assignments used by HAP.

The following screen shots indicate how thermostat schedules were assigned using HAP. The schedules were created based off of assumed occupancy over a standard 180-day school year.




Figure 2-E. Thermostat schedule profile 1 used by HAP.




Figure 2-F. Thermostat schedule profile 2 used by HAP.

Fuel and Electric Rates

The fuel and electric rates used in the *HAP* simulation are based off of local electricity and natural gas supplier rate tariffs. Please see Schedules A1 and A2 in **Appendix A** for a detailed breakdown of the rates used in the simulation.

System Simulation

Because the project scope has been reduced for this report, a total building simulation has not been performed. Instead, each of the systems located in the AAJHS athletic wing has been simulated independently. This is possible due to the fact that each of the DX/gas single-zone CAV air handling units operate independently of each other and are not supplied by a central boiler or chiller. The following tables present the results of each system's simulation.

AHUs A-1 and A-2

These air handling units split the load in the larger of two gymnasiums, a zone that occupies approximately 11,200 ft² of floor space. The result of each system's simulation is identical and is thereby only shown once.

| Table 2-B Yearly Simulation for AHUs A-1 & A-2 | | | | | | | | | | | | |
|---|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| Cooling | JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC |
| Load (kBTU) | 0 | 0 | 126 | 3633 | 16507 | 0 | 0 | 0 | 25871 | 2918 | 497 | 44 |
| Load (kWh) | 0 | 0 | 37 | 1064 | 4833 | 0 | 0 | 0 | 7575 | 854 | 146 | 13 |
| Power (kWh) | 0 | 0 | 43 | 1245 | 5655 | 0 | 0 | 0 | 8863 | 999 | 171 | 15 |
| Heating | JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC |
| Load (kBTU) | 17121 | 13140 | 5674 | 2524 | 95 | 0 | 0 | 0 | 0 | 1017 | 4168 | 13149 |
| Load (Therms) | 171 | 131 | 57 | 25 | 1 | 0 | 0 | 0 | 0 | 10 | 42 | 131 |
| Energy (Therms) | 214 | 164 | 71 | 31 | 1 | 0 | 0 | 0 | 0 | 13 | 53 | 164 |

AHUs A-3 and A-4

These air handling units split the load in the smaller of the two gymnasiums, a zone that occupies approximately 7,420 ft² of floor space. The result of each system's simulation is identical and is thereby only shown once.

| Table 2-C Yearly Simulation for AHUs A-3 & A-4 | | | | | | | | | | | | |
|---|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| Cooling | JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC |
| Load (kBTU) | 0 | 0 | 22 | 1163 | 5570 | 0 | 0 | 0 | 8916 | 564 | 75 | 0 |
| Load (kWh) | 0 | 0 | 6 | 341 | 1631 | 0 | 0 | 0 | 2611 | 165 | 22 | 0 |
| Power (kWh) | 0 | 0 | 7 | 399 | 1908 | 0 | 0 | 0 | 3055 | 193 | 26 | 0 |
| Heating | JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC |
| Load (kBTU) | 7720 | 5765 | 2896 | 897 | 0 | 0 | 0 | 0 | 0 | 512 | 1934 | 5581 |
| Load (Therms) | 77 | 58 | 29 | 9 | 0 | 0 | 0 | 0 | 0 | 5 | 19 | 56 |
| Energy (Therms) | 96 | 73 | 36 | 11 | 0 | 0 | 0 | 0 | 0 | 6 | 24 | 70 |

AHU A-5

This air handling unit serves the concourse of the building’s athletic wing, a zone that occupies approximately 4,280 ft² of floor space.

| Table 2-D Yearly Simulation for AHU A-5 | | | | | | | | | | | | |
|--|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| Cooling | JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC |
| Load (kBTU) | 0 | 0 | 460 | 2233 | 8627 | 0 | 0 | 0 | 12544 | 1698 | 13 | 0 |
| Load (kWh) | 0 | 0 | 135 | 654 | 2526 | 0 | 0 | 0 | 3673 | 497 | 4 | 0 |
| Power (kWh) | 0 | 0 | 158 | 765 | 2955 | 0 | 0 | 0 | 4297 | 581 | 5 | 0 |
| Heating | JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC |
| Load (kBTU) | 13730 | 6512 | 1286 | 556 | 14 | 0 | 0 | 0 | 0 | 136 | 2324 | 12764 |
| Load (Therms) | 137 | 65 | 13 | 6 | 0 | 0 | 0 | 0 | 0 | 1 | 23 | 128 |
| Energy (Therms) | 171 | 81 | 16 | 8 | 0 | 0 | 0 | 0 | 0 | 1 | 29 | 160 |

AHU A-6

This air handling unit serves the locker rooms in the building’s athletic wing, a zone that occupies approximately 3,550 ft² of floor space.

| Table 2-E Yearly Simulation for AHU A-6 | | | | | | | | | | | | |
|--|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| Cooling | JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC |
| Load (kBTU) | 0 | 0 | 0 | 296 | 1688 | 0 | 0 | 0 | 2813 | 31 | 0 | 0 |
| Load (kWh) | 0 | 0 | 0 | 87 | 494 | 0 | 0 | 0 | 824 | 9 | 0 | 0 |
| Power (kWh) | 0 | 0 | 0 | 102 | 578 | 0 | 0 | 0 | 964 | 11 | 0 | 0 |
| Heating | JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC |
| Load (kBTU) | 7771 | 5946 | 3661 | 1792 | 155 | 0 | 0 | 0 | 14 | 1524 | 3008 | 6041 |
| Load (Therms) | 78 | 59 | 37 | 18 | 2 | 0 | 0 | 0 | 0 | 15 | 30 | 60 |
| Energy (Therms) | 98 | 74 | 46 | 23 | 3 | 0 | 0 | 0 | 0 | 19 | 38 | 75 |

AHU A-7

This air handling unit serves the fitness rooms in the building’s athletic wing, a zone that occupies approximately 7,250 ft² of floor space.

| Table 2-F Yearly Simulation for AHU A-7 | | | | | | | | | | | | |
|--|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| Cooling | JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC |
| Load (kBTU) | 0 | 0 | 9 | 1139 | 5378 | 0 | 0 | 0 | 7581 | 208 | 30 | 0 |
| Load (kWh) | 0 | 0 | 3 | 333 | 1575 | 0 | 0 | 0 | 2220 | 61 | 9 | 0 |
| Power (kWh) | 0 | 0 | 4 | 390 | 1843 | 0 | 0 | 0 | 2597 | 71 | 11 | 0 |
| Heating | JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC |
| Load (kBTU) | 8758 | 5939 | 1258 | 285 | 0 | 0 | 0 | 0 | 0 | 0 | 968 | 6178 |
| Load (Therms) | 88 | 59 | 13 | 3 | 0 | 0 | 0 | 0 | 0 | 0 | 10 | 62 |
| Energy (Therms) | 110 | 74 | 16 | 4 | 0 | 0 | 0 | 0 | 0 | 0 | 13 | 78 |

Estimated Annual Energy Consumption

The total estimated annual energy consumption has been itemized and is provided below.

| Table 2-G Estimated Annual Energy Consumption | |
|--|---------------------|
| HVAC Components | |
| Electric | 60,490 kWh |
| Natural Gas | 3,190 Therms |
| Non-HVAC Components | |
| Electric | 88,310 kWh |
| Totals | |
| Electric | 148,800 kWh |
| Natural Gas | 3,190 Therms |

These estimated grand totals will be used in the overall economic analysis in **Section 5**.

Estimated Annual Energy Costs

The total estimated annual costs have been itemized and are provided below.

| Table 2-H Estimated Annual Energy Costs | |
|--|-----------------|
| HVAC Components | |
| Cooling | \$7,420 |
| Heating | \$12,970 |
| Subtotal | \$20,390 |
| Non-HVAC Components | |
| Lights | \$11,620 |
| Subtotal | \$11,620 |
| Totals | |
| Grand Total | \$32,010 |

Therefore the estimated grand total for annual cost, including cooling, heating, and lights, is \$32,010. The totals presented here will be used in the overall economic project analysis in **Section 5**.

2A.2 Considered Alternative Solution

As a result of preliminary studies and analysis, an alternative solution including a radiant floor system was explored before the final proposal had been prepared. The details of this consideration and its ultimate rejection are provided below.

Radiant Floor Heating/Cooling

Upon initial inspection, a radiant floor system may have provided a feasible solution to the project's money- and energy-saving goals. In the case of the Altoona Area Junior High School, such a system installed in the athletic wing of the building could utilize the existing boiler and chiller plants to provide hot and chilled water to the piping network. Furthermore, based on initial assumptions, this system had the potential to eliminate the need for existing DX/gas units and their relatively high energy and fuel consumption. By sharing centrally-supplied hot and chilled water, a radiant floor system had the potential to significantly reduce cost and energy consumption, as well as fundamentally simplifying the design and its implications.



Figure 2-G. A Radiant floor system provided an attractive solution for the project.

2A.3 The Ground-source Heat Pump System

In order to familiarize the reader with GSHP systems and their design process, a brief introduction is provided below. The remainder of this report uses terminology that assumes the reader has some level of familiarity with GSHP systems. If a word or phrase is not familiar, it is likely that it has been discussed here.

The Vertical Closed-loop System

A vertical closed-loop system has been selected for this project because land area available for loop field placement is limited at the Altoona Area Junior High School site. If more land were available, a horizontal closed loop system, which requires more available land area, may have been selected. "Vertical", in this application, indicates that the bores drilled into the ground extend vertically down into the ground, usually between 100-400 feet. "Closed loop" indicates that the piping loops are not open to an outside thermal source, such as well or surface body water. A visual depiction of a vertical, closed-loop system is provided below in **Figure 2-H**.

The basic operation of a ground-source heat pump is similar to that of a traditional air-source heat pump, except heat exchange occurs between the earth (soil) and a water or antifreeze solution pumped through a loop manifold installed therein. Several bores can be included on a parallel loop which connects to a central vault which supplies the main feed lines entering the building. The heat pump units installed inside the building work with traditional duct delivery methods to provide conditioned air to the spaces within the building.




Figure 2-H. A visual explanation of a vertical closed-loop GSHP system.

GSHP Advantages

Besides the fundamental advantages of a GSHP system, which include reduced energy consumption and operating costs, there are also some significant architectural advantages:

- Users report a higher level of thermal comfort
- The units are very quiet
- System offers greater level of humidity control
- Low system maintenance
- No externally-mounted equipment

A ground-source heat pump system can also be used for a variety of buildings, ranging from small residential to very large commercial projects. The disadvantage is that the initial equipment and installation costs are typically higher than most traditional HVAC systems. These high initial costs can be offset by low operating and maintenance costs and typically have a fast payback period.

To read about how a GSHP system could potentially reduce energy consumption and operating costs for the Altoona Area Junior High School, please see the several following report sections.

2A.4 Initial Considerations

Before embarking on the actual design of the GSHP system for this project, one must consider several limiting considerations: most notably, the location and size of the loop field and soil conditions. In most practical applications, budget considerations may also limit design variables. In this case, where specific variables are known, they are given. Otherwise, industry standards and program defaults are used.

GSHP Loop Field Site Selection

Upon initial inspection of the site surrounding the Altoona Area Junior High School (see **Figure 2-B**), one may notice that a significant amount of space is occupied by parking lots for the building. This would seem to indicate that the placement of a GSHP loop field would be an easy undertaking: simply excavate a sufficient area of parking lot, drill bores, install pipe network, and replace the parking lot surface. This is often an easy and affordable method of implementation in many projects, but further examination of the AAJHS master plan, presents an even more logical solution.

A rather large amount of land adjacent to the AAJHS site is currently occupied by Roosevelt Junior High School, one of the schools that will be replaced by the new junior high school. As a part of the new school’s master plan, the Roosevelt school building is to be demolished to facilitate the construction of a soccer field at its current site. Because of the ease offered by utilizing this site, it has been selected as the location for the GSHP loop field for this project.



Figure 2-I. The Roosevelt school site offers 112,600 square feet of land that could be utilized for a GSHP loop field.

Figure 2-I, provided above, shows the location of the Roosevelt school site, its adjacency to the Altoona Area Junior High building, and its relative size. An examination of design documents indicates that Roosevelt Junior High School and its athletic field occupy approximately 112,600 square feet, an attractive parcel of land for GSHP loop field selection. With some construction phasing considerations that go beyond the scope of this report, it would seem entirely feasible to construct a GSHP loop field after Roosevelt school’s demolition, especially considering the Altoona Area School District already owns the site.

Load Increase due to Daylighting

The proposed addition of daylighting to the school’s gymnasiums has altered the design loads for which the GSHP system will be designed. Table 2-I, provided below, summarizes these increases in both cooling and heating loads for the system. Please see Section 3 for further details.

| Table 2-I Increased Loading due to Daylighting | | |
|---|----------------|----------------|
| Space | Cooling | Heating |
| Gym #1 | 50.4 MBH | 77.4 MBH |
| Gym #2 | 21.3 MBH | 29.1 MBH |

2A.5 Designing the System

With design loads (including the effects of daylighting) provided by the *Carrier HAP* software and an available 112,600 square feet of land for loop field placement, it was time to begin designing the ground-source heat pump system that replaces the existing DX/gas air handlers in the school's athletic wing. A free and easy-to-use program offered by practitioners at the University of Alabama called *GCHPCalc* proved to be an excellent design tool during the progression of this study. Several screen shots and tables from the program appear in this section, aiding the reader's understanding by condensing important parameters in one location. If interested, the software may be obtained at <http://www.geokiss.com/index.htm>.

Updated Loading Information




Figure 2-J. Zone cooling data provided by the GCHPCalc program.




Figure 2-K. Zone heating data provided by the GCHPCalc program.

With loads provided by the *Carrier HAP* program (including the additional loads from utilizing daylighting) and an estimated occupancy schedule, the loading inputs for the *GCHPCalc* program are provided above in **Figure 2-J** and **Figure 2-K**.

Design Water Temperatures/Flow Rates




Figure 2-L. Design temperatures and flow rates provided by the *GCHPCalc* program.

Ground Temperatures and Properties




Figure 2-M. Ground properties used by the *GCHPCalc* program.

Please note that undisturbed ground temperature was obtained using the US Geological Survey ground water temperature map, which is provided in Figure 1 of **Appendix A**. Also note that values for thermal conductivity and diffusivity are based on program defaults. It is assumed that if

a ground-source heat pump system were to be actually installed, a detailed study would be conducted on-site, providing the designer with more accurate soil property data. While no such study has been conducted for this report, the estimated cost of this procedure has been factored into the economic analysis provided later in this section.

Bore Hole/Pipe Resistance




Figure 2-N. Bore hole and pipe data used by the GCHPCalc program.

Please note that most data used in this area is based off of program defaults and industry standards. It is also worth noting that, if they were to change, any of these values may be easily changed and its influence on the final result can be determined quickly.

Loop Field Configuration




Figure 2-O. The loop field arrangement used by the GCHPCalc program.

An eight by sixteen vertical grid arrangement has been selected for this design, based on the space available at the site. This gives a total of 128 bores, whose depth will be determined by the *GCHPCalc* program.



Figure 2-P. A visual depiction of the 8x16 loop field arrangement and its relation to the school.

Figure 2-P, while not to scale, allows the reader to visualize how an 8x16 loop field fits into the Roosevelt Junior High School site. It also shows the position of the vault, its proximity to the new school, and a possible location for pipeline access.

Required Bore Lengths

| Design Lengths | | | |
|--|--------------------|--|-------------|
| Design Hybrid GCHP | Save Input to File | Print Values | Next Screen |
| Required BORE length with minimal groundwater movement = 35090 ft (274 ft/bore) (Design based on HEATING mode - net annual heat extraction from ground) Required BORE lengths with high rates of groundwater movement (or year 1) Cooling: L= 25110 ft (196 ft/bore). Heating: L= 35090 ft (274 ft/bore) | | | |
| *** Heat Pump Series: Trane (Standard Efficiency) *** | | | |
| Temperatures Unit Inlet (cooling) = 85.0°F Unit Outlet (cooling) = 96.3°F Unit Inlet (heating) = 45.0°F Unit Outlet (heating) = 39.7°F Normal ground temp = 54.0°F | | Maximum Block Loads/Demands Cooling Load/Demand = 1450 MBtuh / 178 kW Heating Load/Demand = 1388 MBtuh / 140 kW Cooling EER (Ht Pump/Sys) = 8.2 / 7.9 Heating COP (Ht Pump/Sys) = 2.9 / 2.8 Loop Pump Head/Flow Rate = 60 ft / 363 gpm Loop Pump Power/Demand = 7.8 hp / 6.9 kW | |
| U-bend/Bore Data U-tube Diameter = 1.00 inch Separation dist. = 20.0 ft Grid = 8 wide by 16 deep Grout Conductivity = 0.90 Btu/hr-ft*F Bore Diameter = 6.00 inches | | Ground Data Thermal Conductivity = 1.20 Btu/hr-ft*F Thermal Diffusivity = 0.80 ft ² /day Ground Temperature = 54.0 °F | |

Figure 2-Q. The required bore length provided by the *GCHPCalc* program.

As is indicated by the program outputs, a minimum depth of 274 feet is required for each bore. The total equivalent length is given as 35,090 feet, which can be verified by multiplying 128 bores times 274 ft/bore, which gives 35,072 feet, a figure very close to the program output.

Equipment Selection and Integration




Figure 2-R. Heat pump selections provided by the GCHPCalc program.

The GCHPCalc program also offers the designer a choice of generic heat pump models and suggests sizes and quantities based on the selected system. The program indicates that a total of eleven #150 and one #72 Trane high efficiency heat pumps should be selected for this project. The generic model numbers, in this case, indicate the nominal size for each unit. Here, #150 corresponds to a 12.5-ton vertical water-source heat pump (WSHP), and #72 corresponds to a 6-ton vertical WSHP. These units are part of the 6-25 ton GEV commercial WSHP product series. Please view the equipment literature located in **Appendix B** for further general information and specification data.

2A.6 Modeling the System

With data provided by the GCHPCalc program and known design parameters, a cost and energy consumption simulation could be conducted. For this part of the study, RETScreen International, a sustainable energy modeling program provided free from the government of Canada, was utilized. Several screen shots and tables provided by the program are used in the following section to clarify the modeling procedure and the outputs that have been calculated. If interested, the software may be obtained at <http://www.retscreen.net/>.

Climate Data

The RETScreen International software contained climate data for Altoona, PA in its database. In this case, the data had been collected at the Blair County Airport, as can be seen below in **Figure 2-S**. Values have been changed to English units to assist the reader in interpreting the data. This data will assist the software when running its algorithm for providing energy consumption and cost figures for the project.




Figure 2-S. Climate data for Altoona, PA provided by RETScreen International.

Load Inputs

| Building Heating and Cooling Load | Estimate | Notes/Range |
|-----------------------------------|---------------------|--|
| Type of building | - Commercial | |
| Available information | - Descriptive data | |
| Building floor area | m² 3,130 | |
| Number of floors | floor 1 | 1 to 6 |
| Window area | - Standard | |
| Insulation level | - High | |
| Occupancy type | - Daytime | |
| Equipment and lighting usage | - Moderate | |
| Building design heating load | kW 70.9 | |
| | million Btu/h 0.242 | |
| Building heating energy demand | MWh 140.7 | |
| | million Btu 479.9 | |
| Building design cooling load | kW 209.6 | |
| | ton (cooling) 59.6 | |
| Building cooling energy demand | MWh 310.6 | |
| | million Btu 1,059.7 | Return to Energy Model sheet |

Figure 2-T. Load inputs for the RETScreen International software.

Please note that several parameters had to be converted to metric units for compatibility with the program. In this case, building floor area has been converted from 33,680 square feet to 3,130 square meters. Also note that the loads calculated by the RETScreen software are imprecise and have been used only in estimating the costs associated with the GSHP system. For a more complete and accurate breakdown of system loads, please see **Section 2A.1**.

Site Conditions

| Site Conditions | | Estimate | Notes/Range |
|---------------------|----------------|-------------|--|
| Project name | | AAJHS | See Online Manual |
| Project location | | Altoona, PA | |
| Available land area | m ² | 4,760 | |
| Soil type | - | Light rock | |
| Design heating load | kW | 70.9 | → Complete H&CLC sheet |
| Design cooling load | kW | 209.6 | |

Figure 2-U. Site condition parameters for the RETScreen International software

System Characteristics

| System Characteristics | | Estimate | Notes/Range |
|---|----------------|----------------------|-------------|
| Base Case HVAC System | | | |
| Building has air-conditioning? | yes/no | Yes | |
| Heating fuel type | - | Natural gas | |
| Heating system seasonal efficiency | % | 80% | 55% to 350% |
| Air-conditioner seasonal COP | - | 3.0 | 2.4 to 5.0 |
| Ground Heat Exchanger System | | | |
| System type | - | Vertical closed-loop | |
| Design criteria | - | Cooling | |
| Typical land area required | m ² | 1,051 | |
| Ground heat exchanger layout | - | Standard | |
| Total borehole length | m | 3,621 | |
| Heat Pump System | | | |
| Average heat pump efficiency | - | Standard | |
| Standard cooling COP | - | 3.50 | |
| Standard heating COP | - | 2.80 | |
| Total standard heating capacity | kW | 176.6 | |
| | million Btu/h | 0.603 | |
| Total standard cooling capacity | kW | 201.3 | |
| | ton (cooling) | 57.3 | |
| Supplemental Heating and Heat Rejection System | | | |
| Suggested supplemental heating capacity | kW | 0.0 | |
| | million Btu/h | 0.000 | |
| Suggested supplemental heat rejection | kW | 0.0 | |
| | million Btu/h | 0.000 | |

Figure 2-V. System characteristics for the RETScreen International software

Annual Energy Production

| Annual Energy Production | | Estimate | Notes/Range |
|-------------------------------|-------------|----------|-------------|
| Heating | | | |
| Electricity used | MWh | 66.0 | |
| Supplemental energy delivered | MWh | 0.0 | |
| GSHP heating energy delivered | MWh | 140.7 | |
| | million Btu | 479.9 | |
| Seasonal heating COP | - | 2.1 | 2.0 to 5.0 |
| Cooling | | | |
| Electricity used | MWh | 87.0 | |
| GSHP cooling energy delivered | MWh | 310.6 | |
| | million Btu | 1,059.7 | |
| Seasonal cooling COP | - | 3.6 | 2.0 to 5.5 |
| Seasonal cooling EER | (Btu/h)/W | 12.2 | 7.0 to 19.0 |

Figure 2-W. Annual energy production estimated by RETScreen International. [Complete Cost Analysis sheet](#)

2A.7 Results

With the outputs provided by the *RETScreen International* software, one may begin to assemble a feasibility study: namely, cost and energy consumption figures. While *RETScreen International* provides a detailed breakdown of the associated costs for the GSHP system, many of the parameters are program defaults and are not editable. Therefore many of the cost outputs provided by the program have been altered to more accurately reflect the considerations of this particular project.

Initial costs

Much of the cost for the proposed GSHP system will come from initial costs: preliminary studies, development, engineering fees, equipment costs, system balance, and other miscellaneous costs. Each of these items has been estimated by detailed break-down and is provided in the tables below.

| Table 2-J Estimated Feasibility Study Costs | |
|--|-----------------|
| Site Investigation | \$ 650 |
| Soil/hydrology Assessment | \$ 1,625 |
| Preliminary Design | \$ 1,050 |
| Detailed Cost Estimate | \$ 975 |
| Report Preparation | \$ 1,200 |
| Travel and Accommodation | \$ 0 |
| Feasibility Study Credit | \$ (3,000) |
| Total | \$ 2,500 |

| Table 2-K Estimated Development Costs | |
|--|-----------------|
| Permits and Approvals | \$ 650 |
| Land Survey | \$ 650 |
| Project Financing | \$ 1,260 |
| Project Management | \$ 1,875 |
| Travel and Accommodation | \$ 0 |
| Development Credit | \$ (2,500) |
| Total | \$ 1,935 |

| Table 2-L Estimated Engineering Costs | |
|--|-----------------|
| GSHP System Design | \$ 2,625 |
| Tenders and Contracting | \$ 1,625 |
| Construction Supervision | \$ 1,875 |
| Engineering Credit | \$ (4,500) |
| Total | \$ 1,625 |

| Table 2-M Estimated Equipment Costs | |
|--|-------------------|
| Heat Pumps | \$ 66,442 |
| Circulating Pumps | \$ 2,909 |
| Circulating Fluid | \$ 1,664 |
| Drilling and Grouting | \$ 43,451 |
| Ground HX loop pipes | \$ 18,105 |
| Fittings and Valves | \$ 2,416 |
| ECHS Credit | \$ (20,000) |
| Total | \$ 114,986 |

| Table 2-N Estimated System Balance Costs | |
|---|------------------|
| Supplemental Heating System | \$ 0 |
| Supplemental Heat Rejection | \$ 0 |
| Internal Piping and Insulation | \$ 12,080 |
| Balance of System Credit | \$ (1,000) |
| Total | \$ 11,080 |

| Table 2-O Estimated Miscellaneous Costs | |
|--|------------------|
| Training | \$ 980 |
| Contingencies | \$ 19,946 |
| Total | \$ 20,946 |

Total Estimated Initial Cost

The total estimated initial costs have been itemized and are provided below. The overall total will be used in the overall economic project analysis in **Section 5**.

| Table 2-P Total Estimated Initial Costs | |
|--|-------------------|
| Feasibility Study | \$ 2,500 |
| Development | \$ 1,935 |
| Engineering | \$ 1,625 |
| Equipment | \$ 114,986 |
| System Balance | \$ 11,080 |
| Miscellaneous | \$ 20,946 |
| Total | \$ 153,072 |

Therefore the estimated grand total for initial cost, including feasibility studies, development, engineering, equipment, system balance, and miscellaneous costs, is \$153,072.

Annual Costs

Annual costs estimated by *RETScreen International* include operation and maintenance costs and fuel and electricity costs. Each of these items has been itemized and is provided in tabular form below.

| Table 2-Q Estimated O&M Costs | |
|--|-----------------|
| O&M Labor | \$ 2,500 |
| Travel and Accommodations | \$ (3,500) |
| Contingencies | \$ 6,606 |
| Total | \$ 5,606 |

| Table 2-R Estimated Fuel and Electricity Costs | |
|---|------------------|
| Electricity | \$ 9,182 |
| Incremental Electricity Load | \$ 1,275 |
| | \$ 10,457 |

Total Estimated Annual Cost

The total estimated annual costs have been itemized and are provided below.

| Table 2-S Total Estimated Annual Costs | |
|---|------------------|
| Operation and Maintenance | \$ 5,606 |
| Fuel and Electricity | \$ 10,457 |
| Total | \$ 16,063 |

The estimated grand total for annual cost, including operation and maintenance, and fuel and electricity, is \$16,063. The totals presented here will be used in the overall economic project analysis in **Section 5**.

Total Estimated Annual Energy Consumption

| Table 2-T Total Est. Energy Consumption | |
|--|--------------------|
| Cooling | 87,000 kWh |
| Heating | 66,000 kWh |
| Total | 153,000 kWh |

The estimated grand total for annual energy consumption is 153,000 kWh. This total will be used in the overall economic project analysis in **Section 5**. Note that no natural gas figure is given here because this GSHP system does not consume any.

2B.1 Stage Analysis Summary

Preliminary analysis indicated that the Altoona Area Junior High School auditorium stage would experience a deficiency of outdoor air delivery, given the current HVAC system design. A comparison with ASHRAE Std. 62-1 provisions indicates that the stage is deficient by approximately 1190 CFM of outdoor air as designed. This comparison also confirmed that the band room, a space directly adjacent to the stage, would experience a surplus of 1230 CFM of outdoor air. These spaces are served by two roof-mounted CW/HW air handling units, given the marks AHU C-2 and AHU C-3, respectively. A summary of these findings is provided below in **Table 2-U**.

| Table 2-U Actual and Calculated OA Requirement Comparison | | | | |
|--|--------------|----------------------|--------------------------|-------------------|
| System | Space | Min OA Actual | Min OA Calculated | Difference |
| AHU C-2 | Stage | 200 CFM | 1390 CFM | -1190 CFM |
| AHU C-3 | Band Room | 2305 CFM | 1075 CFM | +1230 CFM |

These findings invite the prospect of improving air quality for the auditorium by diverting outdoor air delivery from the band room to the stage. That is, AHU C-3 would potentially serve multiple zones: the stage and the band room. Successfully doing so would mandate the redesign of duct work in this area of the building and perhaps some minor equipment resizing. This procedure is not explored in this report. Instead, these findings serve as justification for examining acoustic considerations brought on by this proposed air diversion scheme. For more information, please see **Section 4** of this report.

3. Lighting Breadth Study

Among the topics available to explore in a breadth study relevant to this report, lighting seemed a logical choice. More precisely, this is an exploration of the use of daylighting with the use of skylights, and its impact on HVAC considerations. Therefore the design of a daylighting system in the gymnasiums and its impact on the overall project analysis is presented here.

The objective of this study is to further reduce energy consumption by limiting the use of a traditional lighting system. The intent is not to replace the lighting system in the AAJHS gymnasiums, but to use a daylighting system in tandem with the existing design. It is useful to note that in most practical applications, a control system would be implemented when daylighting is utilized, but the design and configuration of such a system is quite sophisticated. While the use of such a control system is considered in the following simulation data, the operational details have been omitted.

3A. Designing and Modeling the System

Like many pieces of engineering software, the program *SkyCalc Skylight Design Assistant*, allows the engineer to form a design by adjusting parameters based on simulated results. The *SkyCalc* program was utilized for both the design and simulation of the daylighting-only system. Several of the following tables and screenshots were taken directly from the program and present a condensed summary of input parameters and simulation outcomes.

Note that climate data utilized by the program is from Albany, NY, the closest geographically available data to Altoona, PA. Target lighting level is set to 30 fc, the standard for gymnasium playing surfaces.

Input Parameters

Gymnasium #1

| | |
|-----------------|------------------------|
| Building | |
| Building type | Class, K-12 9 mo |
| Bldg area | 19,000 ft ² |
| Ceiling height | 35 ft |
| Wall color | Off-white paint |

Figure 3-A. Building inputs for Gymnasium #1 used in the SkyCalc program.

| Building | Default | User Revisions | Design Input |
|--|---------|----------------------|--------------|
| Building width (ft) | 97 | 100 | 100 |
| Building length (ft) | 195 | Change width or area | 190 |
| Wall reflectance | 70% | 60% | 60% |
| Ceiling reflectance | 70% | 70% | 70% |
| Floor reflectance | 20% | 20% | 20% |
| Shelving reflectance | 40% | | 40% |
| Roof U-value (Btu/h•°F•ft ²) | 0.063 | | 0.063 |

Figure 3-B. Additional building inputs for Gymnasium #1 used in the SkyCalc program.

| Electric Lighting | Default | User Revisions | Design Input |
|---|-----------------|----------------|-----------------|
| Lighting setpoint (fc) | 50 | 30 | 30 |
| Task height (ft) | 2.50 | 0.00 | 0.00 |
| Lighting power density (W/ft ²) | 0.73 | 1.10 | 1.10 |
| Fraction lighting uncontrolled | 10% | | 0.10 |
| Lighting schedule | Classroom, K-12 | Default | Classroom, K-12 |
| Room and luminaire depreciation | 80% | | 80% |

Figure 3-C. Electric lighting inputs for Gymnasium #1 used in the SkyCalc program.

Skylights:

Number of skylights

Skylight width ft

Skylight length ft

Max skylight spacing = 52.5 ft (1.5 x ceiling ht)

Skylight Description

Glazing type

Glazing layers

Glazing color

Skylight Well

Light well height feet

Well color

Safety grate or screen Yes, No

Figure 3-D. Selected skylight inputs for Gymnasium #1 used in the SkyCalc program.

Please note that the skylight dimensions and quantities given here are based on review of the simulation results and geometric considerations. At any time, these values may be changed to attain desired simulation results.

Gymnasium #2

Building

Building type

Bldg area ft²

Ceiling height ft

Wall color

Figure 3-E. Building inputs for Gymnasium #2 used in the SkyCalc program.

| Building | Default | User Revisions | Design Input |
|--|---------|----------------------|--------------|
| Building width (ft) | 61 | 74 | 74 |
| Building length (ft) | 122 | Change width or area | 100 |
| Wall reflectance | 70% | 60% | 60% |
| Ceiling reflectance | 70% | 70% | 70% |
| Floor reflectance | 20% | 20% | 20% |
| Shelving reflectance | 40% | | 40% |
| Roof U-value (Btu/h•°F•ft ²) | 0.063 | | 0.063 |

Figure 3-F. Additional building inputs for Gymnasium #2 used in the SkyCalc program.

| Electric Lighting | Default | User Revisions | Design Input |
|---|-----------------|----------------|-----------------|
| Lighting setpoint (fc) | 50 | 30 | 30 |
| Task height (ft) | 2.50 | 0.00 | 0.00 |
| Lighting power density (W/ft ²) | 0.83 | 1.10 | 1.10 |
| Fraction lighting uncontrolled | 10% | | 0.10 |
| Lighting schedule | Classroom, K-12 | Default | Classroom, K-12 |
| Room and luminaire depreciation | 80% | | 80% |

Figure 3-G. Electric lighting inputs for Gymnasium #2 used in the SkyCalc program.

Skylights:

Number of skylights

Skylight width ft

Skylight length ft

Max skylight spacing = 52.5 ft (1.5 x ceiling ht)

Skylight Description

Glazing type

Glazing layers

Glazing color

Skylight Well

Light well height feet

Well color

Safety grate or screen Yes, No

Figure 3-H. Selected skylight inputs for Gymnasium #2 used in the SkyCalc program.

Again, note that the skylight dimensions and quantities given here are based on review of simulation results and geometric considerations.

Simulation Outputs

Gymnasium #1




Figure 3-I. A graphic spread of footcandle values over a one-year period for Gymnasium #1.

Gymnasium #2




Figure 3-J. A graphic spread of footcandle values over a one-year period for Gymnasium #2.

From these results it is apparent that skylights will provide either over-abundance or a deficiency of light. Using the existing lighting system and diffuse bezels over the skylights will solve this problem, without sacrificing the comfort of the occupant.

3B. Results

Space Renderings

To examine the success of an installed daylighting system, it is often useful to utilize a light-rendering program to provide a visualization of the target space. In this instance, the program

AGI was used to make basic renderings of the gymnasiums. The design visualization time and date was set to noon during the winter solstice to provide a worst-case scenario depiction.




Figure 3-K. A winter solstice interior rendering for daylight only in Gymnasium #1 by AGI.




Figure 3-L. A winter solstice interior rendering for daylight only in Gymnasium #2 by AGI.

Estimated Annual Cost and Energy Savings

The final results from the SkyCalc simulation are presented in tabular form below.

| Table 3-A Estimated Annual Energy Savings | |
|--|---------------|
| Gymnasium #1 | |
| Lights (kWh) | 30,911 |
| Gymnasium #2 | |
| Lights (kWh) | 11,778 |
| Total (kWh) | 42,689 |

| Table 3-B Estimated Annual Cost Savings | |
|--|----------------|
| Gymnasium #1 | |
| Lights | \$2,782 |
| Gymnasium #2 | |
| Lights | \$1,060 |
| Total | \$3,842 |

The estimated grand total for annual energy savings is 42,689 kWh. The estimated grand total for annual cost savings is \$3,842. These totals will be used in the overall economic project analysis in **Section 5**.

4. Acoustics Breadth Study

As indicated by the analysis provided in **Section 2B.1**, the Altoona Area Junior High School auditorium would experience a deficiency in outdoor air delivery given the current system design. Given that the system is reworked to address this deficiency, certain acoustical issues are raised, namely, the sound level effects of placing new diffusers in a space where sound attenuation is critical. The objective of this study is to explore the sound level ratings of the current design, the impact of the redesign, and possible improvements to be made to both systems.

4.1 The Current Design

An examination of the design documents for the project indicates that the building's stage is served by a large roof-mounted CW/HW air handling unit (AHU C-2) which distributes air to the space through five 14-inch round diffusers. **Table 4-A**, provided below, summarizes the characteristics of this air flow.

| Neck Size | Air Flow | NC Rating |
|-----------|----------|-----------|
| 14" | 500 CFM | <20 |

Note that the diffuser air flow was obtained directly from the project design documentation. The noise criteria level (NC) was found using a reference chart provided by Krueger HVAC. Please see Schedule B2 in **Appendix B** for more information.

4.2 The Redesign

The proposed redesign would stipulate that at least 1190 CFM of additional air would have to be delivered to the stage space. An examination of the current design in **Section 4.1** indicates that the diffusers serving the stage already deliver 500 CFM, nominally. Pragmatism dictates that two additional diffusers of the same size could deliver 1000 CFM, nominally, without affecting the NC rating or other architectural concerns. This would reduce the stage's outdoor air deficiency to a virtually negligible amount.

4.3 Possible Improvements

Acoustics standards dictate that NC ratings must fall below a certain values to adequately eliminate background noise in performance-critical spaces. This value is generally accepted to be below 20. The characteristics of a typical air diffuser provided in **Table 4-A** indicate that 500 CFM of air flowing through a 14" neck size will result in a noise criteria rating that is below 20. Therefore, diverting outdoor air to the stage area would not result in any major acoustic concerns as long as the diffuser size is kept at 14" or greater. Typically, the larger the diffuser is sized, the lower the background noise will be. Diffusers are typically designed large in performance spaces for this reason.

Please see **Appendix B** for more information on diffuser sizing and noise criteria determination.

5. Project Summary

This section is included to indicate the success of the stated project goals in a concise, organized format. They address both depth study aspects as well as affected breadth studies. The procedures used to obtain the following facts and figures are detailed in the previous sections of this report.

Ground Source Heat Pump System (Mechanical Depth)

The HVAC system featuring seven single-zone CAV DX/gas air handling units that occupy the Altoona Area Junior High School athletic building as originally designed have been redesigned to feature a ground source heat pump (GSHP) system. The GSHP system was considered due to an anticipation of lowered energy consumption and cost. The results of this system redesign are presented below.

The GSHP system has been designed to feature an eight by sixteen (128 bores total) loop field configuration that will occupy a parcel of land currently occupied by Roosevelt Junior High School, a building slated to be demolished and replaced with a soccer field as a part of the AAJHS master plan. The design process was carried out with the aid of a computer program called *GCHPCalc*. The program stipulated that vertical bores for the GSHP system should be drilled to 274 feet below the earth surface. The program also suggested that eleven 12.5-ton and one 6-ton vertical high efficiency water-source heat pumps be selected and integrated into a traditional duct network, much like the one that currently exists as designed.

In order to gage the success of the GSHP system, a first and annual cost simulation was performed using the aid of a program called *RETScreen International*. The results of this simulation are presented below in comparison to the original design values.

| Table 5-A Estimated System First Cost | |
|--|-----------------|
| Original | Redesign |
| \$57,850 | \$153,070 |

| Table 5-B Estimated Annual Energy Consumption | | | |
|--|--------------|-----------------|-------------|
| Original | | Redesign | |
| Electricity | 148,800 kWh | Electricity | 198,620 kWh |
| Natural Gas | 3,190 Therms | Natural Gas | 0 Therms |

| Table 5-C Estimated Annual Energy Costs | | | |
|--|-----------------|-----------------|-----------------|
| Original | | Redesign | |
| Cooling | \$7,420 | Energy | \$10,460 |
| Heating | \$12,970 | | |
| Lights | \$11,620 | Lights | \$7,780 |
| Total | \$32,010 | Total | \$18,240 |

Please note that the reduction in lighting costs can be attributed to the implementation of a daylighting system in the AAJHS gymnasiums. A summary of this breadth study is provided below.

Daylighting System (Lighting Breadth)

The existing lighting system in the AAJHS gymnasiums was not redesigned, but rather enhanced through the use of daylighting in the form of skylights. A program called *SkyCalc* aided in the design and simulation of the system. The program indicated that satisfactory daytime lighting levels could be achieved year-round by utilizing a number of 8x6-ft. triple-glazed polycarbonate skylights. Outcomes indicated that thirty skylights should be used in gymnasium #1, while twelve skylights would be sufficient in gymnasium #2. A program called *AGI* was used to make some simple renderings of the gymnasium spaces, which graphically enhanced the system's effectiveness.

Auditorium Increased Indoor Air Quality (Mechanical Depth)

Noted outdoor air deficiencies in the school's auditorium invited the prospect of correction through the diversion of air delivery from the air handling unit serving the band room. It was determined that an additional 1190 CFM of outdoor air was required to satisfy the provisions of ASHRAE Std. 62.1 – 2004. To correct this problem, the addition of two 500 CFM diffusers to the school stage space was considered. This correction invited the prospect of exploring acoustic considerations as a subsequent breadth study.

Air Diffuser Selection (Acoustics Breadth)

After determining that the proposed diversion of outdoor air to the school's auditorium was feasible, acoustic considerations were explored. An analysis of the existing air diffusers indicated that the noise criteria (NC) rating was adequate given their current 14-inch neck size and nominal air flow of 500 CFM. By diverting an additional 1000 CFM of outdoor air through the space and utilizing the same diffusers already specified in the design, the outdoor air requirement as well as an adequate NC rating has been achieved.

6. Conclusions

This section is provided to summarize the results of the studies conducted for this report and offer conclusions based on these results. As with the project summary in **Section 5**, these conclusions aim to integrate the main depth studies with subsequent breadth studies and present an overall project whose aspects intertwine in a relevant and interesting fashion.

Ground Source Heat Pump System and Gymnasium Daylighting System

This report has verified that the use of a ground source heat pump (GSHP) system has the potential to reduce annual maintenance and operating costs by as much as 57%, at the expense of a higher initial first cost. It was estimated that a GSHP system could cost as much as \$95,000 more than the original design. Also it was determined that annual electricity consumption could increase by as much as 33%, while totally eliminating the need for natural gas usage in the system. Furthermore, while a proposed gymnasium daylighting system utilizing skylights increased the thermal loads for the system redesign, their potential in decreasing electric lighting costs as much as 67% has been demonstrated.

The findings of this report indicate that a GSHP system with integrated daylighting have the theoretical potential to significantly reduce energy costs and consumption. Therefore, this system should be considered as an adequate alternative to the original design.

Auditorium Increased Indoor Air Quality and Air Diffuser Selection

This report has verified the feasibility of diverting outdoor air from a space with a surplus to a space with noted deficiencies. The use of additional air diffusers will not have an adverse effect on background noise if the proper diffuser size is selected. If a diversion of outdoor air to meet the requirements of ASHRAE Std. 62.1 was carried out to improve the original design, it is the finding of this report that the acoustic considerations, while critical, are minimal.

References & Photo Credits

Altoona Area School District
<http://www.aasdcat.com/aasd/>

ANSI/ASA Std. 12.60 – 2002

ASHRAE Std. 62.1 – 2004

Ground Source Heat Pump Design
<http://www.geokiss.com/>

International Ground Source Heat Pump Association
<http://www.igshpa.okstate.edu/>

Krueger – Excellence in Air Distribution
<http://www.krueger-hvac.com/>

Performance Engineering Group
<http://www.performanceengineering.com/>

RETScreen International
<http://www.retscreen.net/ang/home.php>

Trane Commercial & Residential Air Solutions
<http://www.trane.com/Default.asp>

US Department of Energy
<http://www.energy.gov/>

Appendix A

Useful Schedules and Figures

Schedule A1. Natural Gas Rate Tariffs

| | | | | | | | | | | | | | | | | | | | | | | |
|--|--|---|---------|--|--|---------|--|--|----------|--|--|----------|--|--|----------|-----|---|----------|-----|--|-----------|-----|
| <p>THE PEOPLES NATURAL GAS COMPANY d/b/a DOMINION PEOPLES</p> | <p>SUPPLEMENT NO. 93 TO GAS PA—PUC NO. 43 FIFTIETH REVISED PAGE NO. 39 CANCELING FORTY-NINTH REVISED PAGE NO. 39</p> | | | | | | | | | | | | | | | | | | | | | |
| <p>RATE CS-L COMMERCIAL SERVICE - LARGE</p> | | | | | | | | | | | | | | | | | | | | | | |
| <p><u>AVAILABILITY</u></p> <p>This rate is available to commercial ratepayers consuming 1,000 Mcf or greater annually (other than those that the Company determines shall acquire service under Rate GS-SB or those that use natural gas as a motor vehicle fuel), located throughout the territory described in the "Description of Territory" in this tariff, and shall be applied to consumption for each month determined in accordance with Rule 10.</p> <p>The Company shall determine the annual consumption of each CS-L ratepayer in order to assess the appropriate customer charge. This rate will be used for provision of supplier of last resort service to commercial ratepayers.</p> | | | | | | | | | | | | | | | | | | | | | | |
| <p><u>RATE TABLE</u></p> <p><u>Customer Charge per meter per month:</u></p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 80%;">For ratepayers with annual consumption equal to or greater than 1,000 Mcf but less than 2,500 Mcf</td> <td style="width: 10%; text-align: right;">\$34.20</td> <td style="width: 10%;"></td> </tr> <tr> <td>For ratepayers with annual consumption equal to or greater than 2,500 Mcf but less than 25,000 Mcf</td> <td style="text-align: right;">\$52.25</td> <td></td> </tr> <tr> <td>For ratepayers with annual consumption equal to or greater than 25,000 Mcf</td> <td style="text-align: right;">\$332.50</td> <td></td> </tr> </table> <p><u>Delivery Charges:</u></p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 80%;">Delivery Charge per 1,000 cubic feet (Mcf)</td> <td style="width: 10%; text-align: right;">\$1.9506</td> <td style="width: 10%;"></td> </tr> <tr> <td>Capacity Charge per 1,000 cubic feet (Mcf)</td> <td style="text-align: right;">\$0.5236</td> <td style="text-align: right;">(D)</td> </tr> <tr> <td>Gas Cost Adjustment Charge per 1,000 cubic feet (Mcf)</td> <td style="text-align: right;">\$1.6971</td> <td style="text-align: right;">(I)</td> </tr> </table> <p><u>Commodity Charge:</u></p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 80%;">Natural Gas Supply Charge per 1,000 cubic feet (Mcf)</td> <td style="width: 10%; text-align: right;">\$10.2183</td> <td style="width: 10%; text-align: right;">(I)</td> </tr> </table> | | For ratepayers with annual consumption equal to or greater than 1,000 Mcf but less than 2,500 Mcf | \$34.20 | | For ratepayers with annual consumption equal to or greater than 2,500 Mcf but less than 25,000 Mcf | \$52.25 | | For ratepayers with annual consumption equal to or greater than 25,000 Mcf | \$332.50 | | Delivery Charge per 1,000 cubic feet (Mcf) | \$1.9506 | | Capacity Charge per 1,000 cubic feet (Mcf) | \$0.5236 | (D) | Gas Cost Adjustment Charge per 1,000 cubic feet (Mcf) | \$1.6971 | (I) | Natural Gas Supply Charge per 1,000 cubic feet (Mcf) | \$10.2183 | (I) |
| For ratepayers with annual consumption equal to or greater than 1,000 Mcf but less than 2,500 Mcf | \$34.20 | | | | | | | | | | | | | | | | | | | | | |
| For ratepayers with annual consumption equal to or greater than 2,500 Mcf but less than 25,000 Mcf | \$52.25 | | | | | | | | | | | | | | | | | | | | | |
| For ratepayers with annual consumption equal to or greater than 25,000 Mcf | \$332.50 | | | | | | | | | | | | | | | | | | | | | |
| Delivery Charge per 1,000 cubic feet (Mcf) | \$1.9506 | | | | | | | | | | | | | | | | | | | | | |
| Capacity Charge per 1,000 cubic feet (Mcf) | \$0.5236 | (D) | | | | | | | | | | | | | | | | | | | | |
| Gas Cost Adjustment Charge per 1,000 cubic feet (Mcf) | \$1.6971 | (I) | | | | | | | | | | | | | | | | | | | | |
| Natural Gas Supply Charge per 1,000 cubic feet (Mcf) | \$10.2183 | (I) | | | | | | | | | | | | | | | | | | | | |
| <p><u>MARKET BASED COMMODITY CHARGE ADJUSTMENT (CCA)</u></p> <p>This adjustment will be applicable to Non-Priority One ratepayers that previously had been receiving transportation service from the Company for at least twelve consecutive months and transfers to service under this rate schedule. Once applied, the CCA will be applicable for twelve consecutive months of service under this rate schedule. The Gas Cost Adjustment Charge shall not be applicable if the CCA is being charged.</p> <p>The CCA shall be determined monthly and shall equal the difference between the Company's city gate price and the currently effective commodity charge under this rate schedule. The CCA shall never be less than zero. The Company's city gate price shall be based on the first of the month Dominion Transmission Inc. Appalachia Index price as published in Inside FERC's Gas Market Report plus applicable Dominion Transmission, Inc. transportation charges and retainerage.</p> | | | | | | | | | | | | | | | | | | | | | | |
| <p><u>MINIMUM MONTHLY BILL</u></p> <p>The minimum monthly bill per meter shall be the customer charge per ratepayer per month. In the event of an emergency curtailment in the delivery of gas by the Company to a ratepayer pursuant to Rule 17, or complete or partial suspension of operation by the ratepayer due to fire, flood, explosion, or other similar acts of God, the minimum monthly bill may be reduced in direct proportion to the ratio of the number of days of curtailed service or complete or substantial suspension of operation to the number of days in the billing period.</p> | | | | | | | | | | | | | | | | | | | | | | |
| <p>ISSUED: March 31, 2008 EFFECTIVE: April 1, 2008</p> | | | | | | | | | | | | | | | | | | | | | | |

Schedule A1. Natural Gas Rate Tariffs (continued)

| | |
|---|---|
| THE PEOPLES NATURAL GAS COMPANY | GAS PA—PUC NO. 43 ORIGINAL PAGE NO. 40 |
| RATE C8-L COMMERCIAL SERVICE - LARGE | |
| <u>SURCHARGES</u> | |
| All applicable riders to this tariff. | |
| <u>LATE-PAYMENT CHARGE</u> | |
| A late-payment charge of 1.50 percent per month shall be applied for failure to make payment in full for all charges billed by the Company by the due date shown on the bill. This charge is to be calculated on the overdue portion of the bill, excluding any unpaid late-payment charges. | |
| <u>RULES AND REGULATIONS</u> | |
| The Company's Rules and Regulations in effect from time to time, where not inconsistent with any specific provision hereof, are a part of this rate schedule. | |
| <u>WAIVER</u> | |
| The Company reserves the right to waive the ratepayer customer charge per meter for additional meters. An example of when this charge may be waived is if the Company determines that such meters have been installed principally and primarily for the Company's convenience and not due to the load characteristics of the ratepayer. | |
| ISSUED: March 2, 2000 | EFFECTIVE: March 3, 2000 |

Schedule A2. Electricity Rate Tariffs

PENNSYLVANIA ELECTRIC COMPANY

Electric Pa. P.U.C. No. 79

Original Page 100

RATE SCHEDULES

RATE GS-LARGE

GENERAL SERVICE SECONDARY - TIME-OF-DAY RATE

AVAILABILITY:

This Rate is available to Full Service and Delivery Service Customers using electric service through a single delivery location for lighting, heating and/or power service whose registered demand is equal to or greater than 400 KW in two (2) consecutive months and Off-peak Thermal Storage Customers whose registered demand is equal to or greater than 100 KW in two (2) consecutive months. THE OFF-PEAK THERMAL STORAGE PROVISION SHALL BE RESTRICTED TO EXISTING CUSTOMERS AT EXISTING LOCATIONS AS OF JANUARY 11, 2007. Secondary voltage shall be supplied to Customers at a single transformer location when load does not require transformer capacity in excess of 2,500 KVA. Upon a Customer's request, the Company may, at its option, provide transformers having a capacity of greater than 2,500 KVA.

New Customers requiring transformer capacity in excess 2,500 KVA and existing Customers whose load increases such that a transformer change is required (over 2,500 KVA) shall be required to take untransformed service.

All of the following charges are applicable to Full Service Customers. All of the following charges, excluding the Generation Charge and the Transmission Charge, are applicable to Delivery Service Customers.

GENERAL MONTHLY CHARGES:

Distribution Charge

\$41.29 per month, plus
 \$4.70 per kW for all billed kW
 \$0.254 per KVAR

Competitive Transition Charge

\$1.75 per kW for all billed kW

Issued: January 17, 2007

Effective: January 11, 2007

Schedule A2. *Electricity Rate Tariffs (continued)*

PENNSYLVANIA ELECTRIC COMPANY

Electric Pa. P.U.C. No. 79
Original Page 101

RATE SCHEDULES

Rate GS-Large (continued)

Generation Charge

4.827 cents per kWh for all kWh

Transmission Service Charge (Per Rider D – Transmission Service Charge Rider)

0.616 cents per kWh for all kWh (January 11, 2007 through May 31, 2008)

From June 1, 2008 forward, the Company will provide and charge for Transmission Service to Customers taking Full-Service in accordance with the provisions of Rider D - Transmission Service Charge Rider, which charge shall apply to all kWh billed under this Rate Schedule.

Issued: January 17, 2007

Effective: January 11, 2007

Schedule A2. Electricity Rate Tariffs (continued)

PENNSYLVANIA ELECTRIC COMPANY

Electric Pa. P.U.C. No. 79
Original Page 102

RATE SCHEDULES

Rate GS-Large (continued)

DETERMINATION OF BILLING DEMAND:

The monthly billing demand shall be the higher of:

1. The maximum 15-minute integrated demand registered during the On-peak hours during the month.
2. Forty percent (40%) of the maximum 15-minute integrated demand registering at any time during the month.

KVAR DEMAND

The monthly reactive billing demand shall be the maximum 15-minute integrated reactive demand registered at any time during the month.

The On-peak hours shall be from 8:00 a.m. to 8:00 p.m., prevailing time, Monday through Friday excluding holidays. All other hours shall be Off-peak. The Off-peak holidays are: New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day and Christmas Day. On-peak hours are subject to change from time to time by the Company after giving notice of such changes to Customers.

MINIMUM CHARGE:

No bill shall be rendered by the Company for less than,

\$41.29 per month, plus

one-half (1/2) of the demand charge at current rate levels for the highest kilowatt demand billed during the current and preceding eleven (11) months.

Issued: January 17, 2007

Effective: January 11, 2007

Schedule A2. Electricity Rate Tariffs (continued)

PENNSYLVANIA ELECTRIC COMPANY

Electric Pa. P.U.C. No. 79
Original Page 103

RATE SCHEDULES

Rate GS-Large (continued)

PAYMENT TERMS:

As per Rule 13, Payment of Bills.

TERM OF CONTRACT:

Each Customer shall be required to enter into a service/supply contract with the Company for a minimum one (1) year term. The supply portion of the contract ("supply contract") applies to Generation Supply and is suspended when a Customer takes Delivery Service only and resumes with a new anniversary date when a Customer returns to Full Service. If the service/supply contract is terminated by the Customer prior to its expiration, the Minimum Charge provisions of this Rate Schedule shall apply. If the Customer's capacity or service requirements increase, the Company, in its sole and exclusive judgment, may at any time require the Customer to enter into a new service/supply contract.

GENERAL PROVISIONS:

- A. **COMBINED BILLING:** This Provision is restricted as of June 18, 1976, to existing loads at existing locations. Combined Billing shall be permitted for three-phase multi-metered points at secondary voltages established prior to June 18, 1976. The billing demand shall be the sum of the individual demands of each metered service. Customer locations and loads may not continue to be billed under this General Provision A: (i) if the Customer increases the capacity of either service entrance wiring, or (ii) the Customer increases the electrical load in the facility necessitating a change in the Company's facilities.

Issued: January 17, 2007

Effective: January 11, 2007

Schedule A2. Electricity Rate Tariffs (continued)

PENNSYLVANIA ELECTRIC COMPANY

Electric Pa. P.U.C. No. 79

Original Page 104

RATE SCHEDULES

Rate GS-Large (continued)

- B. **SERVICE AT PRIMARY VOLTAGE:** Customers served at Primary Voltage may be billed under this Rate GS-Large, at the Company's sole and exclusive discretion, when a Customer requires Primary Service at a voltage less than the nearest available Primary Voltage, if the Company agrees to provide the Primary Voltage requested by the Customer.
- C. **OFF-PEAK THERMAL STORAGE SERVICE: THIS PROVISION SHALL BE RESTRICTED TO EXISTING CUSTOMERS AT EXISTING LOCATIONS AS OF JANUARY 11, 2007 NO CUSTOMERS WILL BE PERMITTED TO TAKE SERVICE UNDER THIS PROVISION AFTER JANUARY 11, 2007.** Available to Customers whose primary heating and/or cooling system is electric thermal storage. Electric thermal storage systems are those heating and cooling systems where the space conditioning of a building is provided by a system that uses energy primarily during Off-peak periods. On-peak hours for demand and energy billing shall be from 8:00 a.m. to 6:00 p.m., prevailing time, Monday through Friday during the billing months of October through May and 10:00 a.m. to 8:00 p.m., prevailing time, Monday through Friday during the billing months of June through September. All other hours shall be Off-peak.
- D. **MARKET BASED BILLING:** All billing under the Standard Pricing Adjustment ("SPA") shall be in accordance with Rider L.


RIDERS:

Bills rendered by the Company under this Rate Schedule shall include the charges stated in or calculated by any applicable Rider.

Issued: January 17, 2007

Effective: January 11, 2007

Figure A1. USGS Ground Water Temperature Map



Appendix B

Equipment Literature

Schedule B1. Trane WSHP Cut Sheets



High Efficiency Horizontal/Vertical Water-Source Heat Pump

Models GEHB/GEVB

6 to 25 Tons - 60 Hz

12 1/2 - 25 Tons



6-15 Tons



6 - 10 Tons



April 2006

WSHP-PRC014-EN

Schedule B1. Trane WSHP Cut Sheets (continued)



Introduction


Feature Highlights

The 6 through 25 ton horizontal and vertical water-source heat pump is used in a broad range of applications. Schools, office buildings, health care/rehabilitation facilities, condominiums and retirement facilities are just a few of the types of buildings utilizing the energy conscious water-source design.

Model GEH (pictured below) is a ceiling hung product that provides a serviceability to maintenance components; indoor air quality standards; sound attenuation; and best of all, higher efficiencies rated in accordance to ARI-ISO 13256-1 performance and ASHRAE 90.1 standards.

Trane's new design incorporates system advantages such as:

1. Maximum return-air and supply-air flexibility
2. Superior maintenance accessibility
3. Dual-sloped, plastic drain pan
4. Multiple fan speed motor packages
5. Quiet unit design
6. Integrated controls
7. Dual circuit design
8. High and low pressure safeties as standard
9. Dehumidification option
10. Waterside economizing option
11. Supplemental electric heat option



Schedule B1. Trane WSHP Cut Sheets (continued)



Features and Benefits

Cabinet Description

The cabinet design incorporates sturdy (non painted) galvanized metal form maximum durability and corrosive resistive exterior. The equipment offers superior installation flexibility with service accessibility.

The cabinet front allows service access for the controls. The new horizontal and vertical design offers four product variations of return-air and supply-air combinations. All combinations are order specific and may not be modified at the job site. See Figure 1 for air side combinations.

Hanging the horizontal configuration is accomplished through the robust metal stiffeners located beneath the unit. Optional vibration isolators are available to help decrease sound vibration during equipment operation.

Airflow Combinations

The 6 through 15-ton horizontal's airflow flexibility includes the following combinations to aid in applications where the equipment is required to hug a corridor or wall.

The four configurations are:

1. Left return-air with back supply-air combination
2. Left return-air with right supply-air combination
3. Right return-air with back supply-air combination
4. Right return-air with left supply-air combination

The sleek, narrow cabinet of the 6 to 25-ton vertical is designed to fit through a standard 36" doorway for installation during new or retrofit construction. The equipment is available in four supply-air/return-air combinations. These combinations are order specific via the unit model number.

The four combinations include:

1. Front return-air with back supply-air combination
2. Front return-air with top supply-air combination
3. Back return-air with front supply-air combination
4. Back return-air with top supply-air combination




Figure 1. GEH Airflow Options




Figure 2. GEV Airflow Options

Schedule B1. Trane WSHP Cut Sheets (continued)



Features and Benefits




Figure 3. GEV Panel Design



Figure 4. Plastic Drain Pan



Figure 5. Reciprocating Compr.



Figure 6. Co-axial Heat Exchanger

Access Panels

The upper panels of the 12 1/2 through 25-ton verticals feature a key hole hanging design for ease of maintenance of the unit, allowing the panel to be hooked into place when attaching the panel to the unit. The panels are also sealed with a rubber gasket at all four edges to help eliminate air from escaping around the panel's edge. See *Figure 3* for GEV panel design.

Hanging Device

The hanging channel for the horizontal unit runs the length of the equipment. The structural integrity of the design helps assure no bracket deflection or unit bowing from the unit's weight.

Optional isolation for the hanging bracket is provided with a rubber grommet design. This isolation device helps prevent sound vibration from reaching the structural support members of the building during compressor start and stop.

Drain Pan

The unit drain pan is composed of plastic, corrosive resistive material. The pan is positively sloped to comply with ASHRAE 62 for (IAQ) indoor air quality conformity.

Access to the drain pan is provided through two access panels for cleaning purposes for all models. See *Figure 3* for plastic drain pan.

Cabinet Insulation

The cabinet insulation design meets UL 181 requirements. The air stream surface of the insulation is fabricated of a non-biodegradable source.

Refrigeration Piping

The unit's copper tubing is created from a 99% pure copper formation that conforms to the American Society of Testing (ASTM) B743 for seamless, light-annealed processing.

The unit's copper refrigeration system is designed to be free from contaminants and conditions such as drilling fragments, dirt, or oil. This excludes the possibility of these contaminants from damaging the compressor motor.

Compressor

Dual circuit designs of the GEH and GEV models feature reciprocating compressors in the 6 and 7 1/2 ton sizes, while the 10 through 25 ton units include scroll compressors. The compressors are highly efficient, and incorporate external vibration isolators and thermal overload protection. See *Figure 5* for reciprocating compressor.

Co-axial Water-to-Refrigerant Coil

The unit's internal heat exchanging water coil is engineered for maximum heat transfer.

The copper or cupro-nickel seamless tubing is a tube within a tube design. The inner-water tube contains a deep fluted curve to enhance heat transfer and minimize fouling and scaling. It is available in either copper or cupro-nickel (selectable option) coil. The outer refrigerant gas tube is made from steel material. The coil is leak tested to assure there is no cross leakage between the water tube and the refrigerant gas (steel tube) coil. *Co-axial heat exchangers are more tolerant to freeze rupture.* See *Figure 6* for co-axial water coil.

Schedule B1. Trane WSHP Cut Sheets (continued)



Features and Benefits

Water Connections

Water hookups for the 6 through 25 ton units are located internal to the equipment to help alleviate damage to the water copper during shipment or job storage of units prior to installation. Each unit (although dual circuit) contains a single supply and return water connection. See *Figure 7* for large tonnage water hook-up, model GEV. Fittings for the supply and return are internally threaded.

Expansion Valve

The refrigerant flow metering is made through the thermal expansion valve (TXV). It allows the unit to operate with an entering fluid temperature from 25 F to 110 F, and entering air temperatures from 40 F to 90 F. The valve is designed to meter refrigerant flow through the circuitry to achieve desired heating or cooling.

Unlike cap-tube assemblies, the expansion valve device allows the exact amount of refrigerant required to meet the coil load demands. This precise metering by the TXV increases the efficiency of the unit. See *Figure 15* for thermal expansion valve.

Reversing Valve

A system reversing valve (4-way valve) is included with all heating/cooling units. This valve is piped to be energized in the cooling mode to allow the system to provide heat if valve failure were to occur. Once the valve is energized for cooling, it will remain energized until the control system is turned to the OFF position, or a heating cycle is initiated.

Units with the cooling only option will not receive a reversing valve. See *Figure 9* for reversing valve.

Blower Motor

A belt driven motor selection powers the fan for the 6 through 25 ton dual circuit units. The 6 through 15 ton units include a single fan assembly, while the 20 and 25-ton units include dual fan assemblies. Because the motor sheave and the motor base are adjustable in the field, a greater variation in external static pressures are available. The large tonnage units are capable of providing 0 ESP to 3.0

ESP allowing a higher static ductwork to be applied on the mechanical system when the application requires extensive ductwork design. This is a low cost alternative to purchasing, installing, and maintaining multiple smaller tonnage units to meet the required air flow demand for the space.

Access to the 6 through 25 ton units is made through the back of unit by way of two panels, and/or through a side access panel if adjustment to the motor belt or motor base are needed. See *Figure 10* for motor accessibility.

Blower Housing

The blower housing is constructed of non-corrosive galvanized steel. It is a double wide/double inlet, forward curved wheel moved by an integral horsepower motor with sealed bearings.

Air-Side Filter

The air-side filter incorporates a 1-inch thick (nominal) or 2-inch thick (nominal) disposable fiberglass option. These filters include an average synthetic dust weight arrestance of approximately 75%. This dust holding capability includes a colorless, odorless adhesive to retain dirt particles within the filter media after fiber contact.




Figure 7. GEV Water Connections



Figure 8. Thermal Expansion Valve



Figure 9. Reversing Valve




Figure 10. Belt Driven Motor (GEH)

Schedule B1. Trane WSHP Cut Sheets (continued)



Features and Benefits

Boilerless Control/Electric Heat

Boilerless Control/Electric Heat (option)

In cooling dominant regions where heat may be used 15 to 30 days out of the winter season, eliminating the boiler may be an economical advantage to the building owner. Eliminating a boiler from the system reduces costs associated with the mechanical system installation, as well as the maintenance and service of the boiler.

How can heat be provided for the few days of the year when heat is necessary? Through the water-source heat pump of course. The advantage of the water-source heat pump is its ability to provide heat recovery within the closed water-loop. While some WSHPs may be extracting heat from the closed water loop, other WSHPs may be adding heat to the closed water loop. This creates a perfect system balance for heat sharing or movement from one space to another.

But when water temperatures fall in a boilerless system, and no further heat recovery may be made via the closed loop, heat may be added to the space through a boilerless control electric heat option. See Figure 11 for the boilerless control electric heat system diagram.

With the boilerless electric heat option, the 6 through 25-ton models will contain boilerless controls ONLY to interface for a field provided supplemental electric heat selection. The heater for this model shall be placed external to the equipment by the contractor for ease of installation. All power connections for the electric heater will be completely separate from the unit for field supplied electric heat.

How it Works

In heating mode, when the water temperature falls below 55 F (factory setting), the electric heater is energized, locking out the compressor. The systems electric heat source will continue to be utilized for primary heating until the loop temperature rises above 60 F. Once the entering water temperature rises above 60 F, the boilerless controller returns the unit to normal compressor heating operation and locks out the electric heater. This maximizes efficiency from the unit during the few days requiring heat from the mechanical system.

If the unit employs a cooling only unit design, the electric heat contactor is wired directly to the thermostat for primary heating, and the compressor contactor for cooling.

Note: For geothermal applications, the boilerless controller has an adjustable setting of 25, 35, 45, 55 and 60 degrees.

What is NOT available with the boilerless electric heat option?

1. Hot gas reheat
2. Basic 24 volt controls
3. Tracer™ ZN510 controls
4. 115 and 575 volt ratings
5. Supplemental or emergency heat applications
6. A factory installed heater




Figure 11. Electric Heat System

Schedule B1. Trane WSHP Cut Sheets (continued)



Features and Benefits

Waterside Economizer (option)

The beauty of the waterside economizer is its ability to take advantage of any loop condition that results in cool water temperatures. A prime example would be during fall, winter and spring when cooling towers have more capacity than required and could be controlled to lower temperatures for economizer support.

Another more common inexpensive means of free comfort cooling includes buildings systems where perimeter heating and core cooling are needed. In this system, the perimeter units extract heat from the building loop while in the heating mode, forcing the building loop temperature to drop. Where as, the core are of a building may require cooling in summer or in winter based upon lighting, people and equipment.

If the water-source system design contained an economizing coil option, the moderate temperature loop water circulated through a core water-source system can provide an inexpensive means to satisfy room comfort without operating the water-source heat pump's compressor.

During economizer mode, fluid enters the unit, and passes by a water temperature sensing bulb. This temperature sensing bulb determines whether the two position, three-way valve will direct the water through the waterside economizing coil, and to the heat pump condenser, or through the condenser only. If the water temperature is 55 F or less, fluid will flow into the economizing coil, while simultaneously halting mechanical operation of the compressor. Mechanical cooling will continue on a call for second stage from the thermostat.

The factory built waterside economizer is available on all 6 to 15 ton GEH models and 6 to 25 GEV models.

Note: The condensate overflow option is not available with the waterside economizer option.

Hot Gas Reheat (option)

For space conditioning and climate control, Trane provides an accurate and cost effective dehumidification control through a hot gas reheat option. This option is designed to accommodate unit sizes 072 through 240.

With this reheat option, the return air from the space is conditioned by the air-to-refrigerant coil, then reheated by the reheat coil to control not only the space temperature, but to also reduce the relative humidity of the space. The moisture removal capability of a specific heat pump is determined by the units latent capacity rating.

When operating in the reheat mode (meaning the sensible temperature has been met in the space), the humidistat signals the reheat relay coil to energize, allowing the high pressure refrigerant gas to flow from the compressor, through the reheat valve, into the reversing valve, or through the reheat coil for dehumidification.

Note: Trane places an air separation space between the air-to-refrigerant coil, and the reheat coil to allow for maximum moisture removal.

Common Reheat Applications

The hot gas reheat option is designed to support building applications requiring fresh-air ventilation units delivering unconditioned-air directly to the space. It also provides dehumidification to large latent load spaces such as auditoriums, theaters and classrooms, or anywhere humidity control is a problem.

Do's and Don'ts in Design

The factory installed hot gas reheat option is only available with Deluxe or ZN524 controls packages.

The water-source heat pumps with hot gas reheat should not be used as a make-up air unit.




Figure 12. Waterside Economizer System

Schedule B1. Trane WSHP Cut Sheets (continued)



Selection Procedure

The performance standard ARISO 13256-1 became effective Jan. 1, 2000. It replaces ARI standards 320, 325 and 330. This new standard has three major categories: Water Loop (ARI 320), Ground Water (ARI 325), Ground Loop (ARI 330). Although these standards are similar there are some differences.

The cooling efficiency is measured in EER but includes a Watt-per-Watt unit of measure similar to the traditional COP measurement.

The entering water temperature has changed to reflect the centigrade temperature scale. For instance the water loop heating test is performed with 68-degree F (20-degree C) water instead of 70-degree F. The cooling tests are performed with 80.6-degree F (27-degree C) dry bulb and 66.2-degree F (19-degree C) wet bulb entering air instead of the traditional 80-degree F dry bulb, and 67-degree F wet bulb entering air temperatures. This data (80.6/66.2) may be converted to 80/67 by using the entering air correction table.

A pump power correction has been added onto the existing power consumption. Within each model, only one water flow rate is specified for each performance category, and pumping watts are calculated utilizing the pump power correction formula: $(\text{gpm} \times 0.0631) \times \text{press drop} \times 2990 / 300$.

Note: *GPM relates to water flow, and press drop relates to the drop through the unit heat exchanger at rated water flow in feet of head. The fan power is corrected to zero external static pressure. The nominal airflow is rated at a specific external static pressure. This effectively reduces the power consumption of the unit, and increases cooling capacity but decreases heating capacity. These watts are significant enough in most cases to increase EER and COP over ARI 320, 325, and 330 ratings.*

Cooling Dominated Applications

If humidity levels are moderate to high in a cooling dominated application, the heat pump should be selected to meet or exceed the calculated sensible load. Also, the unit's sensible capacity should be no more than 115% of the total cooling load (sensible + latent), unless the calculated latent load is less than the latent capacity of the unit.

The sensible-to-total cooling ratio can be adjusted with airflow. If the airflow is lowered, the unit latent capacity will increase. When less air is pulled across the DX coil, more moisture will condense from the air.

Heating Dominated Applications

Unit sizing in heating dominated applications is based upon humidity levels for the climate, and goals for operating cost and installation costs.

If humidity levels are moderate, the heat pump should be selected with the heating capacity equal to 125% of the cooling load.

If humidity levels are low in the application and low operating cost is important, the heat pump and ground loop should be sized for 90% to 100% of the heating load.

If humidity levels are low and lower initial cost is important, then the heat pump and ground loop should be sized for 70% to 85% of the heating load, with the remaining load to be treated with electric resistance heat.

Installation cost will be reduced in this approach because of the smaller heat pump selection and less loop materials.

In general, the system will not use enough electric heat to offset the higher installation costs associated with a fully sized or oversized system.

Finally, a unit sized for the entire heating load in a heating dominated application will be oversized in cooling. Comfort is reduced from increased room humidity caused by short-run times. Short cycling will also shorten the life expectancy of

the equipment and increase power consumption and operating cost.

Many rebate incentives require the heat pump and ground loop to be sized for the entire heating load. Check with you local utility for their requirements.

Selection Program

All WSHP products should be selected through the Trane Official Product Selection System, **TOPSS**.




If this program has not been made available, ask a local Trane sales engineer to supply the desired selections or provide a copy of the program.

Required Fields

The first step in the selection is to determine either:

- Total cooling capacity
- Sensible capacity
- Heating capacity

The maximum allowable water pressure drop and selection ranges can also be identified.



Schedule B1. Trane WSHP Cut Sheets (continued)



Selection Procedure

Model Number

GEHB07211D0AB0DLD010N00110001000000

5
10
15
20
25
30

DIGITS 1-3: UNIT CONFIGURATION

GEH = High Efficiency Horizontal
 GEV = High Efficiency Vertical

DIGIT 4: DEVELOPMENT SEQUENCE B

DIGITS 5-7: NOMINAL CAPACITY

072 = 6 Ton
 090 = 7 1/2 Ton
 120 = 10 Ton
 150 = 12 1/2 Ton
 180 = 15 Ton
 240 = 20 Ton
 300 = 25 Ton

DIGIT 8: VOLTAGE (Volts/Hz/Phase)

1 = 208/60/1 6 = 220-240/50/1
 2 = 230/60/1 7 = 265/60/1
 3 = 208/60/3 8 = 230/60/3
 4 = 460/60/3 9 = 380-415/50/3
 5 = 575/60/3

DIGITS 9: HEAT EXCHANGER

1 = Copper-Water Coil
 2 = Cupro-Nickel Water Coil

DIGITS 10: CURRENT DESIGN SEQUENCE

DIGITS 11: REFRIGERATION CIRCUIT

0 = Heating and Cooling Circuit
 2 = Heating and Cooling Circuit with Hot Gas Reheat
 3 = Heating and Cooling Circuit with Waterside Economizer
 4 = Heating and Cooling Circuit with HGR and WSE
 A = Cooling ONLY Circuit
 C = Cooling ONLY Circuit with Hot Gas Reheat
 D = Cooling ONLY Circuit with Waterside Economizer
 E = Cooling ONLY Circuit with HGR and WSE

DIGITS 12: BLOWER CONFIGURATION

A = Drive Package A (GEH/GEV)
 B = Drive Package B (GEH/GEV)
 C = Drive Package C (GEH/GEV)
 D = Drive Package D (GEH/GEV)
 E = Drive Package E (GEH/GEV)
 F = Drive Package F (GEH/GEV)
 G = Drive Package G (GEH/GEV)
 H = Drive Package H (GEH/GEV)
 J = Drive Package J (GEV)

DIGIT 13: FREEZE PROTECTION

A = 20 Degree F Freezestat
 B = 35 Degree F Freezestat

DIGIT 14: OPEN DIGIT = 0

DIGIT 15: SUPPLY-AIR ARRANGEMENT

B = Back Supply-Air Arrangement
 F = Front Supply-Air Arrangement
 L = Left Supply-Air Arrangement
 R = Right Supply-Air Arrangement
 T = Top Supply-Air Arrangement

DIGIT 16: RETURN-AIR ARRANGEMENT

B = Back Return-Air Arrangement
 F = Front Return-Air Arrangement
 L = Left Return-Air Arrangement
 R = Right Return-Air Arrangement

DIGIT 17: CONTROL TYPES

D = Deluxe 24 V Controls
 C = Tracer ZN510 Controls
 B = Tracer ZN524 Controls

DIGITS 18: TSTAT/SENSOR LOCATION

0 = Wall Mounted Location

DIGITS 19: FAULT SENSORS

0 = No Fault Sensor
 1 = Condensate Overflow Sensor
 2 = Filter Maintenance Timer
 3 = Condensate Overflow and Filter Maintenance Timer
 4 = Fan Status Sensor
 6 = Condensate Overflow and Fan Status
 H = Fan Status and Filter Maintenance Timer
 J = Fan Status, Filter Maintenance Timer and Condensate Overflow Sensor

DIGITS 20: TEMPERATURE SENSOR

0 = No Additional Temperature Sensor
 1 = Entering Water Sensor

DIGITS 21: NIGHT SETBACK CONTROL

0 = No Night Setback Relay
 N = Night Setback Relay

DIGITS 22: ELECTRIC HEAT

0 = No Electric Heat
 4 = External Boilerless Electric Heat
 5 = External Supplemental Electric Heat

Schedule B1. Trane WSHP Cut Sheets (continued)



Selection Procedure

Model Number - Continued

**DIGITS 23: UNIT MOUNTED
DISCONNECT**

0 = No Unit Mounted Disconnect

DIGITS 24: FILTER TYPE

1 = 1" Throwaway Filter

2 = 2" Throwaway Filter

**DIGITS 25: ACOUSTIC
ARRANGEMENT**

0 = Enhanced Sound Attenuation

1 = Deluxe Sound Attenuation

**DIGITS 26: FACTORY
CONFIGURATION**

0 = Standard Factory Configuration

DIGITS 27: PAINT COLOR

0 = No Paint Selection Available

DIGITS 28: OUTSIDE AIR

0 = No Outside Air Option Available

**DIGITS 29: PIPING
ARRANGEMENT**

0 = Standard Piping Arrangement

**DIGITS 30-36: DOES NOT APPLY TO
GEH or GEV**

0000000 = Digits 30-36 are not applicable to the GEH or GEV products

Schedule B1. Trane WSHP Cut Sheets (continued)



General Data

Table 1. General Unit Information

| Model GEH | | 072 | 090 | 120 | 150 | 180 |
|-------------------------|---------------------|------------------------|------------------------|------------------------|------------------------|------------------------|
| Unit Size | Length (in) | 40 3/4 | 40 3/4 | 40 3/4 | 46 3/4 | 46 3/4 |
| | Height (in) | 21 | 21 | 21 | 28 | 28 |
| | Width (in) | 79 | 79 | 79 | 85 | 85 |
| Compressor Type | | Reciprocating | Reciprocating | Scroll | Scroll | Scroll |
| Approximate Weight | with Pallet (lb) | 701 | 714 | 831 | 907 | 999 |
| Approximate Weight | without Pallet (lb) | 652 | 666 | 789 | 865 | 957 |
| Filter Size | Actual (in) | 19 5/8 x 24 5/8 (3) | 19 5/8 x 24 5/8 (3) | 19 5/8 x 24 5/8 (3) | 24 5/8 x 24 5/8 (3) | 24 5/8 x 24 5/8 (3) |
| Water in/out size (FPT) | inches | 1 1/4 | 1 1/4 | 1 1/2 | 1 1/2 | 1 1/2 |
| Condensate size (NPTI) | inches | 3/4 | 3/4 | 3/4 | 3/4 | 3/4 |
| Blower Wheel Size | Belt Drive (in) | 12.62 x 12.62 | 12.62 x 12.62 | 12.62 x 12.62 | 15.00 x 15.00 | 15.00 x 15.00 |

| Model GEV | | 072 | 090 | 120 | 150 | 180 |
|--------------------------------|---------------------|------------------------|------------------------|------------------------|------------------------|------------------------|
| Unit Size | Length (in) | 42 | 42 | 42 | 81 5/8 | 81 5/8 |
| | Height (in) | 62 5/8 | 62 5/8 | 62 5/8 | 68 | 68 |
| | Width (in) | 36 1/4 | 36 1/4 | 36 1/4 | 36 1/4 | 36 1/4 |
| Compressor Type | | Recip (2) | Recip (2) | Scroll (2) | Scroll (2) | Scroll (2) |
| Approximate Weight | with Pallet (lb) | 617 | 648 | 861 | 1215 | 1225 |
| Approximate Weight | without Pallet (lb) | 577 | 608 | 821 | 1170 | 1180 |
| Filter Size | Actual (in) | 19 5/8 x 19 5/8 (4) | 19 5/8 x 19 5/8 (4) | 19 5/8 x 19 5/8 (4) | 19 5/8 x 24 5/8 (6) | 19 5/8 x 24 5/8 (6) |
| Water in/out size | inches | 1 1/4 FPT | 1 1/4 FPT | 1 1/2 FPT | 1 1/2 FPT | 1 1/2 FPT |
| Condensate size (NPTI) | inches | 3/4 | 3/4 | 3/4 | 3/4 | 3/4 |
| Blower Wheel Size and quantity | | 12.62 x 12.62 | 12.62 x 12.62 | 12.62 x 12.62 | 15.00 x 15.00 | 15.00 x 15.00 |

| Model GEV | | 240 | 300 |
|--|---------------------|------------------------|-----------------------------------|
| Unit Size | Length (in) | 81 5/8 | 81 5/8 |
| | Height (in) | 68 | 68 |
| | Width (in) | 36 1/4 | 36 1/4 |
| Compressor Type | | Scroll (2) | Scroll (2) |
| Approximate Weight | with Pallet (lb) | 1615 | 1665 |
| Approximate Weight | without Pallet (lb) | 1580 | 1640 |
| Filter Size | Actual (in) | 19 5/8 x 24 5/8 (6) | 19 5/8 x 24 5/8 (6) |
| Water in/out size (sweat) | inches | 2 FPT | 2 FPT |
| Condensate size (NPTI) | inches | 3/4 | 3/4 |
| Blower Wheel Size and quantity (regular-low static/high static) | | (2) 12.62 x 12.62 (2) | 15.00 x 11.00 / (2) 12.62 x 12.62 |

Table 2. General Information on Air-to-Refrigerant Coil (2-compressor circuit)

| Unit Size | 072 | 090 | 120 | 150 | 180 | 240 |
|---|--|--|--|--|--|------------------------------|
| Working Pressure | 425 | 425 | 425 | 425 | 425 | 425 |
| Tubes High | (GEH) 18 (GEV) 24 4 | (GEH) 18 (GEV) 28 4 | (GEH) 18 (GEV) 36 4 | (GEH) 24 (GEV) 28 (GEH) 4 (GEV) 2 | (GEH) 24 (GEV) 32 (GEH) 4 (GEV) 3 | 36 4 |
| Tubes Deep | 6 refrig flow paths (2X) | (GEH) 6 refrig flow paths-2X (GEV) 7 refrig flow paths-2X | 9 refrig flow paths (2X) | (GEH) 8 refrig flow paths-2X (GEV) 7 refrig flow paths-2X | (GEH) 8 refrig flow paths-2X (GEV) 9 refrig flow paths-2X | 18 refrig flow paths (2X) |
| No. of Circuits | (GEH) 18 x 48 x 3.464 (GEV) 24 x 34 x 3.464 | (GEH) 18 x 54 x 3.464 (GEV) 28 x 34 x 3.464 | (GEH) 18 x 73 x 3.464 (GEV) 36 x 34 x 3.464 | (GEH) 24 x 73 x 3.464 (GEV) 28 x 73 x 1.734 | (GEH) 24 x 73 x 3.464 (GEV) 32 x 73 x 2.598 | 36 x 73 x 3.464 |
| Finned vol. (h,w,d) | (GEH) 6.00 (GEV) 5.67 | (GEH) 6.75 (GEV) 6.61 | (GEH) 9.125 (GEV) 8.50 | (GEH) 12.167 (GEV) 14.19 | (GEH) 12.167 (GEV) 16.22 | 18.25 |
| Coil Surface Area (Ft ²) | 14 | 14 | 14 | 14 | 14 | 14 |
| Fins Per Inch | Copper | Copper | Copper | Copper | Copper | Copper |
| Tube Material | 3/8 | 3/8 | 3/8 | 3/8 | 3/8 | 3/8 |
| Tube OD (in) | 0.014 | 0.014 | 0.014 | 0.014 | 0.014 | 0.014 |
| Wall Thickness | Copper | Copper | Copper | Copper | Copper | Copper |
| Return Bands | | | | | | |

Schedule B1. Trane WSHP Cut Sheets (continued)



Performance Data

Table 3. ARIHSO WLHP and GLHP Performance

| Unit Size | Rated Water Flow (GPM) | Rated Air Flow (SCFM) | Cooling Capacity WLHP (BTUH) | EER WLHP | Heating Capacity WLHP (BTUH) | COP WLHP | Cooling Capacity GLHP (BTUH) | EER GLHP | Heating Capacity GLHP (BTUH) | COP GLHP |
|-----------|------------------------|-----------------------|------------------------------|----------|------------------------------|----------|------------------------------|----------|------------------------------|----------|
| GEH 072 | 18.0 | 2400 | 74900 | 14.4 | 84600 | 4.6 | 74300 | 15.4 | 48500 | 3.3 |
| GEH 090 | 22.5 | 3000 | 90500 | 12.7 | 106300 | 4.2 | 90200 | 13.4 | 62700 | 3.1 |
| GEH 120 | 30.0 | 4000 | 120900 | 12.4 | 148500 | 4.4 | 119700 | 13.4 | 90800 | 3.1 |
| GEH 150 | 37.5 | 5000 | 143100 | 14.4 | 170300 | 5.0 | 141600 | 15.3 | 105700 | 3.4 |
| GEH 180 | 45.0 | 6000 | 174500 | 12.8 | 204100 | 4.5 | 170700 | 13.6 | 122900 | 3.1 |
| GEV 072 | 18.0 | 2400 | 72900 | 13.7 | 85100 | 4.8 | 72600 | 14.8 | 51600 | 3.5 |
| GEV 090 | 22.5 | 3000 | 90300 | 13.0 | 104300 | 4.5 | 89800 | 14.0 | 63200 | 3.2 |
| GEV 120 | 30.0 | 4000 | 120200 | 12.7 | 142800 | 4.4 | 118000 | 13.5 | 86400 | 3.2 |
| GEV 150 | 37.5 | 5000 | 144000 | 15.5 | 171400 | 5.5 | 148100 | 17.3 | 105400 | 3.9 |
| GEV 180 | 45.0 | 6000 | 173600 | 13.0 | 209800 | 4.8 | 178900 | 14.5 | 128700 | 3.5 |
| GEV 240 | 60.0 | 8000 | 250300 | 13.1 | 276800 | 4.3 | 257200 | 14.5 | 186600 | 3.4 |
| GEV 300 | 75.0 | 10000 | 282900 | 12.1 | 339400 | 4.2 | 291700 | 13.2 | 220900 | 3.3 |

1. Rated in accordance with ISO Standard 13256-1: 1998 (Water Loop Heat Pumps and Ground Loop Heat Pumps).
 2. Models with capacities greater than 135 000 BTUH are not included in the ARI water-to-air and brine-to-air heat pump certification program.

Schedule B1. Trane WSHP Cut Sheets (continued)



Performance Data

GEV 072 Cooling Performance

Table 19. GEV 072 Cooling Performance

RATED GPM: 18.0 MINIMUM CFM: 1920 RATED ESP (in. H2O): 0.25
 RATED CFM: 2400 MAXIMUM CFM: 2880

| EWT | GPM | Total Mbtuh | Sen Mbtuh | SHR | Power kW | EER | Reject Mbtuh | LWT | Feet Head |
|----------------|-------------|-------------|-------------|-------------|-------------|--------------|--------------|-------------|-------------|
| 45 | 9.0 | 84.5 | 61.8 | 0.73 | 3.83 | 22.05 | 97.6 | 66.7 | 3.9 |
| 45 | 12.0 | 85.8 | 62.3 | 0.73 | 3.62 | 23.68 | 98.1 | 61.4 | 6.4 |
| 45 | 15.0 | 86.6 | 62.7 | 0.72 | 3.48 | 24.93 | 98.5 | 58.1 | 9.4 |
| 45 | 18.0 | 87.3 | 63.0 | 0.72 | 3.37 | 25.90 | 98.8 | 56.0 | 12.8 |
| 45 | 21.0 | 87.7 | 63.2 | 0.72 | 3.29 | 26.68 | 99.0 | 54.4 | 16.6 |
| 55 | 9.0 | 80.9 | 60.2 | 0.74 | 4.37 | 18.50 | 95.8 | 75.3 | 3.9 |
| 55 | 12.0 | 82.2 | 60.8 | 0.74 | 4.16 | 19.75 | 96.4 | 71.1 | 6.4 |
| 55 | 15.0 | 83.1 | 61.2 | 0.74 | 4.02 | 20.69 | 96.8 | 67.9 | 9.4 |
| 55 | 18.0 | 83.8 | 61.5 | 0.73 | 3.91 | 21.42 | 97.2 | 65.8 | 12.8 |
| 55 | 21.0 | 84.3 | 61.7 | 0.73 | 3.83 | 22.00 | 97.4 | 64.3 | 16.6 |
| 68 | 9.0 | 75.9 | 58.1 | 0.77 | 5.01 | 15.17 | 93.0 | 88.7 | 3.9 |
| 68 | 12.0 | 77.3 | 58.7 | 0.76 | 4.81 | 16.09 | 93.7 | 83.6 | 6.4 |
| 68 | 15.0 | 78.3 | 59.1 | 0.75 | 4.67 | 16.77 | 94.2 | 80.6 | 9.3 |
| 68 | 18.0 | 79.0 | 59.4 | 0.75 | 4.57 | 17.30 | 94.6 | 78.5 | 12.7 |
| 68 | 21.0 | 79.6 | 59.6 | 0.75 | 4.49 | 17.72 | 94.9 | 77.0 | 16.5 |
| 77 | 9.0 | 72.4 | 56.7 | 0.78 | 5.42 | 13.37 | 90.9 | 97.2 | 3.9 |
| 77 | 12.0 | 73.9 | 57.3 | 0.78 | 5.22 | 14.14 | 91.7 | 92.3 | 6.4 |
| 77 | 15.0 | 74.9 | 57.7 | 0.77 | 5.09 | 14.71 | 92.2 | 89.3 | 9.3 |
| GLHP 77 | 18.0 | 75.6 | 58.0 | 0.77 | 4.99 | 15.15 | 92.6 | 87.3 | 12.7 |
| 77 | 21.0 | 76.1 | 58.2 | 0.76 | 4.91 | 15.49 | 92.9 | 85.8 | 16.5 |
| 86 | 9.0 | 68.9 | 55.2 | 0.80 | 5.81 | 11.87 | 88.7 | 105.7 | 3.9 |
| 86 | 12.0 | 70.4 | 55.8 | 0.79 | 5.62 | 12.52 | 89.5 | 100.9 | 6.4 |
| 86 | 15.0 | 71.3 | 56.2 | 0.79 | 5.49 | 13.00 | 90.1 | 98.0 | 9.3 |
| WLHP 86 | 18.0 | 72.1 | 56.5 | 0.78 | 5.39 | 13.36 | 90.5 | 96.1 | 12.7 |
| 86 | 21.0 | 72.6 | 56.7 | 0.78 | 5.32 | 13.65 | 90.7 | 94.6 | 16.5 |
| 95 | 9.0 | 65.3 | 53.8 | 0.82 | 6.18 | 10.58 | 86.4 | 114.2 | 3.9 |
| 95 | 12.0 | 66.8 | 54.3 | 0.81 | 6.00 | 11.14 | 87.3 | 109.5 | 6.4 |
| 95 | 15.0 | 67.8 | 54.7 | 0.81 | 5.87 | 11.55 | 87.8 | 106.7 | 9.3 |
| 95 | 18.0 | 68.5 | 55.0 | 0.80 | 5.78 | 11.86 | 88.2 | 104.8 | 12.6 |
| 95 | 21.0 | 69.0 | 55.2 | 0.80 | 5.70 | 12.09 | 88.5 | 103.4 | 16.4 |
| 105 | 9.0 | 61.3 | 52.1 | 0.85 | 6.56 | 9.35 | 83.7 | 123.6 | 3.9 |
| 105 | 12.0 | 62.8 | 52.7 | 0.84 | 6.39 | 9.82 | 84.6 | 119.1 | 6.3 |
| 105 | 15.0 | 63.7 | 53.1 | 0.83 | 6.27 | 10.17 | 85.1 | 116.3 | 9.3 |
| 105 | 18.0 | 64.4 | 53.4 | 0.83 | 6.18 | 10.42 | 85.5 | 114.5 | 12.6 |
| 105 | 21.0 | 64.9 | 53.6 | 0.83 | 6.11 | 10.62 | 85.8 | 113.2 | 16.4 |
| 115 | 9.0 | 57.2 | 50.5 | 0.88 | 6.92 | 8.27 | 80.9 | 133.0 | 3.9 |
| 115 | 12.0 | 58.7 | 51.1 | 0.87 | 6.76 | 8.68 | 81.7 | 128.6 | 6.3 |
| 115 | 15.0 | 59.6 | 51.4 | 0.86 | 6.65 | 8.96 | 82.3 | 126.0 | 9.2 |
| 115 | 18.0 | 60.2 | 51.7 | 0.86 | 6.56 | 9.18 | 82.6 | 124.2 | 12.6 |
| 115 | 21.0 | 60.7 | 51.9 | 0.85 | 6.50 | 9.34 | 82.9 | 122.9 | 16.3 |
| 120 | 9.0 | 55.2 | 49.7 | 0.90 | 7.09 | 7.78 | 79.4 | 137.6 | 3.9 |
| 120 | 12.0 | 56.6 | 50.2 | 0.89 | 6.94 | 8.15 | 80.2 | 133.4 | 6.3 |
| 120 | 15.0 | 57.5 | 50.6 | 0.88 | 6.83 | 8.42 | 80.8 | 130.8 | 9.2 |
| 120 | 18.0 | 58.1 | 50.9 | 0.88 | 6.75 | 8.61 | 81.1 | 129.0 | 12.5 |
| 120 | 21.0 | 58.6 | 51.0 | 0.87 | 6.69 | 8.75 | 81.4 | 127.8 | 16.3 |

1. Performance data is tabulated for cooling at 80.6 F DB/66.2 F WB entering air at ARI/ISO 13256-1 rated CFM.
 2. For conditions other than what is tabulated, multipliers must be used to correct performance. See the fan correction factors Table for CFM other than rated and the cooling correction factors for variations in entering air temperature. WLHP data shown in bold type is performance data at ARI/ISO 13256-1. The bold type for GLHP is a rating point only. For ARI 13256-1 GLHP conditions, apply 15% methanol by volume per the antifreeze correction factors found on Page 69.

Schedule B1. Trane WSHP Cut Sheets (continued)



Performance Data

GEV 072 Heating Performance

Table 20. GEV 072 Heating Performance

| RATED GPM: 18.0 | | MINIMUM CFM: 1920 | | RATED ESP (in. H ₂ O): 0.25 | | | |
|-----------------|-------------|-------------------|-----------------|--|-------------|-------------|--------------|
| RATED CFM: 2400 | | MAXIMUM CFM: 2880 | | | | | |
| EWT | GPM | Htg Cap Mbtuh | Absorb Mbtuh | Power kW | COP | LWT | Feet Head |
| 25 | 9.0 | 45.5 | 31.5 | 4.09 | 3.28 | 18.0 | 5.0 |
| 25 | 12.0 | 46.9 | 32.7 | 4.15 | 3.31 | 19.5 | 7.7 |
| 25 | 15.0 | 47.9 | 33.6 | 4.18 | 3.35 | 20.5 | 10.8 |
| 25 | 18.0 | 48.6 | 34.3 | 4.21 | 3.39 | 21.2 | 14.2 |
| 25 | 21.0 | 49.0 | 34.6 | 4.21 | 3.41 | 21.7 | 17.9 |
| 32 | 9.0 | 51.6 | 36.8 | 4.32 | 3.50 | 23.8 | 5.0 |
| 32 | 12.0 | 53.1 | 38.2 | 4.38 | 3.56 | 25.6 | 7.7 |
| 32 | 15.0 | 54.3 | 39.3 | 4.42 | 3.60 | 26.8 | 10.8 |
| GLHP 32 | 18.0 | 55.2 | 40.0 | 4.44 | 3.64 | 27.6 | 14.2 |
| 32 | 21.0 | 55.6 | 40.4 | 4.45 | 3.66 | 28.1 | 18.0 |
| 45 | 9.0 | 62.4 | 46.4 | 4.69 | 3.90 | 34.7 | 5.0 |
| 45 | 12.0 | 64.3 | 48.1 | 4.75 | 3.96 | 37.0 | 7.7 |
| 45 | 15.0 | 65.7 | 49.4 | 4.80 | 4.01 | 38.4 | 10.8 |
| 45 | 18.0 | 66.7 | 50.3 | 4.82 | 4.05 | 39.4 | 14.2 |
| 45 | 21.0 | 67.3 | 50.8 | 4.83 | 4.08 | 40.2 | 18.0 |
| 55 | 9.0 | 70.3 | 53.4 | 4.93 | 4.17 | 43.1 | 5.0 |
| 55 | 12.0 | 72.4 | 55.3 | 5.00 | 4.24 | 45.8 | 7.7 |
| 55 | 15.0 | 74.0 | 56.8 | 5.05 | 4.30 | 47.4 | 10.8 |
| 55 | 18.0 | 75.1 | 57.8 | 5.08 | 4.34 | 48.6 | 14.2 |
| 55 | 21.0 | 75.7 | 58.4 | 5.08 | 4.37 | 49.4 | 17.9 |
| 68 | 9.0 | 80.4 | 62.7 | 5.18 | 4.54 | 54.1 | 5.0 |
| 68 | 12.0 | 82.8 | 64.9 | 5.25 | 4.62 | 57.2 | 7.7 |
| 68 | 15.0 | 84.7 | 66.6 | 5.30 | 4.68 | 59.1 | 10.8 |
| WLHP 68 | 18.0 | 85.9 | 67.8 | 5.33 | 4.72 | 60.5 | 14.2 |
| 68 | 21.0 | 86.6 | 68.4 | 5.34 | 4.75 | 61.5 | 17.9 |
| 75 | 9.0 | 84.8 | 66.6 | 5.31 | 4.68 | 60.2 | 5.0 |
| 75 | 12.0 | 87.3 | 69.0 | 5.38 | 4.76 | 63.5 | 7.7 |
| 75 | 15.0 | 89.3 | 70.8 | 5.43 | 4.82 | 65.6 | 10.7 |
| 75 | 18.0 | 90.7 | 72.0 | 5.46 | 4.87 | 67.0 | 14.2 |
| 75 | 21.0 | 91.4 | 72.7 | 5.47 | 4.90 | 68.1 | 17.9 |
| 86 | 9.0 | 92.0 | 73.5 | 5.45 | 4.86 | 69.7 | 4.9 |
| 86 | 12.0 | 94.9 | 76.0 | 5.52 | 5.03 | 73.3 | 7.6 |
| 86 | 15.0 | 97.0 | 78.0 | 5.58 | 5.10 | 75.6 | 10.7 |
| 86 | 18.0 | 98.4 | 79.3 | 5.60 | 5.15 | 77.2 | 14.1 |
| 86 | 21.0 | 99.2 | 80.1 | 5.61 | 5.18 | 78.4 | 17.8 |

1. Performance data is tabulated for heating at 68 F DB entering air at ARI/ISO 13256-1 rated CFM.
 2. For conditions other than what is tabulated, multipliers must be used to correct performance. See the fan correction factors Table for CFM other than rated and the heating correction factors for variations in entering air temperature. WLHP data shown in bold type is performance data at ARI/ISO 13256-1. The bold type for GLHP is a rating point only. For ARI 13256-1 GLHP conditions, apply 15% methanol by volume per the antifreeze correction factors found on Page 69.

Table 21. 072 Fan Correction Factors

| Entering CFM | Cooling Capacity | Sensible Capacity | Cooling Input Watts | Heating Capacity | Heating Input Watts |
|-----------------|---------------------|----------------------|---------------------------|---------------------|---------------------------|
| 1920 | 0.961 | 0.891 | 0.992 | 0.973 | 1.044 |
| 2160 | 0.982 | 0.947 | 0.997 | 0.988 | 1.020 |
| 2400 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 |
| 2640 | 1.015 | 1.052 | 1.003 | 1.010 | 0.983 |
| 2880 | 1.029 | 1.102 | 1.005 | 1.018 | 0.969 |

Schedule B1. Trane WSHP Cut Sheets (continued)



Performance Data

GEV 150 Cooling Performance

Table 28. GEV 150 Cooling Performance

| RATED GPM: 37.5 | | MINIMUM CFM: 4000 | | RATED ESP (in. H ₂ O): 0.35 | | | | | |
|-----------------|-------------|-------------------|--------------|--|-------------|--------------|-----------------|-------------|--------------|
| RATED CFM: 5000 | | MAXIMUM CFM: 6000 | | | | | | | |
| EWT | GPM | Total Mbtuh | Sen Mbtuh | SHR | Power kW | EER | Reject Mbtuh | LWT | Feet Head |
| 45 | 18.8 | 155.8 | 118.5 | 0.76 | 7.31 | 21.33 | 175.7 | 63.7 | 4.4 |
| 45 | 25.0 | 155.9 | 118.6 | 0.76 | 7.27 | 21.43 | 175.7 | 59.0 | 7.1 |
| 45 | 31.3 | 156.0 | 118.6 | 0.76 | 7.25 | 21.53 | 175.8 | 56.2 | 10.2 |
| 45 | 37.5 | 156.2 | 118.7 | 0.76 | 7.22 | 21.62 | 175.8 | 54.4 | 13.8 |
| 45 | 43.8 | 156.2 | 118.7 | 0.76 | 7.21 | 21.66 | 175.9 | 53.5 | 17.8 |
| 55 | 18.8 | 153.7 | 117.6 | 0.77 | 7.70 | 19.96 | 174.7 | 73.6 | 4.4 |
| 55 | 25.0 | 153.7 | 117.7 | 0.77 | 7.63 | 20.14 | 174.6 | 68.9 | 7.1 |
| 55 | 31.3 | 154.0 | 117.7 | 0.76 | 7.58 | 20.31 | 174.6 | 66.2 | 10.2 |
| 55 | 37.5 | 154.2 | 117.8 | 0.76 | 7.53 | 20.47 | 174.7 | 64.3 | 13.8 |
| 55 | 43.8 | 154.4 | 117.9 | 0.76 | 7.49 | 20.62 | 174.8 | 63.0 | 17.7 |
| 68 | 18.8 | 149.1 | 115.6 | 0.78 | 8.48 | 17.58 | 172.6 | 86.4 | 4.4 |
| 68 | 25.0 | 149.2 | 115.6 | 0.78 | 8.37 | 17.82 | 172.3 | 81.8 | 7.0 |
| 68 | 31.3 | 149.5 | 115.7 | 0.77 | 8.28 | 18.04 | 172.4 | 79.1 | 10.2 |
| 68 | 37.5 | 149.8 | 115.9 | 0.77 | 8.21 | 18.26 | 172.4 | 77.2 | 13.7 |
| 68 | 43.8 | 150.2 | 116.0 | 0.77 | 8.13 | 18.47 | 172.6 | 75.9 | 17.7 |
| 77 | 18.8 | 145.0 | 113.9 | 0.78 | 9.19 | 15.78 | 170.8 | 95.3 | 4.4 |
| 77 | 25.0 | 145.2 | 113.9 | 0.78 | 9.05 | 16.04 | 170.5 | 90.7 | 7.0 |
| 77 | 31.3 | 145.6 | 114.1 | 0.78 | 8.94 | 16.28 | 170.5 | 88.0 | 10.2 |
| GLHP 77 | 37.5 | 145.0 | 114.3 | 0.78 | 8.84 | 16.51 | 170.6 | 86.1 | 13.7 |
| 77 | 43.8 | 146.4 | 114.4 | 0.78 | 8.75 | 16.73 | 170.7 | 84.8 | 17.7 |
| 86 | 18.8 | 140.6 | 112.0 | 0.80 | 10.05 | 13.99 | 169.1 | 104.1 | 4.4 |
| 86 | 25.0 | 140.8 | 112.1 | 0.80 | 9.88 | 14.25 | 168.8 | 99.6 | 7.0 |
| 86 | 31.3 | 141.2 | 112.2 | 0.79 | 9.75 | 14.49 | 168.8 | 96.9 | 10.1 |
| WLHP 86 | 37.5 | 141.7 | 112.4 | 0.79 | 9.63 | 14.71 | 168.8 | 95.1 | 13.7 |
| 86 | 43.8 | 142.1 | 112.6 | 0.79 | 9.51 | 14.94 | 168.9 | 93.8 | 17.6 |
| 95 | 18.8 | 135.7 | 109.9 | 0.81 | 11.06 | 12.27 | 167.5 | 113.0 | 4.3 |
| 95 | 25.0 | 136.0 | 110.0 | 0.81 | 10.86 | 12.52 | 167.1 | 108.5 | 7.0 |
| 95 | 31.3 | 136.4 | 110.2 | 0.81 | 10.70 | 12.75 | 167.0 | 105.8 | 10.1 |
| 95 | 37.5 | 136.9 | 110.4 | 0.81 | 10.56 | 12.97 | 167.0 | 104.0 | 13.6 |
| 95 | 43.8 | 137.3 | 110.6 | 0.81 | 10.42 | 13.18 | 167.1 | 102.7 | 17.6 |
| 105 | 18.8 | 129.7 | 107.4 | 0.83 | 12.34 | 10.51 | 165.8 | 122.9 | 4.3 |
| 105 | 25.0 | 130.0 | 107.5 | 0.83 | 12.11 | 10.73 | 165.3 | 118.4 | 7.0 |
| 105 | 31.3 | 130.5 | 107.7 | 0.83 | 11.93 | 10.94 | 165.2 | 115.7 | 10.1 |
| 105 | 37.5 | 131.0 | 108.0 | 0.82 | 11.76 | 11.14 | 165.2 | 113.9 | 13.6 |
| 105 | 43.8 | 131.5 | 108.2 | 0.82 | 11.60 | 11.34 | 165.2 | 112.6 | 17.5 |
| 115 | 18.8 | 123.2 | 104.7 | 0.85 | 13.80 | 8.93 | 164.2 | 132.7 | 4.3 |
| 115 | 25.0 | 123.5 | 104.9 | 0.85 | 13.54 | 9.13 | 163.7 | 128.2 | 6.9 |
| 115 | 31.3 | 124.1 | 105.1 | 0.85 | 13.33 | 9.31 | 163.5 | 125.6 | 10.0 |
| 115 | 37.5 | 124.6 | 105.3 | 0.84 | 13.14 | 9.49 | 163.4 | 123.8 | 13.5 |
| 115 | 43.8 | 125.2 | 105.5 | 0.84 | 12.96 | 9.66 | 163.3 | 122.6 | 17.5 |
| 120 | 18.8 | 119.8 | 103.3 | 0.86 | 14.60 | 8.20 | 163.5 | 137.7 | 4.3 |
| 120 | 25.0 | 120.2 | 103.5 | 0.86 | 14.32 | 8.39 | 162.9 | 133.2 | 6.9 |
| 120 | 31.3 | 120.7 | 103.7 | 0.86 | 14.10 | 8.56 | 162.7 | 130.6 | 10.0 |
| 120 | 37.5 | 121.3 | 103.9 | 0.86 | 13.90 | 8.73 | 162.6 | 128.8 | 13.5 |
| 120 | 43.8 | 121.8 | 104.1 | 0.85 | 13.71 | 8.89 | 162.5 | 127.5 | 17.4 |

1. Performance data is tabulated for cooling at 80.6 F DB/66.2 F WB entering air at ARI/ISO 13256-1 rated CFM.
 2. For conditions other than what is tabulated, multipliers must be used to correct performance. See the fan correction factors Table for CFM other than rated and the cooling correction factors for variations in entering air temperature. WLHP data shown in bold type is performance data at ARI/ISO 13256-1. The bold type for GLHP is a rating point only. For ARI 13256-1 GLHP conditions, apply 15% methanol by volume per the antifreeze correction factors found on Page 69.

Schedule B1. Trane WSHP Cut Sheets (continued)



Performance Data

GEV 150 Heating Performance

Table 29. GEV 150 Heating Performance

| RATED GPM: 37.5 | | MINIMUM CFM: 4000 | | RATED ESP (in. H ₂ O): 0.35 | | | |
|-----------------|-------------|-------------------|-----------------|--|-------------|-------------|--------------|
| RATED CFM: 5000 | | MAXIMUM CFM: 6000 | | | | | |
| EWT | GPM | Htg Cap Mbtuh | Absorb Mbtuh | Power kW | COP | LWT | Feet Head |
| 25 | 18.8 | 92.4 | 68.3 | 7.97 | 3.40 | 18.1 | 4.9 |
| 25 | 25.0 | 95.0 | 70.8 | 8.02 | 3.47 | 19.7 | 7.7 |
| 25 | 31.3 | 96.6 | 72.4 | 8.05 | 3.52 | 20.7 | 11.1 |
| 25 | 37.5 | 97.8 | 73.6 | 8.07 | 3.55 | 21.4 | 14.8 |
| 25 | 43.8 | 98.6 | 74.4 | 8.09 | 3.57 | 21.9 | 19.0 |
| 32 | 18.8 | 102.2 | 77.9 | 8.15 | 3.67 | 24.0 | 4.9 |
| 32 | 25.0 | 105.4 | 81.0 | 8.21 | 3.76 | 25.9 | 7.7 |
| 32 | 31.3 | 107.4 | 83.0 | 8.24 | 3.82 | 27.0 | 11.1 |
| GLHP 32 | 37.5 | 108.8 | 84.4 | 8.27 | 3.86 | 27.8 | 14.8 |
| 32 | 43.8 | 109.9 | 85.5 | 8.28 | 3.89 | 28.4 | 19.0 |
| 45 | 18.8 | 121.6 | 97.1 | 8.48 | 4.20 | 34.7 | 4.9 |
| 45 | 25.0 | 125.6 | 100.9 | 8.55 | 4.30 | 37.0 | 7.7 |
| 45 | 31.3 | 129.2 | 104.6 | 8.61 | 4.40 | 38.9 | 11.1 |
| 45 | 37.5 | 131.6 | 106.9 | 8.65 | 4.46 | 39.8 | 14.8 |
| 45 | 43.8 | 132.4 | 107.7 | 8.66 | 4.48 | 40.1 | 19.0 |
| 55 | 18.8 | 138.2 | 113.4 | 8.76 | 4.62 | 43.0 | 4.9 |
| 55 | 25.0 | 142.3 | 117.6 | 8.83 | 4.72 | 45.6 | 7.7 |
| 55 | 31.3 | 145.8 | 121.0 | 8.89 | 4.81 | 47.3 | 11.1 |
| 55 | 37.5 | 148.8 | 123.9 | 8.94 | 4.87 | 48.4 | 14.8 |
| 55 | 43.8 | 151.2 | 126.3 | 8.99 | 4.93 | 49.3 | 19.0 |
| 68 | 18.8 | 160.4 | 135.4 | 9.15 | 5.14 | 53.6 | 4.9 |
| 68 | 25.0 | 165.5 | 140.5 | 9.24 | 5.25 | 56.8 | 7.7 |
| 68 | 31.3 | 170.0 | 144.9 | 9.33 | 5.34 | 58.7 | 11.0 |
| WLHP 68 | 37.5 | 173.7 | 148.6 | 9.40 | 5.42 | 60.1 | 14.8 |
| 68 | 43.8 | 176.8 | 151.6 | 9.46 | 5.48 | 61.1 | 19.0 |
| 75 | 18.8 | 172.8 | 147.7 | 9.38 | 5.40 | 59.2 | 4.9 |
| 75 | 25.0 | 178.5 | 153.3 | 9.49 | 5.51 | 62.7 | 7.7 |
| 75 | 31.3 | 183.5 | 158.3 | 9.59 | 5.61 | 64.9 | 11.0 |
| 75 | 37.5 | 187.8 | 162.5 | 9.68 | 5.68 | 66.3 | 14.8 |
| 75 | 43.8 | 191.3 | 165.9 | 9.75 | 5.75 | 67.4 | 19.0 |
| 86 | 18.8 | 192.9 | 167.6 | 9.79 | 5.78 | 68.1 | 4.8 |
| 86 | 25.0 | 199.7 | 174.2 | 9.93 | 5.89 | 72.0 | 7.7 |
| 86 | 31.3 | 205.6 | 180.0 | 10.06 | 5.99 | 74.4 | 11.0 |
| 86 | 37.5 | 210.6 | 184.9 | 10.17 | 6.07 | 76.1 | 14.8 |
| 86 | 43.8 | 214.7 | 189.0 | 10.26 | 6.13 | 77.3 | 18.9 |

1. Performance data is tabulated for heating at 68 F DB entering air at ARI/ISO 13256-1 rated CFM.
 2. For conditions other than what is tabulated, multipliers must be used to correct performance. See the fan correction factors Table for CFM other than rated and the heating correction factors for variations in entering air temperature. WLHP data shown in bold type is performance data at ARI/ISO 13256-1. The bold type for GLHP is a rating point only. For ARI 13256-1 GLHP conditions, apply 15% methanol by volume per the antifreeze correction factors found on Page 69.

Table 30. 150 Fan Correction Factors

| Entering SCFM | Cooling Capacity | Sensible Capacity | Cooling Input Watts | Heating Capacity | Heating Input Watts |
|------------------|---------------------|----------------------|---------------------------|---------------------|---------------------------|
| 4000 | 0.968 | 0.898 | 0.997 | 0.987 | 1.065 |
| 4500 | 0.986 | 0.951 | 0.999 | 0.994 | 1.028 |
| 5000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 |
| 5500 | 1.013 | 1.049 | 1.001 | 1.005 | 0.978 |
| 6000 | 1.025 | 1.096 | 1.002 | 1.009 | 0.960 |


Schedule B1. Trane WSHP Cut Sheets (continued)



Performance Data

Fan Performance

Figure 19. GEV 072 Top Supply Fan Performance Curve



includes wet coil, no filter

Table 62. GEV 072 - Top Supply - Fan Performance (includes wet coil, no filter)

| Std | Unit External Static Pressure inches W.G. (Wet Coil, No Drive Loss Included & No Return Air Filter) | | | | | | | | | | | | | | | | | | | |
|---------|---|-------------------|------------------|-------------------|------------------|-------------------|------------------|-------------------|------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|--|--|
| | 0.1 | | 0.2 | | 0.3 | | 0.4 | | 0.5 | | 0.6 | | 0.7 | | 0.8 | | 0.9 | | | |
| Airflow | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP | | |
| 1920 | 595 ^A | 0.27 ^A | 649 ^A | 0.32 ^A | 698 ^A | 0.36 ^A | 744 ^A | 0.40 ^A | 788 ^A | 0.45 ^A | 830 ^A | 0.50 ^A | 871 ^A | 0.55 ^A | 912 ^B | 0.60 ^B | 953 ^B | 0.65 ^B | | |
| 2160 | 655 ^A | 0.37 ^A | 705 ^A | 0.42 ^A | 751 ^A | 0.47 ^A | 794 ^A | 0.52 ^A | 835 ^A | 0.57 ^A | 874 ^A | 0.63 ^A | 912 ^B | 0.68 ^B | 949 ^B | 0.74 ^B | 985 ^B | 0.79 ^B | | |
| 2400 | 717 ^A | 0.50 ^A | 763 ^A | 0.56 ^A | 806 ^A | 0.61 ^A | 846 ^A | 0.67 ^A | 884 ^A | 0.72 ^A | 921 ^B | 0.78 ^B | 957 ^B | 0.83 ^B | 991 ^B | 0.89 ^B | 1024 ^B | 0.96 ^B | | |
| 2640 | 780 ^A | 0.65 ^A | 822 ^A | 0.71 ^A | 862 ^A | 0.78 ^A | 900 ^B | 0.84 ^B | 937 ^B | 0.90 ^B | 971 ^B | 0.96 ^B | 1005 ^C | 1.02 ^C | 1038 ^C | 1.08 ^C | 1069 ^C | 1.15 ^C | | |
| 2880 | 844 ^A | 0.84 ^A | 882 ^A | 0.90 ^A | 920 ^B | 0.97 ^B | 956 ^C | 1.04 ^C | 990 ^C | 1.10 ^C | 1023 ^C | 1.17 ^C | 1055 ^C | 1.23 ^C | 1086 ^C | 1.30 ^C | 1116 ^C | 1.36 ^C | | |

| Std | Unit External Static Pressure inches W.G. (Wet Coil, 3% Drive Loss Included & No Return Air Filter) | | | | | | | |
|---------|---|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|
| | 1.0 | | 1.1 | | 1.2 | | 1.3 | |
| Airflow | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP |
| 1920 | 993 ^B | 0.70 ^B | 1034 ^B | 0.76 ^B | 1072 ^B | 0.84 ^B | 1111 ^B | 0.92 ^B |
| 2160 | 1021 ^B | 0.85 ^B | 1058 ^B | 0.90 ^B | 1094 ^B | 0.95 ^B | 1129 ^C | 1.02 ^C |
| 2400 | 1057 ^C | 1.02 ^C | 1091 ^C | 1.08 ^C | 1123 ^C | 1.14 ^C | 1157 ^C | 1.20 ^C |
| 2640 | 1100 ^C | 1.21 ^C | 1130 ^C | 1.28 ^C | 1161 ^C | 1.35 ^C | 1191 ^C | 1.42 ^C |
| 2880 | 1145 ^C | 1.43 ^C | 1175 ^D | 1.51 ^D | 1203 ^D | 1.58 ^D | 1231 ^D | 1.66 ^D |

1. ^A = Package A
2. ^B = Package B
3. ^C = Package C
4. ^D = Package D


Schedule B1. Trane WSHP Cut Sheets (continued)



Performance Data

Fan Performance

Figure 20. GEV 072 Front/Back Supply Fan Performance Curve



includes wet coil, no filter

Table 63. GEV 072 - Front/Back Supply - Fan Performance (includes wet coil, no filter)

| Std Airflow | Unit External Static Pressure inches W.G. (Wet Coil, No Drive Loss Included & No Return Air Filter) | | | | | | | | | | | | | | | | | | | |
|-------------|--|-------------------|------------------|-------------------|------------------|-------------------|------------------|-------------------|------------------|-------------------|------------------|-------------------|------------------|-------------------|-------------------|-------------------|-------------------|-------------------|--|--|
| | 0.1 | | 0.2 | | 0.3 | | 0.4 | | 0.5 | | 0.6 | | 0.7 | | 0.8 | | 0.9 | | | |
| CFM | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP | | |
| 1920 | 559 ^A | 0.30 ^A | 611 ^A | 0.34 ^A | 660 ^A | 0.39 ^A | 706 ^A | 0.44 ^A | 749 ^A | 0.48 ^A | 790 ^A | 0.53 ^A | 831 ^A | 0.59 ^A | 869 ^A | 0.64 ^A | 907 ^B | 0.70 ^B | | |
| 2160 | 616 ^A | 0.41 ^A | 663 ^A | 0.46 ^A | 708 ^A | 0.51 ^A | 751 ^A | 0.56 ^A | 792 ^A | 0.62 ^A | 830 ^A | 0.67 ^A | 867 ^A | 0.73 ^A | 904 ^B | 0.78 ^B | 939 ^B | 0.84 ^B | | |
| 2400 | 674 ^A | 0.55 ^A | 717 ^A | 0.60 ^A | 759 ^A | 0.66 ^A | 799 ^A | 0.72 ^A | 837 ^A | 0.78 ^A | 873 ^A | 0.84 ^A | 909 ^B | 0.90 ^B | 943 ^B | 0.96 ^B | 975 ^C | 1.02 ^C | | |
| 2640 | 733 ^A | 0.71 ^A | 773 ^A | 0.78 ^A | 811 ^A | 0.84 ^A | 849 ^A | 0.90 ^A | 884 ^A | 0.97 ^A | 919 ^C | 1.03 ^C | 953 ^C | 1.10 ^C | 985 ^C | 1.16 ^C | 1016 ^C | 1.23 ^C | | |
| 2880 | 793 ^A | 0.91 ^A | 830 ^A | 0.98 ^A | 865 ^C | 1.05 ^C | 900 ^C | 1.12 ^C | 934 ^C | 1.19 ^C | 966 ^C | 1.26 ^C | 998 ^C | 1.33 ^C | 1029 ^C | 1.40 ^C | 1060 ^C | 1.47 ^C | | |

| Std Airflow | Unit External Static Pressure inches W.G. (Wet Coil, 3% Drive Loss Included & No Return Air Filter) | | | | | | | |
|-------------|--|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|
| | 1.0 | | 1.1 | | 1.2 | | 1.3 | |
| CFM | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP |
| 1920 | 947 ^B | 0.76 ^B | 988 ^B | 0.83 ^B | 1030 ^B | 0.90 ^B | 1068 ^B | 0.97 ^B |
| 2160 | 974 ^B | 0.91 ^B | 1008 ^B | 0.97 ^B | 1042 ^C | 1.04 ^C | 1079 ^C | 1.11 ^C |
| 2400 | 1007 ^C | 1.08 ^C | 1040 ^C | 1.15 ^C | 1071 ^C | 1.22 ^C | 1102 ^C | 1.29 ^C |
| 2640 | 1046 ^C | 1.29 ^C | 1076 ^C | 1.36 ^C | 1106 ^C | 1.43 ^C | 1135 ^D | 1.51 ^D |
| 2880 | 1088 ^D | 1.54 ^D | 1116 ^D | 1.61 ^D | 1144 ^D | 1.69 ^D | 1172 ^D | 1.77 ^D |

1. ^A = Package A
2. ^B = Package B
3. ^C = Package C
4. ^D = Package D


Schedule B1. Trane WSHP Cut Sheets (continued)



Performance Data

Fan Performance

Figure 25. GEV 150 Top Supply Fan Performance Curve



includes wet coil, no filter

Table 63. GEV 150 - Top Supply - Fan Performance (includes wet coil, no filter)

| Std Airflow | Unit External Static Pressure inches W.G. (Wet Coil, 3% Drive Loss Included & No Return Air Filter) | | | | | | | | | | | | | | | | | | |
|----------------|---|-------------------|------------------|-------------------|------------------|-------------------|------------------|-------------------|------------------|-------------------|------------------|-------------------|------------------|-------------------|------------------|-------------------|------------------|-------------------|--|
| | 0.1 | | 0.2 | | 0.3 | | 0.4 | | 0.5 | | 0.6 | | 0.7 | | 0.8 | | 0.9 | | |
| CFM | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP | |
| 4000 | | | | | | | | | | | | | | | | | | | |
| 4500 | | | 607 ^A | 1.22 ^A | 639 ^A | 1.31 ^A | 671 ^A | 1.41 ^A | 702 ^A | 1.52 ^A | 733 ^A | 1.62 ^A | 762 ^A | 1.72 ^A | 791 ^A | 1.82 ^A | 818 ^A | 1.92 ^A | |
| 5000 | 630 ^A | 1.50 ^A | 661 ^A | 1.62 ^A | 690 ^A | 1.72 ^A | 718 ^A | 1.83 ^A | 747 ^A | 1.94 ^A | 776 ^B | 2.06 ^B | 803 ^B | 2.17 ^B | 830 ^B | 2.29 ^B | 856 ^B | 2.40 ^B | |
| 5500 | 686 ^A | 1.96 ^A | 716 ^B | 2.10 ^B | 742 ^B | 2.22 ^B | 768 ^B | 2.33 ^B | 794 ^B | 2.45 ^B | 820 ^B | 2.58 ^B | 847 ^B | 2.71 ^B | 872 ^B | 2.83 ^B | 897 ^B | 2.96 ^B | |
| 6000 | 743 ^B | 2.52 ^B | 771 ^B | 2.68 ^B | 796 ^B | 2.81 ^B | 820 ^B | 2.94 ^B | | | | | 892 ^D | 3.33 ^D | 916 ^D | 3.47 ^D | 939 ^D | 3.61 ^D | |

| Std Airflow | Unit External Static Pressure inches W.G. (Wet Coil, 3% Drive Loss Included & No Return Air Filter) | | | | | | | | | | | | | | | | | |
|----------------|---|-------------------|------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|
| | 1.0 | | 1.1 | | 1.2 | | 1.3 | | 1.4 | | 1.5 | | 1.6 | | 1.7 | | 1.8 | |
| CFM | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP |
| 4000 | 810 ^A | 1.62 ^A | 837 ^A | 1.72 ^A | 864 ^A | 1.81 ^A | 890 ^A | 1.90 ^A | 915 ^C | 1.99 ^C | 939 ^C | 2.09 ^C | 963 ^C | 2.19 ^C | 987 ^C | 2.29 ^C | 1010 ^C | 2.39 ^C |
| 4500 | 845 ^A | 2.02 ^A | 871 ^B | 2.12 ^B | 896 ^B | 2.23 ^B | 920 ^B | 2.34 ^B | 943 ^C | 2.45 ^C | 967 ^C | 2.56 ^C | 991 ^C | 2.67 ^C | 1013 ^C | 2.76 ^C | 1035 ^C | 2.87 ^C |
| 5000 | 882 ^B | 2.51 ^B | 906 ^B | 2.62 ^B | 931 ^B | 2.73 ^B | 954 ^C | 2.84 ^C | 977 ^C | 2.96 ^C | 999 ^D | 3.08 ^D | 1021 ^D | 3.21 ^D | 1043 ^D | 3.33 ^D | 1065 ^D | 3.45 ^D |
| 5500 | 921 ^D | 3.08 ^D | 944 ^D | 3.21 ^D | 967 ^D | 3.33 ^D | 990 ^D | 3.45 ^D | 1013 ^D | 3.57 ^D | 1034 ^D | 3.69 ^D | 1056 ^D | 3.82 ^D | 1076 ^D | 3.95 ^D | 1097 ^D | 4.09 ^D |
| 6000 | 962 ^D | 3.75 ^D | 985 ^D | 3.88 ^D | 1007 ^D | 4.02 ^D | 1028 ^D | 4.15 ^D | 1050 ^D | 4.29 ^D | 1070 ^D | 4.42 ^D | 1091 ^D | 4.55 ^D | 1111 ^D | 4.68 ^D | 1131 ^D | 4.81 ^D |

| Std Airflow | Unit External Static Pressure inches W.G. (Wet Coil, 3% Drive Loss Included & No Return Air Filter) | | | |
|----------------|---|-------------------|-------------------|-------------------|
| | 1.9 | | 2.0 | |
| CFM | RPM | BHP | RPM | BHP |
| 4000 | 1034 ^C | 2.50 ^C | 1059 ^C | 2.61 ^C |
| 4500 | 1057 ^C | 2.98 ^C | 1077 ^D | 3.09 ^D |
| 5000 | 1085 ^D | 3.56 ^D | 1106 ^D | 3.68 ^D |
| 5500 | 1117 ^D | 4.22 ^D | 1136 ^D | 4.35 ^D |
| 6000 | | | | |

- 1. A = Package A
- 2. B = Package B
- 3. C = Package C
- 4. D = Package D


Schedule B1. Trane WSHP Cut Sheets (continued)



Performance Data

Fan Performance

Figure 26. GEV 150 Front/Back Supply Fan Performance Curve



includes wet coil, no filter

Table 69. GEV 150 - Front/Back Supply - Fan Performance (includes wet coil, no filter)

| Std Airflow | Unit External Static Pressure inches W.G. (Wet Coil, 3% Drive Loss Included & No Return Air Filter) | | | | | | | | | | | | | | | | | | | |
|-------------|--|-------------------|------------------|-------------------|------------------|-------------------|------------------|-------------------|------------------|-------------------|------------------|-------------------|------------------|-------------------|------------------|-------------------|------------------|-------------------|------------------|-------------------|
| | 0.1 | | 0.2 | | 0.3 | | 0.4 | | 0.5 | | 0.6 | | 0.7 | | 0.8 | | 0.9 | | 1.0 | |
| CFM | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP |
| 4000 | | | | | | | | | 626 ^A | 1.11 ^A | 658 ^A | 1.20 ^A | 689 ^A | 1.28 ^A | 719 ^A | 1.36 ^A | 749 ^A | 1.45 ^A | 779 ^A | 1.54 ^A |
| 4500 | | | | | 606 ^A | 1.28 ^A | 638 ^A | 1.37 ^A | 666 ^A | 1.46 ^A | 695 ^A | 1.55 ^A | 723 ^A | 1.64 ^A | 751 ^A | 1.74 ^A | 779 ^A | 1.84 ^A | 806 ^A | 1.93 ^A |
| 5000 | | | 626 ^A | 1.59 ^A | 654 ^A | 1.69 ^A | 681 ^A | 1.78 ^A | 708 ^A | 1.88 ^A | 735 ^A | 1.98 ^A | 761 ^B | 2.08 ^B | 787 ^B | 2.19 ^B | 812 ^B | 2.29 ^B | 838 ^B | 2.40 ^B |
| 5500 | 652 ^A | 1.95 ^A | 677 ^B | 2.06 ^B | 703 ^B | 2.17 ^B | 728 ^B | 2.28 ^B | 753 ^B | 2.39 ^B | 778 ^B | 2.50 ^B | 802 ^B | 2.61 ^B | 826 ^B | 2.72 ^B | 850 ^B | 2.83 ^B | 873 ^B | 2.95 ^B |
| 6000 | 707 ^B | 2.51 ^B | 730 ^B | 2.63 ^B | 753 ^B | 2.75 ^B | 777 ^B | 2.87 ^B | 800 ^B | 2.99 ^B | | | | | | | 890 ^D | 3.46 ^D | 912 ^D | 3.59 ^D |

| Std Airflow | Unit External Static Pressure inches W.G. (Wet Coil, 3% Drive Loss Included & No Return Air Filter) | | | | | | | | | | | | | | | |
|-------------|--|-------------------|------------------|-------------------|------------------|-------------------|------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|
| | 1.1 | | 1.2 | | 1.3 | | 1.4 | | 1.5 | | 1.6 | | 1.7 | | 1.8 | |
| CFM | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP | RPM | BHP |
| 4000 | 805 ^A | 1.62 ^A | 832 ^A | 1.71 ^A | 859 ^A | 1.80 ^A | 884 ^A | 1.89 ^A | 910 ^C | 1.96 ^C | 936 ^C | 2.06 ^C | 962 ^C | 2.18 ^C | 987 ^C | 2.29 ^C |
| 4500 | 833 ^B | 2.03 ^B | 858 ^B | 2.12 ^B | 884 ^B | 2.22 ^B | 908 ^C | 2.32 ^C | 932 ^C | 2.42 ^C | 955 ^C | 2.51 ^C | 978 ^C | 2.61 ^C | 1002 ^C | 2.72 ^C |
| 5000 | 863 ^B | 2.51 ^B | 888 ^C | 2.62 ^C | 911 ^C | 2.72 ^C | 935 ^C | 2.83 ^C | 958 ^C | 2.93 ^C | 980 ^D | 3.04 ^D | 1002 ^D | 3.15 ^D | 1024 ^D | 3.25 ^D |
| 5500 | 897 ^D | 3.07 ^D | 919 ^D | 3.18 ^D | 942 ^D | 3.30 ^D | 965 ^D | 3.42 ^D | 987 ^D | 3.54 ^D | 1009 ^D | 3.65 ^D | 1030 ^D | 3.77 ^D | 1050 ^D | 3.88 ^D |
| 6000 | 933 ^D | 3.71 ^D | 955 ^D | 3.84 ^D | 976 ^D | 3.97 ^D | 997 ^D | 4.10 ^D | 1017 ^D | 4.22 ^D | 1038 ^D | 4.35 ^D | 1059 ^D | 4.48 ^D | 1078 ^D | 4.60 ^D |

| Std Airflow | Unit External Static Pressure inches W.G. (Wet Coil, 3% Drive Loss Included & No Return Air Filter) | | | |
|-------------|--|-------------------|-------------------|-------------------|
| | 1.9 | | 2.0 | |
| CFM | RPM | BHP | RPM | BHP |
| 4000 | 1011 ^C | 2.39 ^C | 1039 ^C | 2.49 ^C |
| 4500 | 1029 ^C | 2.83 ^C | 1048 ^C | 2.94 ^C |
| 5000 | 1046 ^D | 3.37 ^D | 1067 ^D | 3.48 ^D |
| 5500 | 1071 ^D | 4.00 ^D | 1091 ^D | 4.12 ^D |
| 6000 | 1099 ^D | 4.73 ^D | 1118 ^D | 4.86 ^D |

- 1. A = Package A
- 2. B = Package B
- 3. C = Package C
- 4. D = Package D


Schedule B1. Trane WSHP Cut Sheets (continued)



Dimensional Data

GEV - Back Return/Front Supply

GEV 072-120



| Unit | A | B | C |
|---------|--------------|---------------|--------|
| GEV 072 | 6 5/8" (168) | 18 3/8" (467) | 1 1/4" |
| 090 | 6 5/8" (168) | 18 3/8" (467) | 1 1/4" |
| 120 | 6 1/2" (165) | 18 1/2" (470) | 1 1/2" |


Schedule B1. Trane WSHP Cut Sheets (continued)



Dimensional Data

GEV - Back Return/Front Supply

GEV 150-180



Schedule B1. Trane WSHP Cut Sheets (continued)



Mechanical Specifications

General

Equipment is completely assembled, piped, internally wired, fully charged with HCFC-22 and test operated at the factory. Filters, thermostat field interface terminal strip, and all safety controls are furnished and factory installed.

The system water inlet and outlet connections are female NPT composed of either a copper or a bronze option.

The 6 through 10-ton equipment contain ETL, CETL and ISO-ARI 13256-1 listings and labels prior to leaving the factory. Larger units are rated in accordance with ISO-ARI 13256-1. Service and caution area labels are placed on the unit in their appropriate locations.

Cabinet

Unit casing is constructed of zinc coated, heavy gauge, galvanized steel.

Access to the refrigerant and controls is provided through the front and side access panels.

All panels are insulated with 1/2-inch thick dual density bonded glass fiber. The exposed side is a high density erosion proof material suitable for use in air streams up to 3600 feet per minute (FPM). The insulation meets the erosion requirements of UL 181. It has a flame spread of less than 25 and a smoke developed classification of less than 50 per ASTM E-84 and UL 723.

Access for inspection and cleaning of the unit drain pan, coils and fan section are provided. The unit shall be installed for proper access.

Filters

One inch or two inch, throwaway filters are standard and factory installed. The filters have an average resistance of 76-percent and dust holding capacity of 26-grams per square foot.

Sound Attenuation

Sound attenuation is applied as a standard feature in the product design.

All units are tested and rated in accordance with ARI 260.

Compressors

The unit contains a high efficiency reciprocating or scroll compressor. External vibration isolation is provided by rubber mounting devices located underneath the mounting base of the compressor. A second isolation of the refrigeration assembly is supported under the compressor mounting base.

Internal thermal overload protection is provided. Protection against excessive discharge pressure is provided by means of a high pressure switch. A loss of charge is provided by a low pressure safety.

Refrigerant Tubing

The refrigerant tubing is of 99% pure copper. This system shall be free from contaminants and conditions such as drilling fragments, dirt and oil. All refrigerant and water lines are insulated with an elastomeric insulation that has a 3/8-inch thick wall in the air-side section of the unit.

Refrigerant Circuits

The refrigerant circuit contains a thermal expansion device. Service pressure ports are factory supplied on the high and low pressure sides for easy refrigerant pressure or temperature testing.

Air-to-Refrigerant Coil

Internally finned, 3/8-inch copper tubes mechanically bonded to a configured aluminum plate fin are standard. Coils are leak tested at the factory to ensure the pressure integrity. The coil is leak tested to 200 psig and pressure tested to 450 psig. The tubes are to be completely evacuated of air and correctly charged with proper volume of refrigerant prior to shipment.

The refrigerant coil distributor assembly is of orifice style with

round copper distributor tubes. The tubes are sized consistently with the capacity of the coil. Suction header is fabricated from rounded copper pipe.

A thermostatic expansion valve is factory selected and installed for a wide range of control.

Drain Pan

The condensate pan is constructed of corrosion resistant material and insulated to prevent sweating. The bottom of the drain pan is sloped on two planes which pitches the condensate to the drain connection. The drain pan is flame rated per UL945V-B. When the unit is installed and trapped per the manufacturers installation manual, and local city specifications, the drain pan shall be designed to leave puddles no more than 2-inch in diameter, no more than 1/8-inch deep, no longer than 3-minutes following the step 3 of the following test.

- Temporarily plug the drain pan.
- Fill the drain pan with 1/2-inch of water or the maximum allowed by the drain pan depth, whichever is smaller.
- Remove the temporary plug.

Water-to-Refrigerant Heat Exchanger

The water-to-refrigerant heat exchanger is of a high quality co-axial coil for maximum heat transfer. The copper or optional cupro-nickel coil shall be deeply fluted to enhance heat transfer and minimize fouling and scaling. The coil has a working pressure of 400 psig on both the refrigerant and water sides.

Schedule B1. Trane WSHP Cut Sheets (continued)



Mechanical Specifications

Indoor Fan

The blower has nine blower motor/sheave combinations available.

Options of the blower motor/fan packages are selected and wired from the factory to match performance criteria suggested in the performance section.

The fan(s) are placed in a draw-through configuration. They are constructed of corrosion resistant galvanized material.

Electrical

The unit control box contains all necessary devices to allow heating and cooling operation to occur from a remote wall thermostat. These devices are as follows:

- 24 VAC energy limiting class II 75 VA (minimum) transformer.
- 24 VAC blower motor relay.
- 24 VAC compressor contactor for compressor control.
- Field thermostat connections shall be provided for ease of hook-up to a terminal strip located in the unit's control box.
- Lockout relay which controls cycling of the compressor shall be provided to protect the compressor during adverse operating conditions. The device may be reset by interrupting power to the 24 VAC control circuit. Reset may be done either at a remote thermostat or through a momentary main power interruption.
- A high pressure switch shall protect the compressor against operation at refrigerant system pressures exceeding 395 psig.
- The low-water temperature switch or sensor shall prevent the compressor operation with leaving water temperatures below 20 F.
- Factory installed wire harness shall be available for the Deluxe, ZN510 and ZN524 control packages.

Nameplate information shall be provided for the application of either time-delay fuses or HACR circuit breakers for branch circuit protection from the primary source of power.

Deluxe Controls (option)

The deluxe control package provides a 75 VA transformer with circuit breaker. The controller includes a lockout relay, anti-short cycle compressor protection, random start delay, brown-out protection, low pressure time delay, compressor delay on start and an open relay for night setback or pump request. Optional wiring from the factory for night setback, condensate overflow, hot gas reheat, electric heat, and compressor enable is also provided. Three LEDs (light emitting diodes) are included for diagnostics of the equipment.

Tracer ZN510 Controller (option)

This system utilizes factory furnished and mounted DDC controls for operation of up to 120 units on a Comm 5 (LonMark) link. The Tracer ZN510 control package includes a 75 VA transformer. The controller provides random start delay, heating/cooling status, occupied/unoccupied mode, fan status and filter maintenance options. Optional wiring from the factory for condensate overflow is available. Three LEDs (light emitting diodes) are included for diagnostics of the equipment.

The ZN510 is capable of a standalone application, or as applied to a full building automation installation.

Tracer ZN524 Controller (option)

The ZN524 controller utilizes factory furnished and mounted DDC controls for operation of up to 120 units on a Comm 5 (LonMark) link. The Tracer ZN524 control package includes a 75 VA (minimum) transformer. The controller provides random start delay, heating/cooling status, occupied/unoccupied mode, fan status and filter maintenance options. Optional wiring from the factory for condensate overflow is available. Three LEDs (light emitting diodes) are included for diagnostics of the equipment.

The ZN524 is capable of a standalone application, or as applied to a full building automation installation.

With this controller, the unit is capable of a hot gas reheat (for dehumidification), boilerless control

for electric heat, waterside economizing, and support of variable speed pump control applications.

Economizing Coil (option)

The waterside economizing package is an external unit accessory piping kit and wiring ready for turn-key installation to the unit. The economizing coil is designed to perform with the WSHP at unit measured flow rate of 80.6 F DB/66.2 F WB with 45 F EWT.

All hydronic coils are of 3/8" (6-20 ton units), 1/2" (25 ton unit) copper and aluminum plate fin combination. All coils are proof and leak tested from the manufacturer.

The proof test is performed at 1.5 times the maximum operating pressure and the leak test at the maximum operating pressure.

A dual sloped non corrosive drain pan is easily accessible and cleanable for the hydronic economizing coil.

An electronic two-position, 3-way valve meters water flow to the economizing coil during the economizing mode. It is factory set to energize the economizing mode at 55 F, while simultaneously halting mechanical operation of the compressor.

The economizer is field attached to the equipment.

Electric Heat (option)

Boilerless control electric heat is factory wired and tested.

The boilerless control option is composed of a controls interface for a field provided boilerless or supplemental electric heat selection. The heater for this model is placed external to the equipment by the contractor for ease of installation. All power connections for the electric heater will be completely separate from the unit for field supplied electric heat.

Schedule B1. Trane WSHP Cut Sheets (continued)

Mechanical Specifications

Hot Gas Reheat (option)

Dehumidification is provided through a hot gas reheat option. The coil consists of 3/8" x 1/2" copper tubes mechanically expanded into evenly spaced aluminum fins. All coils are proof and leak tested. The proof test must be performed at 1.5 times the maximum operating pressure and the leak test performed at the maximum operating pressure.

Ball Valves (option)

Ball valves are field installed between the unit and the supply and return lines of the loop to stop water flow to the unit in a maintenance or service situation.

Motorized Water Valve (option)

When extreme fluid temperature conditions do not exist with an open loop system, a motorized water valve may be applied to each water-source heat pump. The motorized valve shall stop flow to the unit, causing pressures to rise. This rise in pressure will halt pump operation to provide greater energy savings of the entire system.

Hoses (option)

Hoses consists of a stainless steel outer braid with an inner core of tube made of a nontoxic synthetic polymer material. The hoses are suitable for water temperatures ranging between 33 F and 211 F without the use of glycol.

Automatic Flow Devices (option)

The automatic flow kit contains a Hays Mesurflo® automatic flow control valve, two ball valves, two flexible hoses, a high flow Y-strainer, and may include a strainer blow-down and various other accessories.

The automatic flow control valve is factory set to a rated flow, and shall automatically control the flow to within 10% of the rated value over a 40 to 1 differential pressure, operating range (2 to 80 PSID). Operational temperature is rated from fluid freezing, to 225-degrees F. The valve body shall be constructed from hot forged brass UNS C37700 per ASTM B-283 latest revision. For more information pertaining to the automatic balancing hose kits, see literature documentation WSHP-SLB005-EN.



Trane
A business of American Standard Companies
www.trane.com

For more information, contact your local Trane office or e-mail us at comfort@trane.com

| | |
|-------------------------|----------------------------------|
| Literature Order Number | WSHP-PR0014-EN |
| File Number | PL-UN-000-WSHP-PR 0014-EN |
| Date | April 2006r |
| Supersedes | PL-UN-000-WSHP-PR 0014-EN (0104) |
| Stocking Location | Inland |

Trane has a policy of continuous product and product data improvement and reserves the right to change design and specifications without notice.

Schedule B2. Krueger Air Diffuser Cut Sheets



SUPPLY | ROUND DIFFUSERS

RM2/RM4/RA2/RA4 SERIES | FOUR-CONES



RM2/5RM2/RM4/5RM4/RA2/RA4 PERFORMANCE DATA: HORIZONTAL/VERTICAL THROW

▼ IP/METRIC DATA: RM2/5RM2/RM4/5RM4/RA2/RA4 (NO DAMPER)

| | Neck Vel | Air Flow | IP Data | | | | | | | | | HZ | VT | Neck Vel | Air Flow | Metric Data | | | | | | | | |
|-------------|----------|----------|------------|------|----------|------|------------------|------|------|------|---------------------|-----------|-----------|----------|----------|------------------|---------------------|------|------|-------------|------|------|------|------|
| | | | Horizontal | | Vertical | | Horizontal Throw | | | | Vertical Projection | | | | | Horizontal Throw | Vertical Projection | | | | | | | |
| | | | Pa | Pt | Pa | Pt | 10°F | 20°F | 30°F | 40°F | 10°F | | | | | | 20°F | 30°F | 40°F | m | 5°C | 11°C | 17°C | 22°C |
| FPM | CFM | "WG | "WG | "WG | "WG | ft | ft | ft | ft | ft | ft | ft | ft | ft | ft | m | m | m | m | | | | | |
| 6" Dia. | 200 | 39 | 0.00 | 0.01 | 0.00 | 0.01 | 1-1-2 | 0 | 0 | 0 | 0 | - | - | 1.0 | 19 | 1 | 1 | 1 | 1 | 0.2-0.3-0.7 | 0.1 | 0.1 | 0.1 | 0.1 |
| | 400 | 79 | 0.01 | 0.02 | 0.02 | 0.03 | 1-2-4 | 2 | 1 | 1 | 1 | - | - | 2.0 | 37 | 3 | 5 | 5 | 2 | 0.5-0.7-1.4 | 0.5 | 0.4 | 0.3 | 0.3 |
| | 600 | 118 | 0.02 | 0.05 | 0.04 | 0.06 | 2-3-7 | 4 | 3 | 3 | 2 | 20 | 21 | 3.0 | 56 | 6 | 12 | 12 | 6 | 0.7-1.0-2.0 | 1.1 | 0.8 | 0.8 | 0.8 |
| | 800 | 157 | 0.04 | 0.08 | 0.07 | 0.11 | 3-4-8 | 6 | 5 | 4 | 4 | 29 | 30 | 4.1 | 74 | 11 | 21 | 21 | 10 | 0.9-1.4-2.3 | 1.9 | 1.4 | 1.4 | 1.1 |
| | 900 | 177 | 0.06 | 0.11 | 0.09 | 0.14 | 3-5-8 | 8 | 6 | 6 | 5 | 32 | 33 | 4.8 | 83 | 14 | 26 | 26 | 13 | 1.0-1.5-2.5 | 2.4 | 1.8 | 1.7 | 1.4 |
| | 1000 | 196 | 0.07 | 0.13 | 0.11 | 0.17 | 4-6-9 | 10 | 7 | 7 | 8 | 36 | 36 | 5.1 | 93 | 17 | 33 | 33 | 16 | 1.1-1.7-2.8 | 3.0 | 2.2 | 2.1 | 1.8 |
| | 1100 | 216 | 0.08 | 0.16 | 0.13 | 0.21 | 4-6-9 | 12 | 9 | 8 | 7 | 38 | 39 | 5.6 | 102 | 21 | 39 | 39 | 19 | 1.2-1.9-2.7 | 3.6 | 2.7 | 2.5 | 2.1 |
| 8" Dia. | 200 | 70 | 0.00 | 0.01 | 0.00 | 0.01 | 1-1-3 | 1 | 1 | 1 | 1 | - | - | 1.0 | 33 | 1 | 1 | 1 | 1 | 0.3-0.5-0.9 | 0.3 | 0.2 | 0.2 | 0.2 |
| | 400 | 140 | 0.01 | 0.02 | 0.02 | 0.03 | 2-3-6 | 4 | 3 | 3 | 2 | - | - | 2.0 | 66 | 3 | 5 | 5 | 2 | 0.6-0.9-1.8 | 1.1 | 0.8 | 0.8 | 0.7 |
| | 600 | 209 | 0.02 | 0.05 | 0.04 | 0.06 | 3-4-9 | 6 | 6 | 6 | 5 | 21 | 22 | 3.0 | 99 | 6 | 12 | 12 | 6 | 0.9-1.4-2.7 | 2.5 | 1.9 | 1.8 | 1.5 |
| | 800 | 279 | 0.04 | 0.08 | 0.07 | 0.11 | 4-8-10 | 14 | 11 | 10 | 9 | 30 | 31 | 4.1 | 132 | 11 | 21 | 21 | 10 | 1.2-1.8-3.1 | 4.4 | 3.3 | 2.9 | 2.6 |
| | 900 | 314 | 0.06 | 0.11 | 0.09 | 0.14 | 4-7-11 | 16 | 13 | 11 | 10 | 33 | 34 | 4.6 | 148 | 14 | 26 | 26 | 13 | 1.4-2.0-3.3 | 4.9 | 4.0 | 3.3 | 3.1 |
| | 1000 | 349 | 0.07 | 0.13 | 0.11 | 0.17 | 5-7-11 | 18 | 15 | 12 | 11 | 36 | 37 | 5.1 | 165 | 17 | 33 | 33 | 16 | 1.5-2.3-3.5 | 5.5 | 4.4 | 3.6 | 3.4 |
| | 1100 | 384 | 0.08 | 0.16 | 0.13 | 0.21 | 5-8-12 | 20 | 16 | 13 | 12 | 39 | 40 | 5.6 | 181 | 21 | 39 | 39 | 19 | 1.7-2.5-3.6 | 6.0 | 4.9 | 4.0 | 3.8 |
| 10" Dia. | 200 | 109 | 0.00 | 0.01 | 0.00 | 0.01 | 1-2-4 | 2 | 1 | 1 | 1 | - | - | 1.0 | 51 | 1 | 1 | 1 | 1 | 0.4-0.6-1.1 | 0.5 | 0.4 | 0.3 | 0.3 |
| | 400 | 218 | 0.01 | 0.02 | 0.02 | 0.03 | 2-4-7 | 7 | 5 | 5 | 4 | - | - | 2.0 | 103 | 3 | 5 | 5 | 2 | 0.8-1.1-2.3 | 2.0 | 1.5 | 1.4 | 1.2 |
| | 600 | 327 | 0.02 | 0.05 | 0.04 | 0.06 | 4-6-11 | 15 | 11 | 10 | 9 | 22 | 23 | 3.0 | 154 | 6 | 12 | 12 | 6 | 1.1-1.7-3.3 | 4.5 | 3.3 | 3.1 | 2.8 |
| | 800 | 436 | 0.04 | 0.08 | 0.07 | 0.11 | 5-7-13 | 20 | 16 | 13 | 13 | 31 | 32 | 4.1 | 206 | 11 | 21 | 21 | 10 | 1.5-2.3-3.9 | 6.2 | 5.0 | 4.1 | 3.8 |
| | 900 | 491 | 0.06 | 0.11 | 0.09 | 0.14 | 6-8-13 | 23 | 18 | 15 | 14 | 34 | 35 | 4.6 | 232 | 14 | 26 | 26 | 13 | 1.7-2.5-4.1 | 6.9 | 5.6 | 4.6 | 4.3 |
| | 1000 | 545 | 0.07 | 0.13 | 0.11 | 0.17 | 6-9-14 | 25 | 20 | 17 | 16 | 37 | 38 | 5.1 | 257 | 17 | 33 | 33 | 16 | 1.9-2.8-4.3 | 7.7 | 6.2 | 5.1 | 4.8 |
| | 1100 | 600 | 0.08 | 0.16 | 0.13 | 0.21 | 7-10-15 | 28 | 22 | 18 | 17 | 40 | 41 | 5.6 | 283 | 21 | 39 | 39 | 19 | 2.1-3.1-4.5 | 8.5 | 6.8 | 5.6 | 5.3 |
| 12" Dia. | 200 | 157 | 0.00 | 0.01 | 0.00 | 0.01 | 1-2-4 | 2 | 2 | 2 | 1 | - | - | 1.0 | 74 | 1 | 1 | 1 | 1 | 0.5-0.7-1.4 | 0.7 | 0.6 | 0.5 | 0.4 |
| | 400 | 314 | 0.01 | 0.02 | 0.02 | 0.03 | 3-4-9 | 10 | 7 | 7 | 6 | 11 | 12 | 2.0 | 148 | 3 | 5 | 5 | 2 | 0.9-1.4-2.7 | 3.0 | 2.2 | 2.1 | 1.7 |
| | 600 | 471 | 0.02 | 0.05 | 0.04 | 0.06 | 4-7-13 | 20 | 16 | 13 | 12 | 23 | 24 | 3.0 | 222 | 6 | 12 | 12 | 6 | 1.4-2.0-4.0 | 6.0 | 4.8 | 4.0 | 3.7 |
| | 800 | 628 | 0.04 | 0.08 | 0.07 | 0.11 | 6-9-15 | 26 | 21 | 17 | 16 | 31 | 32 | 4.1 | 297 | 11 | 21 | 21 | 10 | 1.8-2.7-4.6 | 8.0 | 6.4 | 5.3 | 5.0 |
| | 900 | 707 | 0.06 | 0.11 | 0.09 | 0.14 | 7-10-16 | 29 | 24 | 20 | 18 | 35 | 36 | 4.6 | 334 | 14 | 26 | 26 | 13 | 2.0-3.1-4.9 | 9.0 | 7.2 | 5.9 | 5.6 |
| | 1000 | 785 | 0.07 | 0.13 | 0.11 | 0.17 | 7-11-17 | 33 | 26 | 22 | 20 | 38 | 39 | 5.1 | 371 | 17 | 33 | 33 | 16 | 2.3-3.4-5.2 | 10.0 | 8.0 | 6.6 | 6.2 |
| | 1100 | 864 | 0.08 | 0.16 | 0.13 | 0.21 | 8-12-18 | 35 | 28 | 24 | 22 | 41 | 42 | 5.6 | 408 | 21 | 39 | 39 | 19 | 2.5-3.7-5.4 | 10.8 | 8.4 | 7.3 | 6.8 |
| 14" Dia. | 200 | 214 | 0.00 | 0.01 | 0.00 | 0.01 | 2-3-5 | 3 | 2 | 2 | 2 | - | - | 1.0 | 101 | 1 | 1 | 1 | 1 | 0.5-0.8-1.6 | 1.0 | 0.8 | 0.7 | 0.6 |
| | 400 | 428 | 0.01 | 0.02 | 0.02 | 0.03 | 3-5-10 | 13 | 10 | 9 | 8 | 11 | 12 | 2.0 | 202 | 3 | 5 | 5 | 2 | 1.1-1.6-3.2 | 4.1 | 3.0 | 2.9 | 2.4 |
| | 600 | 641 | 0.02 | 0.05 | 0.04 | 0.06 | 5-8-15 | 24 | 19 | 16 | 15 | 23 | 24 | 3.0 | 303 | 6 | 12 | 12 | 6 | 1.6-2.4-4.7 | 7.4 | 5.9 | 4.9 | 4.6 |
| | 800 | 855 | 0.04 | 0.08 | 0.07 | 0.11 | 7-10-18 | 32 | 26 | 21 | 20 | 32 | 33 | 4.1 | 404 | 11 | 21 | 21 | 10 | 2.1-3.2-5.4 | 9.8 | 7.9 | 6.5 | 6.1 |
| | 900 | 962 | 0.06 | 0.11 | 0.09 | 0.14 | 8-12-19 | 36 | 29 | 24 | 23 | 35 | 36 | 4.6 | 454 | 14 | 26 | 26 | 13 | 2.4-3.6-5.7 | 11.0 | 9.9 | 7.3 | 6.9 |
| | 1000 | 1069 | 0.07 | 0.13 | 0.11 | 0.17 | 9-13-20 | 39 | 31 | 27 | 25 | 39 | 40 | 5.1 | 505 | 17 | 33 | 33 | 16 | 2.6-4.0-6.0 | 12.0 | 9.3 | 6.1 | 7.6 |
| | 1100 | 1176 | 0.08 | 0.16 | 0.13 | 0.21 | 10-14-21 | 41 | 32 | 29 | 27 | 41 | 42 | 5.6 | 555 | 21 | 39 | 39 | 19 | 2.9-4.4-6.3 | 12.6 | 9.8 | 8.9 | 8.1 |
| 16" Dia. | 200 | 279 | 0.00 | 0.01 | 0.00 | 0.01 | 2-3-6 | 4 | 3 | 3 | 3 | - | - | 1.0 | 132 | 1 | 1 | 1 | 1 | 0.6-0.9-1.8 | 1.3 | 1.0 | 0.9 | 0.8 |
| | 400 | 559 | 0.01 | 0.02 | 0.02 | 0.03 | 4-6-12 | 17 | 13 | 12 | 10 | 12 | 13 | 2.0 | 264 | 3 | 5 | 5 | 2 | 1.2-1.8-3.6 | 5.2 | 3.9 | 3.7 | 3.0 |
| | 600 | 838 | 0.02 | 0.05 | 0.04 | 0.06 | 6-9-16 | 29 | 23 | 19 | 18 | 24 | 25 | 3.0 | 395 | 6 | 12 | 12 | 6 | 1.8-2.7-5.4 | 8.7 | 7.0 | 5.6 | 5.4 |
| | 800 | 1117 | 0.04 | 0.08 | 0.07 | 0.11 | 8-12-20 | 38 | 31 | 25 | 24 | 32 | 33 | 4.1 | 527 | 11 | 21 | 21 | 10 | 2.4-3.6-6.2 | 11.6 | 9.4 | 7.7 | 7.3 |
| | 900 | 1257 | 0.06 | 0.11 | 0.09 | 0.14 | 9-13-22 | 43 | 33 | 29 | 27 | 36 | 37 | 4.6 | 593 | 14 | 26 | 26 | 13 | 2.7-4.1-6.8 | 13.0 | 10.1 | 8.7 | 8.2 |
| | 1000 | 1396 | 0.07 | 0.13 | 0.11 | 0.17 | 10-15-23 | 45 | 35 | 32 | 29 | 39 | 40 | 5.1 | 659 | 17 | 33 | 33 | 16 | 3.0-4.5-6.9 | 13.7 | 10.7 | 9.6 | 8.8 |
| | 1100 | 1538 | 0.08 | 0.16 | 0.13 | 0.21 | 11-16-24 | 47 | 37 | 35 | 31 | 42 | 43 | 5.6 | 725 | 21 | 39 | 39 | 19 | 3.3-5.0-7.2 | 14.4 | 11.2 | 10.6 | 9.3 |

ROUND DIFFUSERS

RM2 - RM4 - RA2 - RA4

► Throw values are given terminal velocities of 150, 100, and 50 FPM (0.75, 0.50, and 0.25 m/s). Horizontal throw values are given for isothermal conditions. Vertical throw values are for a terminal velocity of 50 FPM at the temperature differences shown. NC values are based on octave band 2 - 7 sound power levels minus a room absorption of 10dB, re 10⁻¹² watts. Dash (-) in space denotes a NC value of less than 10. Data was obtained from tests conducted in accordance with ANSI/ASHRAE Standard 70, ISO Standard 5219, and ISO Standard 3741. See K-Select program for performance data not shown, including octave band data.

Schedule B2. Krueger Air Diffuser Cut Sheets (cont'd.)

SUPPLY | ROUND DIFFUSERS



RM2/RM4/RA2/RA4 SERIES | FOUR-CONES



RM2/5RM2/RM4/5RM4/RA2/RA4 PERFORMANCE DATA: HORIZONTAL/VERTICAL THROW

▼ IP/METRIC DATA: RM2/5RM2/RM4/5RM4/RA2/RA4 (NO DAMPER)

ROUND DIFFUSERS

Table with columns for Neck Vel, Air Flow, Horizontal, Vertical, Horizontal Throw, Vertical Projection, HZ, VT, Neck Vel, Air Flow, Horizontal, Vertical, Horizontal Throw, Vertical Projection. Rows are grouped by diameter (18", 20", 24", 30", 36") and include FPM and CFM values.

► Throw values are given terminal velocities of 150, 100, and 50 FPM (0.75, 0.50, and 0.25 m/s). Horizontal throw values are given for isothermal conditions. Vertical throw values are for a terminal velocity of 50 FPM at the temperature differences shown. NC values are based on octave band 2 - 7 sound power levels minus a room absorption of 10dB, re 10^-12 watts. Dash (-) in space denotes a NC value of less than 10. Data was obtained from tests conducted in accordance with ANSI/ASHRAE Standard 70, ISO Standard 5219, and ISO Standard 3741. See K-Select program for performance data not shown, including octave band data.

Schedule B2. Krueger Air Diffuser Cut Sheets (cont'd.)



SUPPLY | ROUND DIFFUSERS

RM/RA SERIES | CONE DIFFUSERS



INTRODUCTION: RM/RA SERIES

Krueger's RM/RA round ceiling diffusers provide excellent performance in variable air volume systems. The round ceiling diffusers have three or four cones depending on model selected to provide a uniform appearance regardless of design specifications. Krueger's round ceiling diffusers come in three styles.

The first style, RM1/5RM1, is used when vertical throw is not needed, but the consumer needs to adjust the room air induction. This is accomplished by utilizing the two position inner cones. At position one, capacity is maximized. In position two, room air induction is increased.

The second style, RM2/5RM2/RM4/5RM4, is used when horizontal and vertical discharge is required. This is accomplished by utilizing the three position inner cones. At position one, capacity is maximized and throw is horizontal. In position two, room air induction is increased and the throw remains horizontal. When set in position three, the air projects vertically from the diffuser.

The third style, RA2/RA4, is used when horizontal and vertical discharge is required with infinite adjustability between horizontal and vertical. In the full open setting, capacity is maximized and throw is horizontal. In the full closed setting, air projects vertically from the diffuser.

Krueger's round ceiling diffusers come with a safety cable to secure the inner cones after removal. (Safety cable is optional for 12" inlet size or smaller.)

MODELS

- MODEL RM1 - Steel, 3-Cones, 2-Position Adjustments
- MODEL 5RM1 - Aluminum, 3-Cones, 2-Position Adjustments
- MODEL RM2 - Steel, 4-Cones, 3-Position Adjustments
- MODEL 5RM2 - Aluminum, 4-Cones, 3-Position Adjustments
- MODEL RM4 - Steel, 4-Cones, 3-Position Adjustments with Large Outer Anti-smudge Cone
- MODEL 5RM4 - Aluminum, 4-Cones, 3-Position Adjustments with Large Outer Anti-smudge Cone
- MODEL RA2 - Steel, 4-Cones, Fully Adjustable
- MODEL RA4 - Aluminum, 4-Cones, Fully Adjustable, with Large Outer Anti-smudge Cone

FEATURES

- Horizontal Only (RM1/5RM1) Air Distribution
- Horizontal/Vertical (RM2/5RM2/RM4/5RM4/RA2/RA4) Air Distribution
- Designed for Heating and Cooling Applications
- 360° Discharge Air Pattern
- Excellent Performance in Variable Air Volume Systems
- Designed for Exposed Duct or Hard Ceiling Applications

ACCESSORIES

- Optional Safety Cable (12" Inlets or Smaller)
- Optional Round Straightening Grid

RM1 ▶



RM2 ▶



RA4 ▶



ROUND DIFFUSERS

RM - RA SERIES

Schedule B2. Krueger Air Diffuser Cut Sheets (cont'd.)

SUPPLY | ROUND DIFFUSERS




RA2 | FOUR-CONES



RA2 DIMENSIONAL INFORMATION

▼ RA2, CROSS SECTION



ROUND DIFFUSERS


▼ RA2, AVAILABLE NECK SIZES

| Nominal Round Duct Size | Ceiling Opening Diameter B | Outside Diameter C | Position 1 (Horizontal) D | Position 3 (Vertical) D | H | P |
|-------------------------|----------------------------|--------------------|---------------------------|-------------------------|--------------|--------------|
| 6" | 12" (305) | 13 1/2" (343) | 1 7/16" (37) | 11/16" (17) | 1 5/8" (41) | - |
| 8" | 16" (406) | 18" (457) | 1 13/16" (46) | 7/8" (19) | 2 1/8" (54) | - |
| 10" | 20" (508) | 22 1/2" (572) | 2 1/4" (57) | 1 1/8" (29) | 2 5/8" (67) | - |
| 12" | 24" (635) | 27" (686) | 2 11/16" (68) | 1 1/4" (32) | 3 1/4" (83) | - |
| 14" | 28" (711) | 31 1/2" (800) | 3 1/8" (79) | 1 3/16" (30) | 3 3/4" (95) | 2 1/2" (64) |
| 16" | 32" (813) | 36" (914) | 3 5/16" (84) | 1 5/16" (33) | 4 1/4" (108) | 2 5/8" (67) |
| 18" | 36" (914) | 40 1/2" (1029) | 3 3/4" (95) | 1 1/2" (38) | 4 7/8" (124) | 2 3/4" (70) |
| 20" | 40" (1016) | 45" (1143) | 4 1/8" (105) | 1 5/8" (41) | 5 3/8" (137) | 3" (76) |
| 24" | 48" (1219) | 54" (1372) | 4 7/8" (121) | 1 7/8" (48) | 6 1/2" (165) | 3 1/8" (79) |
| 30" | 60" (1524) | 67 1/2" (1715) | 5 9/16" (141) | 1 7/8" (48) | 8" (203) | 4 3/8" (111) |
| 36" | 60" (1524) | 67 1/2" (1715) | 5 9/16" (141) | 1 7/8" (48) | 8" (203) | 4 3/8" (111) |

► Dimensions in () are mm.

RA2 REFERENCE CHART

▼ AIRFLOW VS. NC LEVEL: RA2 (NO DAMPER)



R A 2

Schedule B2. Krueger Air Diffuser Cut Sheets (cont'd.)

SUPPLY | ROUND DIFFUSERS




RM2/RM4/RA2/RA4 SERIES | FOUR-CONES




RM2/5RM2/RM4/5RM4/RA2/RA4 REFERENCE CHARTS: HORIZONTAL THROW

▼ DIFFUSER SPACING FOR 80% ADPI: RM2/5RM2/RM4/5RM4/RA2/RA4, 6" NECK (NO DAMPER)



▼ DIFFUSER SPACING FOR 80% ADPI: RM2/5RM2/RM4/5RM4/RA2/RA4, 14" NECK (NO DAMPER)



► Charts are at 20 BTUH/ft² loads.
See the Engineering section of this catalog for instructions on how to read these charts and additional ADPI information.

ROUND DIFFUSERS

RM2 - RM4 - RA2 - RA4