


Technical Assignment 3

Mechanical Systems Existing Conditions Evaluation



Xanadu Meadowlands Sports Complex Building A East Rutherford, New Jersey

Prepared For:

Dr. James D. Freihaut, PhD

Department of Architectural Engineering

The Pennsylvania State University

Prepared By:

Jason M. Sambolt

Mechanical Option

November 28, 2007

Table of Contents

Executive Summary	Page 3
Building Design Summary	Page 4
Mechanical System Design Objectives and Requirements	Page 5
Mechanical Systems Summary	Page 7
Mechanical Systems Control Logic	Page 10
Design Ventilation Requirements	Page 19
Design Heating and Cooling Loads	Page 21
Annual Energy Use	Page 22
Critique of Mechanical System	Page 24
References	Page 25
Appendix A: Mechanical Equipment Schedules	Page 26
Appendix B: Full Glycol System Schematics	Page 30

Executive Summary

Building A of the Xanadu Sports Complex is comprised of a retail section and an indoor ski resort. While the retail section's mechanical system is a fairly commonly used system the indoor ski resort's mechanical system, introduces a more exotic system that needs to be examined in detail to fully understand how such a building will work. In order to maintain ideal temperatures for snow storage and production a large amount of energy and proper controls to control the process is needed.

This report will look at both the retail's and ski resort's mechanical system and evaluate the current design. A brief summary of how the building will be used is included to provide an idea of what the mechanical system will be serving. The report also looks at some of the factors that affected the design of the systems, such as relevant codes, design conditions, and site conditions. With the design factors given, a description of both systems is provided to create an overall summary of the systems designed. In order to provide understanding of the control process for an uncommon system the control logics section of this report has been written in a format which breaks all major equipment into individual schematics. These schematics provide a detailed look at the controls involved, and a narrative is provided to describe the processes involved. A summary of the ventilation system, design loads, energy use, and annual costs are provided in the final sections of the report.

Based on the findings of this report a critique of the mechanical system design is provided. The findings indicate that areas of improvement exist with the annual energy use, energy sources, indoor air quality, and equipment efficiencies. This critique will provide areas of improvement that will be fully explored in a future redesign project.

Building Design Summary

Building A of the Meadowlands Xanadu complex is designated as the sports district. All sports related retail stores and activities will be housed in this building. Building A has essentially two sections; the south side of Building A will contain all retail stores while the north side of the building will house the Snowdome indoor ski resort.

The retail section of Building A will contain a wide variety of sporting goods stores, a restaurant, and night clubs. The majority of leasable space will be used for retail sales; however, these retail spaces are not included in the current contract. Therefore, for these types of spaces an analysis will not be applicable. All work in retail spaces, night clubs, the ski resort lodge, and the restaurant will be fit out by the tenant near the end of construction.

The north section of Building A will house The United States' first indoor ski resort named the Snowdome. During normal operation the slopes will be comprised of snow laying flat over the distance of the run. However, during special events the slopes can be made into quarter pipes, and jumps can be added for competitions. Aside from skiing and snowboarding competitions the Snowdome is planned to be used for concerts, fashion shows, and parties with a wintery touch. The Snowdome will house 160,000 square feet of cold side space and will include a novice ski slope at 330 feet long by 120 feet wide and an advanced ski slope at 780 feet long and 150 feet wide. During times of normal operation the peak occupancy load is expected to be 300; while during special events the space is designed to provide enough fresh air for 999 people.

Figure 1 below shows the occupancy categories break down for the building.




Figure 1: Building A Occupancy Category Distributions

Mechanical System Design Objectives and Requirements

Building Code

The entire Xanadu Sports Complex including the mechanical system was designed to comply with Building Officials and Code Administrators (BOCA) 1996. Chapter 28 of the BOCA 1996 code covers the provisions of a building's mechanical system. The mechanical section covers topics such as acceptable pipe material, insulation requirements, and plenum sizes; however, prescriptive methods for designing ventilation systems and acceptable comfort levels are not present in the code. It is evident that the BOCA 1996 code is nowhere near as detailed as the current International Mechanical Code (IMC) regulations.

Outdoor and Indoor Design Conditions

The design outdoor conditions used for the load calculations and energy analysis were obtained using the ASHRAE Fundamentals Handbook 2005, and the weather data files were obtained from TRACE 700. The ASHRAE Handbook lists the closest city, Newark, New Jersey, as having a design summer temperature of 91°F DBT and a 73°F WBT. A winter design temperature of 14°F DBT was used and WBT was not used due to the fact that Trace assumes dry winter conditions for certain climate zones. Other weather factors assigned by Trace are clearness factors of 0.99 and a ground reflectance value of 0.2.

The indoor design conditions for the retail section of Building A were not available from the design engineer. For this reason an assumption was made, and the design dry bulb temperature was set at 72°F. While the retail design conditions were not available, the indoor ski resort's conditions were. In the Snowdome during normal day operation, temperatures must be maintained between 30°F and 32°F. However, at night fresh snow is made on a daily schedule, and temperatures must be cooled to approximately 24°F to ensure proper snow making.

Site Factors

As with many of the other design considerations, the design engineer was not available to provide information regarding design considerations; however, a look at the site reveals a problem with the introduction of uncontaminated air to the building. Figure 2 below provides an aerial photo of the site before construction began. The red silhouette represents Building A while the grey silhouette represents the rest of current construction. Figure 2 shows how close the complex is to the New Jersey Turnpike Interstate 95 and Route 120, which are both heavily trafficked on a daily basis. For this reason it is important to avoid introducing highly contaminated air through the building's ventilation system.



Figure 2: Aerial Photo of Complex Site Previous to Construction

Mechanical Systems Summary

Retail Mechanical System

The air side mechanical system for the retail section of Building A uses four roof top air handling units that serve all the common areas of the building. In Building A common spaces are comprised of walkways to the different stores and restaurants, restrooms, back of house rooms, and a large central area that will create a large atrium for all the levels of shopping. All tenant spaces will not have any mechanical work done at this time and will be finished by the leaser towards the completion of the building. All four common area rooftop units are controlled by variable frequency drives with two running modes: occupied mode during normal operating hours and unoccupied mode during the nighttime. A programmable time clock will control when the occupied or unoccupied mode begins to run. A thermostat will control the cycling of the supply fan and energize the electric heating coil to maintain the nighttime setback temperature during the unoccupied mode. During the occupied mode the supply fan will operate continuously. The use of an economizer to maximize atmospheric cooling will also be implemented for all four of the rooftop units.

RTU-1 serves the first and second floor common areas on the east side of the building, and RTU-2 serves the first and second floor common areas on the west side of the building. Both units supply 16,100 cfm of air each with 1,496 cfm of that supply air being outside air. Each unit's cooling coil has a capacity of approximately 38 tons and an electric heating coil capacity of 150 kilowatts. RTU-3 and RTU-4 serve the third floor common areas. Both of these units supply 31,000 cfm of air each with 3,037 cfm of that supply air being outside air. Each unit's cooling coil has a capacity of approximately 78 tons and an electric heating coil capacity of 190 kilowatts. A graphical representation of the atrium's ventilation system can be seen in Figure 3.




Figure 3: Retail Ventilation

In addition to the rooftop units, wall mounted electric unit heaters are used in mechanical spaces, entrance vestibules, and exit stairways to maintain thermal comfort. To ensure fresh air enters the back of house rooms, exhaust fans are installed to negatively pressurize the rooms. With the use of exhaust fans, fresh air that has been supplied to the walkways on the floor will be drawn to the rooms with negative pressure. Small air condition units are also used in elevator machine rooms and the main ground floor entrance to supply cooling when needed.

Snowdome Mechanical System

The challenge of an indoor ski resort is to ensure that snow can be maintained year round and to maintain a highly controlled environment. During normal day operation, temperatures must be maintained between 30°F and 32°F. However, at night fresh snow is made on a daily schedule, and temperatures must be cooled to approximately 24°F to ensure proper snow making. The Xanadu Snowdome plans to achieve ideal conditions by using cooled supply air, under floor glycol piping, recirculation coolers, and snow guns to provide the best skiing conditions every day of the year.

The Snowdome ventilation system is comprised of a single 30,000 cfm air handling unit with 15,000 cfm of the supply air being outside air. The unit uses a main common intake system with one primary and two secondary cooling coils. The air is pre-cooled by means of a thermal wheel and then cooled down to above freezing by the primary cooling coil. The air is then cooled below freezing by the secondary coils which are fed by a cold glycol system. A hot glycol system line is also fed to the secondary coils and will only be used

when the coils need to be defrosted. The system is fully variable in volume, achieved by using inverters on the fans, to suit the current occupancy.

Two 222 ton electric screw chillers operating at 1.5°F leaving glycol temperature provide the cold glycol to the air handling unit's coils, under floor piping matrix, recirculation coolers, and snow guns. Both chillers operate in conjunction with an evaporative condenser located on the roof of the Snowdome mechanical mezzanine which houses all the mechanical equipment.

Mounted along the ceiling of the Snowdome are recirculation coolers and snow guns. Both devices will be run using the cold glycol system during normal operation. However, when the devices need to be defrosted, the cold glycol system will be shut off, and the hot glycol system will be turned on for defrosting. The snow guns also require compressed air for the use of snow making; therefore, a compressed air line will be provided to each snow gun.




Figure 4: Snowdome Mechanical System

Mechanical Systems Control Logic

This section of the report is meant to gain an understanding of the control logic behind the building's mechanical system. While the retail section's mechanical system consists of a basic direct expansion rooftop unit system, the indoor ski resort presents a very special case with unique mechanical equipment. In an attempt to simplify the control logic behind the Snowdome, this section will provide a narrative of the control process and provide a schematic for individual pieces of equipment. Appendix A provides an overall schematic of the Snowdome mechanical system to demonstrate how the individual pieces work as a system.

Retail Rooftop Air Handling Units

The control logic for all four rooftop units serving the retail sections of Building A are the same. A programmable time clock will ensure the supply fan operates continuously during the hours the stores are open. The units have three set cycles: occupied, unoccupied, and morning warm-up.

During the occupied cycle the fan will operate continuously. When the outside air enthalpy sensor E1 reads a value less than the return air enthalpy sensor E2, dampers D1, D2, and D3 will modulate to maximize atmospheric cooling. The supply air temperature sensed by T3 will then be maintained to the design setpoint by modulating the electric heat coil EHC or energizing the direct expansion cooling coil DXCC. The supply air temperature will be set at 55°F, however, is adjustable. During the unoccupied cycle the fan and electric heating coil will maintain a setback temperature of 55°F. During morning warm-up dampers D1 and D3 will remain closed. Damper D2 will remain open, and the fan will operate with the electric heating coil until temperature sensor T5 reaches 65°F. At this time the system will return to the occupied cycle. Figure 5 below provides a schematic for a typical retail rooftop unit.




Figure 5: Schematic of a Typical Retail Rooftop Air Handling Unit

Snowdome Air Handling Unit

The Snowdome's ventilation system is comprised of a main common intake system with one primary and two secondary cooling coils. The air is pre-cooled by means of a thermal wheel TW and then cooled to just above freezing by the primary cooling coil C1. The air is then cooled to below freezing temperatures by either one of the secondary coils C2a or C2b, which are fed by the main cold glycol system. The system is fully variable in volume to suit the occupancy which is achieved by inverters on the fans.

During normal operation the system will operate on a time control from the BAS and in conjunction with the occupancy of the Snowdome. The fresh air supply will be varied from a minimum set point which will be controlled by a carbon dioxide sensor. The system will ensure that the carbon dioxide level is maintained below 1000 parts per million. The signal from the sensor will be sequenced with the exhaust fan inverter to maintain the correct pressure. The unit will provide ventilation during regular operating hours and while the snow plows are grooming the snow at night. To ensure proper indoor air quality the unit is equipped with two sets of filters: a panel-type pre-filter PF and a main set of bag filters SF. The differential pressure transducers DPTs across the filters will indicate a dirty filter condition. Coil C2a will be used as a duty coil and will only shutdown for a defrosting cycle or if a problem arises with the coil, at which point coil C2b will take the cooling responsibility. The coil temperature sensor T4 will sense the coil temperature, and as long as it stays at its design temperature, dampers D1, D2, and D3 will remain open. However, if temperature sensor T4 detects a problem with coil C2a then dampers D1, D2, and D3 will close and dampers D4, D5, and D6 will open to allow the coil C2b to cool the air. At this point the cold glycol valve MV3 will close to stop the glycol flow to coil C2a, and the valve MV5 will open to allow the cold glycol to flow into coil C2b.

Temperature sensor T3 will ensure that the temperature leaving the first coil is maintained at 41°F by modulating the temperature of the entering cold glycol. The glycol temperature sensor T10 will ensure that the glycol temperature never falls below 30°F. If T10 reads a temperature of 30°F, it will override the control of valve MV1 to allow the temperature to rise above 30°F. The off coil temperature of cooling coil C2a will be sensed by temperature sensor T6 which will control the modulation of the three-way valve MV2 on the primary cold glycol circuit.

Since coils C2a and C2b operate below freezing temperatures ice buildup will need to be addressed with a defrost cycle. The defrost cycle will be initiated through the use of a time channel within the BAS but will also be checked for loss of air flow through the DPT. Once it has been determined that the defrost cycle should be initiated, the cold glycol valves MV3 and MV4 will close along with dampers D1, D2, and D3. The heater ACH between dampers

D2 and D3 will energize to prevent the freezing of the damper blades. At this point the hot glycol valves MV7 and MV8 will open. The cold and hot glycol valves will have end switches to provide a closed signal and will ensure that both valves are never open simultaneously. On the completion of the defrost cycle the hot glycol valves MV7 and MV8 will close, and the coil will remain switched off until required. Also the heater ACH will remain on until the coil is charged again. Figure 6 below provides a schematic for the Snowdome air handling unit while Figure 7 provides a schematic for the glycol connections to the unit's coils.




Figure 6: Schematic of the Snowdome Air Handling Unit




Figure 7: Schematic of the Snowdome Air Handling Unit Coil Connections

Snowdome Chillers and Main Cold Glycol Pumps

The Snowdome Glycol Chillers provide cold glycol to all the recirculation coolers, snowguns, under floor piping matrix, air handling unit cooling coils, and snowmaking tank. The chiller system will be on at all times to ensure proper temperatures are maintained in the skiing area. The return glycol temperature sensor T1 will enable the number of chillers to be controlled at low load. A separate output to the chillers will change the chiller operating at set points required by the system for snow making. The main glycol pumps will run in a duty/standby operation. A differential pressure switch located across each pump will sound an alarm on sensing a no flow condition through the duty pump, and the standby pump will begin to run. The system will monitor the hours of operation of each pump and share operating time between them. A time delay between the switching of the duty pump will occur to ensure that the system does not shut down. As mentioned earlier, the chillers should never shut down. The only time of shut down will occur under a manual control or a power failure. In a manual shut down the duty pump will continue to run for a prescribed period of time; however, if the system loses pressure, the pumps will shut down immediately. If a power failure occurs, the compressors will automatically restart once the power is restored. Figure 8 below provides a schematic for the chillers and main glycol pumps.




Figure 8: Schematic of Chillers and Main Glycol Pumps

Snowdome Recirculation Coolers

Thirteen ceiling mounted recirculation coolers will help maintain skiing conditions year round. The cooler fans will operate normally at all times, however, will shut off during the defrosting process. The controls for the coolers will also provide a sleep function which will stop individual coolers if cooling is not required in the zone served by the cooler for a preset time. This will help provide power savings during periods of low ambient temperatures and low occupancy.

During normal operation the cooler fans will run at a low speed which is controlled by the fan inverter. The fan speed will be increased by a modulating control function if temperature sensor T1 reads that the return air temperature rises above 32°F to increase the cooling duty. When the temperature falls back within the limit, the fans will revert to the low speed. The output of the cooling coil will be controlled by modulating the cold glycol supply flow. The return air temperature sensor T1 will send a signal to the controller which will modulate the three-way valve MV1 to provide the supply air temperature. Along the cold glycol supply line are temperature sensors that ensure the proper glycol temperature is maintained. If one of these sensors determine that the main cold glycol flow temperature has risen to high, all the recirculation cooler fans will shutdown in order to reduce the amount of heat produced.

At night during the snowmaking cycle, the cooler fans will run at full speed, and the return air set point will change to the lower 27°F air temperature. Also, since the system runs below freezing conditions a defrost cycle will periodically need to be run. This process is possible due to the hot glycol system. In order to defrost the coolers and still maintain skiing conditions, no more than three coolers will be defrosted at a time. In order to run the defrost cycle the cold glycol valve will close, and the fans will remain on to raise the temperature of the remaining glycol in the coil to room temperature. After a preset time the fans will shut down and the hot glycol valves MV2 and MV3 will open to allow the hot glycol into the coil. The coil temperature sensor T3 will read the coil temperature, and once the coil reaches a set temperature the defrost cycle will be shut off. Valves MV2 and MV3 will close and the cold glycol valve MV1 will open. Figure 9 below provides a schematic for the operation of a typical recirculation cooler.




Figure 9: Schematic of a Typical Recirculation Cooler

Snowdome Snowmaking Water Tank Cooling

The snowmaking water tank's function is to cool the water that will be used for snowmaking to a temperature near freezing in preparation for a phase change. The water temperature of the snowmaking water and the filling tank will operate under fully automatic controls to balance out the demand for cooling and the water supply.

During non snowmaking periods the water tank will be filled with the cold water supply via valve SV1. The supply water is cooled by a plate-type heat exchanger located in the bottom of the tank. The heat exchange is fed with glycol from the main return glycol system. The cooling system is comprised of an injection design with the glycol flow being controlled by a three-way valve V3, and the glycol circulation is controlled by pump P4. The flow through V3 is controlled by the tank temperature sensor T1. The modulating of valve V3 will ensure that the water temperature in the snowmaking tank is to be maintained at the design temperature of 36°F. A second temperature sensor T2 will ensure that the glycol temperature never falls too low. To ensure proper snowmaking, ice is required on the plate heat exchanger. To provide consistent ice formation the tank is fitted with a compressed air blower which is connected to a sparge pipe under the plates which discharges air bubbles from the base of the tank. Figure 10 below provides a schematic for the operation of the snowmaking water tank.




Figure 10: Schematic of the Snowmaking Water Tank

Snowdome Snowmelting Pit

A snowmelting pit is located at the bottom of the ski slope to melt all unwanted snow. Every night before the snowmaking process begins plows will scrape the top two inches of old snow into the snow melting pits. After the snow is removed a fresh two inches of snow will be made to sit on top of the existing fourteen inches of old snow underneath.

The snowmelting pit uses the hot glycol recovery system to provide the heat to melt the waste snow. The meltpit is designed to retain an amount of water at all times, and the temperature of the water is monitored by temperature sensor T1. When snow is added to the pit, the temperature of the water will fall and this will be detected by T1, and the snowmelting process will be initiated. During this time the two-way hot glycol control valve MV3 will open to allow hot glycol to circulate through the heat exchanger, and the drain valve MV2 will close, and the main valve MV1 will remain open. The spray pump P5 will start to circulate the water through the heat exchanger and discharge the warm water onto the snow via the spray nozzles. The level sensor will prevent operation of the spray pump in the event of a low level of water and will also control the water level within the pit. When the snow has melted, the water temperature sensed by T1 will rise, and the system will automatically shut down. The drain valve MV2 will open, and the main valve MV1 will close. The water will then be pumped to the drain until the preset level is reached. Also, at this time the hot glycol valve MV3 will close shutting off the flow to the heat exchanger. Figure 11 below provides a schematic for the operation of the snowmelting pit.




Figure 11: Schematic of the Snowmelting Pit

Snowdome Snowguns

Ceiling mounted snowguns will be used at night time to create fresh snow. The snowguns will start from a main time clock control loop which will start the operation after the top two inches of old snow has been cleared. Once the snow making process has begun the recirculation coolers will step up to full load to lower the indoor temperature to 27°F. Once the indoor temperature setpoint has been reached the air compressor and water pumps will start. Once the compressed air is flowing valve V1 will open. After a preset time, the water valve V2 will open. At this point the snowgun will be fully operational. Once the snowmaking process is over the system will begin to shut down. During shutdown valves V1 and V2 will close, and the air compressor and water pumps will shut down. Figure 12 below provides a schematic for the operation of a typical snowgun.




Figure 12: Schematic of a Typical Snowgun

Design Ventilation Requirements

The American Society of Heating, Refrigerating and Air-Conditioning Engineers Standard 62.1 (ASHRAE 2007) provides a source to ensure that minimum ventilation requirements are met within a building. Proper outdoor air ventilation to spaces in the building is essential in maintaining a proper level of indoor air quality. The Ventilation Rate Procedure found in Standard 62.1 determines ventilation rates based on space application, occupancy levels, and floor area. With a space's known occupancy category the required fresh air per floor area and per occupants can be obtained from Table 6-1 in Standard 62.1-2007. Through the equations prescribed in Standard 62.1, a compliance check was performed on the building for Technical Report One. Table 1 below summarizes the findings from the first technical report.

Table 1: Air Handling Unit Compliance Summary

Air Handling Unit	Serves	Ventilation Efficiency	Required O.A. (cfm)	Supplied O.A. (cfm)	Meets Standard?
RTU-1	1st & 2nd Floor East Common Areas	0.6	9,410	1,358	No
RTU-2	1st & 2nd Floor West Common Areas	0.6	11,564	1,637	No
RTU-3	3rd Floor	1.0	1,515	3,039	Yes
RTU-4	3rd Floor	1.0	1,563	3,038	Yes
AHU-Snowdome	Indoor Ski Resort	1.0	48,000	15,000	No

The results from the ventilation calculations show some potential problems in the mechanical system when it comes to proper ventilation. The roof top units that serve the upper floor of the retail section of the building dump the majority of all the air from the units directly into the large atrium space and nowhere else. This design reduces the amount of ductwork needed and essentially uses the corridors as the duct to carry ventilation air to spaces. The single air handling unit in the indoor ski resort also did not meet the requirements found from Standard 62.1. The peak load will occur during special events when 999 occupants are planned to reside in the space. This results in a minimum ventilation of 48,000 cfm of outside air; however, the maximum amount of outside air that can be supplied is 15,000 cfm.

While the majority of the building relies on air handling units to supply fresh air, the ground floor relies on louvers in the exterior walls to allow for natural ventilation. Section 5.1 of Standard 62.1 lists the minimum free air requirements of exterior openings per floor area to ensure proper ventilation. Table 2 below summarizes the results found from the first technical report.

Table 2: Naturally Ventilated Space Compliance

Room	Space	ASHRAE 62.1				Design Case		Meets Standard?	Notes:
		Area (SF)	Natural Ventilation		Required Opening (SF)	Opening (SF)			
			Direct	In-Direct					
A 005	Atrium Entrance	2,101	-	-	84	0	No	1	
A 006	Electrical Equip.	470	X		19	1	No	2	
A 007	Telecom Room	178	-	-	7	0	No		
A 008	Electrical Equip.	244	X		10	1	No	2	
A 009	Electrical Equip.	692	X		28	3	No	3	
A 010	Telecom Room	327	-	-	13	0	No		
A 011	Water Room	294	-	-	12	0	No		
A 012	Electrical Equip.	383	-	-	15	9	No	3	

1. Open to the atrium spaces on the above floors
2. Louver is open to the adjacent loading dock
3. Louver is open to the adjacent parking garage

The natural ventilation analysis of the ground floor also shows some areas that can potentially be under ventilated. Three of the spaces are to be ventilated using natural ventilation that would be delivered through louvers on the exterior walls; however, the free area of the louvers is very small in comparison to the minimum requirements presented by ASHRAE 62.1. Besides not meeting the size requirements, the louvered natural ventilation also fails the Air Intake Minimum Separation Distance which can be found in Table 5 of ASHRAE 62.1 (ASHRAE 2007). This section requires that any opening that is to be used for natural ventilations be at a minimum of 25 feet from truck loading docks, which in this case is closer than the requirement. The rest of the spaces on the ground floor are completely closed off and do not have either exterior louvers or interior louvers to gain ventilation from other rooms.

Design Heating and Cooling Loads

For Technical Report Two Building A's design loads were estimated using Trane Air Conditioning Economics (TRACE) 700 software. As with other actual design values, the designer calculated loads are not available; therefore, only the estimates found in Report Two will be discussed. To accurately calculate design loads, design data was used when the information was available. Assumptions occurred due to the fact that all the retail spaces have not been designed in the current contract. To simulate these spaces, recommended lighting densities and occupancy densities were used to estimate internal loads. Table 3 lists the roof top unit capacities calculated from the load calculations.

Table 3: Building A Design Loads

Unit	Area (SF)	Cooling (MBh)	Heating (MBh)	SF/Ton
Designed In Current Contract				
Entrance Air Conditioner	2,101	57.9	NA	435
RTU-A1	16,623	458	512	436
RTU-A2	29,832	458	512	782
RTU-A3	7,596	930	649	98
RTU-A4	5,381	930	649	70
Snowdome	160,000	5328	NA	360
Calculated Leaser Units				
Cabela's RTU	200,794	5,613	4,430	429
117c- Specialty Store RTU	3,920	108	85	434
Sky Venture RTU	13,260	173	145	920
Golfdom RTU	20,498	574	457	428
120b- Specialty Store RTU	12,996	361	286	432
Princeton Ski RTU	11,297	314	248	432
Ski Lodge RTU	26,812	6,677	4,606	482
Burton RTU	7,724	213	167	434
Cubra Libre RTU	19,906	2,791	2,190	434
Ipapeze RTU	7,016	196	155	430
Chickie & Pete's RTU	26,921	1,203	1,297	269
Night Club 1 RTU	8,832	586	1,070	181
Night Club 2 RTU	6,962	462	844	181
Miscellaneous				
Unit Heaters	NA	NA	31	NA
Stair Heaters	NA	NA	12	NA
	588,471	27,053	18,345	414
	Totals			Average

Annual Energy Use

Based on the results from the design load calculations from TRACE 700, the buildings energy use and cost of operation was determined for Technical Report Two. Each separate system was created in the energy model, and all the major equipment efficiencies found during the ASHRAE 90.1 compliance check and relevant data were used from design documents to accurately model energy use. For items such as supply air fans, the design document listed static pressure was inputted, and TRACE estimates the efficiency based on the type of fan. The annual energy consumption calculated using the TRACE energy model was broken into six categories. The results can be found in Table 4.

Table 4: Annual Energy Consumption

Component	Annual Energy Consumption Summary (kWh)
Lighting	7,418,382
Receptacles	2,774,240
Cooling	2,412,629
Heating	4,143,470
Fans	750,000
Snowdome	4,391,635
	21,890,356

To accurately model the annual operating costs, utility rates needed to be derived. Utility rates were derived using the utility provider's website. The rates used are summarized in Table 5.

Table 5: PSEG Electricity Rates

Charge Type	Months	Rate
Electric Demand On Peak	October-May	\$3.894 /kW
	June-September	\$7.227 /kW
Electric Demand Off Peak	October-May	\$2.923 /kW
	June-September	\$5.420 /kW
Electric Consumption On Peak	October-May	\$0.088 /kWh
	June-September	\$0.097 /kWh
Electric Consumption Off Peak	October-May	\$0.070 /kWh
	June-September	\$0.071 /kWh

A breakdown of the operation cost on a monthly basis revealed lower costs in the heating season and higher costs in the cooling season. This is a result from the increase of utility rates during the summer months. The actual values of the monthly breakdown are found in Table 6.

Table 6: Monthly Utility Costs

Month	On Peak	Off Peak	Total
January	\$14,936	\$15,469	\$30,405
February	\$13,595	\$14,367	\$27,962
March	\$10,386	\$12,691	\$23,077
April	\$11,236	\$8,370	\$19,606
May	\$27,539	\$8,014	\$35,553
June	\$27,539	\$19,582	\$47,121
July	\$29,760	\$21,064	\$50,824
August	\$28,960	\$20,752	\$49,712
September	\$23,923	\$17,280	\$41,203
October	\$10,862	\$7,908	\$18,770
November	\$10,484	\$8,247	\$18,731
December	\$12,412	\$14,421	\$26,833
Total	\$221,632	\$168,165	\$389,797

Critique of Mechanical System

While the Xanadu Sports Complex was designed using BOCA 1996 and complies fully with this code, current codes and standards have evolved greatly over the last ten years which creates a broad range of issues that can be explored to further improve the system performance. Issues of annual energy use, energy sources, indoor air quality, and equipment efficiencies are the main areas of concern.

The initial cost of the mechanical system for the retail space is relatively low. The low initial cost of a system is attractive at first; however, during the life of the building problems may arise that will cost the owner much more money. The low cost of the retail mechanical system can be attributed to the lack of ductwork to all parts of the building. This lack of direct ventilation to spaces can create future indoor air quality problems if the right amount of fresh outside air is not provided. The lack of ductwork can also cause the use of the equipment to run longer using more energy and costing the owner more money in monthly utility bills. This problem can occur since the return registers for the entire building are located very close to where RTU-3 and RTU-4 are dumping the majority of the building's air. This can cause short circuiting which will prevent the conditioned air from reaching the thermostats which will in turn provide inaccurate readings to the mechanical system. The initial cost of the Snowdome mechanical system is rather expensive, however, is on par with other indoor ski resorts around the world. The market for indoor ski resorts is a small one, and at this point in time most have followed the same approach as this project.

In order to run an indoor ski resort year round a large amount of energy needs to be consumed. The Xanadu Sports Complex runs entirely on electricity which not only tends to be very expensive in big cities, it also produces a large number of harmful emissions. The environmental impact a system of this size has is a large one, and any possible changes that can reduce this should be further analyzed in future reports. Since indoor ski resorts are a new breed of building type, simple answers may not be evident and will require in-depth investigation.

References

ASHRAE. 2005, 2005 ASHRAE Handbook – Fundamentals. American Society of Heating Refrigeration and Air Conditioning Engineers, Inc., Atlanta, GA. 2001.

ASHRAE. 2004, ANSI/ASHRAE, Standard 90.1 – 2004, Energy Standard for Buildings Except Low-Rise Residential Buildings. American Society of Heating Refrigeration and Air Conditioning Engineers, Inc., Atlanta, GA. 2004.

Turner Construction Company. 2007, Mechanical Construction Documents. Turner Construction Company, East Rutherford, NJ. 2007.

Turner Construction Company. 2007, Architectural Construction Documents. Turner Construction Company, East Rutherford, NJ. 2007.

Turner Construction Company. 2007, Electrical Construction Documents. Turner Construction Company, East Rutherford, NJ. 2007.

Appendix A: Mechanical Equipment Schedules

Retail Rooftop Units

Mark	Supply Fan					Cooling Coil				Elec. Heat		Compressors			Cond. Fans		EER/COP
	SA (cfm)	OA (cfm)	SP (in)	HP	RPM	EAT (°F DB/WB)	LAT (°F DB/WB)	Total (MBH)	Sens. (MBH)	kW	LAT (°F)	Qty.	HP	LRA	Qty.	HP	
RTU-A1	16,100	1,496	2	20	959	76.6/63.4	54.0/52.6	458	404	150	96.5	2	27.3	178	6	1	9.5/2.78
RTU-A2	16,100	1,496	2.5	25	959	76.6/63.4	54.0/52.6	458	404	150	96.5	2	27.3	178	6	1	9.5/2.78
RTU-A3	31,000	3,037	2	30	1106	76.6/63.4	54.0/52.6	930	820	190	85.5	4	27.3	178	10	1	9.2/2.7
RTU-A4	31,000	3,037	2	30	1106	76.6/63.4	54.0/52.6	930	820	190	85.5	4	27.3	178	10	1	9.2/2.7

Snowdome Air Handling Unit

Mark	Air Capacity		Supply Fan		Exhaust Fan		Fan Speed	Thermal Wheel, Summer			
	SA (cfm)	RA (cfm)	ESP (in)	HP	ESP (in)	HP		Supply EAT (°F DB/WB)	Supply LAT (°F DB/WB)	Exhaust EAT (°F DB/WB)	Exhaust LAT (°F DB/WB)
1	15000	13500	1	25	1	15	Variable	96/78	47.5/47.5	29/28.1	83.2/70.5

Mark	Cooling Coil 1						Cooling Coils 2				
	EAT (°F DB/WB)	LAT (°F DB/WB)	EGT (°F)	LGT (°F)	Cap. (MBH)	GPM	EAT (°F DB/WB)	LAT (°F DB/WB)	EGT (°F)	Cap. (MBH)	GPM
1	50.5/48.9	41/40.9	31	41.1	274	65	41/41	27.2/27.2	1.5	373	71

Recirculation Coolers

Mark	Capacity		Normal Oper.		Snowmaking Oper.		EGT (°F)	GPM	Fan	
	Norm. (TR)	Snow (TR)	EAT °F	RPM	EAT °F	RPM			Qty.	HP
RC1	26.6	23	29	300	21	1140	4	60	4	3
RC2	26.6	23	29	300	21	1140	4	60	4	3
RC3	26.6	23	29	300	21	1140	4	60	4	3
RC4	26.6	23	29	300	21	1140	4	60	4	3
RC5	26.6	23	29	300	21	1140	4	60	4	3
RC6	26.6	23	29	300	21	1140	4	60	4	3
RC7	20.9	18.7	29	300	21	1140	4	53	3	3
RC8	20.9	18.7	29	300	21	1140	4	53	3	3
RC9	20.9	18.7	29	300	21	1140	4	53	3	3
RC10	20.9	18.7	29	300	21	1140	4	53	3	3
RC11	26.6	23	29	300	21	1140	4	60	4	3
RC12	20.9	18.7	29	300	21	1140	4	53	3	3
RC13	20.9	18.7	29	300	21	1140	4	53	3	3

Evaporative Condensers

Mark	Total Heat (MBH)	Design Cap. (MBH)	Refrig.	CT (°F)	EAT (°F WB)	Fan		Noise (dB)
						CFM	HP	
1	7,794	7,712	R22	105	78.1	155,800	2 x 15	74
2	7,794	7,712	R22	105	78.1	155,800	2 x 15	74

Chillers

Mark	Design Cap. (Tons)	Evaporator		Aux. Condenser			Motor	Noise (dB)
		GPM	LGT °F	GPM	LWT °F	kBtu/h	BHP	
1	222	405	1.5	152	77	800	458.9	86
2	222	405	1.5	152	77	800	458.9	86

Exhaust Fans

Mark	Airflow (cfm)	ESP (in)	HP	RPM	Roof/Wall Opening
EF-A1	3,000	1.2	1.5	1,379	20.5" x 20.5"
EF-A2	4,400	1	1.5	1,725	20.5" x 20.5"
EF-A3	2,200	0.5	0.5	1,056	33.75" x 33.75"
EF-A4	1,200	0.5	0.33	965	33.75" x 33.75"
EF-A5	1,700	0.5	0.5	1,029	33.75" x 33.75"
EF-A6	2,000	0.75	0.75	1,249	33.75" x 33.75"
EF-A7	2,000	0.75	0.75	1,249	33.75" x 33.75"
EF-A8	2,000	0.75	0.75	1,249	33.75" x 33.75"
EF-A9	3,300	1	1.5	1,407	20.5" x 20.5"
EF-A10	5,100	1	1.5	894	26.5" x 26.5"
EF-A11	700	0.375	0.125	1,550	19.25" x 19.25"
EF-S1	6000	1	5	1493	36.5" x 36.5"
EF-S2	5200	0.5	0.75	1330	26.5" x 26.5"
EF-S3	1550	1	0.75	2285	NA
EF-S4	300	4.9	1.5	3480	NA

Pumps


Mark	GPM	Static Feet	Fluid	Oper. Temp (°F)	Design Temp (°F)	RPM
P1a	890	125	50% MEG.	-1.5	-4	1,750
P1b	890	125	50% MEG.	-1.5	-4	1,750
P2a	334.4	125	50% MEG.	77	104	1,750
P2b	334.4	125	50% MEG.	77	104	1,750
P3	47.5	125	Water	36	68	1,750
P4	89	125	50% MEG.	16	-4	1,750
P5	104	10	Water	36	68	1,750
P6a	71.5	98	50% MEG.	31	-4	1,750
P6b	71.5	98	50% MEG.	31	-	1,750

Air Compressor

Mark	Design Cap. (cfm)	Max. Pressure (psig)	Motor		Noise (dB)
			kW	HP	
1	403	153	75	100	69

Appendix B: Full Glycol System Schematics

Cold Glycol System



Hot Glycol System

