

---

## SECTION FIVE | Electrical

---

### 1A. MAIN LOBBY and LIBERTY AVENUE FACADE

[with SECOND LEVEL LOBBY, GIFT SHOP, BOX OFFICE, GRAND STAIRCASE]

#### Existing Design

The main lobby is a large space with few distinct boundaries that flows through most of the first floor of the building. It is a very important space in the building and control systems will be essential to a strong lighting and electrical system design.

The existing electrical design for the main lobby utilizes three separate lighting panels (1N1, 1E1, ALDR5). These panels are in various locations and control is split between dimming and switching. The other spaces that will be combined with the main lobby for the redesigned control system also use the three previously mentioned panels, as well as 2N1 and 2E1.

#### Redesigned System

The new electrical system for the lower and upper lobbies, as well as connected spaces, will combine many lighting loads onto a single dimming system. More dimming control was a goal for the redesigned lighting system and therefore it was a logical choice to combine these loads into a complete system, rather than using a collection of panels to supply power. A new dimming rack has been specified that is large enough to handle all the aforementioned loads. It also eliminates the need for separation of loads onto normal and emergency circuits due to an automatic emergency transfer switch located in the dimmer rack assembly. The panel specified for these spaces has eight modules with four control circuits per module with a maximum of 20A connected load per circuit. The panel is main lugs only and is protected at the distribution panel. Specifications are available in Appendix K.

The new system utilizes 27 circuits with a total of 27.07 KW of connected load and has six circuits of spare capacity. A total demand load of 93.99 A, including a 1.25 growth multiplier, was used to size the feeder and protection. The feeder has been sized at (4) #3 wires of type THW copper in 1.25" conduit. The breaker protecting the feeder on distribution panel 1NDP1 is sized at 100 A.

The 27 circuits are divided into 19 control zones. 16 of the 19 zones, those of the interior spaces, will be controlled by a single head unit located in the box office. The remaining zones will be controlled by a separate unit in the box office. These units will be linked together.

Dimmer rack/panelboard layouts for both the existing and new system are provided below. Electrical plans are available in Appendix F. Product Information for the dimmer racks and control units is available in Appendix H.

**Redesign Analysis**

The redesigned system offers incredible flexibility and greatly simplifies the existing system. Utilizing a main point of control will provide management with the ability to set and alter various scenes on the fly, creating a dynamic environment. Electrically, the system is convenient and centralized. The lighting loads are grouped together and are separated from the auditorium dimmer racks. The dimmer rack is located in a central location to help minimize cost and complexity of feeders.



the studio i company  
architectural lighting

AWC  
DR-201  
01 October 2007

Area	Control Channel #	Circuit / Dimmer #	Description	Fixt. Type	Approx. # Fixt.	Watts / Fixture	Approx. Total Connected Load (Watts)	Load Type	E Circuit
Lobby	1	1	1st Floor Drum Lower	SAX	17	50	1063	ELV	
		2	1st Floor Drum Lower	SAX	17	50	1063	ELV	
	2	3	1st Floor Drum Upper		70	15	1313	NEON	
		4	1st Floor Drum Upper		70	15	1313	NEON	
	3	5	Art Lights Lobby	SBC	10	65	813	ELV	
	4	6	2nd Floor Drum	SAF	6	225	1350	INC	
		7	2nd Floor Drum	SAF	6	225	1350	INC	
		8	2nd Floor Drum	SAF	6	225	1350	INC	
		9	2nd Floor Drum	SAZ	6	225	1350	INC	
		10	Spare				0		
		11	Spare				0		
		12	Spare				0		

<b>TOTAL:</b>	<b>10.96</b>	<b>k W</b>
---------------	--------------	------------

**NOTE:** Contractor must pull separate neutrals for each circuit.  
A factor of 1.25 has been added to all LV, FL, & HID loads.

**Figure 5.1A.1** | Dimmer Rack DR-201 – Existing Design – Layout Provided by Studio i Lighting. Yellow highlighting indicated loads involved in the redesign.

(SECOND FLOOR) PANEL 2N1

PANEL TYPE		MAIN LUGS		PANEL		BUS RATING		208/120V 3Ø 4W						
DESCRIPTION	WIRE SIZE	K.W.	AMPS	TRIP	POLE	CIRC.	PHASE	CIRC.	POLE	TRIP	AMPS	K.W.	WIRE SIZE	DESCRIPTION
							A B C							
FEEL 211, ELEC 212, 215 - LTG		.960		20	1	1	●	2	1	20		.605		OPEN OFFICE 220 - LTG
LOBBY 201 + BRIDGE 200 - LTG		.320			3	3	●	4				1.10		OPEN OFFICE 220 - LTG
LOBBY 201 - LTG		.448			5	5	●	6				.320		HALLWAY 230 - LTG
LOBBY 201 - LTG		.512			7	7	●	8				.832		MENS 245 WOMENS 243 LTG
STAIR 204 - LTG		1.38			9	9	●	10				.924		CONF RM. 240 - LTG
STAIR 204 - LTG		.500			11	11	●	12				.972		MULTI-PURPOSE 247 - LTG
SPARE					13	13	●	14				.840		MULTI-PURPOSE 247 - LTG
					15	15	●	16						SPARE
					17	17	●	18						
Dimmed Room LTG		.128			19	19	●	20						
SPARE					21	21	●	22						
					23	23	●	24						
					25	25	●	26						
					27	27	●	28						
					29	29	●	30						
					31	31	●	32	1	60		3.2		TEMP. EXHIBIT 210 - BUS DUCT
					33	33	●	34	1	60		3.2		TEMP. EXHIBIT 210 - BUS DUCT
					35	35	●	36	1	60		3.2		TEMP. EXHIBIT 210 - BUS DUCT
AREA PROTECTION Panel				20	37	37	●	38	1	60		3.2		TEMP. EXHIBIT 210 - BUS DUCT
					39	39	●	40	1	20				SPARE
					41	41	●	42	1	20				SPARE

TOTAL LOAD 4.3 KW      PHASE A \_\_\_\_\_      POSITION SIZE \_\_\_\_\_  
 K.W. \_\_\_\_\_      PHASE B \_\_\_\_\_      AT DIST. BOARD \_\_\_\_\_  
 FEEDER SIZE \_\_\_\_\_      PHASE C \_\_\_\_\_      FUSE OR TRIP \_\_\_\_\_  
 VOLTAGE \_\_\_\_\_      TOTAL = 22.7 KW

Figure 5.1A.2 | Panel 2N1 – Existing Design – Layout Provided by Hornfeck Engineering.

(FIRST FLOOR) PANEL 1N1

PANEL TYPE		MAIN LUGS		PANEL		BUS RATING		208/120V 3Ø 4W						
DESCRIPTION	WIRE SIZE	K.W.	AMPS	TRIP	POLE	CIRC.	PHASE	CIRC.	POLE	TRIP	AMPS	K.W.	WIRE SIZE	DESCRIPTION
							A B C							
HALLWAY 115 - LTG		1.20		20	1	1	●	2	1	20		.80		HALLWAY 131 - LTG
LOBBY 101 - LTG		.320			3	3	●	4				1.39		DRESSING RMS 126 - LTG
LOBBY 101 - LTG		1.12			5	5	●	6				1.60		DRESSING RMS 121 - LTG
LOBBY 101 - LTG		.448			7	7	●	8				.940		CHORUS DRESS RM 123 - LTG
GIFT SHOP 103 - LTG		1.20			9	9	●	10				.512		INNER LOBBY - LTG
GIFT SHOP 103 - LTG		.900			11	11	●	12				.832		MENS RM 145 WOMENS 143 - LTG
COAT CLOSET 107 - LTG		.480			13	13	●	14				.510		KITCHEN 140 - LTG
MEMBERSHIP BOX 102 - LTG		.810			15	15	●	16						SPARE
ENTRANCE 100 - LTG		.232			17	17	●	18						
SPARE					19	19	●	20						
SPARE					21	21	●	22						
EXTERIOR MAIN ENTRY		.052			23	23	●	24						
EXTERIOR LOAD POOL LTG		.156			25	25	●	26	20					AREA PROTECTION
EXTERIOR TYPE SAG		.312			27	27	●	28						SPARE
EXTERIOR TYPE SAG		.35			29	29	●	30			3			SPARE
EXTERIOR TYPE SAG - A		.35			31	31	●	32	1	60		3.2		PERM. EXHIBIT 110 - BUS DUCT
EXTERIOR TYPE SAG		.36			33	33	●	34	1	60		3.2		PERM. EXHIBIT 110 - BUS DUCT
EXTERIOR TYPE SAG		.36			35	35	●	36	1	60		3.2		PERM. EXHIBIT 110 - BUS DUCT
EXTERIOR TYPE SAG		.36			37	37	●	38	1	60		3.2		PERM. EXHIBIT 110 - BUS DUCT
SPARE					39	39	●	40						SPARE
SPARE					41	41	●	42						SPARE

TOTAL LOAD 9.0 KW      PHASE A \_\_\_\_\_      POSITION SIZE \_\_\_\_\_  
 K.W. \_\_\_\_\_      PHASE B \_\_\_\_\_      AT DIST. BOARD \_\_\_\_\_  
 FEEDER SIZE \_\_\_\_\_      PHASE C \_\_\_\_\_      FUSE OR TRIP \_\_\_\_\_  
 VOLTAGE \_\_\_\_\_      TOTAL = 28.4 KW

Figure 5.1A.3 | Panel 1N1 – Existing Design – Layout Provided by Hornfeck Engineering

LIFE SAFETY (Second Floor) PANEL 2E1

PANEL TYPE		MAIN LUGS		PANEL		BUS RATING								
DESCRIPTION	W. S. S.	K. W.	AMPS	TRIP	POLE	CIR.	PHASE	CIR.	POLE	TRIP	AMPS	K. W.	W. S. S.	DESCRIPTION
							A B C							
PASSAGE WAY		.448		20	1	1	•	2	1	20		.36		FIRE SMOKE DAMPER
OPEN OFFICE HALLWAY		.672			3		•	4				.36		FIRE SMOKE DAMPER
PREST ROOMS		.064			5		•	6				.36		SECURITY PANEL
SPARE					7		•	8				.36		AV RACK
					9		•	10				.36		AV RACK
					11		•	12				.36		SPARE
STAIR NO. 1		.320			13		•	14				.36		FIRE ALARM NOTIFICATION (2)
SPARE					15		•	16				.36		SPARE
					17		•	18						
					19		•	20						
					21		•	22						
					23		•	24						
					25		•	26						
					27		•	28						
					29		•	30						
					31		•	32						
					33		•	34						
					35		•	36						
					37		•	38						
					39		•	40						
					41		•	42						

TOTAL LOAD 1.50 KW PHASE A \_\_\_\_\_ POSITION SIZE \_\_\_\_\_  
 K.W. \_\_\_\_\_ AMPS \_\_\_\_\_ PHASE B \_\_\_\_\_ AT DIST. BOARD \_\_\_\_\_  
 FEEDER SIZE \_\_\_\_\_ PHASE C \_\_\_\_\_ FUSE OR TRIP \_\_\_\_\_  
 VOLTAGE \_\_\_\_\_ TOTAL = 3.66 KW

Figure 5.1A.4 | Panel 2E1 – Existing Design – Layout Provided by Hornfeck Engineering

LIFE SAFETY (FIRST Floor) PANEL 1E1

PANEL TYPE		MAIN LUGS		PANEL		BUS RATING								
DESCRIPTION	W. S. S.	K. W.	AMPS	TRIP	POLE	CIR.	PHASE	CIR.	POLE	TRIP	AMPS	K. W.	W. S. S.	DESCRIPTION
							A B C							
HALLWAY 113		.448		20	1	1	•	2	1	20		.360		FIRE SMOKE DAMPER
HALLWAY 131		.563			3		•	4				.360		FIRE SMOKE DAMPER
DRESSING ROOMS		.624			5		•	6				.360		SECURITY PANEL
LOBBY 101		.320			7		•	8				.360		AV RACK
LOBBY 101		.444			9		•	10				.360		AV RACK
STAIR NO. 6					11		•	12				.360		AV RACK
SPARE					13		•	14				.360		FIRE ALARM NOTIFICATION (1)
					15		•	16				.360		FIRE ALARM CONTROL PANEL
					17		•	18						SPARE
EXTERIOR LUG		.256			19		•	20						
SPARE					21		•	22						
					23		•	24						
					25		•	26						
					27		•	28						
					29		•	30						
					31		•	32						
					33		•	34						
					35		•	36						
					37		•	38						
					39		•	40						
					41		•	42						

TOTAL LOAD 2.65 KW PHASE A \_\_\_\_\_ POSITION SIZE \_\_\_\_\_  
 K.W. \_\_\_\_\_ AMPS \_\_\_\_\_ PHASE B \_\_\_\_\_ AT DIST. BOARD \_\_\_\_\_  
 FEEDER SIZE \_\_\_\_\_ PHASE C \_\_\_\_\_ FUSE OR TRIP \_\_\_\_\_  
 VOLTAGE \_\_\_\_\_ TOTAL = 5.53 KW

Figure 5.1A.5 | 1E1 – Existing Design – Layout Provided by Hornfeck Engineering

DIMMER RACK LAYOUT: DR101/201										
AREA	CONTROL CHANNEL	CIRCUIT / DIMMER	DESCRIPTION	FIXT. TAG	NO. OF FIXT.	WATTS/ FIXTURE	MULT.	TOTAL WATTS	PHOTO CELL?	EMER. CRCT?
LOWER LOBBY	1	1	Theater Drum Upper	D	25	50	1.0	1250		
	2	2	Theater Drum Lower	D	25	50	1.0	1250		
	3	3	Downlights - Linear - 101	A	11	63	1.25	866	■	■
		4	Downlights - Linear - 101	A	17	63	1.25	1339		■
LOWER LOBBY	4	5	Downlights - Linear - 106	A	4	63	1.25	315		■
		6	Downlights - Linear 106 + P	A/F	8/4	63/32	1.25	790	■	
	5	7	Downlights - Round	E	15	49	1.25	919		
	6	8	Downlights - Cabinets	E1/H	7/4	50/49	1.25	683		
GIFT SHOP	7	9	Downlights	H	20	50	1.25	1250		
		10	Downlights	H	17	50	1.25	1063		■
Box Office	8	11	Downlights	E1/I	15/3	49/38	1.25	1061		
SPARE	9	12								
VESTIBULE	10	13	Downlights	I	6	38	1.25	285	■	■
STAIRCASE	11	14	Wallwash	C	4	300	1.0	1200		
		15	Wallwash	C	4	300	1.0	1200		
	12	16	Downlights	B	10	64	1.25	800		■
UPPER LOBBY	13	17	Theater Drum + Track	C	5	300	1.0	1800		
		18	Theater Drum + Track	C	5	300	1.0	1800		
		19	Theater Drum + Track	C	5	300	1.0	1800		
		20	Theater Drum + Track	C	4	300	1.0	1800		
UPPER LOBBY	14	21	Downlights - Linear	A	10	63	1.25	788	■	■
		21	Downlights - Linear	A	10	63	1.25	788		■
	15	22	Downlights - Round	E	13	49	1.25	796		■
	16	23	Downlights - Pendant	F	6	32	1.25	240		
EXTERIOR	17	25	Inside	R	85	10	1.25	1063		
		26	Inside	R	85	10	1.25	1063		
	18	27	Sail LED	S	120	3	1.25	450		
	19	28	Downlights - Exterior	M	15	22	1.25	413		
SPARE		29								
SPARE		30								
SPARE		31								
SPARE		32								

Panel Type: Lutron LP8/16-1204ML-20  
Distribution Panel Power Supply: 1NDP1  
Emergency Panel Power Supply: BE1  
Location: Control Booth (151)

LOAD = 27.07 kW  
(125% GROWTH FACTOR) DEMAND LOAD = 93.99 A  
FEEDER SIZE = (4) #3 in 1.25" Conduit  
PROTECTION = 100 A

Figure 5.1A.6 | New Dimmer Rack DR101/201

## **1B. EDUCATION AND LECTURE ROOM and MEETING ROOM**

### **Existing Design**

The education and lecture room is a classroom space located on the Liberty Avenue side of the second level. The meeting room is adjacent to this space, located in the sail structure at the northeast corner of the building.

The current design for the education and lecture room and meeting room uses a dimmer rack (DR202) connected to a distribution panel (1N1). DR202 serves both spaces but no others. In total between the two rooms, 5 circuits were used. The total connected load was 5.13 KW, which was protected by a 100A three pole circuit breaker on panel 1NDP1. This system was controlled by a main control unit in room 202 with two satellite control units, one in each space. An emergency dimmer transfer rack, located in the same closet, was used to provide emergency power to the rack.

### **Redesigned System**

The new system for the education and lecture room will utilize the same organization as the previous system. The lighting design is not extremely different and the load is nearly identical. There are new fixtures and different zones, but the total load is still very small. A new dimming rack has been specified that eliminates the need for a second emergency transfer panel. The panel specified for these spaces has four modules with four control circuits per module with a maximum of 20A connected load per circuit. The panel is main lugs only and is protected at the distribution panel. Specifications and additional information can be found in Appendix H.

The new system utilizes 8 circuits with a total of 6.48 KW of connected load and has eight circuits of spare capacity. A total demand load of 27A, including a 1.5 growth multiplier, was used to size the feeder and protection. The feeder has been sized at (4) #10 THW 75 C copper conductors in ½" conduit. The breaker protected the feeder on distribution panel 1NDP1 is still sized at 30A.

The system will be controlled by two main wall panels, one in the meeting room and one in the education room. The education room will also feature a secondary control panel. These panels will control both the lights and the window shades that are present in both rooms. Photosensors will be added to the education room to dim the exterior zones because daylight analysis shows that ample daylight is available in the space.

Dimmer rack layouts for both the existing and new system are provided below. See Electrical plans are available in Appendix F.

### **Redesign Analysis**

The new system does not differ dramatically from the existing system, but the system is simplified slightly by eliminating an external emergency power transfer rack. The

streamlined control system will allow for control of both lighting and shading devices. Extra room is left should the need to expand the system arise.



the studio i company  
architectural lighting

AWC  
DR-202/207  
01 October 2007

Area	Control Channel #	Circuit / Dimmer #	Description	Fixt. Type	Approx. # Fixt.	Watts / Fixture	Approx. Total Connected Load (Watts)	Load Type	E Circuit
Educ. Class	1	1	Linear Fluorescent	SK	3	324	1215	FL	
		2	Linear Fluorescent	SK	4	324	1620	FL	
	2	3	Low Voltage Downlight	SK-a	21	50	1313	MLV	
Conf. Room	3	4	Linear Fluorescent	SD1	8	54	540	FL	
	4	5	Linear Fluorescent	SD1	8	54	540	FL	
		6	Spare				0		
		7	Spare				0		
		8	Spare				0		
		9	Empty				0		
		10	Empty				0		
		11	Empty				0		
		12	Empty				0		

**TOTAL: 5.23 kW**

NOTE: Contractor must pull separate neutrals for each circuit.  
A factor of 1.25 has been added to all LV, FL, & HID loads.

Figure 5.1B.1 | Dimmer Rack DR-202/207 – Existing Design – Layout Provided by Studio i Lighting

DIMMER RACK LAYOUT: DR202/207										
AREA	CONTROL CHANNEL	CIRCUIT / DIMMER	DESCRIPTION	FIXT. TAG	NO. OF FIXT.	WATTS/ FIXTURE	MULT.	TOTAL WATTS	PHOTO CELL?	EMER. CRCT?
EDUCATION	1	1	Northwest Downlights + Track	A	5	125	1.25	1141.25	■	
	2	2	Northeast Downlights + Track	A	5	125	1.25	1141.25	■	
	3	3	Southwest Downlights + Track	A	5	125	1.25	1141.25		■
	4	4	Southeast Downlights + Track	A	5	125	1.25	1141.25		■
MEETING	5	5	Pendants	L	3	116	1.25	435		
	6	6	Downlights	E1	8	49	1.25	490		■
	7	7	Accent - Wood/Sail	J	13	50	1.25	812.5		
	8	8	Linear Wallwasher	K	4	35	1.25	175		
SPARE										
SPARE										
SPARE										
SPARE										
SPARE										
SPARE										
SPARE										
SPARE										

Panel Type: Lutron LP4/16-1204ML-20  
Distribution Panel: 1NDP1  
Emergency Panel: BE1  
Location: 202 Closet

LOAD = 6.48 kW  
(200% GROWTH FACTOR) DEMAND LOAD = 26.99 A  
FEEDER SIZE = (3) #10 in .5" Conduit  
PROTECTION = 30 A

Figure 5.1B.2 | New Dimmer Rack DR-202/207

## 2. PHOTOVOLTAIC ARRAY ANALYSIS

With the growth of the LEED movement, photovoltaic (PV) systems are surging as a popular 'green' choice for owners who want an energy conscious design. With numerous government incentives available, the cost-effectiveness of implementing such a system can become complex. As a building seeking LEED certification, a PV system is something that should at least be considered by the designer.

This analysis was conducted utilizing RETScreen, an analysis tool for energy design. Since enough area is not available to provide power for the entire building, the system needs to be an on-grid system. The designed system would not use a battery supply and excess energy would be transferred back to the grid. The following is a summary of the analysis:




Figure 5.2.1 | Available Area for PV Array

**Roof Area available for PV array:** Approximately 12,000 ft<sup>2</sup> (1115 m<sup>2</sup>)

**Product:** BP Solar 5170S

**Power Produced:** 192KWh

**Physical Size:** 1.26 m<sup>2</sup>

**Efficiency:** 13.5%

**Total System Efficiency (Combined Panel and System):** 3%

**Unit Cost:** \$5,750

**Maintenance Costs:** \$10,000/10 Years

**Design Costs:** \$15,000

**Other Equipment Costs (inverter and power equipment):** \$100,000

**Annual Energy Available (Pittsburgh):** 1.53MWh/m<sup>2</sup>




**Energy Rate:** .1236 cents/KWh

**Energy Savings/Year/Panel:** \$28


**Financial Incentives:**

- *Federal tax incentives* do not apply since the August Wilson Center is a non-profit organization.
- The *Pennsylvania Energy Harvest Grant*, or any other state incentive, is no longer available.
- *Duquesne Light* does not currently offer any incentives for implementation of renewable energy.

**Payback Period:** This installation will never provide a return on the investment.



**Figure 5.2.2 | PV Solar Radiation Map (From Electric & Hydrogen Technologies & Systems Center – May 2004)**



**Figure 5.2.3** | Site shadow conditions midday throughout the year. The August Wilson Center is at the center of the model.

#### **Photovoltaic Array Feasibility Conclusion:**

Based on the calculations, it is certainly not feasible to use a photovoltaic array for this project. Figure 5.2.2 shows that Pittsburgh does not receive a substantial amount of solar energy. Additionally based on the buildings location in the urban center of Pittsburgh and the shadowing by adjacent buildings (Figure 5.2.3), the actual energy savings would likely be less that the model predicts. The PV array would likely receive direct sunlight at noon on less than half of the days during the year.

Another factor affecting the feasibility is the low utility rate that this property receives. Finally, since the August Wilson Center is a non-profit organization, it cannot receive federal and state tax incentives for solar energy. This places the full cost of the initial installation on the owner, significantly affecting the payback of the system. Even without considered specific system characteristics, it is evident that PV energy production is not a cost effective choice for the August Wilson Center. In order for the system to have reasonable payback period, the panels would have to be far more efficient than what is currently available.

### 3. SYSTEM TYPE CONVERSION STUDY

The existing design for the August Wilson Center utilizes two parallel service entrances, providing redundancy should one fail through a collector bus which connects to two main switchboards. One of the switchboards (MSB1) feeds primarily mechanical loads and the emergency power system while the second switchboard (MSB2) feeds predominantly lighting and receptacle loads. Both switchboards are currently designed at 280Y/120V.


Studying the single line diagram revealed that MSB1 could be changed to a 480/277V system with minimal disruption to the system. One drawback to this change is the elimination of the point of redundancy, however. In order to make a justifiable decision on the advantage of the system conversion, a comparative cost analysis was conducted.

#### The Existing System:

The portion of the existing system being studied includes the following equipment. The Duquesne Light Transformer has not been included in the cost comparison because it is the responsibility of the utility company.

TYPE	TAG	LOCATION	DESCRIPTION
Transformer	NA	Transformer Vault	Duquesne Light Transformer
Main Switchboard	MSB1	Basement (013)	208Y/120, 3000A MCB
Distribution Panel	BNDP1	Basement (013)	208Y/120, 1200A MLO
Distribution Panel	BNDP2	Basement (013)	208Y/120, 400A MLO
Branch Circuit Panel	2P1	Electrical Room (212)	208Y/120, 225A MLO
Branch Circuit Panel	1KN1	Kitchen (140)	208Y/120, 400A MLO
Branch Circuit Panel	1KN2	Kitchen (140)	208Y/120, 225A MLO

A portion of the existing single line diagram as well as the panelboards that will change are shown on the following pages.



**Figure 5.3.1** | Single Line Diagram for existing system. Highlight shows area to be redesigned. Existing and new Single Line Diagrams are available at a larger scale in Appendix G.

**BASEMENT (ELEVATORS) DISTA. PANEL BNDP1**

PANEL TYPE		MAIN LUGS		PANEL		BUS RATING										
		1200A														
DESCRIPTION	WIRE SIZE	K.W.	AMPS	TRIP	POLE	CIRC.	PHASE			CIRC.	POLE	TRIP	AMPS	K.W.	WIRE SIZE	DESCRIPTION
							A	B	C							
ELEVATOR No. 1 50.0HP (150.0 FLA)	54.0	300	1	1	•	2	•	3	2	300	54.0				ELEVATOR No. 1 50.0HP (150.0 FLA)	
ELEVATOR No. 2 50.0HP (150.0 FLA)	54.0	300	7	5	•	8	•	9	8	250	43.2				ELEVATOR No. 2 50.0HP (150.0 FLA)	
SPACE			3	11	•	12	•	13	12	3	0.0				SPACE	
SPACE			3	15	•	16	•	17	16	3					SPACE	
SPACE			3	19	•	20	•	21	20	3					SPACE	
SPACE			3	21	•	22	•	23	22	3					SPACE	
SPACE			3	23	•	24	•	25	24	3					SPACE	
SPACE			3	25	•	26	•	27	26	3					SPACE	
SPACE			3	27	•	28	•	29	28	3					SPACE	
SPACE			3	29	•	30	•	31	30	3					SPACE	
SPACE				31	•	32	•	33	32						SPACE	
SPACE				33	•	34	•	35	34						SPACE	
SPACE				35	•	36	•	37	36						SPACE	
SPACE				37	•	38	•	39	38						SPACE	
SPACE				39	•	40	•	41	40						SPACE	
SPACE				41	•	42	•		42						SPACE	

TOTAL LOAD 108.0 KW      PHASE A \_\_\_\_\_      PHASE B \_\_\_\_\_      PHASE C \_\_\_\_\_      POSITION SIZE \_\_\_\_\_  
 K.W. \_\_\_\_\_ AMPS \_\_\_\_\_      AT DIST. BOARD \_\_\_\_\_  
 FEEDER SIZE \_\_\_\_\_      FUSE OR TRIP \_\_\_\_\_  
 VOLTAGE \_\_\_\_\_      TOTAL = 205.2 KW

Figure 5.3.2 | BNDP1 – Existing Design – Layout Provided by Hornfeck Engineering

**BASEMENT (MECHANICAL) DISTA. PANEL BNDP2**

PANEL TYPE		MAIN LUGS		PANEL		BUS RATING										
		400A														
DESCRIPTION	WIRE SIZE	K.W.	AMPS	TRIP	POLE	CIRC.	PHASE			CIRC.	POLE	TRIP	AMPS	K.W.	WIRE SIZE	DESCRIPTION
							A	B	C							
DOMESTIC WATER HOT WATER PUMP	36	20	1	1	•	2	•	3	2	20	1.9					AC-1 AC-2 (6.3 FLA) (2.8 FLA)
DHW-1 & DHW-2 (1/2HP) (1/2HP)	.60		3	5	•	6	•	7	6	20						SPACE
DOMESTIC HOT WATER PUMP-DHW-1	.60		7	9	•	10	•	11	10							SPACE
SPACE			3	11	•	12	•	13	12							SPACE
SPACE			3	15	•	16	•	17	16							SPACE
SPACE			3	19	•	20	•	21	20	40	6.3					LOADING DOCK LIFT-MOTOR 5.0HP 17.5 FLA
SPACE			3	21	•	22	•	23	22	3						SPACE
SPACE			3	23	•	24	•	25	24							SPACE
SPACE			3	25	•	26	•	27	26							SPACE
SPACE			3	27	•	28	•	29	28							SPACE
SPACE			3	29	•	30	•	31	30							SPACE
SPACE			3	31	•	32	•	33	32							SPACE
SPACE			3	33	•	34	•	35	34							SPACE
SPACE			3	35	•	36	•	37	36							SPACE
SPACE			3	37	•	38	•	39	38							SPACE
SPACE			3	39	•	40	•	41	40							SPACE
SPACE			3	41	•	42	•		42							SPACE

TOTAL LOAD 1.6 KW      PHASE A \_\_\_\_\_      PHASE B \_\_\_\_\_      PHASE C \_\_\_\_\_      POSITION SIZE \_\_\_\_\_  
 K.W. \_\_\_\_\_ AMPS \_\_\_\_\_      AT DIST. BOARD \_\_\_\_\_  
 FEEDER SIZE \_\_\_\_\_      FUSE OR TRIP \_\_\_\_\_  
 VOLTAGE \_\_\_\_\_      TOTAL = 9.8 KW

Figure 5.3.3 | BNDP2 – Existing Design – Layout Provided by Hornfeck Engineering

400A      PANEL 1KN1

PANEL TYPE		MAIN LUGS		PANEL		BUS RATING		DESCRIPTION							
DESCRIPTION		WIRE SIZE	K.W.	AMPS	TRIP	POLE	CIRC.	PHASE	CIRC.	POLE	TRIP	AMPS	K.W.	WIRE SIZE	DESCRIPTION
								A B C							
SPACE						1			2						SPACE
						3			4						
						5			6						
						7			8						
						9			10						
						11			12						
						13			14						
SPACE						15			16	50		5.4			KITCHEN
						17			18	2					
KITCHEN 140			5.4			19			20	50		5.4			KITCHEN 140
						21			22	2					
SPACE						23			24						SPACE
						25			26	150		7.1			PANEL 1KN2
						27			28						
						29			30		3				
						31			32						
						33			34						
						35			36						
						37			38	50					
						39			40						
						41			42						

TOTAL LOAD \_\_\_\_\_ 5.4 KW      PHASE A \_\_\_\_\_ 17.9 KW      POSITION SIZE \_\_\_\_\_  
 K.W. \_\_\_\_\_ AMPS \_\_\_\_\_      PHASE B \_\_\_\_\_      AT DIST. BOARD \_\_\_\_\_  
 FEEDER SIZE \_\_\_\_\_      PHASE C \_\_\_\_\_      FUSE OR TRIP \_\_\_\_\_  
 VOLTAGE \_\_\_\_\_      TOTAL = 23.3 KW

Figure 5.3.4 | 1KN1 – Existing Design – Layout Provided by Hornfeck Engineering

PANEL 1KN2

PANEL TYPE		MAIN LUGS		PANEL		BUS RATING		DESCRIPTION							
DESCRIPTION		WIRE SIZE	K.W.	AMPS	TRIP	POLE	CIRC.	PHASE	CIRC.	POLE	TRIP	AMPS	K.W.	WIRE SIZE	DESCRIPTION
								A B C							
KITCHEN 140		1.2		20		1			2	20		360			OUTDOOR CAFE - GFS
		1.2				3			4			360			OUTDOOR CAFE - GFS
		1.2				5			6			360			OUTDOOR CAFE - GFS
		1.2				7			8						SPACE
		1.2				9			10						
SPACE						11			12						
						13			14						
						15			16						
						17			18						
						19			20						
						21			22						
						23			24						
						25			26						
						27			28						
						29			30						
						31			32						
						33			34						
						35			36						
						37			38						
						39			40						
						41			42						

TOTAL LOAD \_\_\_\_\_ 6.0 KW      PHASE A \_\_\_\_\_ 1.1 KW      POSITION SIZE \_\_\_\_\_  
 K.W. \_\_\_\_\_ AMPS \_\_\_\_\_      PHASE B \_\_\_\_\_      AT DIST. BOARD \_\_\_\_\_  
 FEEDER SIZE \_\_\_\_\_      PHASE C \_\_\_\_\_      FUSE OR TRIP \_\_\_\_\_  
 VOLTAGE \_\_\_\_\_      TOTAL = 7.1 KW

Figure 5.3.5 | 1KN2 – Existing Design – Layout Provided by Hornfeck Engineering




Figure 5.3.6 | 2P1 – Existing Design – Layout Provided by Hornfeck Engineering

**The Redesigned System:**

Redesigning the system involved recalculating the loading on each panelboard in order to resize the bus and the feeder. Also, the addition of two transformers is necessary to accommodate loads that must run at 120V. Below is the new equipment schedule and panelboard schedules. A new single line diagram is available in Appendix G

TYPE	TAG	LOCATION	DESCRIPTION
Transformer	NA	Trans. Vault	Duquesne Light Transformer
Transformer	2T1	Electrical Room (212)	9 KVA, 480V to 108Y/120V
Transformer	1T3	Kitchen (140)	30 KVA, 480V to 108Y/120V
Main Switchboard	MSB1	Basement (013)	480/277, 1600A MCB
Distribution Panel	BNDP1	Basement (013)	480/277, 400A MLO
Distribution Panel	BNDP2	Basement (013)	480/277, 100A MLO
Branch Circuit Panel	2P1	Electrical Room (212)	480/277, 100A MLO
Branch Circuit Panel	2P1A	Electrical Room (212)	480/277, 60A MLO
Branch Circuit Panel	1KN1	Kitchen (140)	208Y/120, 400A MCB
Branch Circuit Panel	1KN2	Kitchen (140)	208Y/120, 225A MLO (Unchanged)

Table 5.3.3: Feeder Sizes For Converted System							
TAG	FROM	TO	SETS	NO. WIRES	TYPE	SIZE	CONDUIT
A	TRANS.	MSB1	4	4	CU THWN	500	3" EMT
B	MSB1	2P1	1	4	CU THWN	#6	1" EMT
C	MSB1	AHU-1	1	4	CU THWN	2/0	2" EMT
D	MSB1	AHU-5	1	4	CU THWN	3/0	2" EMT
E	MSB1	AHU-2	1	4	CU THWN	#1	1.5" EMT
F	MSB1	AHU-4	1	4	CU THWN	#2	1.25" EMT
G	MSB1	1T3	1	4	CU THWN	#3	1.25" EMT
H	MSB1	BNDP1	1	4	CU THWN	400	3" EMT
I	MSB1	BNDP2	1	4	CU THWN	#8	1" EMT
J	BNDP1	ELEV 2	1	4	CU THWN	#4	1.25" EMT
K	BNDP1	ELEV 1	1	4	CU THWN	#4	1.25" EMT
L	BNDP1	ELEV 1	1	4	CU THWN	#4	1.25" EMT
M	BNDP1	ELEV 3	1	4	CU THWN	#6	1" EMT
N	2P1	2T1	1	4	CU THWN	#10	1/2" EMT
O	2T1	2P1A	1	4	CU THWN	#10	1/2" EMT
P	1KN1	1KN2	1	4	CU THWN	#6	1" EMT
Q	1T3	1KN1	1	4	CU THWN	#2	1.25" EMT

PANEL BOARD SCHEDULE											
VOLTAGE: 480/277V,3PH,4W SIZE/TYPE BUS: 400A SIZE/TYPE MAIN: M.L.O			PANEL TAG: BNDP1 PANEL LOCATION: BASEMENT B013 PANEL MOUNTING: SURFACE					MIN. C/B AIC: 25K OPTIONS:			
DESCRIPTION	LOAD (W)	C/B SIZE	POS. NO.	A	B	C	POS. NO.	C/B SIZE	LOAD (W)	DESCRIPTION	
ELEVATOR NO. 1 (50 HP) [65 FLA]	18000	150A/3P	1	*			2	150A/3P	18000	ELEVATOR NO. 1 (50 HP)	
	18000		3		*		4		18000	[65 FLA]	
	18000		5			*	6		18000		
ELEVATOR NO. 2 (50 HP) [65 FLA]	18000	150A/3P	7	*			8	100A/3P	14400	ELEVATOR NO. 3 (40HP)	
	18000		9		*		10		14400	[52 FLA]	
	18000		11			*	12		14400		
SPARE		150A/3P	13	*			14	150A/3P		FUTURE LIFT	
			15		*		16				
			17			*	18				
SPARE		150A/3P	19	*			20	150A/3P		SPARE	
			21		*		22				
			23			*	24				
SPARE		100A/3P	25	*			26	100A/3P		SPARE	
			27		*		28				
			29			*	30				
CONNECTED LOAD (KW) - A	68.40							TOTAL DESIGN LOAD (KW)	205.20		
CONNECTED LOAD (KW) - B	68.40							SPACE (GROWTH) FACTOR	1.35		
CONNECTED LOAD (KW) - C	68.40							TOTAL DESIGN LOAD (A)	333		

Figure 5.3.7 | New Panel BNDP1



PANEL BOARD SCHEDULE										
VOLTAGE: 480/277V,3PH,4W SIZE/TYPE BUS: 100A SIZE/TYPE MAIN: M.L.O.			PANEL TAG: BNDP2 PANEL LOCATION: BASEMENT B013 PANEL MOUNTING: SURFACE					MIN. C/B AIC: 25K OPTIONS:		
DESCRIPTION	LOAD (W)	C/B SIZE	POS. NO.	A	B	C	POS. NO.	C/B SIZE	LOAD (W)	DESCRIPTION
DOMESTIC WATER HTR CONTL	360	20A/1P	1	*			2	20A/2P	950	AC-1 & AC-2
DHWP-1 & DHWP-2 (1/12 HP EA)	600	20A/1P	3		*		4		950	[2.73 + 1.21 FLA]
DOMESTIC HOT WATER HTR DHW-1	600	20A/1P	5			*	6	20A/1P		SPARE
SPARE		20A/1P	7	*			8	20A/1P		SPARE
SPARE		20A/1P	9		*		10	20A/1P		SPARE
SPARE		20A/1P	11			*	12	20A/1P		SPARE
SPARE		20A/1P	13	*			14	20A/1P		SPARE
SPARE		20A/1P	15		*		16	20A/1P		SPARE
SPARE		20A/1P	17			*	18	20A/1P		SPARE
SPACE			19	*			20	20A/3P	2100	LOADING DOCK LIFT MOTOR (5 HP)
SPACE			21		*		22		2100	[7.58 FLA]
SPACE			23			*	24		2100	
SPACE			25	*			26			SPACE
SPACE			27		*		28			SPACE
SPACE			29			*	30			SPACE
SPACE			31	*			32			SPACE
SPACE			33		*		34			SPACE
SPACE			35			*	36			SPACE
CONNECTED LOAD (KW) - A	3.41								TOTAL DESIGN LOAD (KW)	9.76
CONNECTED LOAD (KW) - B	3.65								SPACE (GROWTH) FACTOR	1.50
CONNECTED LOAD (KW) - C	2.70								TOTAL DESIGN LOAD (A)	20

Figure 5.3.8 | New Panel BNDP2

PANEL BOARD SCHEDULE										
VOLTAGE: 480/277V,3PH,4W SIZE/TYPE BUS: 100A SIZE/TYPE MAIN: M.L.O.			PANEL TAG: 2P1 PANEL LOCATION: ELECTRICAL ROOM 212 PANEL MOUNTING: SURFACE					MIN. C/B AIC: 22K OPTIONS:		
DESCRIPTION	LOAD (W)	C/B SIZE	POS. NO.	A	B	C	POS. NO.	C/B SIZE	LOAD (W)	DESCRIPTION
EXH FAN EF-3 (1/3 HP)	864	20A/1P	1	*			2	20A/1P	864	EXH FAN EF-1 (1/3 HP)
SPARE		20A/1P	3		*		4	20A/1P		SPARE
SPARE		20A/1P	5			*	6	20A/2P	1331	COND UNIT CU-4
SPARE		20A/1P	7	*			8		1331	[5.54 FLA]
COND UNIT CU-1	1533	20A/3P	9		*		10	20A/3P	1533	COND UNIT CU-5
[5.54 FLA]	1533		11			*	12		1533	[5.54 FLA]
	1533		13	*			14		1533	
COND UNIT CU-2	1533	20A/3P	15		*		16	20A/3P	497	EXH FAN EF-2 (1.0 HP)
[5.54 FLA]	1533		17			*	18		497	[1.79 FLA]
	1533		19	*			20		497	
COND UNIT CU-3	1533	20A/3P	21		*		22	20A/3P	2500	PANEL 2P1A
[5.54 FLA]	1533		23			*	24		2500	
	1533		25	*			26		2500	
SPACE			27		*		28			SPACE
SPACE			29			*	30			SPACE
SPACE			31	*			32			SPACE
CONNECTED LOAD (KW) - A	12.19								TOTAL DESIGN LOAD (KW)	31.78
CONNECTED LOAD (KW) - B	9.13								SPACE (GROWTH) FACTOR	1.25
CONNECTED LOAD (KW) - C	10.46								TOTAL DESIGN LOAD (A)	51

Figure 5.3.9 | New Panel 2P1

PANEL BOARD SCHEDULE										
VOLTAGE: 208Y/120V,3PH,4W SIZE/TYPE BUS: 60A SIZE/TYPE MAIN: M.L.O.			PANEL TAG: 2P1A PANEL LOCATION: ELECTRICAL ROOM 212 PANEL MOUNTING: SURFACE					MIN. C/B AIC: 22K OPTIONS:		
DESCRIPTION	LOAD (W)	C/B SIZE	POS. NO.	A	B	C	POS. NO.	C/B SIZE	LOAD (W)	DESCRIPTION
WP ROOF TOP GFI RCPT	720	20A/1P	1	*			2	20A/1P	540	WP ROOF TOP GFI RCPT
WP ROOF TOP GFI RCPT	720	20A/1P	3		*		4	20A/1P	540	WP ROOF TOP GFI RCPT
HEAT TRACE	0	20A/1P	5			*	6	20A/1P	720	WP ROOF TOP GFI RCPT
SPARE	0	20A/1P	7	*			8	20A/1P	0	SPARE
AHU-1 LTG & CONTROLS	720	20A/1P	9		*		10	20A/1P	720	AHU-4 LTG & CONTROLS
AHU-2 LTG & CONTROLS	720	20A/1P	11			*	12	20A/1P	720	AHU-5 LTG & CONTROLS
SPARE	0	20A/1P	13	*			14	20A/1P	0	SPARE
SPARE	0	20A/1P	15		*		16	20A/1P	0	SPARE
SPARE	0	20A/1P	17			*	18	20A/1P	0	SPARE
SPACE			19	*			20			SPACE
SPACE			21		*		22			SPACE
SPACE			23			*	24			SPACE
CONNECTED LOAD (KW) - A	1.26						TOTAL DESIGN LOAD (KW)			7.50
CONNECTED LOAD (KW) - B	2.70						POWER FACTOR			1.00
CONNECTED LOAD (KW) - C	2.16						TOTAL DESIGN LOAD (AMPS)			21

Figure 5.3.10 | New Panel 2P1A

**Sample Calculations for New Sizing:**

*Brach Circuit Breaker for Motor (Sample for Elevator No. 2):*  
MCA (NEC 2005 430.250) = 65A \* 1.25 (First Motor) = 81.25A  
MOPD (NEC 2005 430.52) = 250% (Inverse Time Breaker)  
2.5 \* 65A = 162.5A

BREAKER SIZE: 150A  
WIRE SIZE: (3) #4 Conductors

*Transformer (Sample for Panel 1KN1):*  
Calculated Design Load: 23.3 KW, 28.8A  
Transformer: 30 kVA  
Secondary Protection: 83.3\*1.25 = 104.1A [110A] (NEC Table 450.3 (B) = 125%)  
Primary Protection: 36.1\*2.5 = 90.25A [100A] (NEC Table 450.3 (B) = 250%)

*Feeder Calculation (From MSB1 to BNDP1) \*Not the size used for cost comparison*  
Design Load (Includes Growth) = 333A  
Feeder Size = 400 MCM THW Copper in 3" Conduit (335A Capacity)

**Cost Analysis:**

The cost comparison between the new and existing systems was completed using *R.S. Means 2008 Electrical Cost Data*. The existing system from the most recent set of drawings is designed and sized for the original contract, which was a guaranteed maximum price (GMP). Because of this, all equipment

and feeders were grossly oversized. Feeders were sized to match bus size. In order for the cost estimate to provide comparable results, this same method was utilized. The bus sizes have all been resized based on the new panel demand loads, however, greatly reducing the feeder sizes.

As noted previously, the utility transformer has not been included in this analysis because it is the responsibility of Duquesne Light. Additionally, feeders N, O, P, and Q have been omitted due to insignificant lengths.

The cost comparison is broken down in the following table:

<b>Table 5.3.3: Electrical System Redesign - 208/120V to 480/277V - Cost Analysis</b>								
<b>PANELS</b>								
Label	Load (KW)	Ex. Size (A)	Ex. Cost	New Size (A)	New Cost			
MSB1	-	3000	\$40,600.00	1600	\$26,100.00			
MSB2	NO CHANGE IN SIZE							
BNDP1	205.2	400	\$1,750.00	100	\$900.00			
BNDP2	9.8	1200	\$5,275.00	400	\$1,750.00			
1KN1	23.2	400	\$3,125.00	100	\$1,300.00			
1KN2	NO CHANGE IN SIZE							
2P1	30.4	225	\$1,175.00	100	\$900.00			
2P1A	NA	NA	NA	60	\$700.00			
			<b>Subtotal = \$48,800.00</b>	<b>Subtotal = \$30,350.00</b>				
<b>FEEDERS</b>								
				<b>Per 100'</b>		<b>(All feeders 75 C type THWN)</b>		
Label	Length (ft)	No. Wires	Ex. Size	Ex. Cost/Unit	Ex. Cost	New Size	New Cost/Unit	New Cost
A	30	4	(4) 500	\$1,550.00	\$7,440.00	(4) 500	\$1,550.00	\$7,440.00
B	35	4	4/0	\$755.00	\$1,063.04	3	\$244.00	\$343.55
C	129	4	(2) 4/0	\$755.00	\$7,773.48	2/0	\$505.00	\$2,599.74
D	248	4	(2) 250	\$870.00	\$17,226.00	3/0	\$620.00	\$6,138.00
E	76	4	500	\$1,550.00	\$4,705.80	1	\$350.00	\$1,062.60
F	190	4	350	\$1,150.00	\$8,753.80	2	\$291.00	\$2,215.09
G	242	4	(2) 3/0	\$620.00	\$12,003.20	2	\$291.00	\$2,816.88
H	15	4	(4) 350	\$1,150.00	\$2,760.00	(2) 3/0	\$620.00	\$744.00
I	15	4	(2) 3/0	\$620.00	\$744.00	3	\$244.00	\$146.40
J	35	4	350	\$1,150.00	\$1,610.00	4	\$209.00	\$292.60
K	35	4	350	\$1,150.00	\$1,610.00	4	\$209.00	\$292.60
L	35	4	350	\$1,150.00	\$1,610.00	4	\$209.00	\$292.60
M	35	4	350	\$1,150.00	\$1,610.00	6	\$152.00	\$212.80
				<b>Subtotal = \$68,909.32</b>			<b>Subtotal = \$24,596.86</b>	
<b>OTHER</b>								
Item	Existing	Existing Cost	New Size	New Cost				
1TKN1	NA	NA	30 kVA	\$3,425.00				
2TP1A	NA	NA	9 kVA	\$2,200.00				
				<b>Subtotal = \$5,625.00</b>				
					<b>Existing System Total = \$117,709.32</b>			
					<b>New System Total = \$60,571.86</b>			
					<b>COST DIFFERENCE = \$57,137.46</b>			

**System Conversion Conclusion:**

As shown in Table 5.3.3, converting MSB1 and its connected loads to a 480/277V system saves a significant amount of money. For a project that is trying to reduce the bottom line, this change seems to be a viable option. The tabulated data does not include further cost savings that would result from a reduction of individual breakers for branch circuits.

The second factor that must be considered in the conversion of this system is the loss of redundancy provided by the collector bus. Since the system includes a substantial emergency generator and the system does not include critical loads, it is my opinion that using a 480/277V system for switchboard MSB1 is an appropriate choice for this project.

#### **4. PROTECTIVE DEVICE COORDINATION STUDY and FAULT CURRENT ANALYSIS**

As a sample calculation, a protective device coordination study and a fault current analysis was performed for a selected path through the system. The calculations that follow summarize these two procedures. That path is as follows:

*Utility Transformer > Main Switchboard (MSB1) > Distribution Panel (1NDP1) > End-Use Panel (1N1)*

The results show that the currently designed system uses has equipment specified which, in one case, is less than that required by the calculations. Branch circuit panelboard 1TN1 requires 25000 AIC but the specified equipment is rated at 22,000 AIC. It is likely that a fault current analysis was not conducted for the production of this set of documents.

Types EHD, FDB, FD and HFD 20 Amperes ———— Curve No. SC-4135-87B  
 Type LA, 225 Amperes, 2 and 3 Poles ———— Curve No. SC-3587-76A  
 Type PB, 1200 Amperes, 2 and 3 Poles ———— Curve No. SC-3602-76B




Figure 5.4.1 | Protective Device Coordination Study

**Table 5.4.1: Summary Results of Fault Analysis**

Point	Location	Available Fault (A)	Standard Breaker Rating (A)
A	Utility Company Secondary	41630	42000
B	Switchboard (MSB2)	40197	42000
C	Distribution Panel (1NDP1)	34195	42000
D	End Use Panel (1N1)	24599	25000

**Table 5.4.2: Fault Current Analysis (Per Unit Method)**

	System Voltage = 208					
	Base KVA = 10000					
	Utility Company Available Fault = 100000000	$\Sigma X$	$\Sigma R$	$\Sigma Z$		$I_{sc} (A)$
<b>Utility Primary</b>						
	$X_{(p.u.)} = KVA_{base} / \text{Utility S.C. KVA} = 0.0001$	0.000	0.000	0.000		<b>277572245</b>
	$R_{(p.u.)} = 0.0000$					
<b>Transformer Secondary</b>						
%Z = 5.00	$X_{(p.u.)} = \%X * KVA_{base} / 100 * KVA_{xfrmr} = 0.5951$	0.595	0.301	0.667		<b>41630</b>
X/R = 1.98	$R_{(p.u.)} = \%R * KVA_{base} / 100 * KVA_{xfrmr} = 0.3005$					
%X = 4.46						
%R = 2.25						
kVA = 750						
<b>Switchboard MSB1</b>						
Wire = 500	$X = (L/1000) * X_t * (1/Sets), X_{(p.u.)} = 0.0202$	0.615	0.313	0.691		<b>40197</b>
Length = 15	$R = (L/1000) * R * (1/Sets), R_{(p.u.)} = 0.0127$					
Sets = 8						
X = 0.047						
R = 0.029						
<b>Panel Board 1NDP1</b>						
Wire = 400	$X = (L/1000) * X_t * (1/Sets), X_{(p.u.)} = 0.0991$	0.714	0.385	0.812		<b>34195</b>
Length = 35	$R = (L/1000) * R * (1/Sets), R_{(p.u.)} = 0.0720$					
Sets = 4						
X = 0.049						
R = 0.036						
<b>Panel Board 1N1</b>						
Wire = 4/0	$X = (L/1000) * X_t * (1/Sets), X_{(p.u.)} = 0.2068$	0.921	0.652	1.128		<b>24599</b>
Length = 18	$R = (L/1000) * R * (1/Sets), R_{(p.u.)} = 0.2663$					
Sets = 1						
X = 0.050						
R = 0.064						