



Appendix D. Mechanical Breadth

<p>MECHANICAL BREADTH</p> <p>1) TYPICAL FLOOR</p> <p>↳ SQUARE FOOTAGE:</p> <table style="margin-left: 40px;"> <tr> <td>FIRST FLOOR</td> <td>29,537</td> <td>GSF</td> </tr> <tr> <td><u>TYPICAL 2-4</u></td> <td>30,550</td> <td>GSF (x 3)</td> </tr> <tr> <td>FIFTH</td> <td>29,420</td> <td>GSF</td> </tr> </table> <p>↳ WALL LENGTH:</p> <p>PLAN NORTH:</p> $15' + 30.6 + 24.854 = 220 \text{ LF}$ <p>PLAN SOUTH: 205 LF</p> <p>PLAN EAST/WEST:</p> $20' + 30.4 + 8 + 24 + 11'-10 + 9 = 190 \text{ LF}$ <p>↳ HEIGHT OF LEVEL: TYPICAL 13'-8"</p> <p>↳ OCCUPANCY: OFFICE</p> <p>MAX # PPL: 1,508 PPL WITH E</p> <p>↳ % GLASS:</p> <p>• EAST ELEVATION</p> $A_{\text{BRICK}} = (58' \cdot 13.67' - 2 \cdot 8'^2) + (2 \cdot 4' \cdot 13.67')$ $+ (47' \cdot 13.67' - 8'^2)$ $= 1353 \text{ FT}^2$ $A_{\text{GLASS}} = 2 \cdot 8^2 + 8^2 + 13.67' \cdot 11' + 2 \cdot 4' \cdot 13.67'$ $+ 56' \cdot 13.67' + 4 \cdot 13.67'$ $= 1272 \text{ FT}^2$ $A_{\text{MULTIPLY}} = 0.1 \cdot A_{\text{GLASS}} = 127 \text{ FT}^2$ <p>• ALUMINUM</p> $\% \text{ GLASS} = \frac{1272 - 127}{1353 + 1272} = 0.44$	FIRST FLOOR	29,537	GSF	<u>TYPICAL 2-4</u>	30,550	GSF (x 3)	FIFTH	29,420	GSF	<p>PG 1 SMPJ</p>
FIRST FLOOR	29,537	GSF								
<u>TYPICAL 2-4</u>	30,550	GSF (x 3)								
FIFTH	29,420	GSF								



MECHANICAL BREADTH

Pg 2 EMPJ

• WEST ELEVATION:

$$A_{brick} = [(124 + 52) \cdot 13.67 - 7 \cdot 8^2] = 1958 \text{ FT}^2$$

$$A_{glass} = 4' \cdot 13.67 + 11' \cdot 13.67 + 7 \cdot 8^2 = 653 \text{ FT}^2$$

$$A_{mullions} = 0.05 A_{glass} = 0.05(653) = 33 \text{ FT}^2$$

$$\Delta \text{ GLASS} = \frac{653 - 33}{1958 + 653} = 0.18$$

• SOUTH ELEVATION:

$$A_{brick} = 7' \cdot 13.67 \cdot 3 + 64' \cdot 13.67 - 4 \cdot 8^2 + 11' \cdot 13.67'$$

$$= 1056 \text{ FT}^2$$

$$A_{glass} = 4 \cdot 8^2 + 50' \cdot 13.67 + 26' \cdot 13.67 \cdot 2$$

$$= 1650 \text{ FT}^2$$

$$A_{mullions} + \text{aluminum} = 0.1 A_{glass} = 165 \text{ FT}^2$$

$$\Delta \text{ Glass} = \frac{1650 - 165}{1056 + 1650} = 0.55$$

• NORTH ELEVATION

$$A_{brick} = (7' \cdot 4 + 4' \cdot 4) \cdot 13.67' = 602 \text{ FT}^2$$

$$A_{glass} = (18' + 26' \cdot 4 + 50' + 8') \cdot 13.67' = 2460 \text{ FT}^2$$

$$A_{mullions} + \text{aluminum} = 0.1 A_{glass} = 246 \text{ FT}^2$$

$$\Delta \text{ GLASS} = \frac{2460 - 246}{2460 + 602} = 0.72$$

$$\text{TOTAL } \Delta \text{ GLASS} = \frac{1272 - 127 + 653 - 33 + 1650 - 165 + 2460 - 246}{1353 + 1272 + 1958 + 653 + 1056 + 1650 + 2460 + 602}$$

$$= 0.497 \cdot 100 = \boxed{49.7 \%}$$



MECHANICAL BREADTH

PG 3 SMPJ

↳ R-VALUES WALLS & ROOF
NOT AVAILABLE

↳ U-VALUES WINDOWS

ASSUME SPECTRICALLY SELECTIVE TINT DOUBLE GLAZED

↳ $U = 0.24 \rightarrow 0.3$ (TABLE 2.491
ARCH. GRAPH. STANDARDS)

② BUILDING INFORMATION

• EXISTING

↳ PITTSBURGH, PA

↳ TOTAL FLOORS: 5

↳ WINDOW SHADING UNKNOWN

↳ ADJACENT BUILDINGS:

- SIMILAR 3 TO 5 STORY BUILDINGS
ACROSS STREET ON WEST SIDE ONLY

• NEW

↳ OAKLAND, CA

↳ TOTAL FLOORS: 7



System Checksums
By PSUAE

EXISTING

Variable Volume Reheat (30% Min Flow Default)

System - 001

COOLING COIL PEAK		CLG SPACE PEAK		HEATING COIL PEAK		TEMPERATURES	
Mo/Hr: 7 / 15	Mo/Hr: 9 / 13	Mo/Hr: 13 / 1	Mo/Hr: 9 / 13	Mo/Hr: 13 / 1	Mo/Hr: 13 / 1	Mo/Hr: 13 / 1	Mo/Hr: 13 / 1
Outside Air:	OADB/WB/HR: 86 / 71 / 95	OADB: 76	OADB: 76	OADB: 5	OADB: 5	OADB: 5	OADB: 5
Space Sens. + Lat. Sens. + Plenum Sens. + Lat. Sens.	Space Sensible Of Total	Space Percent Sensible Of Total (%)	Space Sensible Of Total	Space Sensible Of Total	Space Sensible Of Total	Space Sensible Of Total	Space Sensible Of Total
Btu/h	Btu/h	(%)	Btu/h	Btu/h	Btu/h	Btu/h	Btu/h
Envelope Loads			Envelope Loads				
Sky/lt Solar	0	0.00	Sky/lt Solar	0	0.00	Sky/lt Solar	0
Sky/lt Cond	0	0.00	Sky/lt Cond	0	0.00	Sky/lt Cond	0
Roof Cond	0	0.00	Roof Cond	0	0.00	Roof Cond	0
Glass Solar	433,559	12.62	Glass Solar	680,221	33.76	Glass Solar	-633,320
Glass Cond	102,275	2.98	Glass Cond	11,064	0.55	Glass Cond	-20,488
Wall Cond	77,317	2.25	Wall Cond	55,129	2.74	Wall Cond	-136,725
Partition	0	0.00	Partition	0	0.00	Partition	0
Exposed Floor	0	0.00	Exposed Floor	0	0.00	Exposed Floor	0
Infiltration	0	0.00	Infiltration	0	0.00	Infiltration	0
Sub Total ==>	613,151	20.91	746,414	37.05	-770,045	-880,513	28.47
Internal Loads			Internal Loads				
Lights	500,482	18.21	Lights	500,482	24.84	Lights	0
People	679,500	19.78	People	377,500	18.74	People	0
Misc	234,601	6.83	Misc	208,534	10.35	Misc	0
Sub Total ==>	1,414,583	44.83	1,086,517	53.93	0	0	0.00
Ceiling Load	230,151	0.00	Ceiling Load	181,836	9.03	Ceiling Load	-110,468
Ventilation Load	0	0.00	Ventilation Load	0	0.00	Ventilation Load	0
Ov/Undr Sizing	0	0.00	Ov/Undr Sizing	0	0.00	Ov/Undr Sizing	0
Exhaust Heat	-26,844	-0.78	Exhaust Heat	0	0.00	Exhaust Heat	0
Sup. Fan Heat	185,836	5.41	OA Preheat Diff.	0	0.00	OA Preheat Diff.	0
Ret. Fan Heat	111,502	3.25	RA Preheat Diff.	0	0.00	RA Preheat Diff.	0
Duct Heat PkUp	0	0.00	Additional Reheat	0	0.00	Additional Reheat	0
Reheat at Design	0	0.00	Grand Total ==>	2,014,767	100.00	Grand Total ==>	-3,092,413
Grand Total ==>	2,257,886	100.00	3,434,834	100.00	3,434,834	100.00	100.00

COOLING COIL SELECTION		HEATING COIL SELECTION	
Total Capacity	Sens Cap.	Total Capacity	Sens Cap.
ton	MBh	ton	MBh
Main Clg	286.2	3,434.8	2,581.0
Aux Clg	0.0	0.0	0.0
Opt Vent	0.0	0.0	0.0
Total	286.2	3,434.8	2,581.0

AIRFLOWS		ENGINEERING CKS	
Cooling	Heating	Cooling	Heating
cfm	cfm	cfm	cfm
Vent	30,200	% OA	23.4
Infil	0	cfm/ft²	0.85
Supply	129,216	ft²/ton	451.43
Return	40,138	Btu/hr-ft²	533.65
MinStop/Rh	40,138	No. People	1,510
Exhaust	40,138		
Rm Exh	30,200		
Auxiliary	0		
	0		
	0		

AREAS		HEATING COIL SELECTION	
Gross Total	Glass It² (%)	Capacity	Coil Airflow
sq ft		MBh	cfm
Floor	152,750	Main Htg	-1,351.6
Part	0	Aux Htg	0.0
ExFir	0	Preheat	-1,740.8
Roof	30,550	Humidif	0.0
Wall	56,350	Opt Vent	0.0
	16,905	Total	-3,092.4

Figure 79 – TRACE Results

Project Name: C:\CDSTRACE700\Projects\Sam Thesis.trc
Dataset Name: C:\CDSTRACE700\Projects\Sam Thesis.trc

TRACE® 700 v4.1 calculated at 01:36 PM on 04/02/2008
Alternative - 1 - System Checksums report Page 1 of 1



System Checksums
By PSUAE

OAKLAND

Variable Volume Reheat (30% Min Flow Default)

COOLING COIL PEAK		CLG SPACE PEAK		HEATING COIL PEAK		TEMPERATURES	
Peaked at Time: Mo/Hr: 7 / 15		Mo/Hr: 8 / 15		Mo/Hr: 13 / 1			
Outside Air: OADBWB/HR: 98 / 70 / 65		OADB: 97		OADB: 32			
Envelope Loads	Space Sens. + Lat. Sens. Btu/h	Plenum Sens. + Lat. Sens. Btu/h	Net Total Btu/h	Space Sensible Btu/h	Space Peak Btu/h	Coil Peak Btu/h	Percent Total (%)
SkyLite Solar	0	0	0	0	0	0	0.00
SkyLite Cond	0	0	0	0	0	0	0.00
Roof Cond	0	277,480	277,480	0	0	-130,775	6.00
Glass Solar	732,080	0	732,080	810,512	0	0	0.00
Glass Cond	163,302	0	163,302	153,291	5.16	-276,707	12.69
Wall Cond	135,656	29,412	165,068	138,293	4.65	-138,840	6.37
Partition	0	0	0	0	0	0	0.00
Exposed Floor	0	0	0	0	0	0	0.00
Infiltration	0	0	0	0	0	0	0.00
Sub Total ==>	1,031,038	306,892	1,337,930	1,102,097	-388,612	-546,323	25.06
Internal Loads	Lights	700,675	875,844	700,675	0	0	0.00
People	677,250	175,169	677,250	376,250	0	0	0.00
Misc	328,442	0	328,442	328,442	0	0	0.00
Sub Total ==>	1,706,367	175,169	1,881,536	1,405,367	0	0	0.00
Ceiling Load	Ventilation Load	482,061	-482,061	463,491	-157,712	0	0.00
Ov/Undr Sizing	0	0	0	0	0	-1,275,032	58.49
Exhaust Heat	0	-26,756	-26,756	0	0	0	0.00
Sup. Fan Heat	4,437.0	295,982	295,982	0	0	0	0.00
Ret. Fan Heat	177,589	177,589	177,589	0	0	-358,424	16.44
Duct Heat PkUp	0	0	0	0	0	0	0.00
Reheat at Design	0	0	0	0	0	0	0.00
Grand Total ==>	3,219,466	150,833	4,436,981	2,870,955	-546,324	-2,179,778	100.00

COOLING COIL SELECTION		HEATING COIL SELECTION	
Total Capacity ton	Sens Cap. MIBh	Capacity MIBh	Coil Airflow cfm
369.8	4,437.0	-1,221.3	64,185
0.0	0.0	0.0	60.6
0.0	0.0	-958.5	30,100
0.0	0.0	0.0	0.0
Total	369.8	0.0	0.0
	4,437.0	0.0	0.0

AREAS		HEATING COIL SELECTION	
Gross Total	Glass It ² (%)	Main Htg	Lvg
213,850	0	Aux Htg	Ent
Floor	0	Preheat	ft ²
Part	0	Humidif	ft ²
EXFir	0	Opt Vent	ft ²
Roof	91,650	Total	ft ²
Wall	78,890		
	23,667		
	30		

ENGINEERING CKS	
% OA	Cooling Heating
14.8	14.8
cfm/ft ²	64,185
0.95	60.6
0.30	77.6
cfm/ton	550.05
578.37	578.37
Btu/hr-ft ²	20.75
-10.19	-10.19
No. People	1,505

Project Name: C:\CDS\TRACE700\Projects\Sam Thesis.1tc
Dataset Name: C:\CDS\TRACE700\Projects\Sam Thesis.1tc

Figure 80 – TRACE Results

TRACE® 700 v4.1 calculated at 01:42 PM on 04/02/2008
Alternative - 2 System Checksums report Page 1 of 1