

Manoa Elementary School



Amanda Cronauer

Faculty Advisor: Dr. William Bahnfleth
14 April 2010

Presentation Overview

Spring 2010


- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations

Project Background

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations

Project Information:
Project Size: 85,355 sf
Location: Havertown, PA
Cost: \$21.2 million
Stories: Classroom [3], Administration [1]
Construction Dates: May 2007-November 2008
Delivery Method: Design-Bid-Build

Project Team:
Owner: Haverford School District
Architect: McKissick Associates Architects
General Contractor: John S. McManus, Inc.
Structural Engineer: Baker Ingram & Associates, Inc.
MEP Engineer: H.F. Lenz Company



Building Layout

Spring 2010

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations

Amanda Cronauer | Mechanical Option



Building Layout

Spring 2010

Amanda Cronauer | Mechanical Option

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations



Building Layout

Spring 2010

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations



Building Layout

Spring 2010

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations

Amanda Cronauer | Mechanical Option



Building Layout

Spring 2010

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations

Amanda Cronauer | Mechanical Option



Building Layout

Spring 2010


Amanda Cronauer | Mechanical Option

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations




Existing Mechanical System

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations



Classroom Wing:

- [2] Rooftop Variable Air Volume Units
- Direct Expansion Cooling
- Hot Water Perimeter Heating
- Energy Recovery Ventilators
- [2] Air Cooled Condensing Units



Administration Wing:

- Rooftop VAV Unit with Energy Recovery Ventilator [AHU-3]
- [2] Rooftop Constant Volume Units
- Direct Expansion Cooling
- Hot Water Heating
- [3] Air Cooled Condensing Units

Design Objectives

Spring 2010

- Project Background
 - Existing Mechanical Summary
 - Design Objectives
 - Alternative Descriptions
 - Ground Source Heat Pumps
 - Air Source Heat Pumps
 - System Comparison
 - Final Recommendations
-
- Improve System Performance
 - Energy Consumption
 - Emissions
 - Total System Cost
 - Comparison of Proposed System Performance

Alternatives

Spring 2010

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
 - Ground Source Heat Pumps
 - Air Source Heat Pumps
- System Comparison
- Final Recommendations

Ground Source Heat Pumps:

- [+] Decentralized System
- [+] Higher System Efficiencies
- [+] Lower Greenhouse Gas Emissions
- [-] Increased Construction Costs
- [-] Impact of Loop on Ecosystem

Air Source Heat Pumps:

- [+] Decentralized System
- [+] Higher System Efficiencies
- [+] Lower Greenhouse Gas Emissions
- [+] No Extensive Excavation
- [-] Utilizes Electricity

Dedicated Outdoor Air:

- [+] Reduce Load on Heat Pumps
- [+] Smaller

[-] Utilizes Electricity

Vertical Loop Analysis

Spring 2010

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations

Systems to be Replaced:

- Series Fan Powered Boxes → Heat Pump
- Rooftop Air Handling Units → Dedicated Outdoor Air Unit

- Vertical Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Loop Optimization
- [Construction Management Breadth]
- Results
- Horizontal Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Results

Vertical Loop Analysis

Spring 2010

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations

Assumptions:

- Zoning
- Heat Pumps
- DOAS Units

- Vertical Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Loop Optimization [Construction Management Breadth]
- Results
- Horizontal Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Results

Vertical Loop Analysis

Spring 2010

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- **Ground Source Heat Pumps**
- Air Source Heat Pumps
- System Comparison
- Final Recommendations

Loop Sizing:

- Cooling Length

$$L_C = \frac{q_c R_a + (q_{lc} - 3.41W_c)(R_b + PLF_m R_m + R_{gm} + R_{gd} F_{sc})}{t_g - \frac{t_{wi} - t_{wo}}{2} - t_p}$$

- Heating Length

$$L_C = \frac{q_c R_a + (q_{lc} - 3.41W_c)(R_b + PLF_m R_m + R_{gm} + R_{gd} F_{sc})}{t_g - \frac{t_{wi} - t_{wo}}{2} - t_p}$$

- Vertical Loop Analysis
- Systems to be Replaced
- Assumptions
- **Loop Sizing**
- Loop Optimization
- [Construction Management Breadth]
- Results
- Horizontal Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Results

Vertical Loop Analysis

Spring 2010

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations

Loop Sizing:

Cooling Design Information			
Entering Water Temperature (°F)	Leaving Water Temperature (°F)	Cooling Load (MBH)	Total Borehole Length (feet)
75	85	1,434	23,959

Heating Design Information			
Entering Water Temperature (°F)	Leaving Water Temperature (°F)	Heating Load (MBH)	Total Borehole Length (feet)
45	35	1,153	25,052

- Vertical Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Loop Optimization [Construction Management Breadth]
- Results
- Horizontal Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Results

Vertical Loop Analysis

Spring 2010

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations

Loop Sizing:

Heating Design Information			
Entering Water Temperature (°F)	Leaving Water Temperature (°F)	Heating Load (MBH)	Total Borehole Length (feet)
45	35	1,153	25,052

- Vertical Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Loop Optimization
- [Construction Management Breadth]
- Results
- Horizontal Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Results

Vertical Loop Analysis

Spring 2010

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations

Goals:

- Meet Mechanical Load
- Minimize Construction Cost

- Vertical Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Loop Optimization
- Construction Management Breadth
- Results
- Horizontal Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Results

Vertical Loop Analysis

Spring 2010

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations

Assumptions:

- Piping → 1" High Density Polyethylene [HDPE]
 - \$0.53 per linear foot
 - 40 foot lengths
 - \$4.79 per weld
 - \$40.25 per day for welding machine
- Grout → Constant Price of \$5,937 regardless
- Miscellaneous Site Costs → Specified by Number of Boreholes
- Borehole Driller

Earth Auger Data		
Bore Length (feet)	Rent (\$/day)	Output (feet/day)
< 225	12190	1800
225 ≤ Lbore ≤ 325	14840	1200
> 325	12190	900


- Vertical Loop Analysis
 - Systems to be Replaced
 - Assumptions
 - Loop Sizing
 - Loop Optimization
 - Construction Management Breadth
- Results
- Horizontal Loop Analysis
 - Systems to be Replaced
 - Assumptions
 - Loop Sizing
 - Results

Vertical Loop Analysis

Spring 2010

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations

Results:




- Vertical Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Loop Optimization
- Construction Management Breadth
- Results
- Horizontal Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Results

Vertical Loop Analysis

Spring 2010

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations

Results:



- Vertical Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Loop Optimization
- Construction Management Breadth
- Results
- Horizontal Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Results

Vertical Loop Analysis

Spring 2010

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations

Results:

- [115] Boreholes
- [218] feet per borehole
- \$86,889 Total Installed Cost


Drill C: Depths Less than 225 feet													
Calculated Length	# Boreholes	Length per bore	Actual Length	Days	Drilling Rental Weeks	Cost	Pipe Cost	Welding Rental Number Days	Grouting Cost	Miscellaneous Cost	Total Cost		
25,052	115	218	25,070	14	3	\$36,570	\$13,287	627	2	\$3,095	\$5,937	\$28,000	\$86,889

- Vertical Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Loop Optimization
- Construction Management Breadth
- Results
- Horizontal Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Results

Vertical Loop Analysis

Spring 2010

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations




- Vertical Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Loop Optimization
- Construction Management Breadth
- Results
- Horizontal Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Results

Vertical Loop Analysis

Spring 2010

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations




- Vertical Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Loop Optimization
- [Construction Management Breadth]
- Results
- Horizontal Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Results

Vertical Loop Analysis

Spring 2010

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations



- Vertical Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Loop Optimization
- [Construction Management Breadth]
- Results
- Horizontal Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Results

Vertical Loop Analysis

Spring 2010

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations

		System Energy Savings Comparison			
	Savings Over Baseline			Savings Over Designed	
	%	\$	%	\$	
As Designed	9.56	11,936			
Redesign	24.58	30,680	19.91	18,744	

25% Reduction =
7/19 LEED Points
[EA Credit 1]

Greenhouse Gas Emission Data				
	CO2 (lbm/year)	NOX (lbm/year)	SOX (lbm/year)	Total Redesign Savings (lbm/year)
ASHRAE Baseline	2.02E+04	3.05E+01	1.64E+03	1.56E+04
As Designed	1.59E+04	2.47E+01	1.15E+03	1.08E+04
Redesign	6.15E+03	1.10E+01	1.03E+02	

- Vertical Loop Analysis
 - Systems to be Replaced
 - Assumptions
 - Loop Sizing
 - Loop Optimization
 - [Construction Management Breadth]
- Results
- Horizontal Loop Analysis
 - Systems to be Replaced
 - Assumptions
 - Loop Sizing
 - Results

Vertical Loop Analysis

Spring 2010

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations

Simple Payback Period:

Design: Redesign:

- | | |
|---------------------------------|-------------------------------|
| ■ [5] Rooftop AHU's = \$280,000 | • [67] Heat Pumps = \$420,050 |
| ■ [5] ACCU's = \$12,000 | • [5] DOAS Units = \$82,042 |
| ■ Utility = \$112,893 | • Vertical Loop = \$86,889 |
| | • Utility = \$94,129 |

Simple Payback Period: 10.76 years

- Vertical Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Loop Optimization
- [Construction Management Breadth]
- Results
- Horizontal Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Results

Vertical Loop Analysis

Spring 2010

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations

Simple Payback Period:

Design: Redesign:

- | | |
|---------------------------------|-------------------------------|
| ■ [5] Rooftop AHU's = \$280,000 | • [67] Heat Pumps = \$420,050 |
| ■ [5] ACCU's = \$12,000 | • [5] DOAS Units = \$82,042 |
| ■ Utility = \$112,893 | • Vertical Loop = \$86,889 |
| ■ Ductwork = \$319,850 | • Ductwork = \$74,531 |
| | • Utility = \$94,129 |

Simple Payback Period: 1.2 years

- Vertical Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Loop Optimization
- [Construction Management Breadth]
- Results
- Horizontal Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Results

Horizontal Loop Analysis

Spring 2010

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations

Systems to be Replaced:

- Series Fan Powered Boxes → Heat Pump
- Rooftop Air Handling Units → Dedicated Outdoor Air Unit

- Vertical Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Loop Optimization
- [Construction Management Breadth]
- Results
- Horizontal Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Results

Horizontal Loop Analysis

Spring 2010

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations

Assumptions:

- Zoning
- Heat Pumps
- DOAS Units

- Vertical Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Loop Optimization
- [Construction Management Breadth]
- Results
- Horizontal Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Results


Horizontal Loop Analysis

Spring 2010

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations

Assumptions:

- Sizing Method Applicable
- Horizontal, 6-Pipe Coil
- Ground Temperature



- Vertical Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Loop Optimization
- [Construction Management Breadth]
- Results
- Horizontal Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Results

Horizontal Loop Analysis

Spring 2010

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations

Results:


[150] foot per ton loop recommended

[17,925] feet of length required

- Vertical Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Loop Optimization
- Construction Management Breadth
- Results
- Horizontal Loop Analysis
 - Systems to be Replaced
 - Assumptions
 - Loop Sizing
 - Results

Horizontal Loop Analysis


- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations



- Vertical Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Loop Optimization
- [Construction Management Breadth]
- Results
- Horizontal Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Results**

Horizontal Loop Analysis

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations



- Vertical Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Loop Optimization
- [Construction Management Breadth]
- Results
- Horizontal Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Results**

Horizontal Loop Analysis

Spring 2010

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations

		System Energy Savings Comparison			
	Savings Over Baseline			Savings Over Designed	
	%	\$	%	\$	
As Designed	9.56	11,936			
Redesign	12.07	15,065	2.85	3,129	

12% Reduction =
1/19 LEED Point
[EA Credit 1]

Greenhouse Gas Emission Data				
	CO2 (lbm/year)	NOX (lbm/year)	SOX (lbm/year)	Total Redesign Savings (lbm/year)
ASHRAE Baseline	2.02E+04	3.05E+01	1.64E+03	1.43E+04
As Designed	1.59E+04	2.47E+01	1.15E+03	9.55E+03
Redesign	7.40E+03	1.31E+01	1.31E+02	

- Vertical Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Loop Optimization
- [Construction Management Breadth]
- Results
- Horizontal Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Results

Horizontal Loop Analysis

Spring 2010

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations

Simple Payback Period:

Design: Redesign:

- | | |
|---------------------------------|-------------------------------|
| ■ [5] Rooftop AHU's = \$280,000 | • [67] Heat Pumps = \$420,050 |
| ■ [5] ACCU's = \$12,000 | • [5] DOAS Units = \$82,042 |
| ■ Utility = \$112,893 | • Horizontal Loop = \$76,898 |
| ■ Ductwork = \$319,850 | • Ductwork = \$74,531 |
| | • Utility = \$109,764 |

Simple Payback Period: 0.95 years

- Vertical Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Loop Optimization
- [Construction Management Breadth]
- Results
- Horizontal Loop Analysis
- Systems to be Replaced
- Assumptions
- Loop Sizing
- Results

Air Source Heat Pumps

Spring 2010

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations

Systems to be Replaced:

- Series Fan Powered Boxes → Heat Pump
- Rooftop Air Handling Units → Dedicated Outdoor Air Unit

- Analysis
- Systems to be Replaced
- Assumptions
- Results

Air Source Heat Pumps

Spring 2010

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations


Assumptions:

- Zoning
- Heat Pumps
- DOAS Units

- Analysis
- Systems to be Replaced
- Assumptions
- Results


Air Source Heat Pumps

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations



Air Source Heat Pumps

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations



Air Source Heat Pumps

Spring 2010

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps

- System Comparison
- Final Recommendations

		System Energy Savings Comparison			
		Savings Over Baseline		Savings Over Designed	
		%	\$	%	\$
As Designed	9.56	11,936			
Redesign	17.18	21,445	9.20	9,509	

17% Reduction =
3/19 LEED Points
[EA Credit 1]

- Analysis

- Systems to be Replaced
- Assumptions
- Results

Greenhouse Gas Emission Data				
	CO2 (lbm/year)	NOX (lbm/year)	SOX (lbm/year)	Total Redesign Savings (lbm/year)
ASHRAE Baseline	2.02E+04	3.05E+01	1.64E+03	8.75E+03
As Designed	1.59E+04	2.47E+01	1.15E+03	4.00E+03
Redesign	1.22E+04	1.89E+01	8.82E+02	

Air Source Heat Pumps

Spring 2010

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations

Simple Payback Period:

Design:

- [5] Rooftop AHU's = \$280,000
- [5] ACCU's = \$12,000
- Utility = \$112,893
- Ductwork = \$319,850

Redesign:

- [67] Heat Pumps = \$211,403
- [5] DOAS Units = \$83,042
- Ductwork = \$74,531
- Utility = \$103,384


Simple Payback Period: 0.65 years

Analysis

- Systems to be Replaced
- Assumptions
- Results



System Comparison

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations



System Comparison

- Project Background
 - Existing Mechanical Summary
 - Design Objectives
 - Alternative Descriptions
 - Ground Source Heat Pumps
 - Air Source Heat Pumps
 - System Comparison
 - Final Recommendations
- Amanda Cronauer | Mechanical Option



System Comparison

Spring 2010

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations

Greenhouse Gas Emission Data				
	CO2 (lbm/year)	NOX (lbm/year)	SOX (lbm/year)	Total Emissions (lbm/year)
ASHRAE Baseline	2.02E+04	3.05E+01	1.64E+03	2.18E+04
As Designed	1.59E+04	2.47E+01	1.15E+03	1.71E+04
Vertical Loop	6.15E+03	1.10E+01	1.03E+02	6.26E+03
Horizontal Loop	7.40E+03	1.31E+01	1.31E+02	7.54E+03
Air Source	1.22E+04	1.89E+01	8.82E+02	1.31E+04

- Simple Payback Period:**
- Vertical Loop GSHP = [1.2] years
 - Horizontal Loop GSHP = [0.95] years
 - Air Source Heat Pump= [0.65] years

Final Recommendations

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Air Source Heat Pumps
- System Comparison
- Final Recommendations

Emissions and Fuel Consumption:

- Vertical Ground Source Heat Pump

Lowest First Cost:

- Air Source Heat Pump

Fastest Potential Payback:

- Air Source Heat Pump

LEED Points:

- Vertical Ground Source Heat Pump

Special Thanks To:

- Paul Cronauer, H.F. Lenz Contact
- Verne McKissick, McKissick Architects Contact
- Dr. Bahnfleth, Faculty Advisor
- Penn State Architectural Engineering Mechanical Faculty
- Family and Friends for all their support
- Fellow AE Students
- Jonah, moral support

Questions

Spring 2010

