

2010

Marie Ostrowski
Lighting/Electrical
Dr. Mistrick, Prof. Dannerth
Science Building-Phase 1
Buffalo State College-Buffalo, NY
Wednesday, April 7, 2010
Final Summary Report





Science Building - Phase 1 Addition

Owner: Buffalo State College

General Contractor: Savarino Companies

Construction Manager: Bovis Lend Lease

Architect: Cannon Design

Engineers: Cannon Design

Wind/Snow Consultant: Gradient Microclimate Engineering

Commissioning Agent: Horizon Engineering

Size: 96,000 ft²

Stories: 3 above ground

Cost: \$34,807,000

Architecture + Construction

- Phase 1 is an addition to the existing science building and joins via an atrium.
- Phase 2 includes the demolition and renovation of the existing building. The final complex will be upwards of 224,000 ft².
- Phase 1 construction period is October 2009 - March 2012, with completion of both phases set for 2015.

Structural

- One-way reinforced concrete slab supported by cast-in-place concrete beams and columns, two-way reinforced concrete systems for the slab-on-grade
- Steel framed systems for mechanical penthouse, atrium, and link to the existing structure
- Foundations for the building are primarily composed of an H pile system, while the atrium is supported by spread footings

Mechanical

- Laboratory spaces supplied 100% outside air via heat recovery AHUs
- One dedicated VAV supply terminal unit minimum per lab; connected back to its associated fume hoods and exhaust valves
- One central, mixed air VAV AHU serves atrium
- Heating by a 10" 40 PSI metered steam line connected to the campus system
- Cooling by electric centrifugal chiller in penthouse

Electrical

- 5kV service from campus substation routed to unit substation within the building.
- Double-ended 480Y/277 V 3 ϕ 4W substation located in the basement and 208Y/120 V 3 ϕ 4W switchboard in the penthouse
- Dedicated normal, emergency, standby, and optional branches
- Emergency branch served by a 750 kW diesel-driven generator in basement;
- Lighting primarily 277V



Buffalo, NY

Marie Ostrowski — Lighting/Electrical

<http://www.engr.psu.edu/ae/thesis/portfolios/2010/mso139/>

EXECUTIVE SUMMARY

The following report is a technical analysis of the existing design for the Buffalo State College New Science Building Phase 1 addition. It consists of a focus on lighting and electrical redesign of four spaces, as well as detailed studies for a motor controller center design and electrical distribution system analysis through SKM software. In addition to satisfying the AE requirements for the option depths, associated areas or breadths have been studied with regards to daylighting (MAE), mechanical systems, acoustical performance, and LED luminaire performance.

Specifically, daylighting and mechanical systems were both addressed in the analysis of an open loop switching system for the atrium corridor lighting. Initial studies indicate proper daylight and electric light integration can reduce energy consumption associated with atrium lighting without having dramatic effects on the thermal loads within the space. The acoustical study is also situated in the atrium, to ensure the large volume and hard surfaces within the space do not detract from its purpose and evaluate an alternative flooring material.

TABLE OF CONTENTS

| | |
|--|-----|
| Executive Summary..... | iii |
| Introduction | 5 |
| General Building Data | 6 |
| Lighting Depth..... | 11 |
| Director’s Office - Special Purpose Space..... | 11 |
| Genetics Teaching Lab – Work Space | 18 |
| Facade | 27 |
| Atrium..... | 32 |
| Electrical Redesign | 39 |
| Lighting Redesign..... | 39 |
| Depth Topic 1: MCC Design | 52 |
| DEPTH TOPIC 2: SKM ANALYSIS | 57 |
| Short Circuit Study + Calculations..... | 58 |
| Mechanical Breadth..... | 67 |
| LED Luminaire Options (Honors Breadth)..... | 71 |
| Acoustical Breadth..... | 76 |
| Summary + Conclusions..... | 80 |
| REFERENCES..... | 81 |

Appendices

- A – Lighting Cut Sheets
- B – Lighting Plans
- C – Electrical Cut Sheets
- D – SKM Reports

INTRODUCTION

The Science Building Phase 1 construction project is the first phase in a two-phase addition and renovation project for the School of Natural and Social Sciences at Buffalo State College. The 96,000 ft² LEED Gold addition is designed to reflect in its exterior, the high-tech education and research that occur within its laboratories and classrooms. Once completed in 2015 the addition and renovation will become the 224,000 ft² Mathematics and Science Complex.

Design elements of the addition are a conscious testament to the scientific and collaborative developments housed within its walls. Everything in the architectural elements, from materials and colors to proportions, has a purpose and hints towards different theories or scientific concepts.

The layout of the building is largely influenced by circulation, a practical and figurative indication of biological systems. The addition joins the existing building at a central atrium from which smaller corridors branch out to join the west corridor looking out onto the neighboring athletic play fields. The west corridor acts as a curtain wall skin to the building, with a seemingly random assortment of metal and glass panels that calls upon the principles of the Fibonacci sequence, genetics, and optics. The circulation spaces connect students and visitors to a multitude of research/teaching labs and offices where the lessons fuel ongoing developments in science.



FIGURE 1 – WESTERN FAÇADE (COURTESY OF CANNON DESIGN)

GENERAL BUILDING DATA

Building Name: Buffalo State College Science Building – Phase 1

Location: Buffalo, NY

Building Occupant Name: Buffalo State College – Biology, Chemistry, Earth Science and Science Education Departments

Occupancy Type: Education

Size: approximately 96,000 sq. ft.

Number of Stories: 4 above grade (including penthouse)/5 total

Project Team:

Owner: Buffalo State College/State University Construction Fund
<http://www.buffalostate.edu/facilities/>

General Contractor: Savarino Companies

Construction Manager: Bovis Lend Lease
<http://www.bovislendlease.com/>

Architect: Cannon Design
<http://www.cannondesign.com/>

MEP Engineers: Cannon Design
<http://www.cannondesign.com/>

Wind/Snow Consultant: Gradient Microclimate Engineering
<http://gradientwind.com/>

Commissioning Agent: Horizon Engineering
<http://www.horizon-engineering.com/>

Dates of Construction: October 15, 2009 – March 31, 2012 (Phase 1 Projected Completion Date 11/2/2010)

Cost: \$36,064,000 budget overall project cost

Project Delivery Method: Design-Bid-Build

ARCHITECTURE

Codes:

IBC 2006
NEC 2008

Building Code of NYS 2007
New York State Energy Conservation Construction Code
Plumbing Code of NYS
Mechanical Code of NYS
Fuel Gas Code of NYS
SUCF Directives
ASCE 7-02
AISC 301, 303.1, 303-05
ACI 318-02
ANSI C2 – National Electrical Safety Code
NFPA

Zoning: Buffalo State College as an educational institution does not fall under City of Buffalo R-2 zoning requirements.

Historical Requirements: Not Applicable

The Science Building at Buffalo State College houses labs, offices, and classrooms for the school's natural science departments. The building exterior conveys the interior scientific inquiry and development through the materials and design. A high-tech appearance is achieved through numerous design features that cleverly express themes associated with the various science departments including: optics, geology, genetics, biology, and math.

The Phase 1 building project is an addition to the existing science complex and joins to the existing building via an atrium. The linear plan is broken on the western side with a vertex in the middle and two curtain wall segments that are slightly angled.

A combination of genetics and mathematics is portrayed in the arrangement and proportions of the glass and metal panels on the western curtain wall. Brightly colored walls are visible behind the glass panels of the western corridor to mimic the refraction of a prism. Throughout the building, striations, platforms and the linear atrium space refer to geologic forms such as mesas and gorges for proportions. Building circulation takes a cue from biology and creates a main thoroughfare through the atrium space to connect the academic and residential areas of campus. Additionally, the science curriculum is fostered by an environment that supports collaboration. Throughout the building there are gathering spaces for students with writable surfaces. Optimum floor space and flexibility is enabled by the concrete structural system and central utility spine.

BUILDING ENCLOSURE

The walls of the building are a combination of concrete masonry unit assemblies and curtain wall, both using cold metal framing to hang exterior paneling. The western façade uses cold metal framing and a combination of aluminum composite metal wall panels and high performance, insulated glazing. The very top level, the mechanical penthouse, is a shell composed of non-insulated metal panels.

The atrium permits natural light through a series of thirteen sloped glazing assembly clerestories, with condensation resistance and a solar heat gain coefficient ≤ 0.40 . Roof structure is predominantly concrete deck except for the steel roof deck on the penthouse. Roofing layers are similar on each roof type with either a tapered or flat insulation (R-20), membrane underlayment board, and light-colored EPDM (ethylene propylene diene terpolymer) roof membrane.

SUSTAINABILITY FEATURES

The building design is required to satisfy LEED Silver certification and sustainability features are largely attributed to controls for the mechanical and electrical systems. Mechanical system design incorporates variable speed drive motors for air handling pumps and fans to increase efficiency. The lighting systems incorporate automatic lighting controls with occupancy and daylight sensors, as well as dimming systems to extend lamp life of incandescent sources.

The project will satisfy numerous LEED points from the beginning of construction, with strategies such as Construction IAQ Management, to completion with initial building performance being tested by a commissioning agent.

CONSTRUCTION

The Phase 1 addition for the Buffalo State College (BSC) Science Building is scheduled for October 15, 2009 – March 12, 2012. Phase 2 renovations (which would bring total complex area up to 224,000 ft²) are projected to finish in 2015.

Site work throughout demolition and construction is to uphold standards set forth in the NY Guidelines for Urban Erosion and Sediment Control. Construction methods include plans for temporary mechanical services to the existing building following demolition, which comply with the IAQ management plan. Of all waste generated throughout construction, 50% (by weight) is to be salvaged or recycled and documented with progress reports submitted regularly.

ELECTRICAL

Medium voltage service enters the building at 5kV and is routed to a unit substation within the building. The double-ended 4.16kV 480Y/277 V 3 ϕ 4W substation is located in the basement, feeding a 2,000A 208V/120V 3 ϕ 4W switchboard in the basement and a 3,000A 480Y/277 V 3 ϕ 4W switchboard situated in the penthouse. The basement switchboard feeds the normal power in the basement and a 1,000A 208V 3 ϕ 4W bus duct serving laboratory loads on normal power throughout the building and future phase. The penthouse switchboard serves most of the mechanical equipment.

The building is served by four separate, switched branches: Normal, Emergency, Standby, and Optional. The emergency branch of the distribution system is served by a 750 kW diesel-driven generator enclosed in a separate room in the basement.

LIGHTING

General lighting within the building is supplied by linear fluorescent luminaires using T8 or T5 lamps predominantly at 277V. Classrooms and labs utilize pendant, direct/indirect linear fluorescent luminaires to provide even luminance levels across task planes while minimizing shadows. This is important due to the measuring and reading tasks that occur within the space. Corridors in the atrium combine a recessed wall-mounted fixture (switched for emergency power) as well as a decorative, compact fluorescent pendant. The atrium combines daylighting by means of clerestories and skylights with supplementary electric light from pendant, wall-washing, metal halide fixtures that illuminate the acoustical ceiling panels at the top of the space.

MECHANICAL

Heating for the Science Building is provided by a 10" 40 PSI metered steam supply connected to the campus system and distributed by redundant variable flow pumps. AHU preheat coils are energized by low pressure 15 PSI steam.

General cooling is supplied by a high efficiency, water-cooled, electric centrifugal chiller in the penthouse. The penthouse also houses the refrigerant monitoring and exhaust system. Primary/secondary pumping connects the chiller to the AHUs and heat is rejected by two induced draft cooling towers in the penthouse. Data rooms are also served by a back-up DX system while the main telecom room is served by a 10 ton split-system a/c unit.

Three AHUs supply 100% outside air to the labs and provide partial redundancy since they are sized to approximately 50% peak airflow. One AHU is connected to emergency power to prevent excessive negative pressurization. Each lab area has one dedicated VAV terminal unit with a hot water reheat coil and low velocity supply diffusers. The atrium has one mixed air VAV AHU with enthalpy control and outside air flow measuring. An array of nine 3,500 cfm fans is also dedicated to air handling in the atrium.

STRUCTURAL

The majority of the Science Building is composed of a cast-in-place concrete system with steel framing in connecting areas such as the atrium, the northeastern entrance, links to the existing building, and the mechanical penthouse. The foundation consists mainly of an H pile and cap (4' thick typically) system supporting the interior spaces, spread footings for the atrium, and several strip footings along the exterior walls.

The basement structural slab is 10" thick and supported by 2' square grade beams on the west, exterior edge of the building. The first level is a 5" thick, one-way concrete slab spanning north to south, primarily supported by concrete beams B4 24x30. The second and third levels are 8-1/2" one-way concrete slab supported by B1 24x30 beams, which are tapered and cantilevered into the atrium and west, exterior edge of the building. The cantilevers on the western edge of the building support the corridors and the metal and glass panel curtain wall.

Steel framing in the atrium consists of HSS10x.625 columns with a 21'-0" span. HSS8-5/8x.250 columns support the northeastern entrance. Atrium and penthouse framing consists of wide flange beams, primarily W12x14 and W18x50 respectively.

FIRE PROTECTION

Most areas within the building are protected by a wet sprinkler system except for rooms housing extensive electrical, voice, or data equipment which have a partition that is rated at least three hours. The fire command center is located in room 127 and houses the Fire Alarm Control Unit (FACU), Emergency Voice/Alarm Communication (EVAC), Graphic Smoke Control Panel (GSCP), and annunciator panels for the generator and elevators. Alarms are ADA compliant combined speaker/strobe.

Atrium fire protection consists of 175° sidewall sprinklers in the skylight and 135° dry pendant sprinklers in between skylights on the ceiling, as well as a manual smoke exhaust operation controlled by the GSCP. Elevator shafts contain sidewall sprinkler heads.

TRANSPORTATION

There are three passenger elevators in the Science Building addition, one adjacent to the north stairwell and two in the southwest corridor. The electric traction elevators specified are based on Otis Gen2 Machine Room-Less Elevators and are rated for 2500 lbs. The elevators are connected to the fire protection system for automatic recall and are also operable on standby power. The elevator controllers and ATS are located in the basement areaway.

TELECOMMUNICATIONS

The telecom service entrance room is connected to campus utilities by interbuilding, exterior fiber optic cabling. Individual telecom rooms are connected by intrabuilding backbone systems with 24 strand 50 micron cabling in 4" electrical metallic tubing (EMT) conduit. Horizontal cabling throughout the building telecom distribution system is copper. Telephone service for the existing building and addition is being updated from a Centrex phone system to VoIP.

Data outlets are available above counters in the lab spaces and throughout other work spaces. Within the lab furniture, 2" conduit is stubbed up for data and terminated in a furniture doghouse. The labs and offices also have electronic card reader door systems for security. Wireless access points are available in the labs and throughout most of the corridors.

LIGHTING DEPTH

DIRECTOR'S OFFICE - SPECIAL PURPOSE SPACE

SPACE

The private office space in room 319A is occupied by the director of the Great Lakes Center and his administrative support. The Great Lakes Center (GLC) is an institute committed to research and education focused on the scientific understanding of the Great Lakes and holds a regional office at Buffalo State College. The layout of the approximately 350 ft² rectangular office space is specific to the director's day-to-day tasks and includes a table where he can hold small meetings. It is also directly connected to the secretary's office and the GLC research labs. Though all walls are interior, there is a window that looks into the daylight west corridor (transmittance of 0.75).




FIGURE 2-DIRECTOR'S OFFICE (ROOM 319A)

PROGRAM STATEMENT

The objective of the lighting design within the GLC director's office unit is to provide a comfortable yet functional and flexible space. It must meet minimal illuminance levels for daily tasks but also adapt to meeting functions when guests are being entertained or conducting business. In order to achieve these qualities, the

design incorporates diffuse ambient light, accent downlights, and wall-washing for presentation/conference functions.

DIMENSIONS

- GLC Secretary's Office: 12' x 11'-6" = 138 ft²
- Storage: 7'-6" x 11'-6" = 86.25 ft²
- GLC Director's Office: approximately 20' x 17'-10" ≈ 356 ft²
- Gross Area of GLC Unit = 593 ft²
- Net Area of GLC Office Unit = 580.25 ft²

MATERIALS

The director's office is furnished relatively simply. The walls are covered in off-white, matte paint except for the dry erase surfacing area. Cabinetry and shelves are an oak color, the floors are a medium-to-dark brown, and the ceiling is a light colored ACT grid. Swatches of the materials are below followed by their reflectance values.

Furniture



Flooring



Ceiling



TABLE 1 – OFFICE SPACE MATERIALS

| MATERIALS | | | | | | | | |
|-----------------------|------------------------|----------|-------------------|----------------|---------|-------------|--------------|-------------|
| Special Purpose Space | | | Director's Office | | | Room 319A | | |
| | Item | Key Name | Manufacturer | Series/Pattern | Style # | Color | Comments | Reflectance |
| Floor | Carpet Tile | CPT-1 | Interface FLOR | Entropy | 7223 | Wheat | 2'x2' Tile | 0.34 |
| | Carpet Tile | CPT-2 | Interface FLOR | Cubic | 6393 | Height | 2'x2' Tile | 0.36 |
| Wall | Paint | PNT-3 | Sherwin Williams | | SW 7014 | Eider White | | 0.87 |
| | Dry Erase Surfacing | DE-1 | MDC Flooring | Idea Paint | | White | | 0.95 |
| Ceiling | Acoustic Panel Ceiling | APC-2 | Armstrong | Optima | | White | 2'x4' Panels | 0.90 |
| | | | | | | | | |

DESIGN CRITERIA

- **Lighting Power Density (LPD)** values for the enclosed office space must be $\leq 1.10 \text{ W/ft}^2$ according to the ASHRAE Standard 90.1-2007. (1)
- **Horizontal and vertical illuminance levels** should meet a minimum value of 50fc/500lux and 5fc/50lux respectively on task plane surfaces. [2]
- **Color Appearance:** CCT of 3500 K and CRI ≥ 85
- **Direct Glare:** Indirect luminaires with matte finishes provide a more comfortable visual environment by reducing contrast between the lamp and housing and eliminating direct view of the source.
- **Reflected Glare:** Specular finishes throughout the space are not an issue, and VDT screens are effectively shielded with luminaire classification and positioning.
- **Shadows:** Diffuse light should be used in the space to avoid creating shadows on the task plane. Overhead lighting must be positioned so shadows are not created on writing surfaces.
- **Appearance of Space & Luminaires:** The space should provide a corporate image in terms of luminaire style and lighting mood. Fixtures must be laid out in the room so as not to create viewing issues for the occupant.
- **Psychological Reinforcement:** Since the space functions as a “corporate” office and conference room, it should possess the lighting settings to create a relaxed environment. In order to achieve these lighting characteristics, a design incorporating low-level light and non-uniform perimeter accents is implemented.

OFFICE LIGHTING DESIGN

LUMINAIRES, LAMPING + BALLASTS

The office lighting design incorporates a combination of indirect, direct, and accent lighting fixtures. A detailed list of the luminaires, lamps, and ballasts specified is provided below in Table 3. Please note that manufacturer provided cut sheets for all associated equipment can be found in Appendix A. This is true for all spaces considered for lighting redesign.







TABLE 2 – OFFICE LIGHT LOSS FACTORS

| | LLD | LDD | RSDD | BF | LLF |
|----|------|------|------|------|------|
| F1 | 0.95 | 0.85 | 0.96 | 1.00 | 0.78 |
| F2 | 0.90 | 0.84 | 0.96 | 0.99 | 0.72 |
| F3 | 0.95 | 0.85 | 0.96 | 0.98 | 0.76 |
| F4 | 0.90 | 0.81 | 0.96 | 1.02 | 0.72 |
| F5 | 0.85 | 0.85 | 0.96 | 0.98 | 0.68 |
| F6 | 0.81 | 0.81 | 0.96 | 1.05 | 0.66 |

Light Loss Factor Assumptions:

- 0.96 was used for the RSDD value for all luminaires in all spaces
- Evaluation of Operating Atmosphere: Clean
- Cleaning Interval: 1.5 years/18 months

TABLE 3 – OFFICE LUMINAIRES

| LUMINAIRE SCHEDULE | | | | | | | | | | | |
|--------------------|---|---|---|--|--|---------|--|--------|--|---|--|
| LUMINAIRE | CLASSIFICATION | MOUNTING | LAMP | | # LAMPS | BALLAST | VOLTAGE | OPTICS | HOUSING | MANUFACTURER | |
| F1 |  0'-3-1/4"X4" SEMI-INDIRECT FLUORESCENT PENDANT | 7 FT. AFF UNLESS OTHERWISE NOTED | F54T5HO PHILIPS 28W/835 MIN BIPIN T5 HE ALTO UNP | Input Watts Avg Lumens Initial Lumens CCT CRI Maint. Category | 117W 2750 5000 3500K 85 V | 2 | ELEC/T5 ICN2S5490C PHILIPS ELEC, PS | 277V | DIRECT LIGHT THROUGH PERFORATED SQUARE ALUMINUM AREA INDIRECT LIGHT CONTROLLED BY WIDE SPACING OPTIC EDGE SLOT PROJECTION | ALUMINUM, SLIM PROFILE | LIGHTOLIER-ULTRAFLAT 2 SL103BPIU |
| F2 |  4FT. RECESSED WALL WASH DIRECT | FLUSH WITH FINISHED CEILING | F54T5HO PHILIPS 54W/835 MIN BIPIN T5 HO ALTO UNP | Input Watts Avg Lumens Initial Lumens CCT CRI Maint. Category | 61W - 5000 3500K 85 IV | 1 | ELEC/T5HO ICN4S5490C 2LSG PHILIPS ADVANCE ELEC, PS | 277V | EXTRUDED, FROSTED ACRYLIC SOFT GLOW LENS, FORMED SEMI-SPECULAR REFLECTOR | DIE-FORMED AND WELDED STEEL MATTE WHITE FINISH | LITECONTROL LG-VVWD-4414T5HOS GLCWMINDDA/MK7 277 |
| F3 |  7-3/8" DIAMETER RECESSED ADJUSTABLE DOWNLIGHT | FLUSH WITH FINISHED CEILING | F32WTT GE F32TBX 835/A/ECO | Input Watts Avg Lumens Initial Lumens CCT CRI Maint. Category | 36W 2040 2400 3500K 82 V | 1 | ELEC/F32TT ICF-2S26-M1 -BS PHILIPS ADVANCE ELEC, PS | 277 | SPUN ALUMINUM REFLECTOR OPEN APERTURE ADJUSTABLE 30 DEGREE ELEVATION AIMING | ONE PIECE DIE CAST, MATTE BLACK | COOPER LIGHTING-PORTFOLIO CA7042ECP |
| F4 |  2FT., 1LAMP, SURFACE MOUNTED STRIP FLUORESCENT | 9.0 FT. AFF UNLESS OTHERWISE NOTED | F24T5 PHILIPS 24W/835 MIN BIPIN T5 HO ALTO UNP | Input Watts Avg Lumens Initial Lumens CCT CRI Maint. Category | 27 - 2000 3500 85 IV | 1 | ELEC/T5 ICN-2S24-277 PHILIPS ADVANCE ELEC, PS | 277V | OPEN, UNAPERTURED STRIP LIGHT | 20 GAUGE STEEL HOUSING WITH WHITE ENAMEL FINISH | PRUDENTIAL P-T5-STD-1T5-O2BWE277-B_ |
| F5 |  4-1/2" X 8-1/2" RECESSED DOWNLIGHT | FLUSH WITH FINISHED CEILING | F32WTT GE F32TBX 835/A/ECO | Input Watts Avg Lumens Initial Lumens CCT CRI Maint. Category | 36W 2040 2400 3500K 82 V | 1 | ELEC/F32TT ICF-2S26-M1 -BS PHILIPS ADVANCE ELEC, PS | 277 | SPECULAR PRIMARY REFLECTOR; MICROPRISM SPREAD LENS | RIGID HOUSING WITH PARABOLIC SPLAY TRIM | KURT VERSEN T4142 |
| F6 |  1' X 0'-6" WALL SCONCE | 6.0 FT. AFF WALL MOUNTED | F18DBX GE 835/ECO 4P | Input Watts Avg Lumens Initial Lumens CCT CRI Maint. Category | 19 970 1200 3500 82 VI | 1 | ELEC/CFQ CFQ182/G24q GEC218-MVPS 3W GE ELEC,PS | 277 | 20 GAUGE C.R.S. REFLECTOR HIGH REFLECTANCE WHITE POWDER COAT | STEEL HOUSING/REFLECTOR DIE-CAST ALUMINUM END CAPS | FOCAL POINT SOFTLITE V1-FS611BX18 |

Lighting plan

The lighting layout for the office is irregular in plan and does not strive to achieve uniform light except for the main task areas. A detail for this lighting layout, and the remaining three spaces, can be found in Appendix B. The LPD values and limits for this space are easily achieved, even without the decorative sconce fixtures excluded from the calculations.

Performance

LIGHTING POWER DENSITY:

| Luminaire Type | Quantity | Total Input Power (W) |
|----------------|----------|-----------------------|
| F1 | 2 | 234 |
| F2 | 1 | 61 |
| F3 | 2 | 72 |
| F4 | 1 | 27 |
| F5 | 6 | 216 |

TOTAL INPUT POWER: 648 W

REMAINING AVAILABLE INPUT POWER: 4.3 W

LPD: 1.09 W/ft²

The design complies with lighting power density requirements from ASHRAE 90.1 2007.




FIGURE 3 – INTERIOR PERSPECTIVE OF OFFICE WITH ALL LIGHTS ON

AVERAGE ILLUMINANCE: 11.7 FC | MAXIMUM 39.5 FC

The average illuminance levels for the space completely lit are clearly lower than the IESNA recommended levels for an office space. However, as can be illustrated in the following illuminance isolines, the design does provide sufficient levels at the desk and table areas. The non uniform lighting techniques and wall accents were implemented to highlight the space and functions with the room.




FIGURE 4 - ALL ON




FIGURE 5 - TASK LIGHTS ABOVE DESK SWITCHED OFF





FIGURE 6 – SOUTH SECTION CUT OF OFFICE UNIT LOOKING, ALL ON




FIGURE 7 – SOUTH SECTION CUT OF OFFICE UNIT, TASK OFF/CONFERENCE SETTING

GENETICS TEACHING LAB – WORK SPACE

SPACE

The Genetics Teaching Lab (Room 306) is located on the northwest end of the building and borders the corridor overlooking the central atrium. It is surrounded on all sides by corridors or rooms, and therefore does not receive any natural light. The rectangular space serves as a teaching and experimental lab and is furnished with numerous pieces of casework to house tools and equipment. Tables are oriented perpendicular to the long wall in order to facilitate presentations that occur at the front of the room between the two entrances. A portion of the wall is painted with dry-erase surfacing paint to provide the writing surface. Finishes are plain and simple to create a space that is easy to work in and maintain.

PROGRAM STATEMENT

The objective of the lighting design within the Genetics Teaching Lab is to provide a bright, evenly lit environment without glare or shadows that would interfere with the visual tasks associated with experimentation and viewing. Since it also functions as a teaching lab, lighting should also highlight areas of presentation. In order to achieve these qualities, the design incorporates indirect/direct luminaires and baffled openings for ambient and board lighting fixtures. Task lighting is also incorporated in the rear and side of the room for experiment setup and cleaning.

DIMENSIONS

- 26'-11" x 41'-8"
- Area = 1157 ft²




FIGURE 8-- GENETICS TEACHING LAB FLOOR PLAN

MATERIALS

- The genetics lab is predominantly covered by a flat, matte white paint and light wood casework. However, the front of the room is painted a light yellow and hosts a white board surface. The ceiling is a light colored ACT grid and the floor is a gray, linoleum tile. Swatches of the materials are below followed by their reflectance values.


Furniture



Flooring



Walls



Ceiling



TABLE 4 –LAB CLASSROOM MATERIALS

| MATERIALS | | | | | | | | |
|------------|------------------------|----------|------------------------|--------------------------|-----------|-------------|--------------|-------------|
| Work Space | | | Genetics Teaching Lab | | | Room 306 | | |
| | Item | Key Name | Manufacturer | Series/Pattern | Style # | Color | Comments | Reflectance |
| Floor | Linoleum Tile Flooring | LTF-1 | Forbo Flooring Systems | Marmoleum Composite Tile | MCT-621wt | Dove Gray | 13"x13" tile | 0.37 |
| | | | | | | | | |
| Wall | Paint | PNT-1 | Sherwin Williams | | SW 7006 | Extra White | | 0.94 |
| | Paint | PNT-2 | Sherwin Williams | | SW 6681 | Butter up | | 0.88 |
| | Dry Erase Surfacing | DE-1 | MDC Flooring | Idea Paint | | White | | 0.95 |
| Ceiling | Acoustic Panel Ceiling | APC-2 | Armstrong | Optima | | White | 2'x4' Panels | 0.90 |

DESIGN CRITERIA

- **Lighting Power Density:** Lighting power allowance for the space should not exceed **1.4 W/ft²**. Automatic controls should be integrated with the manual control system.
- **Horizontal and vertical illuminance levels** should meet a minimum value of 50fc/500lux and 30fc/300lux respectively. The work plane height is raised to a value of three feet due to the taller lab tables in the space.
- **Color Appearance + Color Contrast:** Since the space demands experimentation involving various viewing methods and tools, color rendering should be of good quality. CCT values should be no smaller than 3000K and CRI should be ≥ 80 .
- **Direct Glare:** Luminaires with matte louvers provide a more comfortable visual environment by reducing contrast between the lamp and housing and minimizing direct view of the source.
- **Light Distribution on Task Plane:** Centrally positioned luminaires with a direct/indirect distribution provide more even luminance levels on the horizontal task plane. Uniformity is essential at the task surfaces in order to avoid distracting patterns or fatigue caused by inadequate luminance ratios.
- **Reflected Glare:** Luminaires should not be positioned in direct line with the task surface. Specular finishes on the task plane should be avoided to minimize veiling reflections.
- **Shadows:** Diffuse, semi-indirect or indirect light should be used in the space to avoid creating shadows on the task plane.
- **Source/Task/Eye Geometry:** Luminaires should be positioned outside of normal viewing angles at work spaces.
- **Points of Interest:** Luminance levels on the dry-erase surface should be no less than 30 fc. Contrast for the overall space should satisfy a ratio of 5:1.
- **Flicker and Strobe:** Flicker should be minimized by employing electronic ballasts.
- **Luminances of Room Surfaces:** Surfaces in the room should be sufficiently illuminated so as not to create the sensation of dark spots. Direct and indirect/diffuse sources create more even light on the surfaces and increase visual comfort.
- **Modeling of Faces of Objects:** Lighting should provide sufficient contrast for visual understanding of object textures and depths.

- Visual clarity should be emphasized with higher luminance levels at work surfaces and moderate levels at the perimeter. Preparation and cleaning tasks performed at the room perimeter require sufficient light levels.

GENETICS TEACHING LAB LIGHTING DESIGN

LUMINAIRES, LAMPING + BALLASTS

The lab lighting design incorporates a combination of indirect, direct, and task lighting fixtures. A detailed list of the luminaires, lamps, and ballasts specified is provided below in Table 5. For equipment cut sheets, please see Appendix A.






TABLE 5- LIGHT LOSS FACTORS

| | LLD | LDD | RSDD | BF | LLF |
|-----|------|------|------|------|------|
| F13 | 0.95 | 0.81 | 0.96 | 1 | 0.74 |
| F14 | 0.95 | 0.87 | 0.96 | 1.00 | 0.79 |
| F15 | 0.90 | 0.81 | 0.96 | 1.1 | 0.77 |
| F16 | 0.95 | 0.87 | 0.96 | 1 | 0.79 |
| F17 | 0.95 | 0.81 | 0.96 | 1 | 0.74 |

Light Loss Factor Assumptions:

- 0.96 was used for the RSDD value for all luminaires in all spaces
- Evaluation of Operating Atmosphere: Clean
- Cleaning Interval: 1.5 years/18 months

TABLE 6 – GENETICS TEACHING LAB LUMINAIRE SCHEDULE

| LUMINAIRE SCHEDULE | | | | | | | | | | | | |
|--------------------|---|----------------------------------|--|-----------------|-------|---|---|---------|---|---|---|--------------|
| LUMINAIRE | CLASSIFICATION | MOUNTING | LAMP | | | | # LAMPS | BALLAST | VOLTAGE | OPTICS | HOUSING | MANUFACTURER |
| F13 |  4FT. INDIRECT LINEAR, PENDANT | 7 FT. AFF UNLESS OTHERWISE NOTED | F28T5 PHILIPS 28W/835 MIN BIPIN T5 HE ALTO UNP | Input Watts | 62W | 2 | ELEC/T5 ICN-2S28-N PHILIPS ADVANCE ELEC, PS | 277V | PRECISION DIE-FORMED SEMI-SPECULAR ALUMINUM REFLECTOR | EXTRUDED ALUMINUM | LIGHTOLIER LSB-24A-28-277-WH | |
| | | | | Avg Lumens | 2750 | | | | | | | |
| | | | | Initial Lumens | 2900 | | | | | | | |
| | | | | CCT | 3500K | | | | | | | |
| | | | | CRI | 85 | | | | | | | |
| | | | | Maint. Category | VI | | | | | | | |
| F14 |  4FT. WALL-MOUNTED CHALKBOARD FIXTURE | 7FT. AFF UNLESS OTHERWISE NOTED | F28T5 PHILIPS 28W/835 MIN BIPIN T5 HE ALTO UNP | Input Watts | 31W | 1 | ELEC/T5 ICN-2S28-N PHILIPS ELEC, PS | 277V | DIE-FORMED STEEL WITH HIGH REFLECTANCE WHITE FINISH; PARABOLIC BAFFLE | DIE FORMED AND WELDED STEEL; 6" OPENING | LITECONTROL W-D-66N14T5-PARSS-CWM-ELB-277 | |
| | | | | Avg Lumens | 2750 | | | | | | | |
| | | | | Initial Lumens | 2900 | | | | | | | |
| | | | | CCT | 3500K | | | | | | | |
| | | | | CRI | 85 | | | | | | | |
| | | | | Maint. Category | III | | | | | | | |
| F15 |  7" APERTURE RECESSED CIRCULAR DOWNLIGHT | FLUSH WITH FINISHED CEILING | PLT26 PHILIPS 26W/835 4P/ALTO 1CT | Input Watts | 29W | 1 | ELEC/PLT ICF-2S26-H1-LD PHILIPS ELEC, PS | 277V | HYDROFORMED ALUMINUM, SEMI-SPECULAR FINISH REFLECTOR; MATTE WHITE CROSS BLADE | 1101F2642U FRAME IN KIT | LIGHTOLIER 1132-1101F2642U | |
| | | | | Avg Lumens | - | | | | | | | |
| | | | | Initial Lumens | 1800 | | | | | | | |
| | | | | CCT | 3500K | | | | | | | |
| | | | | CRI | 82 | | | | | | | |
| | | | | Maint. Category | III | | | | | | | |
| F16 |  4FT. RECESSED LINEAR FLUORESCENT FLANGED EXTRUSION | FLUSH WITH FINISHED CEILING | F28T5 PHILIPS 28W/835 MIN BIPIN T5 HE ALTO UNP | Input Watts | 31W | 1 | ELEC/T5 ICN-2S28-N PHILIPS ELEC, PS | 277V | MATTE PARABOLIC LOUVERS | CONTINUOUS 6063-T5 EXTRUDED ALUMINUM PROFILE | SELUX M100-1T5-MA-004-WH-277 | |
| | | | | Avg Lumens | 2750 | | | | | | | |
| | | | | Initial Lumens | 2900 | | | | | | | |
| | | | | CCT | 3500K | | | | | | | |
| | | | | CRI | 85 | | | | | | | |
| | | | | Maint. Category | III | | | | | | | |
| F17 |  4FT. LINEAR 1" MODULAR FLUORESCENT TASK LIGHTING | SURFACE MOUNTED UNDER CASEWORK | F28T5 PHILIPS 28W/835 MIN BIPIN T5 HE ALTO UNP | Input Watts | 31W | 1 | ELEC/T5 ICN-2S28-N PHILIPS ELEC, PS | 277V | EXTRUDED ACRYLIC LINEAR PRISM LENS | 0.060" EXTRUDED ALUMINUM; ENJECTION MOLDED POLYCARBONATE END CAPS | ALKCO/PHILIPS LINGS100FS46-277-WHG | |
| | | | | Avg Lumens | 2750 | | | | | | | |
| | | | | Initial Lumens | 2900 | | | | | | | |
| | | | | CCT | 3500K | | | | | | | |
| | | | | CRI | 85 | | | | | | | |
| | | | | Maint. Category | VI | | | | | | | |

Lighting plan

The drawings of the lab lighting layout can be found in Appendix B. In order to achieve the light levels within the space, two rows of indirect fluorescent lights were used to achieve the uniform levels of illuminance at the main work plane surface. Most luminaires are positioned within the space using typical mounting configurations. All pendant lights are offset from the floor surface (to the bottom of the luminaire) by a height of seven feet. The only luminaire specified with a mounting different from the standard recessed or surface mounting practice, is the chalkboard washer, which must be hung six inches from the wall surface with the factory provided bracket. An image of the mounting set up is provided in Figure 5.




FIGURE 9 - BOARD WASH LUMINAIRE DETAIL

Though it was recommended that downlights be avoided for this type of space, several downlight luminaires are employed to supplement the dark spots resulting from the task/ambient lighting layout. Downlights have been positioned to maintain minimal direct and reflected glare and also include baffles or diffuse lenses for improved optics and light distribution.

Performance

LIGHTING POWER DENSITY:

| Luminaire Type | Quantity | Total Input Power (W) |
|----------------|----------|-----------------------|
| F13 | 16 | 992 |
| F14 | 5 | 155 |
| F15 | 9 | 261 |
| F16 | 2 | 62 |
| F17 | 1 | 31 |

TOTAL INPUT POWER: 1,501 W

REMAINING AVAILABLE INPUT POWER: 130 W

LPD: 1.29 W/ft²

The design complies with lighting power density requirements from ASHRAE 90.1 2007.



FIGURE 10- PERSPECTIVE OF LAB LIGHTING (WITH ALL LUMINAIRES ON)




FIGURE 11 - AMBIENT AND TASK



AVERAGE ILLUMINANCE AT WORKPLANE: 52.64 FC




FIGURE 12 - SWITCHED AMBIENT, TASK + BOARD



AVERAGE ILLUMINANCE AT WORKPLANE: 33.75 FC



FIGURE 13 – SOUTH PERSPECTIVE SWITCHED AMBIENT



FIGURE 14 – EAST PERSPECTIVE SWITCHED AMBIENT

The average illuminance levels for the space completely lit are satisfy the IESNA recommended levels for a lab space, and exceed by only 5%. The switching allows for lower levels of light for different presentations and tasks within the room, while the perimeter lighting assists in maintaining high illuminance levels for preparatory and cleaning tasks.

FACADE

SPACE

The western curtain wall is the space considered for the outdoor redesign. The surface is composed of alternating metal and glass panels that vary in shape and depth. It runs parallel to a service road and athletic playing fields. Additionally, there is 286 ft. of sidewalk that runs from the main western entrance south to the end of the complex. The sidewalk and the main western entrance are also considered within the outdoor space lighting redesign.

PROGRAM STATEMENT

The façade is the defining architectural element of the BSC Science building and most thoroughly expresses the design goal and theme of the building. Consequently, the intent of the design is to accentuate and complement the existing architecture by highlighting the rectilinear geometries and creating a hierarchy of light. The western corridor which runs behind the curtain wall has a unique, multi-colored interior wall and creates a great deal of visual interest from exterior viewpoints. Bright, white highlights of the façade projections are incorporated to create a composition with depth and form that complements the seemingly irregular glazing and coloring patterns.

DIMENSIONS

Walkway = 286 ft. long

Main Entrance: 11 linear feet

Uppermost height of third level/roof = 43'




FIGURE 15 – EXTERIOR PLAN VIEW OF THE WESTERN FACADE

MATERIALS

The materials used for the façade are glass and aluminum curtain wall panels arranged in varying vertical shapes. The interior corridor walls that are visible from the exterior are gypsum wall board painted in several different matte colors.



DESIGN CRITERIA

- **Horizontal and vertical illuminance** levels should be **5fc and 3fc** respectively at the entrance and **5fc** on the walkway.
- **Lighting power allowance** for the walkway is 1 W/ft. Lighting power allowance for the main and alternate entrance door is 30 and 20 W/ft respectively.
- **Appearance of Space and Luminaires:** The area illuminated by the source should exhibit satisfactory contrast ratios and not interfere with the view of the landscape.
- **Direct Glare:** Luminaires should be mounted at proper heights and setbacks so as not to create glare issues for drivers or pedestrians.

- **Light Pollution/Trespass:** Any and all exterior luminaires should be shielded to cut off indirect light and prevent trespass into the building.
- **Reflected Glare:** Sources and aiming must be coordinated with surrounding surfaces to prevent visual impairment of viewers.
- **Modeling of Faces or Objects:** Light levels, CCT, CRI and distribution all must be considered in providing a light source that provides a secure environment.
- **Color Appearance + Color Contrast:** Sources with good/decent color rendering should be provided based on level of security needed for the area.

FACADE LIGHTING DESIGN

LUMINAIRES, LAMPING + BALLASTS




TABLE 7- LIGHT LOSS FACTORS

| | LLD | LDD | RSDD | BF | LLF |
|-----|------|------|------|-----|------|
| L1 | 0.80 | 0.64 | - | 1.0 | 0.51 |
| F11 | 0.80 | 0.60 | - | 1.0 | 0.47 |
| F12 | 0.80 | 0.64 | - | 1.0 | 0.51 |

Light Loss Factor Assumptions:

- Evaluation of Operating Atmosphere: Dirty
- Value of LLD value assumed 0.80 due to lack of information

TABLE 8- FACADE LUMINAIRE SCHEDULE

| LUMINAIRE SCHEDULE | | | | | | | | | | | |
|--------------------|--|--|--------------------------------|-------------|---------|---------|---|--------|---|---|---|
| LUMINAIRE | CLASSIFICATION | MOUNTING | LAMP | | # LAMPS | BALLAST | VOLTAGE | OPTICS | HOUSING | MANUFACTURER | |
| L1 |  1 FT. SURFACE MOUNTED LED STRIP LIGHT | SURFACE; HEIGHT VARIES WITH WALL PROJECTIONS | - | Input Watts | 15 | - | INTEGRAL DRIVER/ TRANSFORMER | 277V | POLY CARBONATE CLEAR LENS | RIGID HOUSING; EXTRUDED ANODIZED ALUMINUM | PHILIPS-COLOR KINETICS eW GRAZE POWERCORE 523-000030-09 |
| Avg Lumens | | | | - | | | | | | | |
| Initial Lumens | | | | 477 | | | | | | | |
| OCT | | | | 4000 | | | | | | | |
| CRI | | | | - | | | | | | | |
| Maint. Category | VI | | | | | | | | | | |
| F11 |  8" SURFACE MOUNTED DOWNLIGHT | SURFACE MOUNTED | PLC-26 PHILIPS ALTO 26W/835 2P | Input Watts | 55W | 2 | ELEC/T4 INTEGRAL | 277V | PARABOLIC CROSS BAFFLES; PRIMARY LINEAR REFLECTOR | SATIN BRUSHED ALUMINUM; INTERIOR MATTE WHITE FINISH | KURT VERSEN P639CB |
| Avg Lumens | | | | - | | | | | | | |
| Initial Lumens | | | | 1760 | | | | | | | |
| OCT | | | | 3500 | | | | | | | |
| CRI | | | | 82 | | | | | | | |
| Maint. Category | IV | | | | | | | | | | |
| F12 |  3FT. SURFACE MOUNTED BOLLARD | SURFACE MOUNT PLATE | PLC-26 PHILIPS ALTO 26W/835 2P | Input Watts | 29W | 1 | ELEC/T4 ICF-2S26-H1-LD PHILIPS ELEC, PS | 277V | DIFFUSER LENS | 316 MARINE GRADE STAINLESS STEEL | LUMASCAPE LS482-262-F-A3-R-9 |
| Avg Lumens | | | | - | | | | | | | |
| Initial Lumens | | | | 1760 | | | | | | | |
| OCT | | | | 3500 | | | | | | | |
| CRI | | | | 82 | | | | | | | |
| Maint. Category | VI | | | | | | | | | | |

Lighting plan

A series of LED grazers are mounted six inches from the tops of the projected aluminum panels by “L” brackets. Walkway light is provided by bollards, and the interior glow from the corridor is integrated within the design to create an interesting, layered aesthetic. The layout of these fixtures and the other outdoor luminaires can be found in Appendix B. All luminaires around the façade are connected to a lighting control panel and switched via a photo cell positioned on the roof.

Performance




FIGURE 15 – WEST ELEVATION

LIGHTING POWER DENSITY:

Building Exterior Measured Areas

| | | |
|---------|--------|--------|
| Door | 11 | feet |
| Walkway | 286 | feet |
| Façade | 2648.4 | sq. ft |

| Luminaire Type | Quantity | Total Input Power (W) |
|----------------|----------|-----------------------|
| L1 | 40 | 600 |
| F11 | 1 | 55 |
| F12 | 18 | 522 |

| ASHRAE Allowance | Total Allowable Power | Actual Power | Net Difference |
|------------------|-----------------------|--------------|----------------|
| 30 W/lin. Ft. | 330 | 55 | 275 |
| 1 W/lin. Ft. | 286 | 522 | -236 |
| 0.2 W/sq. ft | 529.68 | 600 | -70.32 |
| | Grand Total | 1177 | -31.32 |
| | 1202.964 + 5% | COMPLIES | 25.964 |

TOTAL INPUT POWER: 1,177 W

REMAINING AVAILABLE INPUT POWER: 26 W (with 5% unrestricted allowance)

The design satisfies lighting power density requirements from ASHRAE 90.1 2007 on the condition that the excess allowable power from the building grounds is traded. The entrance has an excess of 275 W

which is greater than the walkway net difference of -236W. Therefore, the trade between the two areas affords LPD compliance. Even though the building façade lighting is over the permitted levels, the grand total of the design is less than the total allowable levels (with the addition of the 5% unrestricted allowance).




FIGURE 16 – SOUTHEAST PERSPECTIVE






FIGURE 17 – NORTHWEST PERSPECTIVE VIEWING WEST MAIN ENTRANCE

ATRIUM

SPACE

The atrium space spans the length of the addition and covers 6,273 ft² at three levels. It serves primarily as a circulation space, though it is also intended for students to use as a casual meeting place. The atrium joins the existing Science 1 Building at its western façade, and therefore has an interior wall composed of brick with light colored acoustical wall panels on its eastern side. The western side of the atrium/lobby is essentially corridor space with a stair case extending from the second to third level. The roof of the atrium supplies daylighting into the space via a system of 12 sloped skylights and clerestories. The finishes of the majority of the atrium surfaces are presented in Table 9.



FIGURES 18 + 19 – EASTERN ATRIUM WALL AND SOUTHERN SECTION

PROGRAM STATEMENT

The atrium space is one of the most challenging design spaces within the Science Building. It functions as a means of conveyance, and has dimensions and volume that give the impression of a canyon. It is the location where the new building meets the old and where daylight mixes with electric light. Keeping all these traits and characteristics in mind when designing, yields a practical, geometric solution that emphasizes the shape and flow of the space with decorative and functional luminaires using fluorescent and HID sources. Additionally, the space is again considered for breadths and studies in daylighting, acoustics, and mechanical performance.

DIMENSIONS

Length = approximately 249 ft.

Width = approximately 33 ft at the center

MATERIALS

Walls



Ceiling



Floor, Accent Wall



TABLE 9 – ATRIUM MATERIALS

| MATERIALS | | | | | | | | |
|------------|------------------------|----------|------------------|----------------|---------|------------|-------------------------------|--------------|
| Work Space | | | Atrium | | | Levels 1-3 | | |
| | Item | Key Name | Manufacturer | Series/Pattern | Style # | Color | Comments | Reflectance |
| Floor | Porcelain Tile | PT-1 | Caesar | More | | Eclipse | 24"x48" Tile (1/16" Joint) | 0.15 |
| | Porcelain Tile | PT-2 | Caesar | More | | Eclipse | 12"x48" Tile (1/16" Joint) | 0.15 |
| Wall | Existing Brick | BRK | Existing | | | | | 0.25 |
| | Painted Wall Board | | Sherwin Williams | | | | | 0.50 |
| Ceiling | Acoustic Panel Ceiling | APC-2 | Armstrong | Optima | | White | 2'x4' Panels | 0.90 |
| | Glazing | G-1 | | | | | | $\tau = 0.7$ |

DESIGN CRITERIA

- **Illuminance:** Horizontal levels should meet a minimum value of 10fc/100 lux.
- **Lighting Power Density:** The level one floor area must not exceed **0.6 W/ft²** while the upper corridor levels must remain under **0.5 W/ft²**.
- **Daylighting Integration and Control:** Daylight penetration is the key function of an atrium. Since this atrium functions primarily as a circulation space, clear glazing is acceptable in the skylight assembly. Issues of glare must be addressed with proper orientation, shading, and positioning of glazing.
- **Direct Glare:** Luminaires at eyelevel or below must be addressed to ensure they will not create any discomfort to the viewer.
- **Light Distribution on Surfaces:** Distributions must meet the design intent of the space. Since the atrium is not a dedicated work space, the accent and decorative lighting creates more isolated spots of light to guide the viewer in a certain direction.
- **Luminances of Room Surfaces:** Horizontal and vertical luminances must be sufficient for circulation.
- **Shadows:** Shadows from any downlight fixtures must be limited so as not to interfere with work surfaces.
- **Color Appearance + Color Contrast:** Color matching is an important criterion in the atrium space. Light sources must be carefully matched so that CCT values do not create great differences in warm or cool light.
- **Modeling of Faces or Objects:** The atrium serves as a decorative space within the building, and therefore, aiming angles and sources must be coordinated with the surfaces to obtain the desired effect.
- **Reflected Glare:** Luminaires and interior glazing must be carefully located to prevent reflections of natural or interior light toward direct view of an occupant.

ATRIUM LIGHTING DESIGN

LUMINAIRES, LAMPING + BALLASTS





TABLE 10- LIGHT LOSS FACTORS

| | LLD | LDD | RSDD | BF | LLF |
|----|------|------|------|------|------|
| F6 | 0.81 | 0.81 | 0.96 | 1 | 0.63 |
| F7 | 0.88 | 0.81 | 0.96 | 1.00 | 0.69 |
| F8 | 0.92 | 0.81 | 0.96 | 1.16 | 0.83 |
| M1 | 0.79 | 0.84 | 0.96 | 1.00 | 0.63 |

Light Loss Factor Assumptions:

- 0.96 was used for the RSDD value for all luminaires in all spaces
- Evaluation of Operating Atmosphere: Clean
- Cleaning Interval: 1.5 years/18 months

TABLE 11 - ATRIUM LUMINAIRE SCHEDULE

| LUMINAIRE SCHEDULE | | | | | | | | | | | | |
|--------------------|---|---|---|----------|----------------|---------|---------|--|---------|--|--|---|
| LUMINAIRE | CLASSIFICATION | MOUNTING | LAMP | | # LAMPS | BALLAST | VOLTAGE | OPTICS | HOUSING | MANUFACTURER | | |
| F6 |  | 1' X 0'-6" WALL SCONCE | 6.0 FT. AFF WALL MOUNTED | F18DBX | Input Watts | 18 | 1 | ELEC/CFQ CFQ182/G24q GEC218-MV/PS 3W GE ELEC,PS | 277 | 20 GAUGE C.R.S. REFLECTOR HIGH REFLECTANCE WHITE POWDER COAT | STEEL HOUSING/REFLECTOR DIE-CAST ALUMINUM END CAPS | FOCAL POINT SOFTLITE V1-FS611BX18 |
| | | | | GE | Avg Lumens | 970 | | | | | | |
| | | | | 835/ECO | Initial Lumens | 1200 | | | | | | |
| | | | | 4P | CCT | 3500 | | | | | | |
| | | | | | CRI | 82 | | | | | | |
| | Maint. Category | VI | | | | | | | | | | |
| F7 |  | 1FT. TAPERED SQUARE SURFACE MOUNT | SURFACE MOUNT 12 FT AFF | FPC22 | Input Watts | 25 | 1 | ELEC/T5 INTEGRAL | 277V | INJECTION MOLDED POLY CARBONATE DIFFUSER | EXTRUDED ALUMINUM | LIGHTOLIER - OPTIMO SERIES ST12AL-S122U-22W-120/277V-1 |
| | | | | SYLVANIA | Avg Lumens | 1585 | | | | | | |
| | | | | 22W T5 | Initial Lumens | 1800 | | | | | | |
| | | | | 835 | CCT | 3500 | | | | | | |
| | | | | | CRI | 82 | | | | | | |
| | Maint. Category | VI | | | | | | | | | | |
| F8 |  | 3'-2" SUSPENDED DECORATIVE | 14' AFF UNLESS OTHERWISE NOTED | F21T5 | Input Watts | 31 | 1 | ELEC/T5 GE228MV/PS-A GE ELEC, PS | 277 | MATTE WHITE ACRYLIC BOTTOM DIFFUSER, TOP COVER | COLD-ROLLED STEEL FRAME AND ALUMINUM BODY; DOUBLE STEM SUSPENSION FABRIC SHADES | SHA PER LIGHTING 101-P FABRIQUE RECTILINEAR 101-P-38-T52-21-SWH (SCA FOR SLOPED CEILING) |
| | | | | GE | Avg Lumens | 1930 | | | | | | |
| | | | | F21W/T5/ | Initial Lumens | 2100 | | | | | | |
| | | | | 835/ECO | CCT | 3500 | | | | | | |
| | | | | | CRI | 85 | | | | | | |
| | Maint. Category | VI | | | | | | | | | | |
| M1 |  | 17-13/16" x 8" LARGE MH WALL WASHER | EXTERNAL YOKE WITH CANTILEVER PENDANT MOUNT | CMH150T6 | Input Watts | 186 | 1 | MAG/CMH150 GEM150ML TLC3D-5 GE MAG | 277V | HIGH PURITY ALUMINUM REFLECTOR AND END PLATES MICRO PRISMATIC TEMPERED LENS | SMOOTH STEEL HOUSING | ELLIPTIPAR STYLE M104 1104-150G-X-01-2-00-0 |
| | | | | GE | Avg Lumens | 11000 | | | | | | |
| | | | | CMH150TU | Initial Lumens | 14000 | | | | | | |
| | | | | 830/G12 | CCT | 3000 | | | | | | |
| | | | | | CRI | 82 | | | | | | |
| | Maint. Category | IV | | | | | | | | | | |

Lighting plan

The ambient lighting in the atrium is provided by a linear arrangement of fluorescent pendant and surface mounted luminaires positioned over the corridors and centered along the center of the space by suspension from the ACT grids. The luminaires suspended through the center of level one have a cable length of 23' which is less than the manufacturer's listed maximum standard length of 25'. Accent lighting is provided by a series of six sconces (of the same style used in the office space). Wall washing is provided from a horizontal pendant-mounted metal halide aligned with the acoustical panel treatments over the existing brick wall. The metal halide lights are to be controlled by an astronomical time clock while the remainders are designed for photosensor switching control, which is analyzed in the daylighting breadth.

Performance

LIGHTING POWER DENSITY:

Building Measured Areas

| | | |
|------------------------|------|-----------------|
| Atrium – Level One | 6273 | ft ² |
| Corridor – Level Two | 2318 | ft ² |
| Corridor – Level Three | 2290 | ft ² |

| <u>Luminaire Type</u> | <u>Quantity</u> | <u>Location</u> |
|-----------------------|-----------------|--------------------------------|
| F6 | 6 | Level One |
| F7 | 26 | Level One |
| | 26 | Level Two |
| F8 | 26 | Level Three |
| | 21 | Level One |
| M1 | 14 | Mounted to East Wall @ 35' AFF |

| <u>ASHRAE Allowance</u> | <u>Total Allowable Power</u> | <u>Actual Power</u> | <u>Net Difference</u> | <u>LPD</u> |
|----------------------------------|------------------------------|---------------------|-----------------------|------------|
| Level One 0.6W/ft ² | 3763.8 W | 3905W | -141.2W | 0.62 |
| Level Two 0.5W/ft ² | 1159W | 650W | 509W | 0.28 |
| Level Three 0.5W/ft ² | 1145W | 806W | 339W | 0.35 |

Since the total net difference of the level two and three corridors is greater than the power density deficit at Level One, the values can be traded to achieve LPD standards according to ASHRAE.





FIGURE 20 - NORTH SECTION AT NIGHT TIME





FIGURE 21 - NORTHWEST PERSPECTIVE FROM LEVEL ONE

ELECTRICAL REDESIGN

LIGHTING REDESIGN

Four spaces within the Buffalo State College New Science Building were chosen for a redesign of the lighting systems. The first, the Director’s Office (Room 319A), houses the Great Lakes Center’s Director, his secretary, and some small storage space. It functions as a work and meeting space and the proposed design incorporates a layout of switched, CFL spotlights and linear fluorescents to address the flexibility of the space while providing a pleasing environment. The second, the Genetics Teaching Lab (Room 306), employs a new switching scheme and additional task lighting at the perimeter lab counters along with possible incorporation of an ambient LED luminaire. The atrium redesign includes additional pendant fixtures within the open space floor area and decorative, fixtures within the corridor. The exterior redesign of the western facade relies primarily on interior glow, but also incorporates a grazing LED light to enhance and highlight façade projections.

For each of the spaces and affected areas, any and all adjustments to the branch circuits and distribution equipment has been recalculated and resized.

TABLE 12 – PANELBOARD CHANGES SUMMARY

| Existing Panelboard Changes & Locations Served | | | | | | |
|--|---------|-----------------|--------|-----------|--------|--------|
| Panel Tag | Voltage | N/EM Indicators | Office | Gen. Lab. | Atrium | Façade |
| 3LNH1 | 480/277 | N | X | X | | X |
| PPSH1 | 480/277 | EM | | X | | |
| 1LNH1 | 480/277 | N | | | X | |
| 2LNH1 | 480/277 | N | | | X | |
| 2LEH1 | 480/277 | EM | | | X | X |

DIRECTOR’S OFFICE

All lights within the space are controlled by line voltage switching. The manual switches are located next to the door leading into the director’s office from the secretary’s office. The wall-washer F2 fixture is controlled by a manual, single pole switch next to the whiteboard. A lighting plan for the director’s office can be found in Appendix B.

The affected lighting loads for the Director’s office and most of the other spaces can be found on panel 3LNH1.

PANELBOARD ADJUSTMENTS

| LOAD | | LOAD, KW | | | CIRC | | | SEQUENCE 3Ø | | | CIRC | | | LOAD, KW | | | LOAD |
|----------------------------------|--------------------------|----------|------|---------------|------------------|------|------|------------------------|---------------|-------------|------------------|----------|---------|-------------------|-----------|-----------|--------------------------|
| | | LIGHT | RCPT | O/M | A | P | # | A | B | C | # | P | A | LIGHT | RCPT | O/M | |
| LIGHTING | 3012,3013,3014 | 1.7 | 3.3 | | 20 | 1 | 1 | 1.1 | | | 2 | 1 | 20 | | | | SPARE |
| LIGHTING | 3010,3007,3006,3004,3001 | 2.5 | | | 20 | 1 | 3 | | 2.5 | | 4 | 1 | 20 | | | | SPARE |
| LIGHTING | 3020,3021, 3022 | 3.2 | | | 20 | 1 | 5 | | | 3.2 | 6 | 1 | 20 | | | | SPARE |
| CORRIDOR | | 2.8 | | | 20 | 1 | 7 | 2.8 | | | 8 | 1 | 20 | | | | SPARE |
| CORRIDOR | C301 | 1.7 | | | 20 | 1 | 9 | | 1.7 | | 10 | 1 | 20 | | | | SPARE |
| LIGHTING | 3036,38,35,32,31,28 | 2.6 | | | 20 | 1 | 11 | | | 2.6 | 12 | 1 | 20 | | | | SPARE |
| CORRIDOR | C301 | 3.5 | | | 20 | 1 | 13 | 3.5 | | | 14 | 1 | 20 | | | | SPARE |
| CORRIDOR | C301 | 2.7 | | | 20 | 1 | 15 | | 2.7 | | 16 | 1 | 20 | | | | SPARE |
| SPACE | | | | | | | 17 | | | 0.0 | 18 | 1 | 20 | | | | SPARE |
| SPACE | | | | | | | 19 | 0.0 | | | 20 | 1 | 20 | | | | SPARE |
| SPACE | | | | | | | 21 | | 0.0 | | 22 | 1 | 20 | | | | SPARE |
| SPACE | | | | | | | 23 | | | 0.0 | 24 | 1 | 20 | | | | SPARE |
| SPACE | | | | | | | 25 | 0.0 | | | 26 | 1 | 20 | | | | SPARE |
| SPACE | | | | | | | 27 | | 3.2 | | 28 | 1 | 20 | 3.2 | | | FUTURE PHASE 2C LIGHTING |
| SPACE | | | | | | | 29 | | | 3.2 | 30 | 1 | 20 | 3.2 | | | FUTURE PHASE 2C LIGHTING |
| SPACE | | | | | | | 31 | 3.2 | | | 32 | 1 | 20 | 3.2 | | | FUTURE PHASE 2C LIGHTING |
| SPACE | | | | | | | 33 | | 3.2 | | 34 | 1 | 20 | 3.2 | | | FUTURE PHASE 2C LIGHTING |
| SPACE | | | | | | | 35 | | | 3.2 | 36 | 1 | 20 | 3.2 | | | FUTURE PHASE 2C LIGHTING |
| SPACE | | | | | | | 37 | 3.2 | | | 38 | 1 | 20 | 3.2 | | | FUTURE PHASE 2C LIGHTING |
| SPACE | | | | | | | 39 | | | 3.2 | 40 | 1 | 20 | 3.2 | | | FUTURE PHASE 2C LIGHTING |
| SPACE | | | | | | | 41 | | | 3.2 | 42 | 1 | 20 | 3.2 | | | FUTURE PHASE 2C LIGHTING |
| SUB-TOTAL, CL, KW | | 20.1 | 0.0 | 0.0 | | | | 14 | 17 | 15 | | | | 25.6 | 0.0 | 0.0 | SUB-TOTAL, CL, KW |
| SECTION 2, CL, KW | | 0.0 | 0.0 | 0.0 | | | | | | | | | | | | | |
| LOAD TYPE | CONNECTED LOAD (KW) | | | | DEMAND LOAD (KW) | | | WIRE SIZE CALCULATIONS | | | | MOUNTING | SURFACE | | | | |
| | PH A | PH B | PH C | DEMAND FACTOR | PH A | PH B | PH C | LARGEST PHASE DEMAND | NO. OF PHASES | DEMAND LOAD | SPARE CAPACITY @ | | | TOTAL DEMAND LOAD | MAIN TYPE | MAIN SIZE | |
| LIGHTING | 13.8 | 16.5 | 15.4 | 1.0 | 13.8 | 16.5 | 15.4 | 16.5 KW | 3 | 45.7 KW | 25% | 11.4 KW | MLO | 225 | | | |
| RECEPTACLES | 0.0 | 0.0 | 0.0 | 0.5 | 0.0 | 0.0 | 0.0 | 480 | | 76 AMPS | | 57.1 KW | | | | | |
| MOTORS/OTHER | 0.0 | 0.0 | 0.0 | 0.8 | 0.0 | 0.0 | 0.0 | 0.90 | | 1.25 | | 95 AMPS | A.I.C. | 25K | | | |
| TOTAL | 13.8 | 16.5 | 15.4 | | 13.8 | 16.5 | 15.4 | | | | | | OTHER | 42 POLE | | | |
| TOTAL CONNECTED LIGHTING LOAD | | | | 45.7 KW | | | | POWER FACTOR @ | 0.90 | | | | | | | | |
| TOTAL CONNECTED RECEPTACLE LOAD | | | | 0.0 KW | | | | DEMAND AMPS | 76 | | | | | | | | |
| TOTAL CONNECTED MOTOR/OTHER LOAD | | | | 0.0 KW | | | | MULT FACTOR | 1.25 | | | | | | | | |
| TOTAL CONNECTED LOAD | | | | 45.7 KW | | | | MINIMUM CCT AMPS | 95 | | | | | | | | |

| PANELBOARD SCHEDULE | | | | | | | | | | | | |
|---|----------|--------------|--|----------|---|---|---|-------------------------------|----------|--------------------------|-----------|-------------|
| VOLTAGE: 480Y/277V,3PH,4W SIZE/TYPE BUS: 225A SIZE/TYPE MAIN: 200A/3P C/B | | | PANEL TAG: 3LNH1 PANEL LOCATION: ELEC. RM. 328 PANEL MOUNTING: SURFACE | | | | | MIN. C/B AIC: 25K OPTIONS: | | | | |
| DESCRIPTION | LOCATION | LOAD (WATTS) | C/B SIZE | POS. NO. | A | B | C | POS. NO. | C/B SIZE | LOAD (WATTS) | LOCATION | DESCRIPTION |
| LTG-LAB | 306 | 3702 | 20A/1P | 1 | * | | | 2 | 20A/1P | 300 | North End | LTG-FAÇADE |
| LTG | 310 | 2500 | 20A/1P | 3 | | * | | 4 | 20A/1P | 300 | South End | LTG-FAÇADE |
| LTG | 320 | 3200 | 20A/1P | 5 | | | * | 6 | 20A/1P | 0 | | SPARE |
| LTG | CORR | 2800 | 20A/1P | 7 | * | | | 8 | 20A/1P | 0 | | SPARE |
| LTG-ATRIUM | C301 | 806 | 20A/1P | 9 | | * | | 10 | 20A/1P | 0 | | SPARE |
| LTG - OFFICE | 319 | 2600 | 20A/1P | 11 | | | * | 12 | 20A/1P | 0 | | SPARE |
| LTG-ATRIUM | C301 | 2604 | 20A/1P | 13 | * | | | 14 | 20A/1P | 0 | | SPARE |
| SPACE | 0 | 0 | 20A/1P | 15 | | * | | 16 | 20A/1P | 0 | | SPARE |
| SPACE | | 0 | 20A/1P | 17 | | | * | 18 | 20A/1P | 0 | | SPARE |
| SPACE | | 0 | 20A/1P | 19 | * | | | 20 | 20A/1P | 0 | | SPARE |
| SPACE | | 0 | 20A/1P | 21 | | * | | 22 | 20A/1P | 0 | | SPARE |
| SPACE | | 0 | 20A/1P | 23 | | | * | 24 | 20A/1P | 0 | | SPARE |
| SPACE | | 0 | 20A/1P | 25 | * | | | 26 | 20A/1P | 0 | | SPARE |
| SPACE | | 0 | 20A/1P | 27 | | * | | 28 | 20A/1P | 3200 | 0 | LTG-PHASE2 |
| SPACE | | 0 | 20A/1P | 29 | | | * | 30 | 20A/1P | 3200 | 0 | LTG-PHASE2 |
| SPACE | | 0 | 20A/1P | 31 | * | | | 32 | 20A/1P | 3200 | 0 | LTG-PHASE2 |
| SPACE | | 0 | 20A/1P | 33 | | * | | 34 | 20A/1P | 3200 | 0 | LTG-PHASE2 |
| SPACE | | 0 | 20A/1P | 35 | | | * | 36 | 20A/1P | 3200 | 0 | LTG-PHASE2 |
| SPACE | | 0 | 20A/1P | 37 | * | | | 38 | 20A/1P | 3200 | 0 | LTG-PHASE2 |
| SPACE | | 0 | 20A/1P | 39 | | * | | 40 | 20A/1P | 3200 | 0 | LTG-PHASE2 |
| SPACE | | 0 | 20A/1P | 41 | | | * | 42 | 20A/1P | 3200 | 0 | LTG-PHASE2 |
| CONNECTED LOAD (KW) - A Ph. | | 15.81 | | | | | | | | TOTAL DESIGN LOAD (KW) | | 69.39 |
| CONNECTED LOAD (KW) - B Ph. | | 13.21 | | | | | | | | POWER FACTOR | | 0.90 |
| CONNECTED LOAD (KW) - C Ph. | | 15.40 | | | | | | | | TOTAL DESIGN LOAD (AMPS) | | 93 |

3LNH1

Sizing Feeder

Spare(s) Contributio 55 (# of Spares*Breaker Size*0.25)
 Design Ampacity 93
 Total 148

OCPD 200

| | |
|--------------------------------|---------|
| Sets | 1 |
| Wire Size | |
| Phase | 3/0 |
| Neutral | 3/0 |
| "Table 250.122" Ground | 6 |
| Wire Area (table 5, sq. in.) | |
| Each Phase | 0.2679 |
| Total -Phase Conductors | 0.8037 |
| Neutral | 0.2679 |
| Ground | 0.0507 |
| Total Area | 1.1223 |
| Min. Conduit Area (above *2.5) | 2.80575 |
| Conduit Size (table 4) | 2" |
| Conduit Size (table C.2) | 2" |
| Remarks | |

| PANELBOARD SIZING WORKSHEET | | | | | | | | | | | | |
|--|-----|-----------------------|------|-----------|-------|-----------------|-------|-----------|---------------|------------|--|----------|
| Panel Tag-----> | | | | | 3LNH1 | Panel Location: | | | ELEC. RM. 328 | | | |
| Nominal Phase to Neutral Voltage-----> | | | | | 277 | Phase: | | | 3 | | | |
| Nominal Phase to Phase Voltage-----> | | | | | 480 | Wires: | | | 4 | | | |
| Pos | Ph. | Load Type | Cat. | Location | Load | Units | I. PF | Watts | VA | Remarks | | |
| 1 | A | LTG-LAB | 3 | 306 | 3702 | w | | 3702 | 4113 | | | |
| 2 | A | LTG-FACADE | | North End | 300 | w | | 300 | 333 | | | |
| 3 | B | LTG | 3 | 310 | 2500 | w | | 2500 | 2778 | | | |
| 4 | B | LTG-FACADE | | South End | 300 | w | | 300 | 333 | | | |
| 5 | C | LTG | 3 | 320 | 3200 | w | | 3200 | 3556 | | | |
| 6 | C | SPARE | | | 0 | w | | 0 | 0 | | | |
| 7 | A | LTG | 3 | CORR | 2800 | w | | 2800 | 3111 | | | |
| 8 | A | SPARE | | | 0 | w | | 0 | 0 | | | |
| 9 | B | LTG-ATRIUM | 3 | C301 | 806 | w | | 806 | 896 | | | |
| 10 | B | SPARE | | | 0 | w | | 0 | 0 | | | |
| 11 | C | LTG - OFFICE | 3 | 319 | 2600 | w | | 2600 | 2889 | | | |
| 12 | C | SPARE | | | 0 | w | | 0 | 0 | | | |
| 13 | A | LTG-ATRIUM | 4 | C301 | 2604 | w | | 2604 | 2893 | | | |
| 14 | A | SPARE | | | 0 | w | | 0 | 0 | | | |
| 15 | B | SPACE | | | 0 | w | | 0 | 0 | | | |
| 16 | B | SPARE | | | 0 | w | | 0 | 0 | | | |
| 17 | C | SPACE | | | 0 | w | | 0 | 0 | | | |
| 18 | C | SPARE | | | 0 | w | | 0 | 0 | | | |
| 19 | A | SPACE | | | 0 | w | | 0 | 0 | | | |
| 20 | A | SPARE | | | 0 | w | | 0 | 0 | | | |
| 21 | B | SPACE | | | 0 | w | | 0 | 0 | | | |
| 22 | B | SPARE | | | 0 | w | | 0 | 0 | | | |
| 23 | C | SPACE | | | 0 | w | | 0 | 0 | | | |
| 24 | C | SPARE | | | 0 | w | | 0 | 0 | | | |
| 25 | A | SPACE | | | 0 | w | | 0 | 0 | | | |
| 26 | A | SPARE | | | 0 | w | | 0 | 0 | | | |
| 27 | B | SPACE | | | 0 | w | | 0 | 0 | | | |
| 28 | B | LTG-PHASE2 | 3 | | 3200 | w | | 3200 | 3556 | | | |
| 29 | C | SPACE | | | 0 | w | | 0 | 0 | | | |
| 30 | C | LTG-PHASE2 | 3 | | 3200 | w | | 3200 | 3556 | | | |
| 31 | A | SPACE | | | 0 | w | | 0 | 0 | | | |
| 32 | A | LTG-PHASE2 | 3 | | 3200 | w | | 3200 | 3556 | | | |
| 33 | B | SPACE | | | 0 | w | | 0 | 0 | | | |
| 34 | B | LTG-PHASE2 | 3 | | 3200 | w | | 3200 | 3556 | | | |
| 35 | C | SPACE | | | 0 | w | | 0 | 0 | | | |
| 36 | C | LTG-PHASE2 | 3 | | 3200 | w | | 3200 | 3556 | | | |
| 37 | A | SPACE | | | 0 | w | | 0 | 0 | | | |
| 38 | A | LTG-PHASE2 | 3 | | 3200 | w | | 3200 | 3556 | | | |
| 39 | B | SPACE | | | 0 | w | | 0 | 0 | | | |
| 40 | B | LTG-PHASE2 | 3 | | 3200 | w | | 3200 | 3556 | | | |
| 41 | C | SPACE | | | 0 | w | | 0 | 0 | | | |
| 42 | C | LTG-PHASE2 | 3 | | 3200 | w | | 3200 | 3556 | | | |
| PANEL TOTAL | | | | | | | | 44.4 | 49.3 | Amps= 59.4 | | |
| PHASE LOADING | | | | | | | | | | | | |
| PHASE TOTAL | | | | | | | | A | | | | |
| PHASE TOTAL | | | | | | | | B | | | | |
| PHASE TOTAL | | | | | | | | C | | | | |
| LOAD CATAGORIES | | | | | | | | Connected | | Demand | | Ver. 104 |
| | | | | | kW | kVA | DF | kW | kVA | PF | | |
| 1 | | receptacles | | | 0.0 | 0.0 | | 0.0 | 0.0 | | | |
| 2 | | computers | | | 0.0 | 0.0 | | 0.0 | 0.0 | | | |
| 3 | | fluorescent lighting | | | 41.2 | 45.8 | 1.25 | 51.5 | 57.2 | 0.90 | | |
| 4 | | HID lighting | | | 2.6 | 2.9 | 1.25 | 3.3 | 3.6 | 0.90 | | |
| 5 | | incandescent lighting | | | 0.0 | 0.0 | | 0.0 | 0.0 | | | |
| 6 | | HVAC fans | | | 0.0 | 0.0 | | 0.0 | 0.0 | | | |
| 7 | | heating | | | 0.0 | 0.0 | | 0.0 | 0.0 | | | |
| 8 | | kitchen equipment | | | 0.0 | 0.0 | | 0.0 | 0.0 | | | |
| 9 | | unassigned | | | 0.6 | 0.7 | 1.25 | 0.8 | 0.8 | 0.90 | | |
| Total Demand Loads | | | | | | | | 55.5 | 61.7 | | | |
| Spare Capacity | | | | | 25% | | | 13.9 | 15.4 | | | |
| Total Design Loads | | | | | | | | 69.4 | 77.1 | 0.90 | | |
| | | | | | | | | | | Amps= 92.8 | | |

| | |
|-------------------------|-------|
| Default Power Factor = | 0.90 |
| Default Demand Factor = | 100 % |

See Appendix B for lighting plans and Appendix C for associated equipment.

GENETICS TEACHING LAB

See existing copy of panel 3LNH1 and new panel 3LNH1 above for updated normal branch circuits and panelboard. The circuit for the teaching lab is in position one. The teaching lab also had minor loads on panel PPSH1 which were removed, see panel below.

| LOAD | | LOAD, KW | | | CIRC | | | SEQUENCE 3Ø | | | CIRC | | | LOAD, KW | | | LOAD | |
|------------------------|-----|----------|------|-------|------|---|-----|-------------|------|------|------|-----|-----|----------|------|-------|----------------------------|--------------------|
| | | LIGHT | RCPT | O/M | A | P | # | A | B | C | # | P | A | LIGHT | RCPT | O/M | | |
| AHU-2 (125 HP) VSD | | | | 35.0 | 225 | 3 | 1 | 36.3 | | | 2 | 1 | 20 | 1.3 | | | PENTHOUSE P001 | |
| - | | | | 35.0 | - | - | 1 | | 36.4 | | 2 | 1 | 20 | 1.4 | | | 3RD FLOOR LIGHTING | |
| - | | | | 35.0 | - | - | 1 | | | 36.5 | 1 | 20 | 1.5 | | | | 2ND FLOOR LIGHTING | |
| | | | | | | | 3 | 0.8 | | | 3 | 15 | | | | | EF-3 (2 HP) | |
| | | | | | | | 3 | | 0.8 | | - | - | | | | | 0.8 | |
| | | | | | | | 3 | | | 0.8 | - | - | | | | | 0.8 | |
| PLSL1 (P-TS1) | 0.0 | 2.0 | 0.0 | 30 | 3 | 5 | 2.0 | | | | 3 | 15 | | | | | EF-4 (2 HP) BACKUP TO EF-3 | |
| - | 0.0 | 1.2 | 0.0 | - | - | 5 | | 1.2 | | | - | - | | | | | - | |
| - | 0.0 | 0.0 | 0.5 | - | - | 5 | | | 0.5 | | - | - | | | | | - | |
| SERVICE ELEVATOR ***** | | | | 14.4 | 100 | 3 | 7 | 23.3 | | | 3 | 80 | | | | | 8.9 | SEF-1 (30 HP) |
| EST 50 HP | | | | 14.4 | - | - | 7 | | 23.3 | | 3 | - | | | | | 8.9 | - |
| - | | | | 14.4 | - | - | 7 | | | 23.3 | - | - | | | | | 8.9 | - |
| | | | | | | | 9 | 8.9 | | | 3 | 80 | | | | | 8.9 | SEF-2 (30 HP) |
| | | | | | | | 9 | | 8.9 | | - | - | | | | | 8.9 | - |
| | | | | | | | 9 | | | 8.9 | - | - | | | | | 8.9 | - |
| | | | | | | | 11 | 27.5 | | | 3 | 200 | | | | | 27.5 | LEF-1 (100 HP) VSD |
| | | | | | | | 11 | | 27.5 | | - | - | | | | | 27.5 | - |
| | | | | | | | 11 | | | 27.5 | - | - | | | | | 27.5 | - |
| | | | | | | | 13 | 1.3 | | | 3 | 30 | 0.0 | 0.8 | 0.5 | | | PLSL2 (P-TS2) |
| | | | | | | | 13 | | 1.7 | | - | - | 0.0 | 1.2 | 0.5 | | | - |
| | | | | | | | 13 | | | 1.2 | - | - | 0.0 | 1.2 | 0.0 | | | - |
| SUB-TOTAL, CL, KW | | 0.0 | 3.2 | 148.7 | | | | 100 | 100 | 99 | | | | 4.2 | 3.2 | 139.3 | SUB-TOTAL, CL, KW | |
| SECTION 2, CL, KW | | 0.0 | 0.0 | 0.0 | | | | | | | | | | | | | | |

| LOAD TYPE | CONNECTED LOAD (KW) | | | DEMAND FACTOR | DEMAND LOAD (KW) | | | WIRE SIZE CALCULATIONS | | | MOUNTING | SURFACE | | |
|----------------------------------|---------------------|------|------|---------------|------------------|------|------|------------------------|---------------|-------------|----------|----------|------------------|-------------------|
| | PH A | PH B | PH C | | PH A | PH B | PH C | LARGEST PHASE DEMAND | NO. OF PHASES | DEMAND LOAD | | | SPARE CAPACITY @ | TOTAL DEMAND LOAD |
| LIGHTING | 1.3 | 1.4 | 1.5 | 1.0 | 1.3 | 1.4 | 1.5 | 79.5 kW | 3 | 237.8 kW | 10% | 261.6 kW | MAIN TYPE | MLO |
| RECEPTACLES | 2.8 | 2.4 | 1.2 | 0.5 | 1.4 | 1.2 | 0.6 | 79.5 kW | 3 | 237.8 kW | 10% | 261.6 kW | MAIN SIZE | 600 |
| MOTORS/OTHER | 96.0 | 96.0 | 96.0 | 0.6 | 76.8 | 76.8 | 76.8 | 480 | 3 | 237.8 kW | 10% | 261.6 kW | A.I.C. | 35K |
| TOTAL | 100.1 | 99.8 | 98.7 | | 79.5 | 79.4 | 78.9 | 480 | 3 | 237.8 kW | 10% | 261.6 kW | OTHER | - |
| TOTAL CONNECTED LIGHTING LOAD | | | | 4.2 kW | | | | POWER FACTOR @ | 0.90 | 0.90 | | | | |
| TOTAL CONNECTED RECEPTACLE LOAD | | | | 6.4 kW | | | | DEMAND AMPS | | 350 AMPS | | | | |
| TOTAL CONNECTED MOTOR/OTHER LOAD | | | | 288.0 kW | | | | MULT FACTOR | | 1.25 | | | | |
| TOTAL CONNECTED LOAD | | | | 298.6 kW | | | | MINIMUM CCT AMPS | | 436 AMPS | | | | |

ATRIUM

THIRD LEVEL: Existing loads on 3LNH1 (ckts. 9, 13, and 15) for the general corridor lighting and ceiling uplighting have been edited and relocated. See above for 3LNH1 and below for panel 2LEH1.

| PANEL | | 2LEH1 | | VOLTAGE | | 480 / 277 | | PH | | 3 | | WIRE | | 4 | | 6/28/2009 | | |
|----------------------------------|---------------------|------------|------|---------------|------------------|-----------|------------------|------------------------|---------------|------------------|-----------|---------|-------|------|-----|-----------|--|-------------------------|
| LOCATION | | ELEC, 2029 | | FED FROM | | BPEH1 | | | | | | | | | | 11:02 AM | | |
| LOAD | LOAD, KW | | | CIRC # | SEQUENCE 3Ø | | | CIRC # | LOAD, KW | | | LOAD | | | | | | |
| | LIGHT | RCPT | O/M | | A | B | C | | A | B | C | | LIGHT | RCPT | O/M | | | |
| 1ST FL LIGHTING CORR | 3.3 | | | 20 | 1 | | | 1 | 6.4 | | | 2 | 1 | 20 | 3.1 | | | 3RD FLOOR LIGHTING CORR |
| EXIT SIGNS 1ST FL | 0.3 | | | 20 | 1 | | | 3 | | 0.6 | | 4 | 1 | 20 | 0.3 | | | EXIT SIGNS 3RD FL |
| 1ST FL-ALCOVE C110, C110A | 0.2 | | | 20 | 1 | | | 5 | | | 3.2 | 6 | 1 | 20 | 3.0 | | | 2ND FLOOR CORR LIGHTING |
| SPARE | | | | 20 | 1 | | | 7 | 0.3 | | | 8 | 1 | 20 | 0.3 | | | EXIT SIGNS 2ND FL |
| SPARE | | | | 20 | 1 | | | 9 | | 0.0 | | 10 | 1 | 20 | | | | SPARE |
| SPARE | | | | 20 | 1 | | | 11 | | | 0.0 | 12 | 1 | 20 | | | | SPARE |
| SPARE | | | | 20 | 1 | | | 13 | 0.0 | | | 14 | 1 | 20 | | | | SPARE |
| SPACE | | | | | | | | 15 | | 0.0 | | 16 | | | | | | SPACE |
| SPACE | | | | | | | | 17 | | | 0.0 | 18 | | | | | | SPACE |
| SPACE | | | | | | | | 19 | 0.0 | | | 20 | | | | | | SPACE |
| SPACE | | | | | | | | 21 | | 0.0 | | 22 | | | | | | SPACE |
| SPACE | | | | | | | | 23 | | | 0.0 | 24 | | | | | | SPACE |
| SPACE | | | | | | | | 25 | 0.0 | | | 26 | | | | | | SPACE |
| SPACE | | | | | | | | 27 | | 0.0 | | 28 | | | | | | SPACE |
| SPACE | | | | | | | | 29 | | | 0.0 | 30 | | | | | | SPACE |
| SPACE | | | | | | | | 31 | 1.1 | | | 32 | 1 | 20 | 1.1 | | | FUTURE PH 2C - LGTS |
| SPACE | | | | | | | | 33 | | 1.1 | | 34 | 1 | 20 | 1.1 | | | FUTURE PH 2C - LGTS |
| SPACE | | | | | | | | 35 | | | 1.1 | 36 | 1 | 20 | 1.1 | | | FUTURE PH 2C - LGTS |
| 2LEH1 | 0.0 | 2.8 | 1.0 | 60 | 3 | | | 37 | 3.9 | | | 38 | 1 | 20 | 0.1 | | | FUTURE PH 2C - EXITS |
| - | 0.0 | 4.7 | 1.5 | - | - | | | 39 | | 6.3 | | 40 | 1 | 20 | 0.1 | | | FUTURE PH 2C - EXITS |
| - | 0.0 | 3.8 | 1.5 | - | - | | | 41 | | | 5.4 | 42 | 1 | 20 | 0.1 | | | FUTURE PH 2C - EXITS |
| SUB-TOTAL, CL, KW | | | | 3.8 | 11.3 | 4.0 | | | 12 | 8 | 10 | | | 10.3 | 0.0 | 0.0 | | SUB-TOTAL, CL, KW |
| SECTION 2, CL, KW | | | | 0.0 | 0.0 | 0.0 | | | | | | | | | | | | |
| LOAD TYPE | CONNECTED LOAD (KW) | | | DEMAND FACTOR | DEMAND LOAD (KW) | | | WIRE SIZE CALCULATIONS | | | MOUNTING | SURFACE | | | | | | |
| | PH A | PH B | PH C | | PH A | PH B | PH C | LARGEST PHASE DEMAND | NO. OF PHASES | SPARE CAPACITY @ | | | | | | | | |
| LIGHTING | 7.9 | 1.8 | 4.4 | 1.0 | 7.9 | 1.8 | 4.4 | 10.1 kW | 3 | 25% | MAIN TYPE | MLO | | | | | | |
| RECEPTACLES | 2.8 | 4.7 | 3.8 | 0.5 | 1.4 | 2.4 | 1.9 | 23.0 kW | | | MAIN SIZE | 100A | | | | | | |
| MOTORS/OTHER | 1.0 | 1.5 | 1.5 | 0.8 | 0.8 | 1.2 | 1.2 | 5.8 kW | | | OTHER | * | | | | | | |
| TOTAL | 11.7 | 8.0 | 9.7 | | 10.1 | 5.4 | 7.5 | 28.8 kW | | | | | | | | | | |
| TOTAL CONNECTED LIGHTING LOAD | | | | 14.1 kW | | | SUPPLY VOLTAGE | | | 480 | | | | | | | | |
| TOTAL CONNECTED RECEPTACLE LOAD | | | | 11.3 kW | | | POWER FACTOR @ | | | 0.90 | | | | | | | | |
| TOTAL CONNECTED MOTOR/OTHER LOAD | | | | 4.0 kW | | | DEMAND AMPS | | | 38 AMPS | | | | | | | | |
| TOTAL CONNECTED LOAD | | | | 29.4 kW | | | MULT FACTOR | | | 1.25 | | | | | | | | |
| | | | | | | | MINIMUM CCT AMPS | | | 48 AMPS | | | | | | | | |

SECOND LEVEL: Existing loads on 2LNH1 and 2LEH1 were updated for new lighting design.

| PANEL | | 2LNH1 | | VOLTAGE | | 480 / 277 | | PH | | 3 | | WIRE | | 4 | | 8/29/2009 | | 10:14 AM | | | | | |
|----------------------------------|---------------------|-----------|------|---------------|------------------|-----------|------|------------------------|---------------|-------------|------------------|----------|---------|-------------------|----------------|----------------|-------------|-------------|------------------|--------------------------|---------|--|--|
| LOCATION | | ELEC 3029 | | FED FROM | | USSHV-B | | | | | | | | | | | | | | | | | |
| LOAD | LOAD, KW | | | CIRC | SEQUENCE 3Ø | | | CIRC | LOAD, KW | | | LOAD | | | | | | | | | | | |
| | LIGHT | RCPT | O/M | | A | B | C | | A | B | C | | LIGHT | RCPT | O/M | | | | | | | | |
| LIGHTING 2011,12,13 | 2.9 | | | 20 | 1 | 1 | 2.9 | | | | 2 | 1 | 20 | | | | | | | SPARE | | | |
| LIGHTING 2017,22,23,24 | 3.3 | | | 20 | 1 | 3 | 3.3 | | | | 4 | 1 | 20 | | | | | | | SPARE | | | |
| CORRIDORS | 3.0 | | | 20 | 1 | 5 | | | | 3.0 | 6 | 1 | 20 | | | | | | | SPARE | | | |
| CORRIDORS C201 | 1.7 | | | 20 | 1 | 7 | 1.7 | | | | 8 | 1 | 20 | | | | | | | SPARE | | | |
| LIGHTING 2033,32,31,30 | 3.3 | | | 20 | 1 | 9 | 3.3 | | | | 10 | 1 | 20 | | | | | | | SPARE | | | |
| LIGHTING 2009,08,05,04,01 | 2.5 | | | 20 | 1 | 11 | | | | 2.5 | 12 | 1 | 20 | | | | | | | SPARE | | | |
| SPACE | | | | | | 13 | 0.0 | | | | 14 | 1 | 20 | | | | | | | SPARE | | | |
| SPACE | | | | | | 15 | 0.0 | | | | 16 | 1 | 20 | | | | | | | SPARE | | | |
| SPACE | | | | | | 17 | | | | 0.0 | 18 | 1 | 20 | | | | | | | SPARE | | | |
| SPACE | | | | | | 19 | 0.0 | | | | 20 | 1 | 20 | | | | | | | SPARE | | | |
| SPACE | | | | | | 21 | 0.0 | | | | 22 | 1 | 20 | | | | | | | SPARE | | | |
| SPACE | | | | | | 23 | | | | 0.0 | 24 | 1 | 20 | | | | | | | SPARE | | | |
| SPACE | | | | | | 25 | 0.0 | | | | 26 | 1 | 20 | | | | | | | SPARE | | | |
| SPACE | | | | | | 27 | 3.4 | | | | 28 | 1 | 20 | 3.4 | | | | | | FUTURE PHASE 2C LIGHTING | | | |
| SPACE | | | | | | 29 | | | | 3.4 | 30 | 1 | 20 | 3.4 | | | | | | FUTURE PHASE 2C LIGHTING | | | |
| SPACE | | | | | | 31 | 3.4 | | | | 32 | 1 | 20 | 3.4 | | | | | | FUTURE PHASE 2C LIGHTING | | | |
| SPACE | | | | | | 33 | 3.4 | | | | 34 | 1 | 20 | 3.4 | | | | | | FUTURE PHASE 2C LIGHTING | | | |
| SPACE | | | | | | 35 | | | | 3.4 | 36 | 1 | 20 | 3.4 | | | | | | FUTURE PHASE 2C LIGHTING | | | |
| SPACE | | | | | | 37 | 3.4 | | | | 38 | 1 | 20 | 3.4 | | | | | | FUTURE PHASE 2C LIGHTING | | | |
| SPACE | | | | | | 39 | | | | 3.4 | 40 | 1 | 20 | 3.4 | | | | | | FUTURE PHASE 2C LIGHTING | | | |
| SPACE | | | | | | 41 | | | | 3.4 | 42 | 1 | 20 | 3.4 | | | | | | FUTURE PHASE 2C LIGHTING | | | |
| SUB-TOTAL, CL, KW | | 16.7 | 0.0 | 0.0 | | | | | 11 | 17 | 16 | | | 27.2 | 0.0 | 0.0 | | | | SUB-TOTAL, CL, KW | | | |
| SECTION 2, CL, KW | | 0.0 | 0.0 | 0.0 | | | | | | | | | | | | | | | | | | | |
| LOAD TYPE | CONNECTED LOAD (KW) | | | | DEMAND LOAD (KW) | | | WIRE SIZE CALCULATIONS | | | | MOUNTING | SURFACE | | | | | | | | | | |
| | PH A | PH B | PH C | DEMAND FACTOR | PH A | PH B | PH C | LARGEST PHASE DEMAND | NO. OF PHASES | DEMAND LOAD | SPARE CAPACITY @ | | | TOTAL DEMAND LOAD | SUPPLY VOLTAGE | POWER FACTOR @ | DEMAND AMPS | MULT FACTOR | MINIMUM CCT AMPS | | | | |
| LIGHTING | 11.4 | 16.8 | 15.7 | 1.0 | 11.4 | 16.8 | 15.7 | 16.8 KW | 3 | 43.9 KW | 25% | 54.9 KW | 480 | 0.90 | 73 AMPS | 1.25 | 91 AMPS | | | MAIN TYPE | MLO | | |
| RECEPTACLES | 0.0 | 0.0 | 0.0 | 0.5 | 0.0 | 0.0 | 0.0 | | | 11.0 KW | | | | | | | | | | MAIN SIZE | 225A | | |
| MOTORS/OTHER | 0.0 | 0.0 | 0.0 | 0.8 | 0.0 | 0.0 | 0.0 | | | | | | | | | | | | | A.I.C. | 25K | | |
| TOTAL | 11.4 | 16.8 | 15.7 | | 11.4 | 16.8 | 15.7 | | | | | | | | | | | | | OTHER | 42 POLE | | |
| TOTAL CONNECTED LIGHTING LOAD | | | | | 43.9 KW | | | | | | | | | | | | | | | | | | |
| TOTAL CONNECTED RECEPTACLE LOAD | | | | | 0.0 KW | | | | | | | | | | | | | | | | | | |
| TOTAL CONNECTED MOTOR/OTHER LOAD | | | | | 0.0 KW | | | | | | | | | | | | | | | | | | |
| TOTAL CONNECTED LOAD | | | | | 43.9 KW | | | | | | | | | | | | | | | | | | |

LEVEL ONE: Existing loads on 1LNH1 and 2LEH1 were updated.

EXTERIOR: All lighting designed for the exterior has been added to 2LEH1 and 3LNH1.

| PANEL | | LOCATION | | VOLTAGE | | PH | | WIRE | | DATE | | TIME | | | | | |
|-----------------------------|-------|-----------|-----|-----------|------|----|-----|----------|----|-----------|----------|----------|-----|------|----------------------------|-----|-------------------|
| TLNH1 | | ELEC 1029 | | 480 / 277 | | 3 | | 4 | | 6/29/2009 | | 10:52 AM | | | | | |
| LOAD | | LOAD, KW | | | CIRC | | | SEQUENCE | | | LOAD, KW | | | LOAD | | | |
| | LIGHT | RCPT | O/M | A | B | C | # | A | B | C | LIGHT | RCPT | O/M | | | | |
| LIGHTING 1006,05,08,00 | 1.4 | | | 20 | 1 | 1 | 1.8 | | | | 2 | 3 | 15 | 0.4 | AC - 1 (2) - (1/2 HP MTRS) | | |
| LIGHTING 1011A,02,01 | 3.3 | | | 20 | 1 | 3 | 3.7 | | | | 4 | - | - | 0.4 | - | | |
| LIGHTING 1016,1015,05,33,30 | 2.7 | | | 20 | 1 | 5 | | | | | 6 | - | - | 0.4 | - | | |
| ATRIUM 1011 | 3.3 | | | 20 | 1 | 7 | 3.3 | | | | 8 | 1 | 20 | | SPARE | | |
| 1011B,11C,20 | 3.4 | | | 20 | 1 | 9 | | | | | 10 | 1 | 20 | | SPARE | | |
| CORRIDORS | 1.8 | | | 20 | 1 | 11 | | | | | 12 | 1 | 20 | | SPARE | | |
| LIGHTING 1021,22,23,24 | 3.1 | | | 20 | 1 | 13 | 3.1 | | | | 14 | 1 | 20 | | SPARE | | |
| SPACE | | | | | | | | | | | 15 | | | | SPARE | | |
| SPACE | | | | | | | | | | | 16 | | | | SPARE | | |
| SPACE | | | | | | | | | | | 17 | | | | SPARE | | |
| SPACE | | | | | | | | | | | 18 | | | | SPARE | | |
| SPACE | | | | | | | | | | | 19 | 3.6 | | | FUTURE PHASE 2C LIGHTING | | |
| SPACE | | | | | | | | | | | 20 | 1 | 20 | 3.6 | FUTURE PHASE 2C LIGHTING | | |
| SPACE | | | | | | | | | | | 21 | | | | FUTURE PHASE 2C LIGHTING | | |
| SPACE | | | | | | | | | | | 22 | 1 | 20 | 3.6 | FUTURE PHASE 2C LIGHTING | | |
| SPACE | | | | | | | | | | | 23 | | | | FUTURE PHASE 2C LIGHTING | | |
| SPACE | | | | | | | | | | | 24 | 1 | 20 | 3.6 | FUTURE PHASE 2C LIGHTING | | |
| SPACE | | | | | | | | | | | 25 | | | | FUTURE PHASE 2C LIGHTING | | |
| SPACE | | | | | | | | | | | 26 | 1 | 20 | 3.6 | FUTURE PHASE 2C LIGHTING | | |
| SPACE | | | | | | | | | | | 27 | | | | FUTURE PHASE 2C LIGHTING | | |
| SPACE | | | | | | | | | | | 28 | 1 | 20 | 3.6 | FUTURE PHASE 2C LIGHTING | | |
| SPACE | | | | | | | | | | | 29 | | | | FUTURE PHASE 2C LIGHTING | | |
| SPACE | | | | | | | | | | | 30 | 1 | 20 | 3.6 | FUTURE PHASE 2C LIGHTING | | |
| SPACE | | | | | | | | | | | 31 | | | | FUTURE PHASE 2C LIGHTING | | |
| SPACE | | | | | | | | | | | 32 | 1 | 20 | 3.6 | FUTURE PHASE 2C LIGHTING | | |
| SPACE | | | | | | | | | | | 33 | | | | FUTURE PHASE 2C LIGHTING | | |
| SPACE | | | | | | | | | | | 34 | 1 | 20 | 3.6 | FUTURE PHASE 2C LIGHTING | | |
| SPACE | | | | | | | | | | | 35 | | | | FUTURE PHASE 2C LIGHTING | | |
| SPACE | | | | | | | | | | | 36 | 1 | 20 | 3.6 | FUTURE PHASE 2C LIGHTING | | |
| SPACE | | | | | | | | | | | 37 | | | | FUTURE PHASE 2C LIGHTING | | |
| SPACE | | | | | | | | | | | 38 | 1 | 20 | 3.6 | FUTURE PHASE 2C LIGHTING | | |
| SPACE | | | | | | | | | | | 39 | | | | FUTURE PHASE 2C LIGHTING | | |
| SPACE | | | | | | | | | | | 40 | 1 | 20 | 3.6 | FUTURE PHASE 2C LIGHTING | | |
| SPACE | | | | | | | | | | | 41 | | | | FUTURE PHASE 2C LIGHTING | | |
| SPACE | | | | | | | | | | | 42 | 1 | 20 | 3.6 | FUTURE PHASE 2C LIGHTING | | |
| SUB-TOTAL, CL, KW | | 19.0 | 0.0 | 0.0 | | | | 23 | 22 | 19 | | | | 43.2 | 0.0 | 1.2 | SUB-TOTAL, CL, KW |
| SECTION 2, CL, KW | | 0.0 | 0.0 | 0.0 | | | | | | | | | | | | | |

| LOAD TYPE | CONNECTED LOAD (KW) | | | DEMAND FACTOR | DEMAND LOAD (KW) | | | WIRE SIZE CALCULATIONS | | | MOUNTING | SURFACE |
|----------------------------------|---------------------|------|------|---------------|------------------|------|------|------------------------|---------------|-------------|-----------|---------|
| | PH A | PH B | PH C | | PH A | PH B | PH C | LARGEST PHASE DEMAND | NO. OF PHASES | DEMAND LOAD | | |
| LIGHTING | 22.2 | 21.1 | 18.9 | 1.0 | 22.2 | 21.1 | 18.9 | 22.5 kW | 3 | 63.1 kW | MAIN TYPE | MLO |
| RECEPTACLES | 0.0 | 0.0 | 0.0 | 0.5 | 0.0 | 0.0 | 0.0 | SPARE CAPACITY @ 25% | | 15.8 kW | MAIN SIZE | 225A |
| MOTORS/OTHER | 0.4 | 0.4 | 0.4 | 0.6 | 0.3 | 0.3 | 0.3 | TOTAL DEMAND LOAD | | 78.9 kW | | |
| TOTAL | 22.6 | 21.5 | 19.3 | | 22.5 | 21.4 | 19.2 | SUPPLY VOLTAGE | | 480 | | |
| TOTAL CONNECTED LIGHTING LOAD | | | | 0.22 kW | | | | POWER FACTOR @ | 0.90 | 0.90 | A.I.C. | 25K |
| TOTAL CONNECTED RECEPTACLE LOAD | | | | 0.0 kW | | | | DEMAND AMPS | | 105 AMPS | OTHER | |
| TOTAL CONNECTED MOTOR/OTHER LOAD | | | | 1.2 kW | | | | MULT FACTOR | | 1.25 | | |
| TOTAL CONNECTED LOAD | | | | 85.4 kW | | | | MINIMUM CCT AMPS | | 131 AMPS | | |

| PANELBOARD SCHEDULE | | | | | | | | | | | | | |
|-----------------------------|----------|--------------|------------------------------|----------|---|---|-------------------|----------|----------|--------------|--------------------------|---------------|-------|
| VOLTAGE: 480Y/277V, 3PH, 4W | | | PANEL TAG: 2LEH1 | | | | MIN. C/B AIC: 25K | | | | | | |
| SIZE/TYPE BUS: 225A | | | PANEL LOCATION: SECOND FLOOR | | | | OPTIONS: | | | | | | |
| SIZE/TYPE MAIN: 125A/3P C/B | | | PANEL MOUNTING: SURFACE | | | | | | | | | | |
| DESCRIPTION | LOCATION | LOAD (WATTS) | C/B SIZE | POS. NO. | A | B | C | POS. NO. | C/B SIZE | LOAD (WATTS) | LOCATION | DESCRIPTION | |
| LTG-1ST FLOOR | CORR | 2750 | 20A/1P | 1 | * | | | 2 | 20A/1P | 2600 | ATR CORR | LTG-3RD FLOOR | |
| EXIT SIGNS | 1ST FL | 300 | 20A/1P | 3 | | * | | 4 | 20A/1P | 300 | 3RD FL | EXIT SIGNS | |
| LTG-ALCOVE | 1ST FL | 200 | 20A/1P | 5 | | | * | 6 | 20A/1P | 2449 | 2ND FL | LTG-CORR | |
| LTG-CORR | 1ST FL | 114 | 20A/1P | 7 | * | | | 8 | 20A/1P | 300 | 2ND FL | EXIT SIGNS | |
| LTG-GRNDS | Exterior | 577 | 20A/1P | 9 | | * | | 10 | 20A/1P | 0 | | SPARE | |
| SPARE | | 0 | 20A/1P | 11 | | | * | 12 | 20A/1P | 0 | | SPARE | |
| SPARE | | 0 | 20A/1P | 13 | * | | | 14 | 20A/1P | 0 | | SPARE | |
| SPACE | | 0 | 20A/1P | 15 | | * | | 16 | 20A/1P | 0 | | SPACE | |
| SPACE | | 0 | 20A/1P | 17 | | | * | 18 | 20A/1P | 0 | | SPACE | |
| SPACE | | 0 | 20A/1P | 19 | * | | | 20 | 20A/1P | 0 | | SPACE | |
| SPACE | | 0 | 20A/1P | 21 | | * | | 22 | 20A/1P | 0 | | SPACE | |
| SPACE | | 0 | 20A/1P | 23 | | | * | 24 | 20A/1P | 0 | | SPACE | |
| SPACE | | 0 | 20A/1P | 25 | * | | | 26 | 20A/1P | 0 | | SPACE | |
| SPACE | | 0 | 20A/1P | 27 | | * | | 28 | 20A/1P | 0 | | SPACE | |
| SPACE | | 0 | 20A/1P | 29 | | | * | 30 | 20A/1P | 0 | | SPACE | |
| SPACE | | 0 | 20A/1P | 31 | * | | | 32 | 20A/1P | 1100 | FUTURE | PHASE 2 LTG | |
| SPACE | | 0 | 20A/1P | 33 | | * | | 34 | 20A/1P | 1100 | FUTURE | PHASE 2 LTG | |
| SPACE | | 0 | 20A/1P | 35 | | | * | 36 | 20A/1P | 1100 | FUTURE | PHASE 2 LTG | |
| 2LEL1 | - | 3800 | 60A/3P | 37 | * | | | 38 | 20A/1P | 1100 | FUTURE | PHASE 2 LTG | |
| - | - | 6200 | - | 39 | | * | | 40 | 20A/1P | 1100 | FUTURE | PHASE 2 LTG | |
| - | - | 5300 | - | 41 | | | * | 42 | 20A/1P | 1100 | FUTURE | PHASE 2 LTG | |
| CONNECTED LOAD (KW) - A Ph. | | 11.76 | | | | | | | | | TOTAL DESIGN LOAD (KW) | | 44.14 |
| CONNECTED LOAD (KW) - B Ph. | | 9.58 | | | | | | | | | POWER FACTOR | | 0.90 |
| CONNECTED LOAD (KW) - C Ph. | | 10.15 | | | | | | | | | TOTAL DESIGN LOAD (AMPS) | | 59 |

| PANELBOARD SIZING WORKSHEET | | | | | | | | | | |
|--|-----|-----------------------|------|-----------|-----------------|-------|--------|--------------|------|------------|
| Panel Tag-----> | | | | 2LEH1 | Panel Location: | | | SECOND FLOOR | | |
| Nominal Phase to Neutral Voltage-----> | | | | 277 | Phase: | | | 3 | | |
| Nominal Phase to Phase Voltage-----> | | | | 480 | Wires: | | | 4 | | |
| Pos | Ph. | Load Type | Cat. | Location | Load | Units | I. PF | Watts | VA | Remarks |
| 1 | A | LTG-1ST FLOOR | 3 | CORR | 2750 | w | 0.90 | 2750 | 3056 | |
| 2 | A | LTG-3RD FLOOR | 3 | ATR CORR | 2600 | w | 0.90 | 2600 | 2889 | |
| 3 | B | EXIT SIGNS | 9 | 1ST FL | 300 | w | 0.90 | 300 | 333 | |
| 4 | B | EXIT SIGNS | 9 | 3RD FL | 300 | w | 0.90 | 300 | 333 | |
| 5 | C | LTG-ALCOVE | 3 | 1ST FL | 200 | w | 0.90 | 200 | 222 | |
| 6 | C | LTG-CORR | 3 | 2ND FL | 2449 | w | 0.90 | 2449 | 2721 | |
| 7 | A | LTG-CORR | 3 | 1ST FL | 114 | w | 0.90 | 114 | 127 | |
| 8 | A | EXIT SIGNS | 9 | 2ND FL | 300 | w | 0.90 | 300 | 333 | |
| 9 | B | LTG-GRNDS | 3 | Exterior | 577 | w | 0.90 | 577 | 641 | |
| 10 | B | SPARE | | | 0 | w | 0.90 | 0 | 0 | |
| 11 | C | SPARE | | | 0 | w | 0.90 | 0 | 0 | |
| 12 | C | SPARE | | | 0 | w | 0.90 | 0 | 0 | |
| 13 | A | SPARE | | | 0 | w | 0.90 | 0 | 0 | |
| 14 | A | SPARE | | | 0 | w | 0.90 | 0 | 0 | |
| 15 | B | SPACE | | | 0 | w | 0.90 | 0 | 0 | |
| 16 | B | SPACE | | | 0 | w | 0.90 | 0 | 0 | |
| 17 | C | SPACE | | | 0 | w | 0.90 | 0 | 0 | |
| 18 | C | SPACE | | | 0 | w | 0.90 | 0 | 0 | |
| 19 | A | SPACE | | | 0 | w | 0.90 | 0 | 0 | |
| 20 | A | SPACE | | | 0 | w | 0.90 | 0 | 0 | |
| 21 | B | SPACE | | | 0 | w | 0.90 | 0 | 0 | |
| 22 | B | SPACE | | | 0 | w | 0.90 | 0 | 0 | |
| 23 | C | SPACE | | | 0 | w | 0.90 | 0 | 0 | |
| 24 | C | SPACE | | | 0 | w | 0.90 | 0 | 0 | |
| 25 | A | SPACE | | | 0 | w | 0.90 | 0 | 0 | |
| 26 | A | SPACE | | | 0 | w | 0.90 | 0 | 0 | |
| 27 | B | SPACE | | | 0 | w | 0.90 | 0 | 0 | |
| 28 | B | SPACE | | | 0 | w | 0.90 | 0 | 0 | |
| 29 | C | SPACE | | | 0 | w | 0.90 | 0 | 0 | |
| 30 | C | SPACE | | | 0 | w | 0.90 | 0 | 0 | |
| 31 | A | SPACE | | | 0 | w | 0.90 | 0 | 0 | |
| 32 | A | PHASE 2 LTG | 3 | FUTURE | 1100 | w | 0.90 | 1100 | 1222 | |
| 33 | B | SPACE | | | 0 | w | 0.90 | 0 | 0 | |
| 34 | B | PHASE 2 LTG | 3 | FUTURE | 1100 | w | 0.90 | 1100 | 1222 | |
| 35 | C | SPACE | | | 0 | w | 0.90 | 0 | 0 | |
| 36 | C | PHASE 2 LTG | 3 | FUTURE | 1100 | w | 0.90 | 1100 | 1222 | |
| 37 | A | 2LEL1 | 1 | - | 3800 | w | 0.90 | 3800 | 4222 | |
| 38 | A | PHASE 2 LTG | 3 | FUTURE | 1100 | w | 0.90 | 1100 | 1222 | |
| 39 | B | - | 1 | - | 6200 | w | 0.90 | 6200 | 6889 | |
| 40 | B | PHASE 2 LTG | 3 | FUTURE | 1100 | w | 0.90 | 1100 | 1222 | |
| 41 | C | - | 1 | - | 5300 | w | 0.90 | 5300 | 5889 | |
| 42 | C | PHASE 2 LTG | 3 | FUTURE | 1100 | w | 0.90 | 1100 | 1222 | |
| PANEL TOTAL | | | | | | | | 31.5 | 35.0 | Amps= 42.1 |
| PHASE LOADING | | | | | | | | | | |
| PHASE TOTAL | | | | | | | | A | | |
| PHASE TOTAL | | | | | | | | B | | |
| PHASE TOTAL | | | | | | | | C | | |
| LOAD CATAGORIES | | | | | | | | | | Ver. 104 |
| | | | | Connected | | | Demand | | | |
| | | | | kW | kVA | DF | kW | kVA | PF | |
| 1 | | receptacles | | 15.3 | 17.0 | 1.00 | 15.3 | 17.0 | 0.90 | |
| 2 | | computers | | 0.0 | 0.0 | | 0.0 | 0.0 | | |
| 3 | | fluorescent lighting | | 15.3 | 17.0 | 1.25 | 19.1 | 21.2 | 0.90 | |
| 4 | | HID lighting | | 0.0 | 0.0 | | 0.0 | 0.0 | | |
| 5 | | incandescent lighting | | 0.0 | 0.0 | | 0.0 | 0.0 | | |
| 6 | | HVAC fans | | 0.0 | 0.0 | | 0.0 | 0.0 | | |
| 7 | | heating | | 0.0 | 0.0 | | 0.0 | 0.0 | | |
| 8 | | kitchen equipment | | 0.0 | 0.0 | | 0.0 | 0.0 | | |
| 9 | | unassigned | | 0.9 | 1.0 | | 0.9 | 1.0 | 0.90 | |
| Total Demand Loads | | | | | | | 35.3 | 39.2 | | |
| Spare Capacity | | | | | 25% | | 8.8 | 9.8 | | |
| Total Design Loads | | | | | | | 44.1 | 49.0 | 0.90 | Amps= 59.0 |

| | |
|-------------------------|-------|
| Default Power Factor = | 0.90 |
| Default Demand Factor = | 100 % |

2LEH1

Sizing Feeder

| | |
|-----------------|------------------------------------|
| Spares | 35 (# of Spares*Breaker Size*0.25) |
| Design Ampacity | 59 |
| Total | 94 |

OCPD 125

| | |
|--------------------------------|---------|
| Sets | 1 |
| Wire Size | |
| Phase | 1 |
| Neutral | 1 |
| "Table 250.122" Ground | 6 |
| Wire Area (table 5, sq. in.) | |
| Each Phase | 0.1562 |
| Total -Phase Conductors | 0.4686 |
| Neutral | 0.1562 |
| Ground | 0.0507 |
| Total Area | 0.6755 |
| Min. Conduit Area (above *2.5) | 1.68875 |
| Conduit Size (table 4) | 1.5" |
| Conduit Size (table C.2) | 1.5" |
| Remarks | |

| PANELBOARD SCHEDULE | | | | | | | | | | | | |
|-----------------------------|------------|--------------|-------------------------------|----------|---|---|-------------------|----------|----------|--------------|--------------------------|-------------|
| VOLTAGE: 480Y/208V,3PH,4W | | | PANEL TAG: 2LNH1 | | | | MIN. C/B AIC: 25K | | | | | |
| SIZE/TYPE BUS: 225A | | | PANEL LOCATION: ELEC. RM. 227 | | | | OPTIONS: | | | | | |
| SIZE/TYPE MAIN: 200A/3P C/B | | | PANEL MOUNTING: SURFACE | | | | | | | | | |
| DESCRIPTION | LOCATION | LOAD (WATTS) | C/B SIZE | POS. NO. | A | B | C | POS. NO. | C/B SIZE | LOAD (WATTS) | LOCATION | DESCRIPTION |
| LTG-2nd Floor | Classrooms | 2900 | 20A/1P | 1 | * | | | 2 | 20A/1P | 0 | | SPARE |
| LTG-2nd Floor | Classrooms | 3300 | 20A/1P | 3 | | * | | 4 | 20A/1P | 0 | | SPARE |
| LTG-2nd Floor | Corridors | 3000 | 20A/1P | 5 | | | * | 6 | 20A/1P | 0 | | SPARE |
| LTG-2nd Floor | Atrium | 600 | 20A/1P | 7 | * | | | 8 | 20A/1P | 0 | | SPARE |
| LTG-2nd Floor | Classrooms | 3300 | 20A/1P | 9 | | * | | 10 | 20A/1P | 0 | | SPARE |
| LTG-2nd Floor | Classrooms | 2500 | 20A/1P | 11 | | | * | 12 | 20A/1P | 0 | | SPARE |
| SPACE | | 0 | 20A/1P | 13 | * | | | 14 | 20A/1P | 0 | | SPARE |
| SPACE | | 0 | 20A/1P | 15 | | * | | 16 | 20A/1P | 0 | | SPARE |
| SPACE | | 0 | 20A/1P | 17 | | | * | 18 | 20A/1P | 0 | | SPARE |
| SPACE | | 0 | 20A/1P | 19 | * | | | 20 | 20A/1P | 0 | | SPARE |
| SPACE | | 0 | 20A/1P | 21 | | * | | 22 | 20A/1P | 0 | | SPARE |
| SPACE | | 0 | 20A/1P | 23 | | | * | 24 | 20A/1P | 0 | | SPARE |
| SPACE | | 0 | 20A/1P | 25 | * | | | 26 | 20A/1P | 0 | | SPARE |
| SPACE | | 0 | 20A/1P | 27 | | * | | 28 | 20A/1P | 3400 | PHASE 2 | LTG |
| SPACE | | 0 | 20A/1P | 29 | | | * | 30 | 20A/1P | 3400 | PHASE 2 | LTG |
| SPACE | | 0 | 20A/1P | 31 | * | | | 32 | 20A/1P | 3400 | PHASE 2 | LTG |
| SPACE | | 0 | 20A/1P | 33 | | * | | 34 | 20A/1P | 3400 | PHASE 2 | LTG |
| SPACE | | 0 | 20A/1P | 35 | | | * | 36 | 20A/1P | 3400 | PHASE 2 | LTG |
| SPACE | | 0 | 20A/1P | 37 | * | | | 38 | 20A/1P | 3400 | PHASE 2 | LTG |
| SPACE | | 0 | 20A/1P | 39 | | * | | 40 | 20A/1P | 3400 | PHASE 2 | LTG |
| SPACE | | 0 | 20A/1P | 41 | | | * | 42 | 20A/1P | 3400 | PHASE 2 | LTG |
| CONNECTED LOAD (KW) - A Ph. | | 10.30 | | | | | | | | | TOTAL DESIGN LOAD (KW) | 66.88 |
| CONNECTED LOAD (KW) - B Ph. | | 16.80 | | | | | | | | | POWER FACTOR | 0.90 |
| CONNECTED LOAD (KW) - C Ph. | | 15.70 | | | | | | | | | TOTAL DESIGN LOAD (AMPS) | 89 |

| PANELBOARD SIZING WORKSHEET | | | | | | | | | | | | | | |
|--|-----|-----------------------|------|------------|-----------------|-------|-------|---------------|------|------------|------|----------|------|------------|
| Panel Tag-----> | | | | 2LNH1 | Panel Location: | | | ELEC. RM. 227 | | | | | | |
| Nominal Phase to Neutral Voltage-----> | | | | 277 | Phase: | | | 3 | | | | | | |
| Nominal Phase to Phase Voltage-----> | | | | 480 | Wires: | | | 4 | | | | | | |
| Pos | Ph. | Load Type | Cat. | Location | Load | Units | I. PF | Watts | VA | Remarks | | | | |
| 1 | A | LTG-2nd Floor | 3 | Classrooms | 2900 | w | | 2900 | 3222 | | | | | |
| 2 | A | SPARE | | | 0 | w | | 0 | 0 | | | | | |
| 3 | B | LTG-2nd Floor | 3 | Classrooms | 3300 | w | | 3300 | 3667 | | | | | |
| 4 | B | SPARE | | | 0 | w | | 0 | 0 | | | | | |
| 5 | C | LTG-2nd Floor | 3 | Corridors | 3000 | w | | 3000 | 3333 | | | | | |
| 6 | C | SPARE | | | 0 | w | | 0 | 0 | | | | | |
| 7 | A | LTG-2nd Floor | 3 | Atrium | 600 | w | | 600 | 667 | | | | | |
| 8 | A | SPARE | | | 0 | w | | 0 | 0 | | | | | |
| 9 | B | LTG-2nd Floor | 3 | Classrooms | 3300 | w | | 3300 | 3667 | | | | | |
| 10 | B | SPARE | | | 0 | w | | 0 | 0 | | | | | |
| 11 | C | LTG-2nd Floor | 3 | Classrooms | 2500 | w | | 2500 | 2778 | | | | | |
| 12 | C | SPARE | | | 0 | w | | 0 | 0 | | | | | |
| 13 | A | SPACE | | | 0 | w | | 0 | 0 | | | | | |
| 14 | A | SPACE | | | 0 | w | | 0 | 0 | | | | | |
| 15 | B | SPACE | | | 0 | w | | 0 | 0 | | | | | |
| 16 | B | SPACE | | | 0 | w | | 0 | 0 | | | | | |
| 17 | C | SPACE | | | 0 | w | | 0 | 0 | | | | | |
| 18 | C | SPACE | | | 0 | w | | 0 | 0 | | | | | |
| 19 | A | SPACE | | | 0 | w | | 0 | 0 | | | | | |
| 20 | A | SPACE | | | 0 | w | | 0 | 0 | | | | | |
| 21 | B | SPACE | | | 0 | w | | 0 | 0 | | | | | |
| 22 | B | SPACE | | | 0 | w | | 0 | 0 | | | | | |
| 23 | C | SPACE | | | 0 | w | | 0 | 0 | | | | | |
| 24 | C | SPACE | | | 0 | w | | 0 | 0 | | | | | |
| 25 | A | SPACE | | | 0 | w | | 0 | 0 | | | | | |
| 26 | A | SPACE | | | 0 | w | | 0 | 0 | | | | | |
| 27 | B | SPACE | | | 0 | w | | 0 | 0 | | | | | |
| 28 | B | LTG | 3 | PHASE 2 | 3400 | w | | 3400 | 3778 | | | | | |
| 29 | C | SPACE | | | 0 | w | | 0 | 0 | | | | | |
| 30 | C | LTG | 3 | PHASE 2 | 3400 | w | | 3400 | 3778 | | | | | |
| 31 | A | SPACE | | | 0 | w | | 0 | 0 | | | | | |
| 32 | A | LTG | 3 | PHASE 2 | 3400 | w | | 3400 | 3778 | | | | | |
| 33 | B | SPACE | | | 0 | w | | 0 | 0 | | | | | |
| 34 | B | LTG | 3 | PHASE 2 | 3400 | w | | 3400 | 3778 | | | | | |
| 35 | C | SPACE | | | 0 | w | | 0 | 0 | | | | | |
| 36 | C | LTG | 3 | PHASE 2 | 3400 | w | | 3400 | 3778 | | | | | |
| 37 | A | SPACE | | | 0 | w | | 0 | 0 | | | | | |
| 38 | A | LTG | 3 | PHASE 2 | 3400 | w | | 3400 | 3778 | | | | | |
| 39 | B | SPACE | | | 0 | w | | 0 | 0 | | | | | |
| 40 | B | LTG | 3 | PHASE 2 | 3400 | w | | 3400 | 3778 | | | | | |
| 41 | C | SPACE | | | 0 | w | | 0 | 0 | | | | | |
| 42 | C | LTG | 3 | PHASE 2 | 3400 | w | | 3400 | 3778 | | | | | |
| PANEL TOTAL | | | | | | | | 42.8 | 47.6 | Amps= 57.2 | | | | |
| PHASE LOADING | | | | | | | | kW | kVA | % | Amps | | | |
| PHASE TOTAL | | | | | | | A | | | | | | | |
| PHASE TOTAL | | | | | | | B | 10.3 | 11.4 | 24% | 41.3 | | | |
| PHASE TOTAL | | | | | | | C | 16.8 | 18.7 | 40% | 67.4 | | | |
| PHASE TOTAL | | | | | | | | 15.7 | 17.1 | 36% | 61.6 | | | |
| LOAD CATAGORIES | | | | | | | | Connected | | Demand | | Ver. 104 | | |
| | | | | | | | kW | kVA | DF | kW | kVA | PF | | |
| 1 | | receptacles | | | | | 0.0 | 0.0 | | 0.0 | 0.0 | | | |
| 2 | | computers | | | | | 0.0 | 0.0 | | 0.0 | 0.0 | | | |
| 3 | | fluorescent lighting | | | | 1.25 | 42.8 | 47.6 | | 53.5 | 59.4 | 0.90 | | |
| 4 | | HID lighting | | | | | 0.0 | 0.0 | | 0.0 | 0.0 | | | |
| 5 | | incandescent lighting | | | | | 0.0 | 0.0 | | 0.0 | 0.0 | | | |
| 6 | | HVAC fans | | | | | 0.0 | 0.0 | | 0.0 | 0.0 | | | |
| 7 | | heating | | | | | 0.0 | 0.0 | | 0.0 | 0.0 | | | |
| 8 | | kitchen equipment | | | | | 0.0 | 0.0 | | 0.0 | 0.0 | | | |
| 9 | | unassigned | | | | | 0.0 | 0.0 | | 0.0 | 0.0 | | | |
| Total Demand Loads | | | | | | | | | | | 53.5 | 59.4 | | |
| Spare Capacity | | | | | | | | | | | 13.4 | 14.9 | | |
| Total Design Loads | | | | | | | | | | | 66.9 | 74.3 | 0.90 | Amps= 89.4 |
| Default Power Factor = | | | | | | | 0.90 | | | | | | | |
| Default Demand Factor = | | | | | | | 100 % | | | | | | | |

2LNH1

Sizing Feeder

| | |
|-----------------|------------------------------------|
| Spares | 65 (# of Spares*Breaker Size*0.25) |
| Design Ampacity | 89 |
| Total | 154 |

OCPD 200

| | |
|--------------------------------|---------|
| Sets | 1 |
| Wire Size | |
| Phase | 3/0 |
| Neutral | 3/0 |
| "Table 250.122" Ground | 6 |
| Wire Area (table 5, sq. in.) | |
| Each Phase | 0.2679 |
| Total -Phase Conductors | 0.8037 |
| Neutral | 0.2679 |
| Ground | 0.0507 |
| Total Area | 1.1223 |
| Min. Conduit Area (above *2.5) | 2.80575 |
| Conduit Size (table 4) | 2" |
| Conduit Size (table C.2) | 2" |
| Remarks | |

| PANELBOARD SCHEDULE | | | | | | | | | | | | |
|-----------------------------|------------|--------------|-------------------------------|----------|---|---|---|-------------------|----------|--------------|--------------------------|-------------|
| VOLTAGE: 480Y/277V,3PH,4W | | | PANEL TAG: 1LNH1 | | | | | MIN. C/B AIC: 10K | | | | |
| SIZE/TYPE BUS: 225A | | | PANEL LOCATION: ELEC. RM. 125 | | | | | OPTIONS: | | | | |
| SIZE/TYPE MAIN: 200A/3P C/B | | | PANEL MOUNTING: SURFACE | | | | | | | | | |
| DESCRIPTION | LOCATION | LOAD (WATTS) | C/B SIZE | POS. NO. | A | B | C | POS. NO. | C/B SIZE | LOAD (WATTS) | LOCATION | DESCRIPTION |
| LTG-1st Floor | Classrms | 1400 | 20A/1P | 1 | * | | | 2 | 20A/1P | 400 | | AC-1 |
| LTG-1st Floor | Classrms | 3300 | 20A/1P | 3 | | * | | 4 | 20A/1P | 400 | 0 | AC-1 |
| LTG-1st Floor | Classrms | 2700 | 20A/1P | 5 | | | * | 6 | 20A/1P | 400 | 0 | AC-1 |
| LTG-1st Floor | Atrium | 2901 | 20A/1P | 7 | * | | | 8 | 20A/1P | 0 | | SPARE |
| LTG-1st Floor | Classrooms | 3400 | 20A/1P | 9 | | * | | 10 | 20A/1P | 0 | | SPARE |
| LTG-1st Floor | Corridors | 1800 | 20A/1P | 11 | | | * | 12 | 20A/1P | 0 | | SPARE |
| LTG-1st Floor | Classrooms | 3100 | 20A/1P | 13 | * | | | 14 | 20A/1P | 0 | | SPARE |
| SPACE | | 0 | 20A/1P | 15 | | * | | 16 | 20A/1P | 0 | | SPARE |
| SPACE | | 0 | 20A/1P | 17 | | | * | 18 | 20A/1P | 0 | | SPARE |
| SPACE | | 0 | 20A/1P | 19 | * | | | 20 | 20A/1P | 3600 | Phase-2 | LTG |
| SPACE | | 0 | 20A/1P | 21 | | * | | 22 | 20A/1P | 3600 | Phase-2 | LTG |
| SPACE | | 0 | 20A/1P | 23 | | | * | 24 | 20A/1P | 3600 | Phase-2 | LTG |
| SPACE | | 0 | 20A/1P | 25 | * | | | 26 | 20A/1P | 3600 | Phase-2 | LTG |
| SPACE | | 0 | 20A/1P | 27 | | * | | 28 | 20A/1P | 3600 | Phase-2 | LTG |
| SPACE | | 0 | 20A/1P | 29 | | | * | 30 | 20A/1P | 3600 | Phase-2 | LTG |
| SPACE | | 0 | 20A/1P | 31 | * | | | 32 | 20A/1P | 3600 | Phase-2 | LTG |
| SPACE | | 0 | 20A/1P | 33 | | * | | 34 | 20A/1P | 3600 | Phase-2 | LTG |
| SPACE | | 0 | 20A/1P | 35 | | | * | 36 | 20A/1P | 3600 | Phase-2 | LTG |
| SPACE | | 0 | 20A/1P | 37 | * | | | 38 | 20A/1P | 3600 | Phase-2 | LTG |
| SPACE | | 0 | 20A/1P | 39 | | * | | 40 | 20A/1P | 3600 | Phase-2 | LTG |
| SPACE | | 0 | 20A/1P | 41 | | | * | 42 | 20A/1P | 3600 | Phase-2 | LTG |
| CONNECTED LOAD (KW) - A Ph. | | 22.20 | | | | | | | | | TOTAL DESIGN LOAD (KW) | 97.76 |
| CONNECTED LOAD (KW) - B Ph. | | 21.50 | | | | | | | | | POWER FACTOR | 0.90 |
| CONNECTED LOAD (KW) - C Ph. | | 19.30 | | | | | | | | | TOTAL DESIGN LOAD (AMPS) | 131 |

| PANELBOARD SIZING WORKSHEET | | | | | | | | | | | | | |
|--|-----------------------|---------------|------|------------|-----------------|-------|-------|---------------|------|------------|-------|----------|------|
| Panel Tag-----> | | | | 1LNH1 | Panel Location: | | | ELEC. RM. 125 | | | | | |
| Nominal Phase to Neutral Voltage-----> | | | | 277 | Phase: | | | 3 | | | | | |
| Nominal Phase to Phase Voltage-----> | | | | 480 | Wires: | | | 4 | | | | | |
| Pos | Ph. | Load Type | Cat. | Location | Load | Units | I. PF | Watts | VA | Remarks | | | |
| 1 | A | LTG-1st Floor | 3 | Classrms | 1400 | w | | 1400 | 1556 | | | | |
| 2 | A | AC-1 | 6 | | 400 | w | | 400 | 444 | | | | |
| 3 | B | LTG-1st Floor | 3 | Classrms | 3300 | w | | 3300 | 3667 | | | | |
| 4 | B | AC-1 | 6 | | 400 | w | | 400 | 444 | | | | |
| 5 | C | LTG-1st Floor | 3 | Classrms | 2700 | w | | 2700 | 3000 | | | | |
| 6 | C | AC-1 | 6 | | 400 | w | | 400 | 444 | | | | |
| 7 | A | LTG-1st Floor | 3 | Atrium | 2901 | w | | 2901 | 3223 | | | | |
| 8 | A | SPARE | | | 0 | w | | 0 | 0 | | | | |
| 9 | B | LTG-1st Floor | 3 | Classrooms | 3400 | w | | 3400 | 3778 | | | | |
| 10 | B | SPARE | | | 0 | w | | 0 | 0 | | | | |
| 11 | C | LTG-1st Floor | 3 | Corridors | 1800 | w | | 1800 | 2000 | | | | |
| 12 | C | SPARE | | | 0 | w | | 0 | 0 | | | | |
| 13 | A | LTG-1st Floor | 3 | Classrooms | 3100 | w | | 3100 | 3444 | | | | |
| 14 | A | SPARE | | | 0 | w | | 0 | 0 | | | | |
| 15 | B | SPACE | | | 0 | w | | 0 | 0 | | | | |
| 16 | B | SPARE | | | 0 | w | | 0 | 0 | | | | |
| 17 | C | SPACE | | | 0 | w | | 0 | 0 | | | | |
| 18 | C | SPARE | | | 0 | w | | 0 | 0 | | | | |
| 19 | A | SPACE | | | 0 | w | | 0 | 0 | | | | |
| 20 | A | LTG | 3 | Phase-2 | 3600 | w | | 3600 | 4000 | | | | |
| 21 | B | SPACE | | | 0 | w | | 0 | 0 | | | | |
| 22 | B | LTG | 3 | Phase-2 | 3600 | w | | 3600 | 4000 | | | | |
| 23 | C | SPACE | | | 0 | w | | 0 | 0 | | | | |
| 24 | C | LTG | 3 | Phase-2 | 3600 | w | | 3600 | 4000 | | | | |
| 25 | A | SPACE | | | 0 | w | | 0 | 0 | | | | |
| 26 | A | LTG | 3 | Phase-2 | 3600 | w | | 3600 | 4000 | | | | |
| 27 | B | SPACE | | | 0 | w | | 0 | 0 | | | | |
| 28 | B | LTG | 3 | Phase-2 | 3600 | w | | 3600 | 4000 | | | | |
| 29 | C | SPACE | | | 0 | w | | 0 | 0 | | | | |
| 30 | C | LTG | 3 | Phase-2 | 3600 | w | | 3600 | 4000 | | | | |
| 31 | A | SPACE | | | 0 | w | | 0 | 0 | | | | |
| 32 | A | LTG | 3 | Phase-2 | 3600 | w | | 3600 | 4000 | | | | |
| 33 | B | SPACE | | | 0 | w | | 0 | 0 | | | | |
| 34 | B | LTG | 3 | Phase-2 | 3600 | w | | 3600 | 4000 | | | | |
| 35 | C | SPACE | | | 0 | w | | 0 | 0 | | | | |
| 36 | C | LTG | 3 | Phase-2 | 3600 | w | | 3600 | 4000 | | | | |
| 37 | A | SPACE | | | 0 | w | | 0 | 0 | | | | |
| 38 | A | LTG | 3 | Phase-2 | 3600 | w | | 3600 | 4000 | | | | |
| 39 | B | SPACE | | | 0 | w | | 0 | 0 | | | | |
| 40 | B | LTG | 3 | Phase-2 | 3600 | w | | 3600 | 4000 | | | | |
| 41 | C | SPACE | | | 0 | w | | 0 | 0 | | | | |
| 42 | C | LTG | 3 | Phase-2 | 3600 | w | | 3600 | 4000 | | | | |
| PANEL TOTAL | | | | | | | | 63.0 | 70.0 | Amps= 84.2 | | | |
| PHASE LOADING | | | | | | | | | | | | | |
| PHASE TOTAL | | | | | | | | A | | | | | |
| | | | | | | | | | | | | | |
| PHASE TOTAL | | | | | | | | B | | | | | |
| | | | | | | | | | | | | | |
| PHASE TOTAL | | | | | | | | C | | | | | |
| | | | | | | | | | | | | | |
| LOAD CATAGORIES | | | | | | | | Connected | | Demand | | Ver. 104 | |
| | | | | | | | | kW | kVA | DF | kW | kVA | PF |
| 1 | receptacles | | | | | | | 0.0 | 0.0 | 1.00 | 0.0 | 0.0 | |
| 2 | computers | | | | | | | 0.0 | 0.0 | | 0.0 | 0.0 | |
| 3 | fluorescent lighting | | | | | | | 61.8 | 68.7 | 1.25 | 77.3 | 85.8 | 0.90 |
| 4 | HID lighting | | | | | | | 0.0 | 0.0 | | 0.0 | 0.0 | |
| 5 | incandescent lighting | | | | | | | 0.0 | 0.0 | | 0.0 | 0.0 | |
| 6 | HVAC fans | | | | | | | 1.2 | 1.3 | 0.80 | 1.0 | 1.1 | 0.90 |
| 7 | heating | | | | | | | 0.0 | 0.0 | | 0.0 | 0.0 | |
| 8 | kitchen equipment | | | | | | | 0.0 | 0.0 | | 0.0 | 0.0 | |
| 9 | unassigned | | | | | | | 0.0 | 0.0 | | 0.0 | 0.0 | |
| Total Demand Loads | | | | | | | | | | | 78.2 | 86.9 | |
| Spare Capacity | | | | | | | | 25% | | | 19.6 | 21.7 | |
| Total Design Loads | | | | | | | | | | | 97.8 | 108.6 | 0.90 |
| | | | | | | | | | | | Amps= | 130.7 | |
| Default Power Factor = | | | | | | | | 0.90 | | | | | |
| Default Demand Factor = | | | | | | | | 100 % | | | | | |

1LNH1

Sizing Feeder



| | | |
|-----------------|-----|-------------------------------------|
| Spares | 30 | (# of Spares * Breaker Size * 0.25) |
| Design Ampacity | 131 | |
| Total | 161 | |
| <hr/> | | |
| OCPD | 200 | |

| | |
|--------------------------------|---------|
| Sets | 1 |
| Wire Size | |
| Phase | 3/0 |
| Neutral | 3/0 |
| "Table 250.122" Ground | 6 |
| Wire Area (table 5, sq. in.) | |
| Each Phase | 0.2679 |
| Total -Phase Conductors | 0.8037 |
| Neutral | 0.2679 |
| Ground | 0.0507 |
| Total Area | 1.1223 |
| Min. Conduit Area (above *2.5) | 2.80575 |
| Conduit Size (table 4) | 2" |
| Conduit Size (table C.2) | 2" |
| | |
| Remarks | |

DEPTH TOPIC 1: MCC DESIGN

Depth Topic One includes the design and layout of a MCC (motor controller center) for the penthouse mechanical equipment as a substitute to the existing switchboard, SWBDN-P. A motor controller center design was initially proposed due to the extent of motors and mechanical equipment that are located in the penthouse. This study seeks to determine whether such a piece of equipment would be a better substitute for the existing configuration and switchboard. All equipment for the basis of the design is specified from the Allen-Bradley Centerline 2100 product series.

Images of the existing power plan and layout for the mechanical penthouse are shown in Figures 11 and 12.



FIGURES 22 + 23 – MECHANICAL PENTHOUSE POWER PLAN

The first step in this design process was to determine which loads would be housed within the MCC. First, the loads for all the mechanical equipment fed from the switchboard were calculated. Calculations provided a total motor load of 2867.9 A, with the largest motor load (the 700 Ton Chiller) being counted as 125% in accordance with the NEC. The existing switchboard has a 3000 A bus and if it were to be directly interchanged with a MCC that housed the same over current protective devices in addition to the starters for the equipment (highlighted in green in the table below), the MCC would also need a 3000A incoming feeder. The only manufacturer that could be found to regularly provide an incoming feeder bus of this size was Rockwell Automation through their Centerline MCC design. Due to the configuration of the horizontal bus, the sections have the capability to provide 300 A or 600 A above or below the horizontal bus, for a maximum 600 A or 1200 A in one section.

As a result of the design, panelboards PPNH1 and PPNH2 were removed. Their loads were primarily the mechanical motors which have been fed directly through the MCC. The remaining lighting panels in the penthouse are fed through three units: one feeder circuit breaker and two transformer units.

TABLE 13 – MCC MOTOR LOAD CALCULATIONS

| EQUIPMENT TAG | LOAD DESCRIPTION | LOAD MAGNITUDE | MECHANICAL EQUIPMENT | | | ASSUMED POWER FACTOR | LOAD IN KVA | LOAD IN KW | |
|---|-----------------------------|----------------|----------------------|------------|----------|----------------------|-------------------|---------------|-------|
| | | | LOAD UNITS | MOTOR AMPS | VOLTAGE | | | | PHASE |
| E1 | AHU 5-1 | 15 | HP | 46.2 | 208 | 3 | 0.95 | 11.8 | 11.19 |
| E2 | EXHAUST FAN EF-1 | 10 | HP | 30.8 | 208 | 3 | 0.95 | 7.85 | 7.46 |
| E3 | EXHAUST FAN EF-2 | 10 | HP | 30.8 | 208 | 3 | 0.95 | 7.85 | 7.46 |
| E4 | EXHAUST FAN EF-3 | 1 | HP | 4.6 | 208 | 3 | 0.85 | 0.88 | 0.75 |
| E5 | EXHAUST FAN EF-4 | 1/2 | HP | 2.4 | 208 | 3 | 0.85 | 0.44 | 0.37 |
| E7 | SUPPLY FAN EF-5 | 3/4 | HP | 3.5 | 208 | 3 | 0.85 | 0.66 | 0.56 |
| E10 | EXHAUST FAN EF-5 | 1 1/2 | HP | 6.6 | 208 | 3 | 0.85 | 1.32 | 1.12 |
| E13 | CONDENSATE PUMP 14A | 1 1/2 | HP | 6.6 | 208 | 3 | 0.85 | 1.32 | 1.12 |
| E14 | CONDENSATE PUMP 14B | 1 1/2 | HP | 6.6 | 208 | 3 | 0.85 | 1.32 | 1.12 |
| E15 | CONDENSATE PUMP 16A | 3/4 | HP | 3.5 | 208 | 3 | 0.85 | 0.66 | 0.56 |
| E16 | CONDENSATE PUMP 16B | 3/4 | HP | 3.5 | 208 | 3 | 0.85 | 0.66 | 0.56 |
| E17 | AHU-1 | 10 | HP | 30.8 | 208 | 3 | 0.95 | 7.85 | 7.46 |
| E20 | RETURN FAN-1 | 10 | HP | 30.8 | 208 | 3 | 0.95 | 7.85 | 7.46 |
| CRU-1 | CONDENSATE RETURN UNIT | 3/4 | HP | 3.50 | 480 | 3 | 0.85 | 0.66 | 0.56 |
| CRU-2 | CONDENSATE RETURN UNIT | 3/4 | HP | 3.50 | 480 | 3 | 0.85 | 0.66 | 0.56 |
| CRU-3 | CONDENSATE RETURN UNIT | 3/4 | HP | 3.50 | 480 | 3 | 0.85 | 0.66 | 0.56 |
| CRU-4 | CONDENSATE RETURN UNIT | 3/4 | HP | 3.50 | 480 | 3 | 0.85 | 0.66 | 0.56 |
| HWP-1 | HOT WATER PUMP | 75 | HP | 96.0 | 480 | 3 | 0.95 | 58.9 | 56.0 |
| HWP-2 | HOT WATER PUMP | 75 | HP | 96.0 | 480 | 3 | 0.95 | 58.9 | 56.0 |
| HRP-1 | HEAT RECOVERY PUMP | 40 | HP | 52.0 | 480 | 3 | 0.95 | 31.4 | 29.8 |
| HRP-2 | HEAT RECOVERY PUMP | 40 | HP | 52.0 | 480 | 3 | 0.95 | 31.4 | 29.8 |
| CT-1 | COOLING TOWER FAN | 40 | HP | 52.0 | 480 | 3 | 0.95 | 31.4 | 29.8 |
| CT-2 | COOLING TOWER FAN | 40 | HP | 52.0 | 480 | 3 | 0.95 | 31.4 | 29.8 |
| SH-1 | CT-1 SUMP HEATER | 9 | KW | - | 480 | 3 | 1.00 | 9.0 | 9.0 |
| SH-2 | CT-1 SUMP HEATER | 9 | KW | - | 480 | 3 | 1.00 | 9.0 | 9.0 |
| SH-3 | CT-2 SUMP HEATER | 9 | KW | - | 480 | 3 | 1.00 | 9.0 | 9.0 |
| SH-4 | CT-2 SUMP HEATER | 9 | KW | - | 480 | 3 | 1.00 | 9.0 | 9.0 |
| AHU-1 | AIR HANDLING UNIT | 75 | HP | 96.0 | 480 | 3 | 0.95 | 58.9 | 56.0 |
| AHU-2 | AIR HANDLING UNIT | 125 | HP | 156 | 480 | 3 | 0.95 | 98.2 | 93.3 |
| AHU-3 | AIR HANDLING UNIT | 125 | HP | 156 | 480 | 3 | 0.95 | 98.2 | 93.3 |
| AHU-4 | AIR HANDLING UNIT | 125 | HP | 156 | 480 | 3 | 0.95 | 98.2 | 93.3 |
| AHU-5 | AIR HANDLING UNIT | 10 | HP | 30.8 | 208 | 3 | 0.95 | 7.9 | 7.5 |
| AHU-6 | AIR HANDLING UNIT | 1 | HP | 4.6 | 208 | 3 | 0.85 | 0.9 | 0.7 |
| AHU-7 | AIR HANDLING UNIT | 1 | HP | 4.6 | 208 | 3 | 0.85 | 0.9 | 0.7 |
| RF-1 | INLINE RETURN FAN | 25 | HP | 34.0 | 480 | 3 | 0.95 | 19.6 | 18.7 |
| LEF-1 | STROBIC TYPE EXHAUST FAN | 100 | HP | 124.0 | 480 | 3 | 0.95 | 78.5 | 74.60 |
| LEF-2 | STROBIC TYPE EXHAUST FAN | 100 | HP | 124.0 | 480 | 3 | 0.95 | 78.5 | 74.60 |
| LEF-3 | STROBIC TYPE EXHAUST FAN | 100 | HP | 124.0 | 480 | 3 | 0.95 | 78.5 | 74.60 |
| LEF-4 | STROBIC TYPE EXHAUST FAN | 100 | HP | 124.0 | 480 | 3 | 0.95 | 78.5 | 74.60 |
| EF-1 | EXHAUST FAN | 1 | HP | 2.1 | 480 | 3 | 0.85 | 0.9 | 0.75 |
| EF-2 | EXHAUST FAN | 3 | HP | 4.8 | 480 | 3 | 0.85 | 2.63 | 2.24 |
| EF-3 | EXHAUST FAN | 2 | HP | 3.4 | 480 | 3 | 0.85 | 1.76 | 1.49 |
| EF-4 | EXHAUST FAN | 2 | HP | 3.4 | 480 | 3 | 0.85 | 1.76 | 1.49 |
| EF-5 | EXHAUST FAN | 3/4 | HP | 1.6 | 480 | 3 | 0.85 | 0.66 | 0.56 |
| EF-6 | EXHAUST FAN | 15 | HP | 21.0 | 480 | 3 | 0.95 | 11.8 | 11.2 |
| SEF-1 | SMOKE EVAC FAN | 30 | HP | 40.0 | 480 | 3 | 0.95 | 23.6 | 22.4 |
| SEF-2 | SMOKE EVAC FAN | 30 | HP | 40.0 | 480 | 3 | 0.95 | 23.6 | 22.38 |
| CH-1 | 700-TON CHILLER (.57KW/TON) | 404 | KW | - | 480 | 3 | 0.95 | 425.3 | 404 |
| CH-2 | 700-TON CHILLER (.57KW/TON) | 404 | KW | - | 480 | 3 | 0.95 | 425.3 | 404 |
| CWP-1 | CHILLED WATER PUMP | 40 | HP | 52.0 | 480 | 3 | 0.95 | 31.4 | 30 |
| CWP-2 | CHILLED WATER PUMP | 40 | HP | 52.0 | 480 | 3 | 0.95 | 31.4 | 30 |
| CLWP-1 | CONDENSER WATER PUMP | 75 | HP | 96.0 | 480 | 3 | 0.95 | 58.9 | 56 |
| CLWP-2 | CONDENSER WATER PUMP | 75 | HP | 96.0 | 480 | 3 | 0.95 | 58.9 | 56 |
| CWS-1 | CHILLED WATER SUPPLY | 150 | HP | 180.0 | 480 | 3 | 0.95 | 117.8 | 111.9 |
| CWS-2 | CHILLED WATER SUPPLY | 150 | HP | 180.0 | 480 | 3 | 0.95 | 117.8 | 111.9 |
| CR-1 | COLD ROOM | 10 | KW | - | 208 | 3 | 0.95 | 10.5 | 10.0 |
| CR-2 | COLD ROOM | 10 | KW | - | 208 | 3 | 0.95 | 10.5 | 10.0 |
| CR-3 | COLD ROOM | 10 | KW | - | 208 | 3 | 0.95 | 10.5 | 10.0 |
| CR-1A | COLD ROOM | 0.6 | KW | - | 120 | 1 | 0.9 | 0.67 | 0.60 |
| CR-2A | COLD ROOM | 0.6 | KW | - | 120 | 1 | 0.9 | 0.67 | 0.60 |
| CR-3A | COLD ROOM | 0.6 | KW | - | 120 | 1 | 0.9 | 0.67 | 0.60 |
| A/C-1A | MAIN TELECOM ROOM/A/C | 69.8 | FLA | - | 208 | 3 | 0.95 | 26.5 | 25.1 |
| A/C-1B | MAIN TELECOM ROOM/A/C | 69.8 | FLA | - | 208 | 3 | 0.95 | 26.5 | 25.1 |
| A/C-2 | NMR | 7.2 | FLA | - | 208 | 3 | 0.85 | 3.1 | 2.6 |
| A/C-3 | XRD | 7.2 | FLA | - | 208 | 3 | 0.85 | 3.1 | 2.6 |
| ACCU-1A | MAIN TELECOM ROOM/A/C | 4.8 | FLA | - | 208 | 3 | 0.85 | 2.0 | 1.7 |
| ACCU-1B | MAIN TELECOM ROOM/A/C | 4.8 | FLA | - | 208 | 3 | 0.85 | 2.0 | 1.7 |
| ACCU-2 | NMR | 11.4 | FLA | - | 208 | 3 | 0.85 | 4.8 | 4.1 |
| ACCU-3 | XRD | 11.4 | FLA | - | 208 | 3 | 0.85 | 4.8 | 4.1 |
| ACCU-4 | *SEE E7 | - | - | - | 208 | 3 | - | - | - |
| FIRE PUMP | FIRE PUMP | 40 | HP | 52.0 | 480 | 3 | 0.95 | 31.41 | 29.84 |
| JOCKY | JOCKY PUMP | 3 | HP | 4.8 | 480 | 3 | 0.85 | 2.63 | 2.24 |
| FOP-1 | FUEL OIL PUMPS | 1/2 | HP | 1.1 | 480 | 3 | 0.85 | 0.44 | 0.37 |
| FOP-2 | FUEL OIL PUMPS | 1/2 | HP | 1.1 | 480 | 3 | 0.85 | 0.44 | 0.37 |
| DI SYS A | DI WATER SYSTEM | 1 1/2 | HP | 3.0 | 480 | 3 | 0.85 | 1.32 | 1.12 |
| DBP-1 | DOMESTIC BOOSTER PUMP | 5 | HP | 7.6 | 480 | 3 | 0.9 | 4.14 | 3.73 |
| DBP-2 | DOMESTIC BOOSTER PUMP | 5 | HP | 7.6 | 480 | 3 | 0.9 | 4.14 | 3.73 |
| DSP-1 | DUPLEX SUMP PUMP | 1/2 | HP | 2.4 | 208 | 3 | 0.85 | 0.44 | 0.37 |
| DSP-2 | DUPLEX SUMP PUMP | 1/2 | HP | 2.4 | 208 | 3 | 0.85 | 0.44 | 0.37 |
| DSE-1 | DUPLEX SEWAGE EJECTOR | 2 | HP | 3.4 | 480 | 3 | 0.85 | 1.76 | 1.49 |
| DSE-2 | DUPLEX SEWAGE EJECTOR | 2 | HP | 3.4 | 480 | 3 | 0.85 | 1.76 | 1.49 |
| ACOM-1 | AIR COMPRESSOR | 15 | HP | 21.0 | 480 | 3 | 0.95 | 11.78 | 11.19 |
| | AIR COMPRESSOR | 15 | HP | 21.0 | 480 | 3 | 0.95 | 11.78 | 11.19 |
| VP-1 | VACUUM PUMP | 7 1/2 | HP | 11.0 | 480 | 3 | 0.95 | 5.89 | 5.60 |
| | VACUUM PUMP | 7 1/2 | HP | 11.0 | 480 | 3 | 0.95 | 5.89 | 5.60 |
| | VACUUM PUMP | 7 1/2 | HP | 11.0 | 480 | 3 | 0.95 | 5.89 | 5.60 |
| AWS-1 | AREA WAY SUMP PUMP | 1/2 | HP | 1.1 | 480 | 3 | 0.85 | 0.44 | 0.37 |
| AWS-2 | AREA WAY SUMP PUMP | 1/2 | HP | 1.1 | 480 | 3 | 0.85 | 0.44 | 0.37 |
| FDS-1 | FOUNDATION DRAIN SUMP | 1/2 | HP | 1.1 | 480 | 3 | 0.85 | 0.44 | 0.37 |
| FDS-2 | FOUNDATION DRAIN SUMP | 1/2 | HP | 1.1 | 480 | 3 | 0.85 | 0.44 | 0.37 |
| VAV 140 | VAV ELEC. COIL | 13.3 | KW | - | 208 | 3 | 1.00 | 13.3 | 13.30 |
| VAV 141 | VAV ELEC. COIL | 2.3 | KW | - | 208 | 3 | 1.00 | 2.3 | 2.30 |
| VAV 142 | VAV ELEC. COIL | 2.3 | KW | - | 208 | 3 | 1.00 | 2.3 | 2.30 |
| VAV 143 | VAV ELEC. COIL | 2.3 | KW | - | 208 | 3 | 1.00 | 2.3 | 2.30 |
| RAD-1 | REFRIGERATED AIR DRYER | 1.5 | HP | 3.0 | 480 | 3 | 0.85 | 1.3 | 1.12 |
| | | | | | | | TOTAL LOAD | 2449.2 | |
| NOTES: Existing equipment denoted by gray font. (e.g. AHU 5-1) | | | | | | | | | |
| | | | | Motor Load | 2867.4 A | | | | |

Proposed Design:

The following diagrams document the layout and equipment of the proposed MCC. With this configuration, the MCC is atypically large at a length of 35'. Though this is unusual, it would technically fit within the mechanical penthouse and still afford the clearance for NEC Condition 2 minimum clear distance for maintenance of 3'-6".




FIGURE 24 – MCC ELEVATION




FIGURE 25 – MCC ISOMETRIC

TABLE 14 – MCC SCHEDULE

| Motor Controller Center | | | | | | | | | | | | |
|-------------------------|---------------------------------|---------|-------|------------------------|------|--------|------------------|-----------|---------|--------------------|------------------|---------------------------------------|
| Section | Item Served | Load | | Overcurrent Protection | | | Motor Controller | | | Transformer kVA | †Space Factor | Catalog Number |
| | | HP | FLA | Phase | Amps | Device | Type | NEMA SIZE | Control | | | |
| 1 | Main Lugs/Incoming | | 3000 | 3 | 3000 | CB* | - | - | - | | 6 | 2191MB-MKC-60-88FNT |
| 2 | Sump Heater, SH-1 | - | - | 3 | 20 | CB | Packaged | 3R | - | | 0.5 | 2193FZ-AKC-32CB-79UT |
| 2 | Transformer, P-TN-1 | - | - | 3 | 50 | CB | - | - | 30 | | 3 | 2197-TKBH-36CB |
| 3 | Sump Heater, SH-2 | - | - | 3 | 20 | CB | Packaged | 3R | - | | 0.5 | 2193FZ-AKC-32CB-79UT |
| 3 | Air Compressor, ACOM-1 | (2) 15 | (2)21 | 3 | 60 | CB | Packaged | - | - | | 1 | 2193FZ-AKC-35CB-79UT |
| 3 | Transformer, P-TN-2 | - | - | 3 | 50 | CB | - | - | 30 | | 3 | 2197-TKBH-36CB |
| 4 | Cooling Tower Fan, CT-1 | 40 | 52 | 3 | 90 | CB | VSD | 1 | - | | 3 | 2163RA-052NKB-14HBA3-46CA-79UT |
| 4 | Sump Heater, SH-3 | - | - | 3 | 20 | CB | Packaged | 3R | - | | 0.5 | 2193FZ-AKC-32CB-79UT |
| 4 | Inline Return Fan, RF-1 | 25 | 34 | 3 | 70 | CB | VSD | - | - | | 2.5 | 2163RA-034NKB-14DA1D-14HBA3-44CA-79UT |
| 5 | Condenser Water Pump, CLWP-1 | 75 | 96 | 3 | 125 | MCP | ALC | 4 | H-O-A | | 2 | 2113B-EAB-6P-49CA-79UT |
| 5 | Cooling Tower Fan, CT-2 | 40 | 52 | 3 | 90 | CB | VSD | 1 | - | | 3 | 2163RA-052NKB-14HBA3-46CA-79UT |
| 5 | Sump Heater, SH-4 | - | - | 3 | 20 | CB | Packaged | 3R | - | | 0.5 | 2193FZ-AKC-32CB-79UT |
| 6 | Condenser Water Pump, CLWP-2 | 75 | 96 | 3 | 125 | MCP | ALC | 4 | H-O-A | | 2 | 2113B-EAB-6P-49CA-79UT |
| 6 | Refrigerated Air Dryer, RAD-1 | 1.5 | 3 | 3 | 15 | CB | Packaged | - | - | | 0.5 | 2193FZ-AKC-32CB-79UT |
| 6 | Vacuum Pump, VP-1 | (3) 7.5 | (3)11 | 3 | 50 | CB | Packaged | - | - | | 0.5 | 2193FZ-AKC-36CB-79UT |
| 7 | Bathroom Exhaust Fan, EF-1 | 1 | 2.1 | 3 | 15 | MCP | ALC | 1 | H-O-A | | 1 | 2113B-EAB-6P-35CA-79UT |
| 7 | Exhaust Fan, EF-2 | 3 | 4.8 | 3 | 15 | MCP | ALC | 1 | H-O-A | | 1 | 2113B-EAB-6P-38CA-79UT |
| 7 | Chilled Water Pump, CWP-1 | 40 | 52 | 3 | 90 | MCP | ALC | 3 | H-O-A | | 1.5 | 2113B-DAB-6P-46CA-79UT |
| 7 | Chilled Water Pump, CWP-2 | 40 | 52 | 3 | 90 | MCP | ALC | 3 | H-O-A | | 1.5 | 2113B-DAB-6P-46CA-79UT |
| 8 | Strobic Type Exhaust Fan, LEF-2 | 100 | 124 | 3 | 200 | CB | VSD | - | - | | 6 | 2163QA-***NKB-50CA |
| 9 | Strobic Type Exhaust Fan, LEF-3 | 100 | 124 | 3 | 200 | CB | VSD | - | - | | 6 | 2163QA-***NKB-50CA |
| 10 | LEF-4 (BACKUP) | 100 | 124 | 3 | 200 | CB | VSD | - | - | | 6 | 2163QA-***NKB-50CA |
| 11 | Chilled Water Supply, CWS-1 | 150 | 180 | 3 | 250 | CB | VSD | - | - | | 6 | 2163QA-***NKB-52CA |
| 12 | CWS-2 (BACKUP) | 150 | 180 | 3 | 250 | CB | VSD | - | - | | 6 | 2163QA-***NKB-52CA |
| 13 | Chiller 1, CH-1 | - | - | 3 | 1200 | CB | VSD | - | - | | 6 | 2163QA-***NKB-**CM |
| 14 | Chiller 2, CH-2 | - | - | 3 | 1200 | CB | VSD | - | - | | 6 | 2163QA-***NKB-**CM |
| 15 | Air Handling Unit, AHU-1 | 75 | 96 | 3 | 125 | CB | VSD | - | - | | 6 | 2163RA-096NKB-14DA1D-14HBA3-49CA |
| 16 | Air Handling Unit, AHU-3 | 125 | 156 | 3 | 225 | CB | VSD | - | - | | 6 | 2163RA-156NKB-14DA1D-14HBA3-51CA |
| 17 | Air Handling Unit, AHU-4 | 125 | 156 | 3 | 225 | CB | VSD | - | - | | 6 | 2163RA-156NKB-14DA1D-14HBA3-51CA |

NOTES: * Located in basement substation USSHV-B
 † Space Factor of 1 = 13", 2 = 26", etc.

This proposed design would most likely not be implemented since the MCC is so large and typically would be more expensive than switchboard units. Even if the two chillers and their VSDs were removed from the MCC, the overall length would only be reduced to 30'-4", which is not a significant savings in space or units. Though the feeder bus could be reduced from 3000A to 1400A or 1600A, separate sets of feeders would then need to be run to the two chiller VSDs.

DEPTH TOPIC 2: SKM ANALYSIS

The SKM Power Tools software was chosen for the second electrical depth in order to conduct several studies around the existing electrical distribution system. While the process of modeling the distribution system was very helpful in understanding all the components and settings of the system, several studies were conducted for a more focused analysis of the existing design. The three main studies conducted with the generated SKM model were arc flash evaluation, over-current device coordination study, and a fault current analysis. Copies of the printed reports can be found in the appendices.

When looking at the model created in SKM, one will notice it is not the full distribution system. This is due to the limit of bus components in the licensed copies of the software within the computer labs. Consequently, the system was modeled with the largest loads and normal branches only.

In working with the model and consulting with the project engineer, several assumptions and project specific conditions became evident. The largest issue discovered was managing voltage drop along the feeders and branches to within the 5% limit. The issues encountered were easily rectified by adjusting the primary taps of the transformers. By setting the taps to -2.5%, the entire system properly satisfied voltage drop conditions, even though the secondary voltage was slightly higher than usual.


Interestingly, I was also able to learn some of the issues the project engineer encountered in the design phase. Because the building is large and comprised mostly of labs, it would not be likely that it operates at full capacity for any extended period of time. However, a diversity factor was unable to be applied, so the engineer created a “dummy load” to correct for the high voltage drop across the transformers in the full load calculations.

SHORT CIRCUIT STUDY + CALCULATIONS

Fault current calculations and overcurrent device coordination studies are important because they ensure the safe and proper function of protective devices for branch circuits and equipment. Short circuits within distribution systems can cause fault currents up to tens of thousands of amperes, and if they are not isolated within cycles the resulting damages could be very harmful to personnel and/or equipment. Primarily, the resulting damage is evident in thermal or mechanical stresses to connected equipment. The calculations presented in the following pages were conducted in addition to those run through SKM, and follow the same path. The whole branch indicated in Figure 26 was studied in SKM whereas the trip curve coordination in Figure 27 was generated with layered manufacturer’s data for local panel 3LNL10 to 2PNL4 (points 5-7). A summarized list of the available fault current at each component (calculated in SKM) is available in Appendix D. A comparison of the SKM short circuit study and the calculated results follows.

| POINT | LOCATION |
|-------|--------------|
| 1 | XF-B-TN2 |
| 2 | USSHV-A |
| 3 | XF-B-TN1 |
| 4 | SWBDN-B |
| 5 | MDP-2PNL4 |
| 6 | MDP-3PNL2 |
| 7 | PANEL 3LNL10 |

FIGURE 26 – ISOLATED PATH FOR PROTECTIVE DEVICE COORDINATION STUDY



| | | |
|--------|---------------------------------|--------|
| Given: | System Voltage | 480 |
| | Base kVA | 2500 |
| | Utility Company Available Fault | 100000 |

Transformer Secondary Side (XF-B-TN2)

| | | | | |
|------|-------|--------|----------|-------------|
| %Z | 5.75 | Zutil | 2.304 | mΩ |
| X/R | 5.66 | Rutil | 0.400859 | mΩ |
| X(%) | 2.5 | Xutil | 0.394745 | mΩ |
| R(%) | 0.313 | Rxfrmr | 0.921975 | mΩ |
| kVA | 2500 | Xxfrmr | 5.218379 | mΩ |
| | | Ztotal | 1.322834 | 5.613124 mΩ |
| | | Isc | 48033 | A |

BUS-USSHVA - SUBSTATION

FEEDER

| | | | |
|--------|--------|--------|---------------|
| L | 5 | | |
| Rcon | 0.0124 | mΩ | 2.97 mΩ/100ft |
| Xcon | 0.0160 | mΩ | 3.85 mΩ/100ft |
| Ztotal | 1.3352 | 5.6292 | |
| Isc | 47880 | A | |

BTN1

FEEDER 4 Sets 500kcmil in plastic

| | | | |
|-------|--------|--------|-----------------------|
| L | 40 | | |
| Rfeed | 0.22 | mΩ | 2.2 mΩ/100ft |
| Xfeed | 0.303 | mΩ | 3.03 mΩ/100ft |
| Zpri | 1.5552 | 5.9322 | (At Primary Windings) |
| α | 2.308 | | |
| Zsec | 0.2920 | 1.1139 | |

TRANSFORMER

| | | | |
|-----|-----|--------|------------------|
| %Z | 5 | | |
| X/R | 4.9 | | |
| kVA | 500 | Rxfrmr | 0.865107 mΩ |
| | | Xxfrmr | 4.239024 mΩ |
| | | Ztotal | 1.1571 5.3530 mΩ |
| | | Isc | 21911 A |

SWBDN-B

| | | | |
|--------|-----------------------------|--------|---------------|
| FEEDER | 6 Sets 400 kcmil in plastic | | |
| L | 30 | | |
| Rcon | 0.205 | mΩ | 2.73 mΩ/100ft |
| Xcon | 0.231 | mΩ | 3.08 mΩ/100ft |
| Ztotal | 1.3619 | 5.5840 | |
| Isc | 20878 | A | |

At 2PNL4

| | | | |
|--------|------------------------|----|---------------|
| L | 125 | | |
| 2 sets | #350 Copper | | |
| 2 | 3" Conduits | | |
| | Assume Plastic Conduit | | |
| R | 1.944 | mΩ | 3.11 mΩ/100ft |
| X | 1.944 | mΩ | 3.11 mΩ/100ft |

Ztotal 3.3056 7.5277

Isc 14596 A

At 3PNL2

| | | | |
|--------|-------------|----|---------------|
| L | 25 | | |
| 2 SETS | 3/0 | | |
| 2 | 2" Conduits | | |
| R | 0.804 | mΩ | 6.43 mΩ/100ft |
| X | 0.4 | mΩ | 3.20 mΩ/100ft |

Ztotal 4.1094 7.9277

Isc 13439

At 3LNL10

| | | | |
|-------|-------|----|---------------|
| L | 25 | | |
| 1 SET | 1/0 | | |
| R | 2.550 | mΩ | 10.2 mΩ/100ft |
| X | 0.835 | mΩ | 3.34 mΩ/100ft |

Ztotal 6.6594 8.7627

Isc 10903

SHORT CIRCUIT STUDY RESULTS:

| POINT | LOCATION | AVAILABLE FAULT (A) | SKM AVAILABLE FAULT (A) | STANDARD BREAKER RATING (kA) | EXISTING DESIGN |
|-------|--------------|---------------------|-------------------------|------------------------------|-----------------|
| 1 | XF-B-TN2 | 48,033 | - | 50 | 63 |
| 2 | USSHV-A | 47,880 | 43,312 | 50 | 100 |
| 3 | XF-B-TN1 | 21,911 | 40,812 | 25 | 100 |
| 4 | SWBDN-B | 20,878 | 19,362 | 22 | 65 |
| 5 | MDP-2PNL4 | 14,596 | 13,591 | 18 | 100 |
| 6 | MDP-3PNL2 | 13,439 | 12,530 | 18 | 65 |
| 7 | PANEL 3LNL10 | 10,903 | - | 18 | 25 |

One can see from the short circuit study results that values from SKM and those generated from the direct-ohmic method do not vary greatly except at Transformer B-TN1. This is most likely due to the assumptions associated with the reactance and resistance values of the transformer or the locations upstream. However, there are significant differences between the standard breaker rating column (based on column three values generated by the direct-ohmic method) and the existing design kAIC ratings. In all cases, the existing design values are higher. This is most likely due to the anticipated loads of the phase two addition. While these loads have been configured into existing panelboard layouts, they are still estimates and could considerably contribute to any overdrawn current throughout the system.


PROTECTIVE DEVICE COORDINATION STUDY

The trip curves in Figure 27, generated from overlaying manufacturer's information of points 5-7 highlighted above in orange, indicate the selected devices are coordinated properly. The load-side breaker (3LNL10) trips first at a rating between 150 A and 200 A followed by the devices upstream. Additional curves for points one through seven were studied in SKM and are included in Appendix D. These further validate the coordination of the overcurrent-protective devices along the path. Additionally, the trip/delay times are summarized in the arc flash evaluation reports (also generated in SKM and included in Appendix D).

Application Data
29-167F
 Page 36



AB DE-ION Circuit Breakers
 Types FDB, FD and HFD 150 Amperes



Curve No. SC-4149-87B

October 1997



FIGURE 27 – COORDINATION STUDY FOR SPECIFIED OCPDS

ARC FLASH EVALUATION STUDY

The arc flash evaluation report generated from SKM builds upon the short circuit study and coordination study to provide data for breaker opening times, arc flash boundaries, and the associated required protective clothing (for maintenance) among other data. The images below are an example of the information presented in the arc flash evaluation study for points six and seven. Since the trip/delay times and protective device arcing faults are smaller for 3LNL10 than 3PNL2, the study proves these components are satisfactorily coordinated.

| Bus Name | Protective Device Name | Bus kV | Bus Bolted Fault (kA) | Bus Arcing Fault (kA) | Prot Dev Bolted Fault (kA) | Prot Dev Arcing Fault (kA) | Trip/Delay Time (sec.) | Breaker Opening Time (sec.) | Ground | Equip Type | Gap (mm) | Arc Flash Boundary (in) | Working Distance (in) | Incident Energy (cal/cm2) | Required Protective FR Clothing Category |
|------------|------------------------|--------|-----------------------|-----------------------|----------------------------|----------------------------|------------------------|-----------------------------|--------|------------|----------|-------------------------|-----------------------|---------------------------|--|
| BUS-3LNH1 | PD-3LNH1 | 0.480 | 11.87 | 7.59 | 11.87 | 7.59 | 0.017 | 0.000 | Yes | PNL | 25 | 9 | 18 | 0.41 | Category 0 |
| BUS-3LNL1 | CB-3LNL1 | 0.208 | 7.12 | 2.91 | 7.12 | 2.91 | 0.031 | 0.000 | Yes | PNL | 25 | 7 | 18 | 0.27 | Category 0 (*N3) |
| BUS-3LNL10 | CB-3LNL10 | 0.208 | 10.21 | 4.41 | 10.21 | 4.41 | 0.018 | 0.000 | Yes | PNL | 25 | 7 | 18 | 0.24 | Category 0 |
| BUS-3PNL2 | PD-3PNL2 | 0.208 | 11.74 | 4.87 | 11.74 | 4.87 | 0.04 | 0.000 | Yes | PNL | 25 | 12 | 18 | 0.61 | Category 0 |

Daylighting (MAE)



3/22 08:00

3/22 10:00

3/22 12:00

3/22 14:00

3/22 16:00

The objective of this study is to evaluate the existing toplighting and sidelighting systems in the atrium and the potential energy savings associated with a proposed photosensor controlled lighting system. The current lighting design for the atrium space does not provide any sensor-triggered automatic lighting controls, but has the potential to reach significant energy savings by properly integrating the daylight and electric lighting. In order to quantify the existing daylight conditions and measure energy savings, a model of the space was imported into the daylight analysis program, Daysim.

PROCEDURE:

- A model of the space was imported into Daysim and AGI32 to establish existing daylight values within the space at the vernal equinox, summer solstice, and winter solstice. While providing visual clues as to daylight penetration and the solar path, these calculations also indicated that the majority of daylight hours provide illuminance levels that surpass the minimum requirement of 10 fc.
 - Inputs for the model were adjusted to keep the most accurate site representation for Buffalo, NY. For example, the scene building rotation was set for a +10°41' to adjust for the difference between magnetic and polar north.

- Building occupancy was modeled for 8:00am to 11:00 pm weekdays from January 10 to May 20; 8:00am to 5:00pm weekdays from May 21 to August 23; and 8:00am to 11:00pm again on weekdays from August 24 to December 23. These dates and times were chosen to represent the operation of the building as a college facility, which would be in session throughout fall, spring, and summer sessions.




FIGURE 28 – BUILDING SET-UP IN DAYSIM

- The adjacent mechanical penthouse was also modeled to provide more accurate results.
- From the initial daylight analyses in Daysim, it was determined that the month of December had the lowest numbers for useful daylight illuminance and daylight autonomy. Therefore, December 21 was chosen as the baseline date to use for the experimentation in determining the effects of daylight switching on the energy consumption.




FIGURE 29 – DA VALUES BY FLOOR LEVEL

- Initially, the daylight and electrical light were going to be analyzed together with the application of a photosensor file and open switching algorithm. However, due to a discovered limitation of the current version of the software, the method was altered to rely solely on daylight autonomy.
- It has been discussed in the current Daylighting course (AE 565), that daylight autonomy can be used as an approximation of the percentage energy saved because it is very close to the values for the critical point, or the area in a space receiving the least contribution from daylight and electric light.
- Daysim calculations were conducted for sensor points at the first, second, and third floors to analyze the daylight signals at each level or zone. The proposed lighting control arrangement would divide each corridor area on each level into a separate zone controlled by a designated photosensor.

- Then results for daylight autonomy were converted into text and viewed with Excel. From here the value of the Daylight Autonomy at the critical point could be selected and applied to the total kilowatt-hrs of energy consumption for illuminating each zone to the target 10 fc/100 lux. The product is approximately equivalent to the energy saved.

CALCULATIONS:

| JULIAN | # DAYS | HOURS | |
|--------------|--------|-------|------|
| 10 | 131 | 15 | 1965 |
| 141 | 95 | 8 | 760 |
| 236 | 139 | 15 | 2085 |
| 365 | | | |
| | | Σ | 4810 |
| TOTAL ANNUAL | | | 3562 |

FIRST FLOOR:

| | | | |
|--------------------------------|-------|----------|----------|
| DA @ CP | 0.457 | | |
| | | W | kW |
| Total Luminaire Input Power | | 1301 | 1.301 |
| Hours of Operation | | 3562 | |
| TOTAL kWh | | 4634.162 | 4634.162 |
| Estimated Annual Savings (kWh) | | 2117.8 | 2117.812 |

SECOND FLOOR:

| | | | |
|--------------------------------|-------|--------|---------|
| DA @ CP | 0.499 | | |
| | | W | kW |
| Total Luminaire Input Power | | 650 | 0.65 |
| Hours of Operation | | 3562 | |
| TOTAL kWh | | 2315.3 | 2315.3 |
| Estimated Annual Savings (kWh) | | 1155.3 | 1155.33 |

THIRD FLOOR:

| | | | | |
|--------------------------------|-------|--|--------|----------|
| DA @ CP | 0.506 | | | |
| | | | W | kW |
| Total Luminaire Input Power | | | 806 | 0.806 |
| Hours of Operation | | | 3562 | |
| TOTAL kWh | | | | 2870.972 |
| Estimated Annual Savings (kWh) | | | 1452.7 | 1452.712 |

RESULTS:

- The switching arrangement for the fluorescent luminaires considered here provides an annual total savings of 4725.8 kWh.

MECHANICAL BREADTH


The purpose of this study is to analyze and understand how the heating and cooling loads are affected by toplighting, or skylights. More specifically, this study focuses on the effect of percent area of skylight glazing compared to the roof area. In order to perform this study, a model of the atrium space was created as a room in TRACE with a simultaneous study conducted in SkyCalc. Glazing for the studies is double, low-e clear glass with a SHGC of 0.38, U value of 0.28 Btu/h-°F-ft², and transmittance of 0.70.

After setting up the model with appropriate site and occupancy/operation schedules, calculations were run for the space for three different scenarios:


1. Existing Skylight Glazing (20.51% of the roof area)
2. Skylights at 10% of the roof area
3. No Skylights

The results are broken into heating and cooling consumption according to fuel type, gas versus electricity.

| With Skylights modeled (20.51% roof) | | January | February | March | April | May | June | July | August | September | October | November | December |
|--------------------------------------|--|---------|----------|-------|-------|-------|-------|-------|--------|-----------|---------|----------|----------|
| Electric | | | | | | | | | | | | | |
| On Pk (kWh) | | 7875 | 6866 | 8144 | 7685 | 13796 | 14793 | 13588 | 15811 | 13256 | 9986 | 8243 | 8022 |
| Off Peak (kWh) | | 3439 | 3239 | 3928 | 3641 | 4635 | 5742 | 6118 | 6269 | 5265 | 4107 | 3927 | 3803 |
| Demand (kW) | | 119 | 119 | 120 | 125 | 143 | 145 | 146 | 147 | 146 | 140 | 126 | 123 |
| With Skylights modeled (10% roof) | | January | February | March | April | May | June | July | August | September | October | November | December |
| Electric | | | | | | | | | | | | | |
| On Pk (kWh) | | 7789 | 7224 | 8601 | 7726 | 13494 | 14408 | 13276 | 15487 | 13050 | 10266 | 8693 | 8074 |
| Off Peak (kWh) | | 3429 | 3168 | 3934 | 3655 | 4525 | 5439 | 5758 | 6194 | 5227 | 4134 | 3944 | 3885 |
| Demand (kW) | | 119 | 119 | 121 | 125 | 143 | 145 | 146 | 147 | 146 | 140 | 126 | 123 |
| Without Skylights modeled | | January | February | March | April | May | June | July | August | September | October | November | December |
| Electric | | | | | | | | | | | | | |
| On Pk (kWh) | | 7875 | 7319 | 8972 | 8648 | 13594 | 14368 | 13144 | 15404 | 13134 | 11327 | 9479 | 8241 |
| Off Peak (kWh) | | 3445 | 3173 | 3958 | 3837 | 4409 | 5335 | 5619 | 6104 | 5209 | 4197 | 3987 | 3923 |
| Demand (kW) | | 120 | 121 | 122 | 129 | 149 | 145 | 146 | 147 | 146 | 140 | 128 | 125 |



| With Skylights Modeled (20.51%) | | | | | | | | | | | | |
|-----------------------------------|---------|----------|-------|-------|-----|------|------|--------|-----------|---------|----------|----------|
| | January | February | March | April | May | June | July | August | September | October | November | December |
| Gas | | | | | | | | | | | | |
| Peak Cons. (therms) | 326 | 238 | 191 | 69 | 0 | 0 | 0 | 0 | 0 | 44 | 115 | 182 |
| Peak Demand (therms/hr.) | 3 | 3 | 3 | 3 | 0 | 0 | 0 | 0 | 0 | 1 | 3 | 3 |
| With Skylights modeled (10% roof) | | | | | | | | | | | | |
| | January | February | March | April | May | June | July | August | September | October | November | December |
| Gas | | | | | | | | | | | | |
| Peak | 331 | 255 | 218 | 83 | 0 | 0 | 0 | 0 | 0 | 54 | 132 | 198 |
| Off Peak | 3 | 3 | 3 | 3 | 0 | 0 | 0 | 0 | 0 | 1 | 3 | 3 |
| Without Skylights | | | | | | | | | | | | |
| | January | February | March | April | May | June | July | August | September | October | November | December |
| Gas | | | | | | | | | | | | |
| Peak | 346 | 290 | 295 | 161 | 0 | 0 | 0 | 0 | 0 | 106 | 195 | 237 |
| Off Peak | 2 | 2 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 2 | 2 | 2 |



The results from TRACE would suggest that the toplight glazing creates higher cooling (electric) loads in the summer. Also, the graph generated from these results would indicate there is a law of diminishing returns in terms of the effect the glazing has on expenditures for gas fuel. That is to say, the largest decrease in consumption of energy occurs in the winter months with 10% toplight glazing area, due to solar heat gain.

These trends are again achieved with the studies conducted in SkyCalc, which also account for lighting load alterations. In the SkyCalc evaluation of scenario one versus two, it is evident that scenario one has a larger overall heating energy consumption simply by direct comparison of the figures for annual energy savings (-17,321 kWh/yr < -7,178 kWh/yr). However, if comparing the percentages of heating to overall HVAC energy savings/costs, scenario two heating is more effective because it only accounts for 56% of the negative energy savings as opposed to 62% of negative energy savings in scenario one. In other words, scenario one heating consumption is greater than that of scenario two.

The addition of an on/off lighting control system provides even more proof that a smaller skylight area (in this case 10% of the roof) is more beneficial for this location. For scenario one, the inclusion of an automatic on/off lighting control for 70% of the lighting yields annual energy savings of -13,462 kWh/yr and annual cost savings of -\$191. While annual energy savings for scenario two with the abovementioned lighting control are still negative overall, there is a positive annual cost savings of \$627. The results for the SkyCalc simulations are presented below:

SCENARIO 1 VS. SCENARIO 2 – NO LIGHTING CONTROL

| Savings from Design Skylighting System | | | |
|--|--------------------------------|-----------------------------|--|
| Savings | Annual Energy Savings (kWh/yr) | Annual Cost Savings (\$/yr) | |
| Lighting | 0 | \$0 | |
| Cooling | -6,557 | -\$1,311 | |
| Heating | -10,764 | -\$367 | |
| Total | -17,321 | -\$1,679 | |

| Skylighting System Description | | Site Description | |
|--------------------------------|-------|------------------|-------------------|
| Skylight unit size (ft2) | 107.2 | Climate Location | Buffalo, NY |
| Number of Skylights | 12 | Climate Zone | ASHRAE B-17 |
| Total Skylight Area (ft2) | 1,286 | Building Type | Class, University |
| Skylight to Floor Ratio (SFR) | 20.5% | Building Area | 6,273 (ft2) |

| Electric Lighting System Description | | | |
|--------------------------------------|---------------------|----------------------|------------------|
| Lighting Type | Lighting Control | Light Level Setpoint | Lighting Density |
| Lensed fluorescent | No Daylight Control | 10 fc | 0.50 W/ft2 |
| Skylight SHGC | 38% | Light Level Setpoint | 10 fc |
| Skylight Tvis | 70% | Lighting Density | 0.50 W/ft2 |
| Well Efficiency (WF) | 82% | Connected Load | 3.1 kW |
| Dirt and Screen Factor | 80% | Fraction Controlled | 0% |
| Overall Skylight System Tvis | 46% | | |

SCENARIO 1

| Savings from Design Skylighting System | | | |
|--|--------------------------------|-----------------------------|--|
| Savings | Annual Energy Savings (kWh/yr) | Annual Cost Savings (\$/yr) | |
| Lighting | 0 | \$0 | |
| Cooling | -3,139 | -\$628 | |
| Heating | -4,040 | -\$138 | |
| Total | -7,178 | -\$766 | |

| Skylighting System Description | | Site Description | |
|--------------------------------|-------|------------------|-------------------|
| Skylight unit size (ft2) | 107.2 | Climate Location | Buffalo, NY |
| Number of Skylights | 6 | Climate Zone | ASHRAE B-17 |
| Total Skylight Area (ft2) | 643 | Building Type | Class, University |
| Skylight to Floor Ratio (SFR) | 10.3% | Building Area | 6,273 (ft2) |

| Electric Lighting System Description | | | |
|--------------------------------------|---------------------|----------------------|------------------|
| Lighting Type | Lighting Control | Light Level Setpoint | Lighting Density |
| Lensed fluorescent | No Daylight Control | 10 fc | 0.50 W/ft2 |
| Skylight SHGC | 38% | Light Level Setpoint | 10 fc |
| Skylight Tvis | 70% | Lighting Density | 0.50 W/ft2 |
| Well Efficiency (WF) | 82% | Connected Load | 3.1 kW |
| Dirt and Screen Factor | 80% | Fraction Controlled | 0% |
| Overall Skylight System Tvis | 46% | | |
| Skylight CU | 52% | | |

SCENARIO 2

SCENARIO 1 VS. SCENARIO 2 – WITH ON/OFF SWITCHED LIGHTING CONTROL

| Savings from Design Skylighting System | | | |
|--|--------------------------------|-----------------------------|--|
| Savings | Annual Energy Savings (kWh/yr) | Annual Cost Savings (\$/yr) | |
| Lighting | 7,236 | \$1,447 | |
| Cooling | -5,620 | -\$1,124 | |
| Heating | -15,079 | -\$515 | |
| Total | -13,462 | -\$191 | |

| Skylighting System Description | | Site Description | |
|--------------------------------|-------|------------------|-------------------|
| Skylight unit size (ft2) | 107.2 | Climate Location | Buffalo, NY |
| Number of Skylights | 12 | Climate Zone | ASHRAE B-17 |
| Total Skylight Area (ft2) | 1,286 | Building Type | Class, University |
| Skylight to Floor Ratio (SFR) | 20.5% | Building Area | 6,273 (ft2) |

| Electric Lighting System Description | | | |
|--------------------------------------|------------------|----------------------|------------------|
| Lighting Type | Lighting Control | Light Level Setpoint | Lighting Density |
| Lensed fluorescent | On/Off | 10 fc | 0.50 W/ft2 |
| Skylight SHGC | 38% | Light Level Setpoint | 10 fc |
| Skylight Tvis | 70% | Lighting Density | 0.50 W/ft2 |
| Well Efficiency (WF) | 82% | Connected Load | 3.1 kW |
| Dirt and Screen Factor | 80% | Fraction Controlled | 70% |
| Overall Skylight System Tvis | 46% | | |
| Skylight CU | 52% | | |

SCENARIO 1

| Savings from Design Skylighting System | | | |
|--|--------------------------------|-----------------------------|--|
| Savings | Annual Energy Savings (kWh/yr) | Annual Cost Savings (\$/yr) | |
| Lighting | 6,820 | \$1,364 | |
| Cooling | -2,254 | -\$451 | |
| Heating | -8,388 | -\$286 | |
| Total | -3,823 | \$627 | |

| Skylighting System Description | | Site Description | |
|--------------------------------|-------|------------------|-------------------|
| Skylight unit size (ft2) | 107.2 | Climate Location | Buffalo, NY |
| Number of Skylights | 6 | Climate Zone | ASHRAE B-17 |
| Total Skylight Area (ft2) | 643 | Building Type | Class, University |
| Skylight to Floor Ratio (SFR) | 10.3% | Building Area | 6,273 (ft2) |

| Electric Lighting System Description | | | |
|--------------------------------------|------------------|----------------------|------------------|
| Lighting Type | Lighting Control | Light Level Setpoint | Lighting Density |
| Lensed fluorescent | On/Off | 10 fc | 0.50 W/ft2 |
| Skylight SHGC | 38% | Light Level Setpoint | 10 fc |
| Skylight Tvis | 70% | Lighting Density | 0.50 W/ft2 |
| Well Efficiency (WF) | 82% | Connected Load | 3.1 kW |
| Dirt and Screen Factor | 80% | Fraction Controlled | 70% |
| Overall Skylight System Tvis | 46% | | |
| Skylight CU | 52% | | |

SCENARIO 2

DISCUSSION:

The existing skylighting design provides up to 4,243 hours/year of full daylighting (according to SkyCalc). While this is greater than a design composed of less glazing area, the tradeoffs between energy consumption prove to be more economical for a smaller glazing area. Scenario two combined with automatic lighting control is the only condition in this study to provide net positive annual cost savings, and it is only when automatic lighting control is incorporated that any kind of positive savings is achieved.

LED LUMINAIRE OPTIONS (HONORS BREADTH)

The following section considers the viability of LED options for general illumination within the building's interior. A background of existing technical characteristics and considerations is presented, followed by a study specific to the building conducted in AGI32.

LED luminaires are quickly gaining momentum as marketable lighting solutions. They are seeing great demand in exterior and accent lighting due to their excellent capacity for colored and dynamic illumination. However, there is great concern among industry professionals about their proper integration within the lighting market, specifically with regards to designs that account for the unique characteristics associated with LED sources. These trends of research and development are comparable to the shift within lighting technology that occurred in the mid-20th century with the implementation of fluorescent sources. There is a great sense of urgency to implement the technology where possible because substantial energy savings and long life are advertised. Yet it should be recognized, that "LEDs still face difficult competition for general illumination because success is defined by correctly matching a technology with the needs of the application" [4].

The considerations for LED product selection should mimic those of any other source, but the designer must be cognizant of the limitations and performance of the source especially within the context of the application. There are numerous characteristics and metrics that need to be considered, including but not limited to: power supply, maintenance, thermal management, economics, and performance.

Performance encompasses numerous properties and characteristics associated with a lighting fixture including photometrics, color rendering, efficiency, and life/reliability. LEDs have the flexibility to accommodate numerous lighting tasks with proper optical design. However, they are also currently associated with issues of glare because of their intense point source. Color quality, rendering, and matching is a major issue associated with white LEDs. While RGB LEDs can be controlled to create a vivid spectrum of colors, binning and color rendering metrics create complications for standard white LED lighting. The CIE is presently developing a new standard for color comparison, because the existing CRI technique does not provide sufficient comparison among different sources. The R_a value does not provide an accurate representation for LEDs because their spectra possess sharp peaks and valleys atypical of other lighting sources whose broader spectra were used as the basis for the development of CRI [5, 6]. Reliability and length of life are perhaps the most marketable traits of an LED, yet they are still being tested. While many manufacturers claim lumen maintenance (of 70%) can be forecast to 60,000 hours, accelerated studies by the Lighting Research Center (LRC) at Rensselaer Polytechnic Institute and others provide evidence this is not the case for all LEDs.

LED performance is inversely proportional to driving current and operating temperatures; as temperature and/or current decrease the lifetime of an LED increases. Since a lifetime of 60,000 hours is difficult to test in a lab, the LRC performed studies to extrapolate data from testing conditions of 6,000 hours. These preliminary studies conducted with phosphor-converted LEDs indicated that an LED downlight operating in open air conditions at 95°C can reach a lumen depreciation of 30% after approximately 5,000 hours [7]. Additionally, the study exhibited high levels of color shift in the test LEDs. The Department of Energy has also collected data on reliability testing via the CALiPER program which includes trends for a larger pool of test sources. A graph of the trends of lumen maintenance for 26 test sources is provided in Figure 30, and includes sources in addition to the phosphor-converted white LEDs of the LRC study [8]. While these studies rely on extrapolated data, they convincingly prove that not all LEDs and LED luminaire combinations existing today maintain lumen output greater than 70% until a operation of 50,000 hours.




FIGURE 30 – FROM DOE CALIPER STUDY [8]

Finally, but not of least importance, the issue of economics must be considered with LED luminaire specification. While there are methods of computing energy savings and simple payback, there has yet to be a documented demonstration that LED lighting systems provide a total lower cost compared to standard lighting systems [4]. This is due to the fact that the incorporation of LED architectural lighting technology is so new, and LED luminaire production has not yet reached a point in development where it can take advantage of economies of scale.

While research and development are ongoing, marketable products are likewise growing in number. As mentioned previously, most existing LED solutions serve specific lighting applications such as display cases, signs, signal lighting, automotive lighting, task lighting, and accent lighting. The exterior design for the Science Building presented in previous sections already implements LED fixtures in exterior applications, where they have proven to provide light at a fraction of the energy consumption in comparison to an alternative source such as metal halide. This study investigates the options for general overhead illumination within commercial or institutional spaces, and presents an evaluation of performance in AGI32 and a simple payback study.

Research of available general illumination products yielded two opportunities for linear downlighting through manufacturers Albeo Technologies and Lunera. Lunera was chosen as the object for further study based on luminaire housing and optics, which are designed to provide a more evenly distributed light and easily fill in for standard four feet, linear luminaires. Based on product literature for the Lunera 6400 luminaire (available in Appendix A), it has an integrated power supply unit that supplies its strips of RGB white LEDs. It provides 1700 lumens at an input power of 30 watts, and can receive source voltage of 120/277 VAC.



FIGURE 31 – ALBEO LUMINAIRE



FIGURE 32– LUNERA 6400

The space chosen for the study is the genetics teaching lab, of which there occur a total of 10 identical spaces throughout the building. At an area of roughly 1,160 ft² the total illuminated area for this suggested design would be 11,600 ft³. Two scenarios were simulated in AGI32 for:

1. 21 luminaires arranged perpendicular to lab table orientation
2. 16 luminaires parallel and in between lab tables

SCENARIO 1




FIGURE 33 - SCENARIO 1

Results Scenario 1:

Average Illuminance = 44.4 fc

LPD = 0.681 W/ft²




FIGURE 34 - SCENARIO 1 ISOLINES

SCENARIO 2




FIGURE 35 - SCENARIO 2

Results Scenario 2:

Average Illuminance = 41.5 fc
 LPD = 0.753 W/ft²




FIGURE 36 - SCENARIO 2 ISOLINES

Individual luminaire price data could not be obtained from Lunera, but their Web site (www.lunera.com) provides a payback calculator tool. Using the tool and applying the settings for a school project at 10,000 ft² in New York yields an estimated 1.9 years payback period. A payback period between one and two years can be a substantial incentive for a designer to employ a new system, however, the results from the rough estimates provided are significantly higher.

The calculations provided below indicate initial costs for the proposed scenarios at roughly half and one-third, respectively, of the price of the fluorescent system. However, the calculated payback period based on lighting energy savings is upwards of 16 years. If the LED system were run for 3,500 hours for 14 years it would reach the estimated 50,000 hour life. Since, the period of payback is greater than the potential luminaire life it would be disqualified as a potential solution. Even at a payback period of seven years, it would not be reasonable to utilize the LED design.

| | | | Input Power | | Annual Power Cons. | Annual Energy Costs | Annual Cash Flow | Payback Period | Initial System Cost | | |
|---|----------|------------------|-------------|------|--------------------|---------------------|------------------|----------------|---------------------|--------|----------|
| | | | W | kW | | | | | Luminaires | Lamps | Ballasts |
| | Existing | Luminaires LSB-2 | 8680 | 8.68 | 30,918 | \$ 3,091.82 | | | 24,500.00 | 103.25 | 4,200.00 |
| 1 | Proposed | Lunera 6400 | 6300 | 6.3 | 22,441 | \$ 2,244.06 | \$ 847.76 | 16 | 13,597.50 | | |
| 2 | Proposed | Lunera 6400 | 4800 | 4.8 | 17,098 | \$ 1,709.76 | \$ 1,382.06 | 7 | 10,360.00 | | |

Assumptions:

- Cost data for the fluorescent luminaires was obtained through distributor R.D. Wright. Estimate values/luminaire = \$175. Ballast prices assumed \$30/ballast (based on Lunera calculator assumptions). Lamp cost data taken from Grainger Supply: \$14.75/lamp.

- Estimated initial costs for Lunera fixtures obtained from applying cost savings presented by Lunera (37% of fluorescent light cost).
- Energy costs assumed: \$0.10/kWh
- Total annual operation hours: 3,562

DISCUSSION

The estimated and manufacturer generated payback periods vary too greatly to be effective in an economic analysis. The large difference in results is most likely the result of inconsistent assumptions between the two methods. If the payback period of 1.9 years could be confirmed, then the system could more reasonably be considered based on economics.

The proposed systems perform reasonably well in supplying the required illuminance levels at the task surfaces. While Scenario 1 performs better quantitatively, Scenario 2 would likely reduce direct and veiling glare since the luminaires are not located directly over the task areas. Scenario one and two both provide net savings in energy costs associated with lighting at 27% and 45% respectively.

CONCLUSIONS

While this system provides energy savings, it would not be a good investment for the building at this time. In addition to unconfirmed payback data, the color quality and reliability of the fixture is not provided. This leaves too many performance issues inadequately addressed. Furthermore, the direct, diffusing lens has the potential to create more issues of glare that could easily be avoided with a parabolic troffer or indirect fixture. It could perform well for a generic classroom, but since these classrooms also house lab activities, this could be a potential issue for the occupants.

ACOUSTICAL BREADTH

The atrium designed for the building serves primarily as a circulation space and a link between the existing building and the new addition. However, since it is a major open space within the academic core of the Buffalo State College campus, it also has the potential to serve as an event or gathering space for university functions such as workshops or information sessions. Therefore the nature and size of the space require an acoustical environment that provides proper reverberation time for speech.

There are numerous architectural characteristics to be considered for the acoustical performance of a space, such as finishes, layout, and dimensions. The volume of a space directly affects the average length of sound reflections, or mean free path. The existing design of the atrium accounts for the large volume and hard surfaces by providing acoustical panel treatments on the wall and suspended from the ceiling. This study evaluates the performance of the existing acoustical treatment for a target reverberation time (T) range of 1.3-1.9 seconds and compares the results with a proposed scenario implementing a more absorptive, carpet floor.


PROCEDURE:

The target T range of 1.3-1.9 seconds was selected based on optimal reverberation times for speech and music in a space [3] as presented in the figure below. In order to quantitatively evaluate the performance, the sound absorption coefficients (α) were first gathered for all the surface materials within the atrium. Then, using the surface area data and absorption coefficients, total room absorption, "a", was calculated to be applied in Sabine's

Formula. Note, in this study "a" is modified to account for the long shape of the atrium with a_{air} , which is equivalent to 8 sabins/1,000 ft³.

$$a = \sum S\alpha + a_{air}$$

Sabine's Formula: $T = 0.05 * \frac{V}{a}$



OPTIMUM REVERBERATION TIMES ACCORDING TO SPACE AND AUDIO NEEDS

The calculations for T at 1,000 Hz are summarized in the tables below

Scenario 1 Existing Conditions

| Location | Material | Absorption Coefficient | Surface Area | Sα |
|----------|-----------|------------------------|--------------|---------|
| Floor | Tile | 0.01 | 10881 | 108.81 |
| Walls | Brick | 0.04 | 5912 | 236.48 |
| | Gyp Board | 0.04 | 10795 | 431.8 |
| | AWP | 0.82 | 3082 | 2527.24 |
| | Tile | 0.01 | 1242.6 | 12.426 |
| | Glass | 0.12 | 550 | 66 |
| Ceiling | Gyp Board | 0.04 | 6568 | 262.72 |
| | ACP | 0.82 | 2166 | 1776.12 |
| | Glass | 0.03 | 1280 | 38.4 |
| | Concrete | 0.02 | 3843 | 76.86 |

| | |
|----------------|---------|
| ΣSα = a | 5,537 |
| Air Absorption | 2,158 |
| Adjusted a* | 7,695 |
| Atrium Volume | 269,739 |

Reverberation Time

$$T = 0.05 * (V/a)$$

$$T = 1.75$$

Satisfactory for Range of 1.3 - 1.9 Sec

Scenario 2 Replacing Level One Floor with Carpet

| Location | Material | Absorption Coefficient | Surface Area | Sα |
|----------|-----------|------------------------|--------------|---------|
| Floor | Tile | 0.01 | 4608 | 46.08 |
| | Carpet | 0.37 | 6273 | 2321.01 |
| Walls | Brick | 0.04 | 5912 | 236.48 |
| | Gyp Board | 0.04 | 10795 | 431.8 |
| | AWP | 0.82 | 3082 | 2527.24 |
| | Tile | 0.01 | 1242.6 | 12.426 |
| | Glass | 0.12 | 550 | 66 |
| Ceiling | Gyp Board | 0.04 | 6568 | 262.72 |
| | ACP | 0.82 | 2166 | 1776.12 |
| | Glass | 0.03 | 1280 | 38.4 |
| | Concrete | 0.02 | 3843 | 76.86 |

| | |
|----------------|---------|
| ΣSα = a | 7,795 |
| Air Absorption | 2,158 |
| Adjusted a* | 9,953 |
| Atrium Volume | 269,739 |

Reverberation Time

$$T = 0.05 * (V/a)$$

$$T = 1.36$$

Significant Improvement

Satisfactory for Range of 1.3 - 1.9 Sec

Scenario 3 Replacing All Floors with Carpet

| Location | Material | Absorption Coefficient | Surface Area | Sα |
|----------|-----------|------------------------|--------------|---------|
| Floor | Carpet | 0.37 | 10881 | 4025.97 |
| Walls | Brick | 0.04 | 5912 | 236.48 |
| | Gyp Board | 0.04 | 10795 | 431.8 |
| | AWP | 0.82 | 3082 | 2527.24 |
| | Tile | 0.01 | 1242.6 | 12.426 |
| Ceiling | Glass | 0.12 | 550 | 66 |
| | Gyp Board | 0.04 | 6568 | 262.72 |
| | ACP | 0.82 | 2166 | 1776.12 |
| | Glass | 0.03 | 1280 | 38.4 |
| | Concrete | 0.02 | 3843 | 76.86 |

| | |
|----------------|--------|
| ΣSα = a | 9,454 |
| Air Absorption | 2,158 |
| Adjusted a* | 11,612 |
| Atrium Volume | 269739 |

Reverberation Time

$$T = 0.05 \cdot (V/a)$$

| |
|----------|
| T = 1.16 |
|----------|

Significant Improvement

< 1.3 - 1.9; comparable to cinema, lecture/conference room

RESULTS:

As indicated from the calculations above, all three scenarios fall within the range of 1.3 to 1.9 seconds, though the performance from scenario three is the best, as is to be expected. Additionally, the difference in noise levels (Noise Reduction) between the existing and second and third scenarios is calculated by:

$$NR = 10 \times \log \frac{a_1}{a_2}$$

| NR | dB |
|-----|-----|
| 1:2 | 1.1 |
| 1:3 | 1.8 |

Again, these results indicate that scenario three performs the best. However, the noise reduction levels are too small to have a dramatic impact on the performance of the space. Human hearing can perceive changes in loudness beginning at 3 dB. Therefore, it is recommended that the initial design be maintained.

SUMMARY + CONCLUSIONS

The senior thesis project provided a unique experience for learning more about the performance and integration of systems within a building. The underlying goal of the work in these studies was to be comprehensive about the redesign and to incorporate as much of my existing knowledge and skills of building systems. As a result, daylighting, mechanical, and acoustical analyses were incorporated in the atrium space. The existing skylight system performs well for daylighting purposes but would not provide any economic benefit to the owner if not incorporated with an automatic switched lighting control system. Additionally, the current acoustical considerations for the atrium satisfy reverberation time requirements of speech. While carpeting would further improve these conditions, it is not necessary and could even conflict with the aesthetics and maintenance of the space. The study for the viability of LED luminaires for interior general illumination proves that existing technologies are not suitable for this classification of application at the present time.

Many of the existing systems perform well, and even above current standards or codes. However, the lighting levels within the existing design of the classrooms far exceed minimum requirements of the IESNA. Additionally, the electrical distribution system that supports the building has been engineered well and is prepared to cover all future loads for the second phase of the project. The proposed design of a MCC would just prove to be too difficult and expensive for this type of application.

REFERENCES

- [1] ASHRAE Standard 90.1 2007: Energy Standard for Buildings. Atlanta: American Society of Heating, Refrigerating and Air Conditioning Engineers, 2007.
- [2] Rea, M.S. The IESNA Lighting Handbook: Reference & Application, Ninth ed. , New York: IESNA, 2000.
- [3] M. D. Egan, Architectural Acoustics, New York: McGraw-Hill, Inc, 1988.
- [4] J.P. Freyssinier, J. Taylor, D. Frering, and P. Rizzo, "Considerations for successful LED applications," Presented at 6th China International Forum on Solid State Lighting, 2009.
- [5] W. Davis, "Measuring color quality of light sources", in Proc. of SPIE Vol. 6337, 2006.
- [6] "Spectral design considerations for white LED color rendering", Optical Engineering, vol. 44, no. 11, Nov, online, 2005.
- [7] N. Narendran, Y. Gu, L. Jayasinghe, J. P. Freyssinier, and Y. Zhu, "Long-term performance of white LEDs and systems," in Proceeding of First International Conference on White LEDs and Solid State Lighting, Tokyo, Japan, Nov. 2007, p. 174-179.
- [8] "LED Measurement Series: LED Luminaire Reliability" [Online] p. 3 [October 2009], Available at: http://apps1.eere.energy.gov/buildings/publications/pdfs/ssl/luminaire_reliability.pdf

ACKNOWLEDGEMENTS

I would like to thank the following people for all of their support and assistance throughout the duration of this senior thesis project:

Architectural Engineering Faculty

Cannon Design Project Architects and Engineers, especially:

Jason Babcock

Raymon Soto

Peter McClive

Joe Robins

Tony Borgesse

Buffalo State College, especially:

Steven Shaffer – Manager, Design & Construction

All of my classmates, friends, and family