

Technical Report 1

ASHRAE Standards 62.1 and 90.1 Compliance Evaluation

Delaware County Community College

STEM Center

Media, PA



Dan Saxton

Mechanical Option

Faculty Consultant: Dr. Stephen Treado

Date Submitted: 10/4/10

Table of Contents

Table of Contents..... 2

Executive Summary..... 4

Part 1: ASHRAE Standard 62.1 Section 5 Evaluation..... 5

 Section 5.1 – Natural Ventilation..... 5

 Section 5.2 – Ventilation Air Distribution..... 5

 Section 5.3 – Exhaust Duct Location..... 5

 Section 5.4 – Ventilation System Controls..... 5

 Section 5.5 – Airstream Surfaces..... 5

 Section 5.6 – Outdoor Air Intakes..... 5

 Section 5.7 – Local Capture of Contaminants..... 6

 Section 5.8 – Combustion Air..... 6

 Section 5.9 – Particulate Matter Removal..... 6

 Section 5.10 – Dehumidification Systems..... 7

 Section 5.11 – Drain Pans..... 7

 Section 5.12 – Finned-Tube Coils and Heat Exchangers..... 7

 Section 5.13 – Humidifiers and Water-Spray Systems..... 7

 Section 5.14 – Access for Inspection, Cleaning, and Maintenance..... 7

 Section 5.15 – Building Envelope and Interior Surfaces..... 8

 Section 5.16 – Buildings with Attached Parking Garages..... 8

 Section 5.17 – Air Classification and Recirculation..... 8

 Section 5.18 – Requirements for Buildings Containing ETS Areas and
 ETS-Free Areas..... 8

Part 2: ASHRAE Standard 62.1 Section 6 Evaluation..... 9

 Section 6.2 – Ventilation Rate Procedure..... 9

 Section 6 Results..... 10

Part 3: ASHRAE Standard 90.1 Evaluation..... 11

 Section 5 – Building Envelope..... 11

 Section 6 – Heating, Ventilating, and Air Conditioning..... 12

 Section 7 – Service Water Heating..... 14

 Section 8 – Power..... 14

 Section 9 – Lighting..... 14

 Standard 90.1 Summary..... 15

Appendix A – Ventilation Rate Calculations..... 16

Appendix B – Lighting Power Density Calculations and Schedule..... 28

List of Figures

Figure 1 – Roof Plan of Outdoor Air Intakes..... 6
Figure 2 – Exhaust Air Riser Diagram..... 6
Figure 3 – Excerpt from LEED Review..... 8
Figure 4 – ASHRAE Standard 90.1 Climate Zones..... 11

List of Tables

Table 1 – Particulate Matter Filters Compliance..... 6
Table 2 – Outside Air – Exhaust Air Comparison..... 7
Table 3 – Outdoor Air Intake Requirement..... 10
Table 4 – Total Building Glazing Area..... 11
Table 5 – Total Roof Skylight Area..... 11
Table 6 – Building Envelope Properties..... 12
Table 7 – Unitary Air Conditioners and Condensing Units..... 13
Table 8 – Fan Power Limitation..... 13
Table 9 – Duct Insulation Properties..... 14

Executive Summary



The Delaware County Community College Science, Technology, Engineering, and Mathematics (STEM) Center is a new addition to their Marple Campus, and is part of the two-building STEM Complex. At 105,000 square feet and four stories it is a focal point for the campus, and stands out with both architectural and sustainable features.

The purpose of this report is to evaluate the compliance of the building against American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE) Standards 62.1 and 90.1.

A section-by-section analysis of Standard 62.1 Section 5 (Systems and Equipment) showed full perceivable compliance. This section considered a variety of criteria, including natural ventilation, airstream surfaces, particulate matter removal, and air distribution. The building specifications indicate a high standard for system quality in all areas considered.

ASHRAE Standard 62.1 Section 6 (Procedures) led to a detailed calculation of ventilation rate for the building. The mechanical system for the STEM Center includes (2) 80,000-cfm rated rooftop air handling units and a substantial amount of outdoor air intake requirements due to the presence of laboratory and other educational spaces. In Section 6, it was determined that the building system is well beyond compliance with the calculated requirements according to ASHRAE. Largely due to the high need for fresh air and air exhaustion within the spaces, as well as the meeting of pressurization requirements, the STEM Center is found to be fully compliant with Standard 62.1 Section 6.

Finally, for ASHRAE Standard 90.1, many systems were considered in a much broader building analysis. Compliance was checked across the building envelope, HVAC systems, service water heating, power, and lighting. In this standard, a few areas of non-compliance were discovered, including building envelope properties and equipment efficiencies. For the most part, compliance was achieved, including a significant difference between the maximum lighting power density and the much lower calculated power density.

Overall, the STEM Center is found to be mostly compliant, faltering in a few sections of the ASHRAE Standards 62.1 and 90.1. It is not surprising to see these limit pushed, however, as Delaware County Community College and the design team have put great efforts into developing a quality and sustainable LEED® certified building.

PART 1 – ASHRAE Standard 62.1, Section 5 Analysis

5.1 Natural Ventilation.

Mechanical ventilation is utilized in the STEM Center, and therefore the natural ventilation requirements do not apply.

5.2 Ventilation Air Distribution.

The ventilation system has the means to achieve the minimum ventilation airflow calculated in ASHRAE Standard 62.1 Section 6. This is made possible by the significant amount of outside air taken in by the two rooftop 80,000 cfm capacity air handlers, which is necessary to assure high air quality in such spaces as laboratories and classrooms.

5.3 Exhaust Duct Location.

Ductwork that contains potentially harmful contaminants comes from the numerous lab spaces and preparation rooms on the second and third floors. This ductwork is appropriately pressurized in accordance with Sheet Metal and Air Conditioning Contractors' National Association (SMACNA) standards using a space pressurization monitoring system. This directs exhaust air to the roof top exhaust fan units.

5.4 Ventilation System Controls.

Direct Digital Controls (DDC) are used on a peer-to-peer Carrier Sense Multiple Access/Collision Detect (CSMA/CD) Ethernet Local Area Network. The control language is both LonTalk™ and BACnet. Spaces are automatically controlled to maintain minimum ventilation and airflow balance. Passive infrared occupancy sensors are used to activate fan system.

5.5 Airstream Surfaces.


PVC-Coated Galvanized Steel ductwork is in accordance with UL 181 and ASTM A 653/A 653 M. Sheet metal surfaces and metal fasteners are used otherwise.

5.6 Outdoor Air Intakes.

Rooftop outdoor air intakes are located sufficiently far away from all exhaust, including the exhaust air coming from laboratory spaces. The roof plan is shown below (Figure 1: Roof Plan of Outdoor Air Intakes), illustrating that ASHRAE Standard 62.1 Table 5-1 for minimum separation distances required are all satisfied.

Outdoor air intake is “Louvered Penthouse” type, drawing air from four sides, and is designed to prevent snow or rain entrainment. Also, appropriate screening is included on the inside of the louvers.

Figure 1: Roof Plan of Outdoor Air Intakes



5.7 Local Capture of Contaminants.

All potentially contaminated air from equipment or otherwise is ducted to rooftop exhaust fan units. Two main Greenheck exhaust fans discharge air upward at 34,000 cfm, and they are shown in Figure 2 taken from the Exhaust Air Riser Diagram (Drawing M-504). Additional exhaust fans also exhaust air to the roof top.

5.8 Combustion Air.

The flue gas system for the STEM Center is designed and installed to prevent leakage of combustion products, using high temperature silicone sealant to be gastight. Sufficient air is provided for combustion, and an integral draft diverter is utilized to “assure precise air and flue gas mixture for efficient venting” according to Specification 236330 for Water Boilers.




Figure 2: Exhaust Air Riser Diagram

5.9 Particulate Matter Removal.

Particulate filters are tested and rated in accordance with ASHRAE Standard 52.1 and 52.2 and are UL Class I or II rated. Table 1 shows compliance with necessary MERV ratings for filters.

Table 1: Particulate Matter Filters Compliance

Filters Used:	MERV Rating	Required MERV Rating	Compliance? (Y/N)
Camil Farr 30/30	8	6	Y
Viledon MV85	13	6	Y

5.10 Dehumidification Systems.

Each AHU is designed to bring in a maximum of 66,000 cfm of outdoor air (132,000 cfm total) and the maximum exhaust air cfm for all exhaust fans combined in 81,060 cfm, thus complying with the 5.10.2 standard for exfiltration. Breakdown of maximum exhaust air cfm for each exhaust fan and the comparison to maximum outdoor air cfm is shown below in Table 2.

Table 2: Outdoor Air – Exhaust Air Comparison

	Maximum Outdoor Air (cfm)	Maximum Exhaust Air (cfm)	
AHU-4	66,000	34,000	EF-1
AHU-5	66,000	34,000	EF-2
		260	EF-3
		1,480	EF-4
		3,390	EF-5
		830	EF-6
		4,600	EF-7
		1,500	EF-8
		1,000	EF-9
Total	132,000	81,060	Total

5.11 Drain Pans.

Hot water and chilled water coil drain pans are sloped in two directions appropriately (greater than 1/8” per foot) and encompass the full width of the coils. Piping for coil drain pans is 80 CPVC. Condensate recessed floor drain is continuously welded for a watertight seal.

5.12 Finned-Tube Coils and Heat Exchangers.

As previously mentioned, adequate number and sizing of drain pans are provided and addressed in specifications.

5.13 Humidifiers and Water-Spray Systems.

The STEM Center does not use humidifiers or water-spray systems; therefore this part of ASHRAE Standard 62.1 Section 5 does not apply.

5.14 Access for Inspection, Cleaning, Maintenance.

Full access has been required for all common HVAC work as per Specification 230500. This includes sufficient sizing of shafts, chases, clearances, access doors, as well as proper location of all equipment to ensure full accessibility.

5.15 Building Envelope and Interior Surfaces.

The STEM Center uses composite-HDPE/bentonite membrane waterproofing, as well as single-component, modified polyurethane waterproofing for perimeter foundation walls. Vapor seal is placed on concealed side of metal wall panels. Metal wall panel assembly includes components necessary for a weathertight system. Air infiltration is no more than 0.06 cfm/sq. ft. of wall area, tested according to ASTM E 283. Composite wall panels are fabricated in a manner that eliminates condensation on the interior side of panel.

5.16 Buildings with Attached Parking Garages.

There is no attached Parking Garage for the STEM Center; therefore this section of Standard 62.1 does not apply.

5.17 Air Classification and Recirculation.

All spaces in the STEM Center are Class 1 air class according to Standard 62.1 Table 6-1, with the exception of all laboratory spaces. For such rooms (Classes 2 and 4), air is exhausted straight to the rooftop exhaust fans and is not recirculated.

5.18 Requirements for Buildings Containing ETS Areas and ETS-Free Areas.

As a requirement for LEED® Certification, the STEM Center is a smoke-free building and therefore the requirements for ETS and ETS-Free areas in Standard 62.1 do not apply. Excerpt from the LEED® review is shown below with item “EQp 2 Environmental Tobacco Smoke Control” highlighted.

	MR 6	Rapidly Renewable Materials	1		1	2.5% materials extracted, processed and manufactured w/ 100% times
	MR 7	Certified Wood	1	1		50% of wood based materials from FSC certified sources
Enhance Indoor Environmental Quality	EQp 1	Minimum IAQ Performance		R		Must meet ASHRAE 62-2004
	EQp 2	Environmental Tobacco Smoke Control		R		Prohibit smoking in the building
	EQ 1	Outdoor Air Delivery Monitoring	1	1		Permanent CO2 monitoring w/ operation adjustments
	EQ 2	Increased Ventilation	1		1	\$ Outdoor Air delivery 30% over ASHRAE 62-2004
	EQ 3.1	Construction IAQ- During Construction	1	1		comply with SMACNA standards, MERV 8 filters during construction
	EQ 3.2	Construction IAQ- Before Occupancy	1	1		employ building flush out or do indoor air quality testing
	EQ 4.1	Low-Emitting Materials- Adhesives/Sealants	1	1		Low VOC adhesives and sealants
	EQ 4.2	Low-Emitting Materials- Paints and Coatings	1	1		Low VOC paints, primers, anti-rust paints, anti-corrosives, sealers, stains
	EQ 4.3	Low-Emitting Materials- Carpet	1	1		CRI Green Labeled Plus carpet, Green Labeled cushion, low VOC adhesive
	EQ 4.4	Low-Emitting Materials- Composite wood/agrifiber	1	1		No-added-urea-formaldehyde composite wood or agrifiber products only
	EQ 5	Indoor Chemical Pollution Source Control	1	1		entryway systems, isolation of chemical pollutants, and MERV 13 filters
	EQ 6.1	Controllability of Systems- Lighting	1	1		Individual lighting controls for 90% of occupants
	EQ 6.2	Controllability of Systems- Thermal Comfort	1		1	Thermal controls as per ASHRAE 55-2004 for 50% of occupants
EQ 7.1	Thermal Comfort- Design	1	1		HVAC and envelope design must meet ASHRAE 55-2004	
EQ 7.2	Thermal Comfort- Verification	1	1		Agreement for post-occupancy survey and remediation	
EQ 8.1	Daylighting	1	1		minimum 2% daylighting factor in 75% of regularly occupied spaces	
EQ 8.2	Views	1	1		views from 90% of regularly occupied spaces	

Figure 3: Excerpt from LEED® Review

PART 2 – ASHRAE Standard 62.1, Section 6 Analysis

6.2 Ventilation Rate Procedure.

Ventilation rate calculations were conducted to determine the minimum outdoor air requirements for ventilation. This analysis was done for nearly all the spaces in the STEM Center (neglecting such spaces as toilet and mechanical rooms), and was based on floor area (A_z), number of occupants (P_z), design supply air cfm (V_{dzd}), and the space type. The rooms analyzed were those selected as potentially critical zones, and these included classrooms, offices, conference rooms, laboratories, preparation rooms, fitness rooms, and locker rooms.

6.2.2 Zone calculations:

The following equations and methods are provided by ASHRAE Standard 62.1 Section 6 for determining outdoor air ventilation rate. These equations, used in an Excel spreadsheet were used to for ventilation rate analysis.

Eqn. 6-1:
$$V_{bz} = R_p * P_z + R_a * A_z$$

A_z = Zone floor area (ft^2)

P_z = Zone population (*people*)

R_p = Outdoor air flow rate ($\frac{cfm}{person}$)

R_a = Outdoor airflow rate ($\frac{cfm}{ft^2}$)

Zone Air Distribution Effectiveness:

$E_z = 1.0$ (As defined by Table 6-2)

Zone Outdoor Airflow:

Eqn. 6-2:
$$V_{oz} = \frac{V_{bz}}{E_z}$$

Primary Outdoor Air Fraction:

Eqn. 6-5:
$$Z_p = \frac{V_{oz}}{V_{pz}}$$

Occupant Diversity:

Eqn. 6-7:
$$D = \frac{P_s}{\sum_{all\ zones} P_z}$$

P_s = System Population

Uncorrected Outdoor Air Intake:

Eqn. 6-6:
$$V_{ou} = D \sum_{all\ zones} (R_p * P_z) + \sum_{all\ zones} (R_a * A_z)$$

Outdoor Air Intake:

Eqn. 6-7:
$$V_{ot} = \frac{V_{ou}}{E_v}$$

Section 6 Results:

Excel spreadsheets of calculations can be found in Appendix A, showing analysis for the building’s two air handlers, AHU-4 and AHU-5. All four floors were analyzed, and the total outdoor air intake required was determined to be 43,738 cfm. This compared to the minimum outdoor air cfm of each air handler (66,000 cfm) shows that the STEM Center design exceeds the ASHRAE standard for outdoor air by a significant amount. Because of the amount of air needed for adequate exhausting of laboratory spaces and supplying of numerous classrooms, a substantial amount of outdoor air is required to maintain indoor air quality for the building occupants. This analysis, shown in Table 3 below, concludes that the building design more than accounts for that need.

Table 3: Outdoor Air Intake Requirement

	Outdoor Air Intake Required (cfm)
First Floor	18,349
Second Floor	10,007
Third Floor	10,462
Fourth Floor	4,930
Total	43,748
Design Maximum	132,000
Outdoor Air cfm	

Because the air handling units greatly exceed the requirements, V_{oz} (unused outdoor air requirement for zone) totaled for all four floors is 22,978 cfm. This value is significant and gives a point of potential improvement for the air handling system.

PART 3 – ASHRAE Standard 90.1

Section 5: Building Envelope

The STEM Center, and the rest of the Delaware County Community College (Marple Campus), lies in **Climate Zone 4A** according to map seen below in Figure 3.




Figure 4: ASHRAE Standard 90.1 Climate Zones

Due mainly to a substantial glass curtain wall system on the south façade of the building, the STEM Center does not comply with the ASHRAE Standard 90.1 maximum allowable vertical fenestration area percentage of 40%. With 2,583 ft² of exterior windows and 19,558 ft² of glass curtain wall, the vertical glazing percentage is 46.61% as tallied in Table 4.

Table 4: Total Building Glazing Area

	Exterior Windows	Glass Curtain Wall	Exterior Walls (Gross)	Percentage Glazing	Max. Percent Allowed	Compliance? (Y/N)
Total Area (SF)	2,583.28	19,558.47	47,501.20	46.61%	40%	N

There is only one skylight, which is circular with an 8’ diameter. This is not nearly enough to exceed the maximum percent allowable as shown below in Table 5.

Table 5: Total Roof Skylight Area

	Dome Skylight	Roof Area (Gross)	Percentage Skylight	Max. Percent Allowed	Compliance? (Y/N)
Total Area (SF)	50.27	28,430.11	0.18%	5%	Y

Requirements for building envelope sealing as per section 5.4.3.1 of Standard 90.1 are met with elastomeric joint sealants. These sealants maintain watertight and airtight continuous joint seals for fenestration, wall systems, building assemblies, etc.

In regards to fenestration air leakage, glazed aluminum curtain-wall systems and all aluminum-framed systems have a maximum air leakage of 0.06 cfm/ft², and skylights have a maximum of 0.3 cfm/ft² according to ASTM E 283 testing. This justifies the standard of 0.4 cfm/ft².

There is a minimum distance between doors for vestibules in section 5.4.3.4. For the STEM Center, vestibules such as the main south side entrance have a distance between interior and exterior doors greater than 7 ft, satisfying the requirement.

Using the Prescriptive Building Envelope Option as per ASHRAE Standard 90.1 Section 5.5 for non-residential building type, and using Tables 5.5-1 through 5.5-8, the building's thermal properties is analyzed. Also used for calculation of thermal properties is Appendix A of ASHRAE Standard 90.1. Displayed below in Table 6 is the summary of that analysis, showing that according to the calculated U-Values and R-Values, all building envelope materials comply, except the floor properties do not satisfy the standard.

Table 6: Building Envelope Properties

	U-Value	Max Std. U-Value	R-Value	Min Std. R-Value	Compliance? (Y/N)
Roof	0.03446	0.048	28	20	Y
Walls	0.05052	0.113	26	13	Y
Floors	0.06733	0.038	30	30	N
Doors	0.2	0.7			Y
			SHGC	Min Std. SHGC	
Glass	0.29	0.5	0.41	0.4	Y
Skylight	1.2	1.3	0.68	0.65	Y

Section 6: Heating, Ventilating, and Air Conditioning

In this section of ASHRAE Standard 90.1, different equipment is analyzed for compliance in such criteria as efficiency and capacity. Tables 6.8.1A-6.8.1J provides the minimum efficiency requirements. Additionally, evaluation of compliance is performed for several other components of the HVAC system as well, and those are as follows:

Standard 6.4.4: All metal ducts have a class C seal level, meeting the requirements of Table 6.4.4.2A.

Standard 6.5.1: No economizer requirement for Climate Zone 4A according to ASHRAE Standard 90.1 Table.

Standard 6.5.6: Due to exhaust rate greater than 15,000 cfm, the STEM Center complies with ASHRAE Standard 90.1 section on fume hoods by using a heat recovery system in accordance with Section 6.5.6.1

Section 6.8 – Minimum Equipment Efficiency:

Unitary Air Conditioners and Condensing Units

Shown below in Table 7 is the evaluation of compliance for the split system condensing units, for which each unit has a Seasonal Energy Efficiency Ratio (SEER) or 13.5.

Table 7: Unitary Air Conditioners and Condensing Units

Mark	Service	MBH	SEER	Minimum SEER	Compliance? (Y/N)
ACC-1A	AH-1A	24,000	13.5	9.5	Y
ACC-1E	AH-1E	24,000	13.5	9.5	Y
ACC-2A	AH-2A	24,000	13.5	9.5	Y
ACC-2E	AH-2E	24,000	13.5	9.5	Y
ACC-3A	AH-3A	24,000	13.5	9.5	Y
ACC-4A	AH-4A	24,000	13.5	9.5	Y

Table 8 shows a comparison of fan horsepower and maximum horsepower required. The maximum horsepower is determined based on the equation in Table 6.5.3.1.1A. For several of the supply and return fans, maximum horsepower is exceeded and does not comply.

Table 8: Fan Power Limitation

	CFM	HP	Factor	Max HP	Compliance? (Y/N)
EF-1	34,000	50	0.0011	37.4	N
EF-2	34,000	50	0.0011	37.4	N
EF-3	260	0.167	0.0011	0.286	Y
EF-4	1,480	0.5	0.0011	1.628	Y
EF-5	3,390	1.5	0.0011	3.729	Y
EF-6	830	0.25	0.0011	0.913	Y
EF-7	4,600	2	0.0011	5.06	Y
EF-8	1,500	0.333	0.0011	1.65	Y
EF-9	1,000	0.333	0.0011	1.1	Y
SF-4A	44,750	60	0.0011	49.225	N
SF-4B	44,750	60	0.0011	49.225	N
RF-4A	21,500	30	0.0011	23.65	N
RF-4B	21,500	30	0.0011	23.65	N
SF-5A	44,750	60	0.0011	49.225	N
SF-5B	44,750	60	0.0011	49.225	N
RF-5A	21,500	30	0.0011	23.65	N
RF-5B	21,500	30	0.0011	23.65	N
SF-1	3,600	1.5	0.0011	3.96	Y

Water-cooled chillers are specified as meeting ASHRAE Standard 90.1 requirements for capacity, energy efficiency, IPLV, and NPLV for centrifugal chillers greater than 300 tons, according to ARI 550/590 rating and testing.

Compliance for duct insulation is checked through calculating R-Values from known insulation type (and subsequent k-values) and minimum thickness. Shown below in Table 9 is the evaluation of this comparison.

Table 9: Duct Insulation Properties

	Insulation Type	Min Thickness	R-Value	Standard R-Value	Compliance? (Y/N)
Supply - Concealed	I-3	2	5.6	6	N
Supply - Outdoors	I-2	2	8.7	6	Y
Return - Outdoors	I-2	2	8.7	3.5	Y
Return - Within 50 ft. of AHU	I-2	2	8.7	3.5	Y

The ASHRAE Standard 90.1 for pipe insulation is satisfied for the STEM Center, as piping insulation thickness is specified at 1" for piping 2" or smaller, and 1.5" for bigger than 2".

Section 7 – Service Water Heating

Two Bryan Model DR-350WT-FDG gas fired domestic water heaters are used for heating. Each has a capacity of 336 GPH, and complies with the minimum efficiency of 80 percent required for water heaters above 100,000 BTU/hr.

Section 8 – Power

ASHRAE Standard 90.1 Section 8 requires a maximum voltage drop of 2% for feeders and 3% for branch circuits. Specifications for wiring indicate a maximum voltage drop of 6%, which is higher than the standard, and therefore deemed not necessarily compliant with this section.

Section 9 – Lighting

9.4.1 Lighting Control

Automatic shutoff for lighting exists for the STEM Center using an internal scheduler that takes into account days of the week, holidays, daylight savings time, etc. This design feature satisfies requirements for Standard 90.1 9.4.1.1 for automatic lighting shutoff. For individual spaces, ceiling mount PIR occupancy sensors account for lighting shutoff when spaces are vacant.

9.5 Building Area Method Compliance Path

According to Standard 90.1 Table 9.5.1, the Lighting Power Densities (LPD) for School/University building area type is 1.2 W/ft². This value is multiplied by the gross lighted floor areas to give an interior lighting power allowance of 126 kW. Found in Appendix B is a breakdown of the building’s lighting wattage per fixture in actual watts, totaling 89 kW. This is well under the allowable lighting power, a difference of 1.2 W/ft² to approximately 0.84 W/ft².

ASHRAE Standard 90.1 Summary:

Through evaluation of Standard 90.1, several instances were found in which the building design does not comply with the standard, as well as a handful of instances in which the building design greatly exceeds the requirements.

In the case of the building glazing area, the non-compliance is a result of a bold architectural feature in which one side of the building is colorful brick façade while the other is a four-story glass curtain wall. It is possible that a tradeoff occurred with the upgrade of the mechanical system in the way of ventilation. As previously discussed, the total maximum outdoor air intake for the two roof top air handling units is over 100,000 cfm, which is substantially higher than the calculated minimum required outdoor air (see Appendix A for breakdown). So whereas the excess of glazing may produce higher solar heat gain, it can be conceived that the increase in air ventilation will improve circulation and comfort as well as air quality.

The other main area of non-compliance is found with the air fans excessive horsepower. This limit may be pushed because of the large need for air exhaust due to the building occupancy types. Several laboratory spaces and preparation rooms make for a high requirement for exhaust air. This increases the need for fan power and raises the maximum horsepower. The number of fans may need to be reconsidered and recalculated.

Appendix A: Outside Air Ventilation Calculations

Building:		Delaware County Community College STEM Center	
System Tag/Name:			
Operating Condition Description:			
Units (select from pull-down list)		IP	
Inputs for System		Name	Units
Floor area served by system	As	13774	sf
Population of area served by system (including diversity)	Ps	383	P
Design primary supply fan airflow rate	Vpsd	20,100	cfm
OA req'd per unit area for system (Weighted average)	Ras	0.06	cfm/sf
OA req'd per person for system area (Weighted average)	Rps	9.1	cfm/p
Inputs for Potentially Critical Zones			
Zone Name	Zone title turns purple italic for critical zone(s)		
Zone Tag	100% diversity		
Space Type	Select from pull-down list		
Floor Area of zone	Az	1,007	sf
Design population of zone	Pz	30	P
Design total supply to zone (primary plus local recirculated)	Vztd	1,200	cfm
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?	Select from pull-down list or leave blank (if N/A)		
Local recirc. air % representative of ave system return air	Er		%
Inputs for Operating Condition Analyzed			
Percent of total design airflow rate at conditioned analyzed	Ds	100%	%
Air distribution type at conditioned analyzed	Ez	C-S	C-S
Zone air distribution effectiveness at conditioned analyzed	Ep	1.00	1.00
Primary air fraction of supply air at conditioned analyzed	Select from pull-down list		
Results			
Ventilation System Efficiency	Ev	0.24	
Outdoor air intake required for system	Vot	18349	cfm
Outdoor air per unit floor area	Vot/As	1.33	cfm/sf
Outdoor air per person served by system (including diversity)	Vot/Ps	47.9	cfm/p
Outdoor air as a % of design primary supply air	Ypd	91%	cfm
Detailed Calculations			
Initial Calculations for the System as a whole			
Primary supply air flow to system at conditioned analyzed	Vps	=	20100
Uncorrected OA requirement for system	You	=	4370
Uncorrected OA req'd as a fraction of primary SA	Xs	=	0.22
Initial Calculations for Individual zones			
OA rate per person	Raz	=	0.12
Total supply air to zone (at condition being analyzed)	Rpz	=	10.00
Unused OA req'd to breathing zone	Vbz	=	1200
Fraction of zone supply not directly recirc. from zone	Fa	=	4.21
Fraction of zone supply from fully mixed primary air	Fb	=	1.00
Fraction of zone OA not directly recirc. from zone	Fc	=	1.00
Unused OA fraction required in supply air to zone	Zd	=	0.35
Unused OA fraction required in primary air to zone	Zp	=	0.35
System Ventilation Efficiency			
Zone Ventilation Efficiency (App A Method)	Evz	=	0.87
System Ventilation Efficiency (App A Method)	Ev	=	0.24
Ventilation System Efficiency (Table 6.3 Method)	Ev	=	n/a
Minimum outdoor air intake airflow			
Outdoor Air Intake Flow required to System	Vot	=	18349
OA intake req'd as a fraction of primary SA	Y	=	0.91
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Vot	=	n/a
OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Y	=	n/a
OA Temp at which Min OA provides all cooling			
OA Temp below which OA intake flow is @ minimum	Deg F	=	53

Building: Delaware County Community College STEM Center																																																																																																																									
System Tag/Name:																																																																																																																									
Operating Condition Description:																																																																																																																									
Units (select from pull-down list)																																																																																																																									
IP																																																																																																																									
<table border="1"> <thead> <tr> <th>Name</th> <th>Units</th> <th>System</th> </tr> </thead> <tbody> <tr> <td>As</td> <td>sf</td> <td>13774</td> </tr> <tr> <td>Ps</td> <td>P</td> <td>383</td> </tr> <tr> <td>Vpsd</td> <td>cfm</td> <td>20,100</td> </tr> <tr> <td>Ras</td> <td>cfm/sf</td> <td>0.06</td> </tr> <tr> <td>Rps</td> <td>cfm/p</td> <td>9.1</td> </tr> </tbody> </table>		Name	Units	System	As	sf	13774	Ps	P	383	Vpsd	cfm	20,100	Ras	cfm/sf	0.06	Rps	cfm/p	9.1																																																																																																						
Name	Units	System																																																																																																																							
As	sf	13774																																																																																																																							
Ps	P	383																																																																																																																							
Vpsd	cfm	20,100																																																																																																																							
Ras	cfm/sf	0.06																																																																																																																							
Rps	cfm/p	9.1																																																																																																																							
Inputs for System Floor area served by system Population of area served by system (including diversity) Design primary supply fan airflow rate OA req'd per unit area for system (Weighted average) OA req'd per person for system area (Weighted average)																																																																																																																									
Inputs for Potentially Critical Zones Zone Name Zone Tag Space type Floor Area of zone Design population of zone Design total supply to zone (primary plus local recirculated) Induction Terminal Unit, Dual Fan Duct or Transfer Fan? Local recirc. air % representative of ave system return air																																																																																																																									
Zone Name: S121B Office S100C Lower Lounge S100E Upper Lounge S100D Computer Lounge S120 Auditorium Zone Tag: 1st Floor 1st Floor 1st Floor 1st Floor 1st Floor Space type: Office space Multipurpose assembly Multipurpose assembly Multipurpose assembly Auditorium seating area Floor Area of zone: 80 1206 2975 1782 1475 Design population of zone: 1 20 44 44 54 Design total supply to zone (primary plus local recirculated): 120 3820 4130 1500 2180 Induction Terminal Unit, Dual Fan Duct or Transfer Fan?: Local recirc. air % representative of ave system return air:																																																																																																																									
Inputs for Operating Condition Analyzed Percent of total design airflow rate at conditioned analyzed Air distribution type at conditioned analyzed Zone air distribution effectiveness at conditioned analyzed Primary air fraction of supply air at conditioned analyzed																																																																																																																									
Ds % 100% Ez % 100% Ep % 100%																																																																																																																									
Results Ventilation System Efficiency: 0.24 Outdoor air intake required for system: 18349 Outdoor air per unit floor area: 1.33 Outdoor air per person served by system (including diversity): 47.9 Outdoor air as a % of design primary supply air: 91%																																																																																																																									
Detailed Calculations Initial Calculations for the System as a whole Primary supply air flow to system at conditioned analyzed Uncorrected OA requirement for system Uncorrected OA req'd as a fraction of primary SA Initial Calculations for Individual Zones OA rate per unit area for zone OA rate per person Total supply air to zone (at condition being analyzed) Unused OA req'd to breathing zone Unused OA requirement for zone Fraction of zone supply not directly recirc. from zone Fraction of zone supply from fully mixed primary air Fraction of zone OA not directly recirc. from zone Unused OA fraction required in supply air to zone Unused OA fraction required in primary air to zone System Ventilation Efficiency Zone Ventilation Efficiency (App A Method) System Ventilation Efficiency (App A Method) Ventilation System Efficiency (Table 6.3 Method) Minimum outdoor air intake airflow Outdoor Air Intake Flow required to System OA intake req'd as a fraction of primary SA Outdoor Air Intake Flow required to System (Table 6.3 Method) OA intake req'd as a fraction of primary SA (Table 6.3 Method) OA Temp at which Min OA provides all cooling OAT: below which OA intake flow is @ minimum																																																																																																																									
<table border="1"> <tbody> <tr> <td>Vps</td> <td>cfm</td> <td>=</td> <td>VpdDs</td> <td>=</td> <td>20100</td> </tr> <tr> <td>Vou</td> <td>cfm</td> <td>=</td> <td>Rps Ps + Ras As</td> <td>=</td> <td>4370</td> </tr> <tr> <td>Xs</td> <td></td> <td>=</td> <td>Vou / Vps</td> <td>=</td> <td>0.22</td> </tr> <tr> <td>Raz</td> <td>cfm/sf</td> <td>=</td> <td></td> <td>=</td> <td></td> </tr> <tr> <td>Rbz</td> <td>cfm/p</td> <td>=</td> <td></td> <td>=</td> <td></td> </tr> <tr> <td>Vaz</td> <td>cfm</td> <td>=</td> <td>Rpz Pz + Rbz Az</td> <td>=</td> <td></td> </tr> <tr> <td>Vbz</td> <td>cfm</td> <td>=</td> <td>Vbz/Ez</td> <td>=</td> <td></td> </tr> <tr> <td>Voz</td> <td>cfm</td> <td>=</td> <td>Ep + (1-Ep)Er</td> <td>=</td> <td></td> </tr> <tr> <td>Fa</td> <td></td> <td>=</td> <td>Ep</td> <td>=</td> <td></td> </tr> <tr> <td>Fb</td> <td></td> <td>=</td> <td>1-(1-Ez)(1-Ep)(1-Er)</td> <td>=</td> <td></td> </tr> <tr> <td>Zd</td> <td></td> <td>=</td> <td>Voz / Vaz</td> <td>=</td> <td></td> </tr> <tr> <td>Zp</td> <td></td> <td>=</td> <td>Voz / Vpz</td> <td>=</td> <td></td> </tr> <tr> <td>Evz</td> <td></td> <td>=</td> <td>(Fa + Fbx - Fcz) / Fa</td> <td>=</td> <td></td> </tr> <tr> <td>Ev</td> <td></td> <td>=</td> <td>min (Evz)</td> <td>=</td> <td>0.24</td> </tr> <tr> <td>Ev</td> <td></td> <td>=</td> <td>Value from Table 6.3</td> <td>=</td> <td>n/a</td> </tr> <tr> <td>Vot</td> <td>cfm</td> <td>=</td> <td>Vou / Ev</td> <td>=</td> <td>18349</td> </tr> <tr> <td>Y</td> <td>cfm</td> <td>=</td> <td>Vot / Vps</td> <td>=</td> <td>0.91</td> </tr> <tr> <td>Y</td> <td>cfm</td> <td>=</td> <td>Vou / Ev</td> <td>=</td> <td>n/a</td> </tr> <tr> <td>Y</td> <td>cfm</td> <td>=</td> <td>Vot / Vps</td> <td>=</td> <td>n/a</td> </tr> <tr> <td>Deg F</td> <td></td> <td>=</td> <td>{(Tp-dTs)-(1-Y)} / (1-dTr)</td> <td>=</td> <td>53</td> </tr> </tbody> </table>		Vps	cfm	=	VpdDs	=	20100	Vou	cfm	=	Rps Ps + Ras As	=	4370	Xs		=	Vou / Vps	=	0.22	Raz	cfm/sf	=		=		Rbz	cfm/p	=		=		Vaz	cfm	=	Rpz Pz + Rbz Az	=		Vbz	cfm	=	Vbz/Ez	=		Voz	cfm	=	Ep + (1-Ep)Er	=		Fa		=	Ep	=		Fb		=	1-(1-Ez)(1-Ep)(1-Er)	=		Zd		=	Voz / Vaz	=		Zp		=	Voz / Vpz	=		Evz		=	(Fa + Fbx - Fcz) / Fa	=		Ev		=	min (Evz)	=	0.24	Ev		=	Value from Table 6.3	=	n/a	Vot	cfm	=	Vou / Ev	=	18349	Y	cfm	=	Vot / Vps	=	0.91	Y	cfm	=	Vou / Ev	=	n/a	Y	cfm	=	Vot / Vps	=	n/a	Deg F		=	{(Tp-dTs)-(1-Y)} / (1-dTr)	=	53
Vps	cfm	=	VpdDs	=	20100																																																																																																																				
Vou	cfm	=	Rps Ps + Ras As	=	4370																																																																																																																				
Xs		=	Vou / Vps	=	0.22																																																																																																																				
Raz	cfm/sf	=		=																																																																																																																					
Rbz	cfm/p	=		=																																																																																																																					
Vaz	cfm	=	Rpz Pz + Rbz Az	=																																																																																																																					
Vbz	cfm	=	Vbz/Ez	=																																																																																																																					
Voz	cfm	=	Ep + (1-Ep)Er	=																																																																																																																					
Fa		=	Ep	=																																																																																																																					
Fb		=	1-(1-Ez)(1-Ep)(1-Er)	=																																																																																																																					
Zd		=	Voz / Vaz	=																																																																																																																					
Zp		=	Voz / Vpz	=																																																																																																																					
Evz		=	(Fa + Fbx - Fcz) / Fa	=																																																																																																																					
Ev		=	min (Evz)	=	0.24																																																																																																																				
Ev		=	Value from Table 6.3	=	n/a																																																																																																																				
Vot	cfm	=	Vou / Ev	=	18349																																																																																																																				
Y	cfm	=	Vot / Vps	=	0.91																																																																																																																				
Y	cfm	=	Vou / Ev	=	n/a																																																																																																																				
Y	cfm	=	Vot / Vps	=	n/a																																																																																																																				
Deg F		=	{(Tp-dTs)-(1-Y)} / (1-dTr)	=	53																																																																																																																				

Building:		Delaware County Community College STEM Center	
System Tag/Name:			
Operating Condition Description:			
Units (select from pull-down list)			
IP			
Inputs for System	Name Units	System	
Floor area served by system	As sf	18409	
Population of area served by system (including diversity)	Ps P	461	
Design primary supply fan airflow rate	Vpsd cfm	29,110	
OA req'd per unit area for system (Weighted average)	Ras cfm/sf	0.13	
OA req'd per person for system area (Weighted average)	Rps cfm/p	9.4	
Inputs for Potentially Critical Zones			
Zone Name			
Zone Tag			
Space type			
Floor Area of zone	Az sf		
Design population of zone	Pz P		
Design total supply to zone (primary plus local recirculated)	Vztd cfm		
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?			
Local recirc. air % representative of ave. system return air	Er %		
Inputs for Operating Condition Analyzed			
Percent of total design airflow rate at conditioned analyzed	Ds %	100%	
Air distribution type at conditioned analyzed	Ez %	CS	
Zone air distribution effectiveness at conditioned analyzed	Ep %	1.00	
Primary air fraction of supply air at conditioned analyzed			
Results			
Ventilation System Efficiency	Ev	0.68	
Outdoor air intake required for system	Vot cfm	10007	
Outdoor air per unit floor area	Vol/As cfm/sf	0.54	
Outdoor air per person served by system (including diversity)	Vol/Ps cfm/p	21.7	
Outdoor air as a % of design primary supply air	Ypd cfm	34%	
Detailed Calculations			
Initial Calculations for the System as a whole			
Primary supply air flow to system at conditioned analyzed	Vps cfm	=	29110
Uncorrected OA requirement for system	Vou cfm	=	6762
Uncorrected OA req'd as a fraction of primary SA	Xs	=	0.23
Initial Calculations for individual zones			
OA rate per unit area for zone	Raz cfm/sf	=	0.12
OA rate per person	Rpz cfm/p	=	10.00
Total supply air to zone (at condition being analyzed)	Vdz cfm	=	1300
Unused OA req'd to breathing zone	Vbz cfm	=	543.4
Unused OA requirement for zone	Voz cfm	=	543
Fraction of zone supply not directly recirc. from zone	Fa	=	1.00
Fraction of zone supply from fully mixed primary air	Fb	=	Ep + (1-Ep)Er
Fraction of zone OA not directly recirc. from zone	Fc	=	1 - (1-Ez)X(1-Er)
Unused OA fraction required in supply air to zone	Zd	=	Voz / Vdz
Unused OA fraction required in primary air to zone	Zp	=	Voz / Vpz
System Ventilation Efficiency			
Zone Ventilation Efficiency (App A Method)	Evz	=	(Fa + FbXs - FcZ) / Fa
System Ventilation Efficiency (App A Method)	Ev	=	min (Evz)
Ventilation System Efficiency (Table 6.3 Method)	Ev	=	Value from Table 6.3
Minimum outdoor air intake airflow			
Outdoor Air Intake Flow required to System	Vot cfm	=	10007
OA intake req'd as a fraction of primary SA	Y	=	0.34
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Y	=	nia
OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Y	=	nia
OA Temp at which Min OA provides all cooling			
OAT below which OA intake flow is @ minimum	Deg F	=	23

Building: Delaware County Community College STEM Center																																																																																																																																																																										
System Tag/Name:																																																																																																																																																																										
Operating Condition Description:																																																																																																																																																																										
Units (select from pull-down list)																																																																																																																																																																										
IP																																																																																																																																																																										
Inputs for System	<table border="1"> <tr><td>System</td><td>18409</td></tr> <tr><td>As</td><td>sf</td></tr> <tr><td>Ps</td><td>P</td></tr> <tr><td>Vpsd</td><td>cfm</td></tr> <tr><td>Ras</td><td>cfm/sf</td></tr> <tr><td>Rps</td><td>cfm/p</td></tr> </table>	System	18409	As	sf	Ps	P	Vpsd	cfm	Ras	cfm/sf	Rps	cfm/p																																																																																																																																																													
System	18409																																																																																																																																																																									
As	sf																																																																																																																																																																									
Ps	P																																																																																																																																																																									
Vpsd	cfm																																																																																																																																																																									
Ras	cfm/sf																																																																																																																																																																									
Rps	cfm/p																																																																																																																																																																									
Population of area served by system (including diversity)	100% diversity																																																																																																																																																																									
Design primary supply fan airflow rate																																																																																																																																																																										
OA req'd per unit area for system (Weighted average)																																																																																																																																																																										
OA req'd per person for system area (Weighted average)																																																																																																																																																																										
Inputs for Potentially Critical zones																																																																																																																																																																										
Zone Name																																																																																																																																																																										
Zone Tag																																																																																																																																																																										
Space type																																																																																																																																																																										
Floor Area of zone																																																																																																																																																																										
Design population of zone																																																																																																																																																																										
Design total supply to zone (primary plus local recirculated)																																																																																																																																																																										
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?																																																																																																																																																																										
Local recirc. air % representative of ave system return air																																																																																																																																																																										
Inputs for Operating Condition Analyzed																																																																																																																																																																										
Percent of total design airflow rate at conditioned analyzed	100%																																																																																																																																																																									
Air distribution type at conditioned analyzed	CS																																																																																																																																																																									
Zone air distribution effectiveness at conditioned analyzed	1.00																																																																																																																																																																									
Primary air fraction of supply air at conditioned analyzed	1.00																																																																																																																																																																									
Results																																																																																																																																																																										
Ventilation System Efficiency	0.68																																																																																																																																																																									
Outdoor air intake required for system	10007																																																																																																																																																																									
Outdoor air per unit floor area	0.64																																																																																																																																																																									
Outdoor air per person served by system (including diversity)	21.7																																																																																																																																																																									
Outdoor air as a % of design primary supply air	34%																																																																																																																																																																									
Detailed Calculations																																																																																																																																																																										
Initial Calculations for the System as a whole																																																																																																																																																																										
Primary supply air flow to system at conditioned analyzed	Vps = 29110																																																																																																																																																																									
Uncorrected OA requirement for system	= Rps Ps + Ras As = 6762																																																																																																																																																																									
Uncorrected OA req'd as a fraction of primary SA	= Vou / Vps = 0.23																																																																																																																																																																									
Initial Calculations for Individual zones																																																																																																																																																																										
OA rate per unit area for zone	Raz																																																																																																																																																																									
OA rate per person	Rpz																																																																																																																																																																									
Total supply air to zone (at condition being analyzed)	Vdz																																																																																																																																																																									
Unused OA req'd to breathing zone	Vbz																																																																																																																																																																									
Unused OA requirement for zone	Voz																																																																																																																																																																									
Fraction of zone supply not directly recirc. from zone	Fa																																																																																																																																																																									
Fraction of zone supply from fully mixed primary air	Fb																																																																																																																																																																									
Fraction of zone OA not directly recirc. from zone	Fc																																																																																																																																																																									
Unused OA fraction required in supply air to zone	Zd																																																																																																																																																																									
Unused OA fraction required in primary air to zone	Zp																																																																																																																																																																									
System Ventilation Efficiency																																																																																																																																																																										
Zone Ventilation Efficiency (App A Method)	Evz = (Fa + Fb)Xs - Fcz) / Fa = 1.04																																																																																																																																																																									
System Ventilation Efficiency (App A Method)	Ev = min (Evz) = 0.68																																																																																																																																																																									
Ventilation System Efficiency (Table 6.3 Method)	Ev = Value from Table 6.3 = n/a																																																																																																																																																																									
Minimum outdoor air intake airflow																																																																																																																																																																										
Outdoor Air Intake Flow required to System	Vot = Vou / Ev = 10007																																																																																																																																																																									
OA intake req'd as a fraction of primary SA	Y = Vot / Vps = 0.34																																																																																																																																																																									
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Vot = n/a																																																																																																																																																																									
OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Y = n/a																																																																																																																																																																									
OA Temp at which Min OA provides all cooling																																																																																																																																																																										
OAT below which OA Intake flow is @ minimum	Deq F = 23																																																																																																																																																																									
<table border="1"> <thead> <tr> <th colspan="2">Potentially Critical Zones</th> </tr> <tr> <th>Zone Name</th> <th>Zone Tag</th> <th>Space type</th> <th>Floor Area (sf)</th> <th>Design Pop</th> <th>Design Total Supply (cfm)</th> <th>Induction Unit</th> <th>Local Recirc. Air %</th> <th>OA Rate per Unit Area (cfm/sf)</th> <th>OA Rate per Person (cfm/p)</th> <th>Total Supply (cfm)</th> <th>Unused OA (cfm)</th> <th>Unused OA Req'd (cfm)</th> <th>Fraction of Zone Supply Not Directly Recirc. (Fa)</th> <th>Fraction of Zone Supply from Fully Mixed Primary Air (Fb)</th> <th>Fraction of Zone OA Not Directly Recirc. (Fc)</th> <th>Unused OA Fraction in Supply Air (Zd)</th> <th>Unused OA Fraction in Primary Air (Zp)</th> <th>Zone Vent. Eff. (Evz)</th> <th>System Vent. Eff. (Ev)</th> <th>Min OA Intake Flow (Vot)</th> <th>OA Intake Req'd as Fraction of Primary SA (Y)</th> <th>OAT for All-Cooling (Deq F)</th> </tr> </thead> <tbody> <tr> <td>S212 Biology</td> <td>S215 Biology</td> <td>2nd Floor</td> <td>1421</td> <td>32</td> <td>2980</td> <td></td> <td></td> <td>100%</td> <td>100%</td> <td>100%</td> <td>100%</td> <td>100%</td> <td>CS</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>10007</td> <td>0.34</td> <td>n/a</td> </tr> <tr> <td>S216 CAD</td> <td>S216 CAD</td> <td>2nd Floor</td> <td>1083</td> <td>32</td> <td>1240</td> <td></td> <td></td> <td>100%</td> <td>100%</td> <td>100%</td> <td>100%</td> <td>100%</td> <td>CS</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>10007</td> <td>0.34</td> <td>n/a</td> </tr> <tr> <td>S217</td> <td>S217</td> <td>Architectural Resource</td> <td>568</td> <td>14</td> <td>530</td> <td></td> <td></td> <td>100%</td> <td>100%</td> <td>100%</td> <td>100%</td> <td>100%</td> <td>CS</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>10007</td> <td>0.34</td> <td>n/a</td> </tr> <tr> <td>S218 CAD</td> <td>S218 CAD</td> <td>2nd Floor</td> <td>1072</td> <td>32</td> <td>1180</td> <td></td> <td></td> <td>100%</td> <td>100%</td> <td>100%</td> <td>100%</td> <td>100%</td> <td>CS</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>10007</td> <td>0.34</td> <td>n/a</td> </tr> <tr> <td>S203A</td> <td>S203A</td> <td>Anatomy Storage</td> <td>476</td> <td>0</td> <td>600</td> <td></td> <td></td> <td>100%</td> <td>100%</td> <td>100%</td> <td>100%</td> <td>100%</td> <td>CS</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>10007</td> <td>0.34</td> <td>n/a</td> </tr> <tr> <td>S213A</td> <td>S213A</td> <td>Biology Storage</td> <td>418</td> <td>0</td> <td>400</td> <td></td> <td></td> <td>100%</td> <td>100%</td> <td>100%</td> <td>100%</td> <td>100%</td> <td>CS</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>10007</td> <td>0.34</td> <td>n/a</td> </tr> </tbody> </table>		Potentially Critical Zones		Zone Name	Zone Tag	Space type	Floor Area (sf)	Design Pop	Design Total Supply (cfm)	Induction Unit	Local Recirc. Air %	OA Rate per Unit Area (cfm/sf)	OA Rate per Person (cfm/p)	Total Supply (cfm)	Unused OA (cfm)	Unused OA Req'd (cfm)	Fraction of Zone Supply Not Directly Recirc. (Fa)	Fraction of Zone Supply from Fully Mixed Primary Air (Fb)	Fraction of Zone OA Not Directly Recirc. (Fc)	Unused OA Fraction in Supply Air (Zd)	Unused OA Fraction in Primary Air (Zp)	Zone Vent. Eff. (Evz)	System Vent. Eff. (Ev)	Min OA Intake Flow (Vot)	OA Intake Req'd as Fraction of Primary SA (Y)	OAT for All-Cooling (Deq F)	S212 Biology	S215 Biology	2nd Floor	1421	32	2980			100%	100%	100%	100%	100%	CS	1.00	1.00	1.00	1.00	1.00	1.00	1.00	10007	0.34	n/a	S216 CAD	S216 CAD	2nd Floor	1083	32	1240			100%	100%	100%	100%	100%	CS	1.00	1.00	1.00	1.00	1.00	1.00	1.00	10007	0.34	n/a	S217	S217	Architectural Resource	568	14	530			100%	100%	100%	100%	100%	CS	1.00	1.00	1.00	1.00	1.00	1.00	1.00	10007	0.34	n/a	S218 CAD	S218 CAD	2nd Floor	1072	32	1180			100%	100%	100%	100%	100%	CS	1.00	1.00	1.00	1.00	1.00	1.00	1.00	10007	0.34	n/a	S203A	S203A	Anatomy Storage	476	0	600			100%	100%	100%	100%	100%	CS	1.00	1.00	1.00	1.00	1.00	1.00	1.00	10007	0.34	n/a	S213A	S213A	Biology Storage	418	0	400			100%	100%	100%	100%	100%	CS	1.00	1.00	1.00	1.00	1.00	1.00	1.00	10007	0.34	n/a
Potentially Critical Zones																																																																																																																																																																										
Zone Name	Zone Tag	Space type	Floor Area (sf)	Design Pop	Design Total Supply (cfm)	Induction Unit	Local Recirc. Air %	OA Rate per Unit Area (cfm/sf)	OA Rate per Person (cfm/p)	Total Supply (cfm)	Unused OA (cfm)	Unused OA Req'd (cfm)	Fraction of Zone Supply Not Directly Recirc. (Fa)	Fraction of Zone Supply from Fully Mixed Primary Air (Fb)	Fraction of Zone OA Not Directly Recirc. (Fc)	Unused OA Fraction in Supply Air (Zd)	Unused OA Fraction in Primary Air (Zp)	Zone Vent. Eff. (Evz)	System Vent. Eff. (Ev)	Min OA Intake Flow (Vot)	OA Intake Req'd as Fraction of Primary SA (Y)	OAT for All-Cooling (Deq F)																																																																																																																																																				
S212 Biology	S215 Biology	2nd Floor	1421	32	2980			100%	100%	100%	100%	100%	CS	1.00	1.00	1.00	1.00	1.00	1.00	1.00	10007	0.34	n/a																																																																																																																																																			
S216 CAD	S216 CAD	2nd Floor	1083	32	1240			100%	100%	100%	100%	100%	CS	1.00	1.00	1.00	1.00	1.00	1.00	1.00	10007	0.34	n/a																																																																																																																																																			
S217	S217	Architectural Resource	568	14	530			100%	100%	100%	100%	100%	CS	1.00	1.00	1.00	1.00	1.00	1.00	1.00	10007	0.34	n/a																																																																																																																																																			
S218 CAD	S218 CAD	2nd Floor	1072	32	1180			100%	100%	100%	100%	100%	CS	1.00	1.00	1.00	1.00	1.00	1.00	1.00	10007	0.34	n/a																																																																																																																																																			
S203A	S203A	Anatomy Storage	476	0	600			100%	100%	100%	100%	100%	CS	1.00	1.00	1.00	1.00	1.00	1.00	1.00	10007	0.34	n/a																																																																																																																																																			
S213A	S213A	Biology Storage	418	0	400			100%	100%	100%	100%	100%	CS	1.00	1.00	1.00	1.00	1.00	1.00	1.00	10007	0.34	n/a																																																																																																																																																			

Delaware County Community College STEM Center																																																	
Building:																																																	
System Tag/Name:																																																	
Operating Condition Description:																																																	
Units (select from pull-down list)																																																	
<table border="1"> <tr> <th>Name</th> <th>Units</th> <th>System</th> </tr> <tr> <td>As</td> <td>sf</td> <td>18409</td> </tr> <tr> <td>Ps</td> <td>P</td> <td>461</td> </tr> <tr> <td>Vpsd</td> <td>cfm</td> <td>29,110</td> </tr> <tr> <td>Ras</td> <td>cfm/sf</td> <td>0.13</td> </tr> <tr> <td>Rps</td> <td>cfm/p</td> <td>9.4</td> </tr> </table>		Name	Units	System	As	sf	18409	Ps	P	461	Vpsd	cfm	29,110	Ras	cfm/sf	0.13	Rps	cfm/p	9.4																														
Name	Units	System																																															
As	sf	18409																																															
Ps	P	461																																															
Vpsd	cfm	29,110																																															
Ras	cfm/sf	0.13																																															
Rps	cfm/p	9.4																																															
<table border="1"> <tr> <th>Name</th> <th>Units</th> <th>System</th> </tr> <tr> <td>As</td> <td>sf</td> <td>18409</td> </tr> <tr> <td>Ps</td> <td>P</td> <td>461</td> </tr> <tr> <td>Vpsd</td> <td>cfm</td> <td>29,110</td> </tr> <tr> <td>Ras</td> <td>cfm/sf</td> <td>0.13</td> </tr> <tr> <td>Rps</td> <td>cfm/p</td> <td>9.4</td> </tr> </table>		Name	Units	System	As	sf	18409	Ps	P	461	Vpsd	cfm	29,110	Ras	cfm/sf	0.13	Rps	cfm/p	9.4																														
Name	Units	System																																															
As	sf	18409																																															
Ps	P	461																																															
Vpsd	cfm	29,110																																															
Ras	cfm/sf	0.13																																															
Rps	cfm/p	9.4																																															
<p>Zone Name</p> <p>Zone Tag</p> <p>Space type</p> <p>Floor Area of zone</p> <p>Design population of zone</p> <p>Design total supply to zone (primary plus local recirculated)</p> <p>Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?</p> <p>Local recirc. air % representative of ave. system return air</p>																																																	
<p>Zone title turns purple italic for critical zone(s)</p> <p>Select from pull-down list</p> <p>Az sf (default value listed; may be overridden)</p> <p>Pz P</p> <p>Vzdz cfm</p> <p>Er Select from pull-down list or leave blank if N/A</p>																																																	
<p>Inputs for Potentially Critical Zones</p>																																																	
<table border="1"> <tr> <th>System</th> <th>S200A Team</th> <th>S201 Collaboration</th> <th>S203B Preparation Room</th> <th>S213B Preparation Room</th> <th>S221 Administrative Assistant</th> <th>S220 Medium Meeting</th> <th>S221A Assistant Dean</th> </tr> <tr> <td></td> <td>2nd Floor</td> <td>2nd Floor</td> <td>2nd Floor</td> <td>2nd Floor</td> <td>2nd Floor</td> <td>2nd Floor</td> <td>2nd Floor</td> </tr> <tr> <td></td> <td>Corridors</td> <td>Conference/Meeting</td> <td>Science Laboratories</td> <td>Science Laboratories</td> <td>Office space</td> <td>Conference/Meeting</td> <td>Office space</td> </tr> <tr> <td></td> <td>276</td> <td>154</td> <td>514</td> <td>589</td> <td>409</td> <td>1135</td> <td>163</td> </tr> <tr> <td></td> <td>6</td> <td>4</td> <td>2</td> <td>3</td> <td>4</td> <td>15</td> <td>2</td> </tr> <tr> <td></td> <td>200</td> <td>200</td> <td>750</td> <td>830</td> <td>700</td> <td>1340</td> <td>400</td> </tr> </table>		System	S200A Team	S201 Collaboration	S203B Preparation Room	S213B Preparation Room	S221 Administrative Assistant	S220 Medium Meeting	S221A Assistant Dean		2nd Floor	2nd Floor	2nd Floor	2nd Floor	2nd Floor	2nd Floor	2nd Floor		Corridors	Conference/Meeting	Science Laboratories	Science Laboratories	Office space	Conference/Meeting	Office space		276	154	514	589	409	1135	163		6	4	2	3	4	15	2		200	200	750	830	700	1340	400
System	S200A Team	S201 Collaboration	S203B Preparation Room	S213B Preparation Room	S221 Administrative Assistant	S220 Medium Meeting	S221A Assistant Dean																																										
	2nd Floor	2nd Floor	2nd Floor	2nd Floor	2nd Floor	2nd Floor	2nd Floor																																										
	Corridors	Conference/Meeting	Science Laboratories	Science Laboratories	Office space	Conference/Meeting	Office space																																										
	276	154	514	589	409	1135	163																																										
	6	4	2	3	4	15	2																																										
	200	200	750	830	700	1340	400																																										
<p>Inputs for Operating Condition Analyzed</p> <p>Percent of total design airflow rate at conditioned analyzed</p> <p>Air distribution type at conditioned analyzed</p> <p>Zone air effectiveness at conditioned analyzed</p> <p>Primary air fraction of supply air at conditioned analyzed</p>																																																	
<table border="1"> <tr> <th>Results</th> <th>Units</th> <th>Value</th> </tr> <tr> <td>Ventilation System Efficiency</td> <td>%</td> <td>100%</td> </tr> <tr> <td>Outdoor air intake required for system</td> <td>cfm</td> <td>CS</td> </tr> <tr> <td>Outdoor air per unit floor area</td> <td>cfm/sf</td> <td>CS</td> </tr> <tr> <td>Outdoor air per person served by system (including diversity)</td> <td>cfm/p</td> <td>1.00</td> </tr> <tr> <td>Outdoor air as a % of design primary supply air</td> <td>cfm</td> <td>1.00</td> </tr> </table>		Results	Units	Value	Ventilation System Efficiency	%	100%	Outdoor air intake required for system	cfm	CS	Outdoor air per unit floor area	cfm/sf	CS	Outdoor air per person served by system (including diversity)	cfm/p	1.00	Outdoor air as a % of design primary supply air	cfm	1.00																														
Results	Units	Value																																															
Ventilation System Efficiency	%	100%																																															
Outdoor air intake required for system	cfm	CS																																															
Outdoor air per unit floor area	cfm/sf	CS																																															
Outdoor air per person served by system (including diversity)	cfm/p	1.00																																															
Outdoor air as a % of design primary supply air	cfm	1.00																																															
<p>Detailed Calculations</p> <p>Initial Calculations for the System as a whole</p> <p>Primary supply air flow to system at conditioned analyzed = VpdDs = 29110</p> <p>Uncorrected OA requirement for system = You = 6762</p> <p>Uncorrected OA req'd as a fraction of primary SA = XS = 0.23</p> <p>Initial Calculations for Individual Zones</p> <p>OA rate per unit area for zone = Raz = 0.06</p> <p>OA rate per person = Rpz = 0.00</p> <p>Total supply air to zone (at condition being analyzed) = Vzdz = 200</p> <p>Unused OA req'd to breathing zone = Vbz = 16.6</p> <p>Unused OA requirement for zone = Voz = 17</p> <p>Fraction of zone supply not directly recirc. from zone = Fa = 1.00</p> <p>Fraction of zone supply from fully mixed primary air = Fb = 1.00</p> <p>Fraction of zone OA not directly recirc. from zone = Fc = 1-(1-Ez)(1-Ep)(1-Er) = 1.00</p> <p>Unused OA fraction required in supply air to zone = Zd = 0.08</p> <p>Unused OA fraction required in primary air to zone = Zp = 0.08</p> <p>System Ventilation Efficiency</p> <p>Zone Ventilation Efficiency (App A Method) = Evz = (Fa + Fbx - Fcz) / Fa = 1.15</p> <p>System Ventilation Efficiency (App A Method) = Ev = min(Evz) = 0.68</p> <p>Ventilation System Efficiency (Table 6.3 Method) = n/a</p> <p>Minimum outdoor air intake airflow</p> <p>Outdoor Air Intake Flow required to System = Vot = 10007</p> <p>OA intake req'd as a fraction of primary SA = Y = 0.34</p> <p>Outdoor Air Intake Flow required to System (Table 6.3 Method) = n/a</p> <p>OA intake req'd as a fraction of primary SA (Table 6.3 Method) = n/a</p> <p>OA Temp at which Min OA provides all cooling</p> <p>OAT below which OA intake flow is @ minimum = Deg F = 23</p>																																																	

Building:		Delaware County Community College STEM Center	
System Tag/Name:			
Operating Condition Description:			
Units (select from pull-down list)		IP	
Inputs for System	Name	Units	System
	Floor area served by system	As sf	192833
	Population of area served by system (including diversity)	Ps P	491
	Design primary supply fan airflow rate	Vpsd cfm	36,410
	OA req'd per unit area for system (Weighted average)	Ras cfm/sf	0.14
	OA req'd per person for system area (Weighted average)	Rps cfm/p	9.6
Inputs for Potentially Critical Zones			
	Zone Name		
	Zone Tag		
	Space type		
	Floor Area of zone	Az sf	
	Design population of zone	Pz P	
	Design total supply to zone (primary plus local recirculated)	Vztd cfm	
	Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?		
	Local recirc. air % representative of ave system return air	Er %	
Inputs for Operating Condition Analyzed			
	Percent of total design airflow rate at conditioned analyzed	Ds %	100%
	Air distribution type at conditioned analyzed	Ez	CS
	Zone air distribution effectiveness at conditioned analyzed	Ep	1.00
	Primary air fraction of supply air at conditioned analyzed		
Results			
	Ventilation System Efficiency	Ev	0.72
	Outdoor air intake required for system	Vot cfm	10452
	Outdoor air per unit floor area	Vot/As cfm/sf	0.54
	Outdoor air per person served by system (including diversity)	Vot/Ps cfm/p	21.3
	Outdoor air as a % of design primary supply air	Ypd cfm	29%
Detailed Calculations			
Initial Calculations for the System as a whole			
	Primary supply air flow to system at conditioned analyzed	Vps cfm	= 36410
	Uncorrected OA requirement for system	You cfm	= 7493
	Uncorrected OA req'd as a fraction of primary SA	Xs	= 0.21
Initial Calculations for individual zones			
	OA rate per unit area for zone	Raz cfm/sf	
	OA rate per person	Rpz cfm/p	
	Total supply air to zone (at condition being analyzed)	Vz cfm	
	Unused OA req'd to breathing zone	Vbz cfm	
	Unused OA requirement for zone	Voz cfm	
	Fraction of zone supply not directly recirc. from zone	Fa	
	Fraction of zone supply from fully mixed primary air	Fb	
	Fraction of zone OA not directly recirc. from zone	Fc	
	Unused OA fraction required in supply air to zone	Zd	
	Unused OA fraction required in primary air to zone	Zp	
System Ventilation Efficiency			
	Zone Ventilation Efficiency (App A Method)	Evz	= 1.10
	System Ventilation Efficiency (App A Method)	Ev	= 0.72
	Ventilation System Efficiency (Table 6.3 Method)	Ev	= 0.66
Minimum outdoor air intake airflow			
	Outdoor Air Intake Flow required to System	Vot cfm	= 10452
	OA intake req'd as a fraction of primary SA	Y	= 0.29
	Outdoor Air Intake Flow required to System (Table 6.3 Method)	Vot cfm	= 11334
	OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Y	= 0.31
OA Temp at which Min OA provides all cooling			
	OAT below which OA intake flows @ minimum	Deg F	= 13

Building: Delaware County Community College STEM Center													
System Tag/Name: IP													
Operating Condition Description: Units (select from pull-down list)													
Inputs for System	<table border="1"> <tr><td>Name</td><td>Units</td></tr> <tr><td>As</td><td>19283 sf</td></tr> <tr><td>Ps</td><td>491 P</td></tr> <tr><td>Vpsd</td><td>36,410 cfm</td></tr> <tr><td>Ras</td><td>0.14 cfm/sf</td></tr> <tr><td>Rps</td><td>9.6 cfm/p</td></tr> </table>	Name	Units	As	19283 sf	Ps	491 P	Vpsd	36,410 cfm	Ras	0.14 cfm/sf	Rps	9.6 cfm/p
Name	Units												
As	19283 sf												
Ps	491 P												
Vpsd	36,410 cfm												
Ras	0.14 cfm/sf												
Rps	9.6 cfm/p												
Inputs for Potentially Critical zones	<p>Zone Name</p> <p>Zone Tag</p> <p>Space type</p> <p>Floor Area of zone</p> <p>Design population of zone</p> <p>Design total supply to zone (primary plus local recirculated)</p> <p>Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?</p> <p>Local recirc. air % representative of ave system return air</p>												
Inputs for Operating Condition Analyzed	<p>Percent of total design airflow rate at conditioned analyzed</p> <p>Air distribution type at conditioned analyzed</p> <p>Zone air distribution effectiveness at conditioned analyzed</p> <p>Primary air fraction of supply air at conditioned analyzed</p>												
Results	<p>Ventilation System Efficiency: 0.72</p> <p>Outdoor air intake required for system: 10452</p> <p>Outdoor air per unit floor area: 0.54</p> <p>Outdoor air per person served by system (including diversity): 21.3</p> <p>Outdoor air as a % of design primary supply air: 29%</p>												
Detailed Calculations	<p>Initial Calculations for the System as a whole</p> <p>Primary supply air flow to system at conditioned analyzed = VpdDs = 36410</p> <p>Uncorrected OA requirement for system = Rps Ps + Ras As = 7483</p> <p>Uncorrected OA req'd as a fraction of primary SA = You / Vps = 0.21</p> <p>Initial Calculations for Individual zones</p> <p>OA rate per unit area for zone = Raz = cfm/sf</p> <p>OA rate per person = You = cfm</p> <p>Total supply air to zone (at condition being analyzed) = Rpz Pz + Raz Az = cfm</p> <p>Unused OA req'd to breathing zone = Vbz/Ez = cfm</p> <p>Unused OA requirement for zone = Voz = cfm</p> <p>Fraction of zone supply not directly recirc. from zone = Fa = cfm</p> <p>Fraction of zone supply from fully mixed primary air = Fb = cfm</p> <p>Fraction of zone OA not directly recirc. from zone = Fc = cfm</p> <p>Unused OA fraction required in supply air to zone = Zd = cfm</p> <p>Unused OA fraction required in primary air to zone = Zp = cfm</p> <p>System Ventilation Efficiency</p> <p>Zone Ventilation Efficiency (App A Method) = (Fa + FBxS - Fcz) / Fa = 0.72</p> <p>System Ventilation Efficiency (App A Method) = min (Evz) = 0.66</p> <p>Ventilation System Efficiency (Table 6.3 Method) = Value from Table 6.3 = 0.66</p> <p>Minimum outdoor air intake airflow</p> <p>Outdoor Air Intake Flow required to System = Vot = cfm</p> <p>OA intake req'd as a fraction of primary SA = Y = cfm</p> <p>Outdoor Air Intake Flow required to System (Table 6.3 Method) = Vot / Vps = 11334</p> <p>OA intake req'd as a fraction of primary SA (Table 6.3 Method) = Y = 0.31</p> <p>OA Temp at which Min OA provides all cooling</p> <p>OAT below which OA Intake flow is @ minimum = Deg F = 13</p>												

Building: Delaware County Community College STEM Center	
System Tag/Name:	
Operating Condition Description:	
Units (select from pull-down list)	
Name	System
As	7741
Ps	347
Vpsd	12,470
Ras	0.12
Rps	9.9
Inputs for Potentially Critical Zones	
Zone Name	Potentially Critical Zones
Zone Tag	S401 S402 S403 S406 S407 S411 S412
Space type	Classroom Classroom Classroom Classroom Classroom Classroom Classroom
Floor Area of zone	611 1000 638 774 860 777 968
Design population of zone	32 50 32 39 44 39 49
Design total supply to zone (primary plus local recirculated)	1,430 1,900 1,000 1,120 1,200 1,140 1,300
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?	
Local recirc. air % representative of ave system return air	
Inputs for Operating Condition Analyzed	
Percent of total design airflow rate at conditioned analyzed	100%
Air distribution type at conditioned analyzed	Select from pull-down list
Zone air distribution effectiveness at conditioned analyzed	
Primary air fraction of supply air at conditioned analyzed	
Results	
Ventilation System Efficiency	0.88
Outdoor air intake required for system	4930
Outdoor air per unit floor area	0.64
Outdoor air per person served by system (including diversity)	14.2
Outdoor air as a % of design primary supply air	40%
Detailed Calculations	
Initial Calculations for the System as a whole	
Primary supply air flow to system at conditioned analyzed	Vps = 12470
Uncorrected OA requirement for system	You = 4353
Unconditioned OA req'd as a fraction of primary SA	Xs = Rps / Vps = 0.35
Initial Calculations for Individual Zones	
OA rate per unit area for zone	Raz = cfm/sf
OA rate per person	Rpz = cfm/p
Total supply air to zone (at condition being analyzed)	Vdz = cfm
Unused OA req'd for breathing zone	Vbz = cfm
Unused OA requirement for zone	Voz = cfm
Fraction of zone supply not directly recirc. from zone	Fa = Ep + (1-Ep)Er
Fraction of zone supply from fully mixed primary air	Fb = Ep
Fraction of zone OA not directly recirc. from zone	Fc = 1-(1-Ez)(1-Ep)(1-Er)
Unused OA fraction required in supply air to zone	Zd = Voz / Vdz
Unused OA fraction required in primary air to zone	Zp = Voz / Vpz
System Ventilation Efficiency	
Zone Ventilation Efficiency (App A Method)	Evz = (Fa + FbXs - FcZ) / Fa = 1.07
System Ventilation Efficiency (App A Method)	Ev = min (Evz) = 0.88
Ventilation System Efficiency (Table 6.3 Method)	Ev = Value from Table 6.3 = 0.68
Minimum outdoor air intake airflow	
Outdoor Air Intake Flow required to System	Vot = cfm
OA intake req'd as a fraction of primary SA	Y = Vot / Vps = 0.40
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Vot = cfm = 6364
OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Y = Vot / Vps = 0.51
OA Temp at which Min OA provides all cooling	
OAT below which OA Intake flow is @ minimum	Deg F = ((Tp-dT)(1-Y)/Tr)+dTTr = 29

Delaware County Community College STEM Center				
Building:				
System Tag/Name:				
Operating Condition Description:				
Units (select from pull-down list)				
Inputs for System	System			
As	7741			
Ps	347			
Vpsd	12,470			
Ras	0.12			
Rps	9.9			
100% diversity				
Inputs for Potentially Critical zones				
Zone Name				
Zone Tag				
Space type				
Floor Area of zone				
Design population of zone				
Design total supply to zone (primary plus local recirculated)				
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?				
Local recirc. air % representative of ave.system return air				
Inputs for Operating Condition Analyzed				
Ds	100%			
Ez	CS			
Ep	1.00			
Results				
Ev	0.88			
Vot	4930			
Vot/As	0.64			
Vot/Ps	14.2			
Ypd	40%			
Detailed Calculations				
Initial Calculations for the System as a whole				
Vps	=	VpdDs	=	12470
You	=	Rps Ps + Ras As	=	4353
Xs	=	You / Vps	=	0.35
Initial Calculations for individual zones				
Raz	=	Rpz Ez + Raz Az	=	0.12
Rpz	=	Vbz/Ez	=	10.00
Vdz	=	Ep + (1-Ep)Er	=	1150
Voz	=	1-(1-Ez)(1-Ep)(1-Er)	=	445.1
Fa	=	Voz / Vdz	=	445
Fb	=	Voz / Vdz	=	1.00
Fc	=	Voz / Vdz	=	1.00
Zd	=	(Fa + Fb)(Xs - FcZz) / Fa	=	0.39
Zp	=	min (EvZ)	=	0.39
System Ventilation Efficiency				
EvZ	=	(Fa + Fb)(Xs - FcZz) / Fa	=	0.96
Ev	=	min (EvZ)	=	0.88
Ev	=	Value from Table 6.3	=	0.68
Minimum outdoor air intake airflow				
Vot	=	You / Ev	=	4930
Y	=	Vot / Vps	=	0.40
Y	=	Vot / Vps	=	6384
Y	=	Vot / Vps	=	0.51
OA Temp at which Min OA provides all cooling				
Deg F	=	((Tb-dTs)(1-Y)/Tr+dTr)	=	29
*AT below which OA intake flow is @ minimum				

Appendix B: Lighting Power Schedule and Calculations

LUMINAIRE SCHEDULE								
FIXTURE TYPE	FIXTURE DESCRIPTION	COMMERCIAL EXAMPLE: MANUFACTURER & CATALOG NUMBER	VOLTAGE	LAMPS	ACTUAL WATTS	INSTANCES	WATTAGE PER FIXTURE TYPE	MOUNTING
A	1' X 4' RECESSED HIGH EFFICIENCY ACRYLIC LENSED LUMINAIRE WITH DIMMING BALLAST	LEDAUTE VECTRA 9714D1STT232S-7-2-E FOCAL POINT FEQ ZUMTOBEL ML4	277	(2) 32W 830 T8	65	606	39390	RECESSED
A1	1' X 4' RECESSED HIGH EFFICIENCY ACRYLIC LENSED LUMINAIRE	LEDAUTE VECTRA 9714D1STT132S-1-2-E FOCAL POINT FEQ ZUMTOBEL ML4	277	(1) 32W 830 T8	33	79	2607	RECESSED
A2	1' X 4' RECESSED HIGH EFFICIENCY ACRYLIC LENSED LUMINAIRE	LEDAUTE VECTRA 9714D1CRT232S-1-2-E FOCAL POINT FEQ ZUMTOBEL ML4	277	(2) 32W 830 T8	65	71	4615	RECESSED
B	2' X 4' RECESSED AO.125" ACRYLIC LENSED LUMINAIRE	COOPER METALUX 2GC8S-332A12S-277V-EB81 LITHONIA LIGHTOLIER	277	(3) 32W 830 T8	94	17	1598	RECESSED
B2	2' X 2' RECESSED AO.125" ACRYLIC LENSED LUMINAIRE	COOPER METALUX 2GC-317A12S-277V-EB81 LITHONIA LIGHTOLIER	277	(3) 17W 830 T8	61	9	549	RECESSED
C	6" OPEN DOWNLIGHT	COOPER PORTFOLIO C6226E-6251LU-WF LITHONIA LIGHTOLIER	277	(2) 26W TTT	58	148	8584	RECESSED
D	6" DIMMABLE OPEN DOWNLIGHT	COOPER PORTFOLIO C62182D-6251LU-WF LITHONIA LIGHTOLIER	277	(2) 18W TTT	43	125	5375	RECESSED
E	6" DIMMABLE OPEN DOWNLIGHT	COOPER PORTFOLIO C6226D-6251LU-WF LITHONIA LIGHTOLIER	277	(2) 26W TTT	58	88	5104	RECESSED
F	3' ROUND RECESSED ACRYLIC LENSED LUMINAIRE	PRUDENTIAL P-8930(4)T8QWATMWS C277X1 MARK LIGHTING MG34-T8EB277 OR APPROVED EQUAL	277	(4) 25W 830 T8	101	22	2222	RECESSED
G	6" ROUND RECESSED ACRYLIC LENSED LUMINAIRE	PRUDENTIAL P-8930(8)T8QWATMWS C277X1 OR APPROVED EQUAL	277	(8) 32W 830 T8	282	9	2538	SURFACE
H	DECORATIVE 6" RECESSED DOWNLIGHT	LIGHTOLIER D6A01-8051C-6218HU OR APPROVED EQUAL	277	(2) 18W Q	39	48	1872	RECESSED
J	RECESSED PERIMETER OPEN WALL WASH LUMINAIRE WITH SLIDING SLEEVE AS REQUIRED. LENGTH AS INDICATED ON PLAN.	FOCAL POINT MARK LIGHTING MP1-T8EBEBB-2 OR APPROVED EQUAL	277	(1) 32W 830 T8 PER 4'	33	81	2673	RECESSED
K	4' RECESSED WALL WASH LUMINAIRE	FOCAL POINT FAVA-NS-1T5-1C-UNV-S-X-WH-4	277	(1) 28W 830 T5	33	12	396	RECESSED
L	6" SURFACE MOUNTED DOWNLOAD	COOPER PORTFOLIO CL6032EP-LI LITHONIA LIGONIER	277	(2) 26 W TTT	59	5	295	COLUMN
M	6" OPEN WALL WASH DIMMABLE DOWNLIGHT	COOPER PORTFOLIO C62182D-6211LU-WF LITHONIA LIGHTOLIER	277	(2) 18W TTT	43	44	1892	RECESSED
N	CEILING SURFACE MOUNTED WET LOCATION	PRISMA DISCUS 28 0724S7 OR APPROVED EQUAL	277	(1) 26W TTT	29	19	551	SURFACE
P	EXTERIOR FULL CUT-OFF FIXTURE ON 12' POLE	BEGA #8309MH OR APPROVED EQUAL	208	150W MH	166	0* *SITE LIGHTING	0	POLE
Q	4'STRIP FIXTURE WITH CAGE	COOPER S8292277VEB81 LITHONIA LIGHTOLIER	277	(2) 32W 830 T8	65	24	1560	PENDANT
Q2	8'STRIP FIXTURE WITH CAGE	COOPER 8T5S232277VEB81 LITHONIA LIGHTOLIER	277	(2) 32W 830 T8	65	22	1430	PENDANT
R	LED STAIR TREAD FIXTURE LENGTH AS INDICATED ON PLAN	PROLUME RIA-XX"-WWF WITH PSX24-100/O AS REQUIRED OR APPROVED EQUAL	120	INCLUDED	27	32	864	STAIR
S	8' WALL MOUNTED UP/DOWN FIXTURE	NATIONAL LIGHTING S66-ID/D-W-4T8-A OR APPROVED EQUAL	277	(4)32W 830 T8	141	16	2256	SURFACE WALL
T	WALL MOUNTED INTERIOR DIRECT FLOOD LIGHT IN SKYLIGHT	OR APPROVED EQUAL	277	(1) 26W	29	4	116	SURFACE WALL
U	ELEVATOR PIT LIGHT	COOPER VT2-232-DR-120-EB	120	(1) 26W TTT	29	3	87	WALL
U2	RECESSED VAPOR TIGHT FIXTURE	COOPER PORTFOLIO C6226E-6280LI4G LITHONIA LIGHTOLIER	277	(2) 26W TTT	58	4	232	RECESSED

V	1/2" 120" LED STRIPS TO BE CONTINUOUSLY MOUNTED IN COVE, LENGTH AS INDICATED ON PLAN	PHILIPS EW 523-000004-00 / 999-000284-00 OR APPROVED EQUAL	120	INCLUDED	0	0	0	COVE
W	MINI 9W LED SPOT FOR SIGNAGE WITH DRIVER	VISUAL LIGHTING BLUX-0401-080-W-NX WITH 901-006-700-LI PER (2) SPOTS OR APPROVED EQUAL	120	INCLUDED	4	6	24	SURFACE
X	EXTERIOR RECESSED LENSED DOWNLIGHT	COOPER PORTFOLIO CL9L42E-10002P LITHONIA LIGHTOLIER	277	(1) 26W TTT	29	52	1508	RECESSED
Y	RECESSED CHROME XENON DISPLAY CASE FIXTURE	PEGASUS PALPX-CH-PHD60 AMERICAN LIGHTING LVPX80CH OR APPROVED EQUAL	120	INCLUDED	0	10	0	RECESSED
Z	DECORATIVE PENDANT	TECH LIGHTING 700FS DAFC OR APPROVED EQUAL	120	50W BIPIN HALOGEN	55	2	110	PENDANT
EXIT	EDGE LIT LED EXIT SIGN WITH RED LETTERS AND SILVER BACKING	COOPER LITHONIA LIGHTOLIER	277	INCLUDED	0	0 Negligible	0	MOUNTING, SIDES, CHEVRONS AS INDICATED ON PLANS.
GENERAL NOTES:							TOTAL:	88448
1	PROVIDE ALL LAMPS WITH 3000K COLOR TEMPERATURE.							
2	PROVIDE ALL LAMPS WITH 80+ CRI.							
3	PROVIDE ALL FIXTURES WITH LINEAR FLUORESCENT LAMPS WITH AN INTEGRAL DISCONNECTING MEANS PER NEC ARTICLE 410-73(G).							
KEYED NOTES:								
L1	PROVIDE DRYWALL KIT.							