

Josh Martz  
Mechanical Option  
Srebric  
Appell Life Sciences  
York, PA  
3/25/2011

## Presentation Outline

- I. Project Background
  - a. Project Team and Building Stats (1)
    - i. Project team: Architect, Engineers
    - ii. Building Stats: stories, area, cost, location
  - b. Building Layout (2)
    - i. Basic floor layout
- II. Existing Mechanical Summary
  - a. Mechanical Room (1)
    - i. Chiller, Boilers
  - b. Office Floors (1)
    - i. AHU's, VAV
  - c. Classroom/Lab Floors(1)
    - i. AHU's, FCU
  - d. Greenhouse Building(1)
    - i. FCU, WIH, etc.
- III. Design Objectives (1)
  - a. Lower Energy Consumption
  - b. Reduce system cost/maintenance
  - c. Comparison of system performance
- IV. Ground Source Heat Pumps (14-15)
  - a. Heating/Cooling Separate studies
  - b. Borehole Sizing/layout
  - c. Energy Consumption/Cost
  - d. Construction Breadth
    - i. Borehole cost, Life Cycle cost
    - ii. Construction Schedule Change
- V. Chilled Beams (4)
  - a. Energy Consumption/Cost
  - b. Run around Coil System
- VI. System Comparison (4)
  - a. Energy Consumption/Cost differences between new and as-designed
  - b. Final Thoughts/Recommendations
- VII. Acknowledgements (1)

About 31-32 slides

# APPELL LIFE SCIENCES

York College of Pennsylvania



Joshua Martz | Dr. Srebric | April, 11 2011

## Outline

- PROJECT BACKGROUND
- EXISTING MECHANICAL SUMMARY
- DESIGN OBJECTIVES
- GROUND SOURCE HEAT PUMPS
- CHILLED BEAMS
- SYSTEM COMPARISON
- ACKNOWLEDGEMENTS

## Project Background

### Project Team

Owner:	York College of Pennsylvania
Architect:	RLPS, Ltd.
CM:	Kinsley Construction
Structural:	Macintosh Engineering
Civil:	LSC Design, Inc.
MEP:	JDB Engineering

### Project Information

Size:	102,000 SF
Location:	York, Pa
Cost:	\$16 million
Stories:	3/Basement
Construction Date:	January 2010-August 2011
Delivery Method:	D-B-B/CM gives GMP



## Outline

- PROJECT BACKGROUND
- EXISTING MECHANICAL SUMMARY
- DESIGN OBJECTIVES
- GROUND SOURCE HEAT PUMPS
- CHILLED BEAMS
- SYSTEM COMPARISON
- ACKNOWLEDGEMENTS

## Borehole Sizing

Cooling Length:

$$L_c = \frac{q_a * R_{ga} + (q_{lc} - 3.41W_c)(R_b + PLF_m * R_{gm} + R_{gd} * F_{sc})}{t_g - \frac{t_{wi} - t_{wo} - t_p}{2}}$$

Heating Length:

$$L_h = \frac{q_a * R_{ga} + (q_{lh} - 3.41W_h)(R_b + PLF_m * R_{gm} + R_{gd} * F_{sc})}{t_g - \frac{t_{wi} - t_{wo} - t_p}{2}}$$

## Design Information

Cooling Design Information			
Entering Water Temperature (F)	Leaving Water Temperature (F)	Cooling Load (Btu/hr)	Borehole Length (ft)
75	85	1594800	12615


Heating Design Information			
Entering Water Temperature (F)	Leaving Water Temperature (F)	Cooling Load (Btu/hr)	Borehole Length (ft)
50	40	1260563	14204

## Outline


- PROJECT BACKGROUND
- EXISTING MECHANICAL SUMMARY
- DESIGN OBJECTIVES
- GROUND SOURCE HEAT PUMPS
- CHILLED BEAMS
- SYSTEM COMPARISON
- ACKNOWLEDGEMENTS

## Borehole Layout

Cooling: (layout of pipes per AHU)



Heating: (layout of pipes per AHU)



## Outline

- PROJECT BACKGROUND
- EXISTING MECHANICAL SUMMARY
- DESIGN OBJECTIVES
- GROUND SOURCE HEAT PUMPS
  - CONSTRUCTION BREADTH
- CHILLED BEAMS
- SYSTEM COMPARISON
- ACKNOWLEDGEMENTS

## Borehole Optimization

### Assumptions

Pipe: 1" High Density Polyethylene (HDPE)

- \$0.69/ft (40 ft lengths)
- Welding
  - \$4.79/weld
  - \$40.25/day per machine
- Grout:
  - Cooling: \$2775
  - Heating: \$3125

Earth Auger Data		
Length Feet	Daily Output Feet/day	Rental \$/week
$L_{\text{bore}} < 225$	1800	12,190
$225 < L_{\text{bore}} < 325$	1200	14,840
$L_{\text{bore}} > 325$	900	16,960

Cooling:

Chart of Best Option for Boreholes

Heating:

Chart of Best Option for Boreholes