


# Nassau Community College Life Sciences Building

Garden City, New York

## Technical Report One

ASHRAE Standard 62.1-2007 and Standard 90.1-2007 Analysis



Prepared By: Michael W. Reilly Jr.

Prepared For: James D. Freihaut, PhD

Date: 10.04.10

## Table of Contents

Executive Summary.....	3
Building Overview.....	4
Mechanical System Overview.....	4
ASHRAE Standard 62.1-2007 Analysis.....	6
Section 5 Analysis.....	6
Section 6 Analysis.....	9
ASHRAE Standard 62.1-2007 Summary.....	10
ASHRAE Standard 90.1-2007 Analysis.....	11
Section 5 – Building Envelope.....	11
Section 6 – Heating, Ventilating, and Air Conditioning.....	13
Section 7 – Service Water Heating.....	15
Section 8 – Power.....	15
Section 9 – Lighting.....	16
Section 10 – Other Equipment.....	17
ASHRAE 90.1-2007 Summary.....	18
References.....	19
Appendix A – Minimum Ventilation Calculation.....	20
Appendix B – Minimum Ventilation Compliance Check.....	41

## List of Tables

Table 1 – Total Building Glazing Area.....	12
Table 2 - Building Material Properties.....	12
Table 3 - Building Fenestration Properties.....	13
Table 4 - Ductwork Insulation Thickness.....	14
Table 5 – Pipe Insulation Thickness.....	14
Table 6 – Life Sciences Building Fan.....	15
Table 7 – Life Sciences Building Power Density.....	17
Table 8 – Life Sciences Building Pump Motor Efficiency Compliance.....	18

## Executive Summary

The purpose of this report is to determine if new building on Nassau Community College's campus are in compliance with both ASHRAE Standard 62.1-2007 and Standard 90.1-2007. The Life Sciences Building is a new 72,400 square foot laboratory building that will house both the chemistry department as well as the upcoming nursing department. The building will be comprised of general lecture halls, computer labs, organic and inorganic chemistry laboratories and office spaces for the faculty.

An analysis of ASHRAE Standard 62.1-2007, Ventilation for Acceptable Indoor Air Quality, was the first standard to be evaluated. The purpose of this standard is to specify minimum ventilation rates and other means to provide acceptable indoor air quality for the building's occupants. Two of the standard's sections were selected, Section 5 and Section 6. These two were selected because they are directly related to the design and specifications of the building rather than the outdoor air, operation and maintenance or construction, which may be out of the designer's control. Section 5 incorporates requirements in the building mechanical components that control indoor air quality such as outdoor intake requirements, particulate filtration and combustion air. All requirements under Section 5 were checked against the Life Sciences Building and were determined to be compliant. Section 6 diagrams a procedure in order to calculate the minimum ventilation air that is required for acceptable indoor air quality. All air handlers in the Life Sciences Building were selected for analysis for a compliance check.

ASHRAE Standard 90.1-2007, Energy Standard for Buildings Except Low-Rise Residential Buildings, was the second analysis in this report. The purpose of this standard is to provide minimum equipment efficiencies and insulation values in order to create an energy efficient design. The Life Science Building was checked against Sections 5 through 10 in this standard. Neither the building's exterior glazing to wall ratio, nor were the U-values for the exterior walls in compliance with this standard. Furthermore, efficiencies for certain fans did not meet the criteria set forth by this standard. In order to make up for the exterior glazing to wall ratio, the glazing far surpasses the requirements for both SHGC and U-value. Power distribution and lighting densities were determined to be in compliance with this standard.

The Life Sciences Building has submitted its application for LEED certification and is striving for LEED Gold. Therefore, it is not surprising that where requirements failed for aesthetic purposes, like the percent glazing ratio, other requirements overachieved. This report will provide a more detailed breakdown of each section in each standard and illustrate which parts of the system fail according to the standard and which parts succeed.

## Building Overview

The Nassau Community College Life Sciences Building will house the expanding Chemistry Department and rising Nursing Department. The building will be a cluster of general lecture halls, computer labs, inorganic and organic laboratories, practical skills nursing rooms and faculty offices. The Life Science Building is a “U-shape” where the courtyard façade is a floor-to-floor glass curtain wall system. Faculty offices on all three floors are facing the courtyard and can have periods of high heat transfer through the curtain wall. The classrooms, lecture halls and laboratories, are located along the opposite exterior perimeter. The façade is composed of copper rain screen panels and long strips of glazing. There may also be periods of high heat transfer through this façade, but it was designed for a high aesthetic appeal rather than thermal function.

The design of the Life Sciences Building was highly influenced by the occupants, both students and faculty, as well as its use. It was designed to easily connect to the greater campus with spaces to accommodate the overall student population, not just the Chemistry and Nursing Departments. Furthermore, function played a role in the design because of the hazardous chemical storage and waste spaces that need to be guarded under restricted access but readily available to the classrooms for learning.

## Mechanical System Overview

The Life Sciences Building receives conditioned air from three air handlers located in the Penthouse. One of the air handlers is a 100 percent outdoor air unit due to the nature of the chemistry laboratories that it serves. The supply air to the laboratory spaces is exhausted through a laboratory exhaust system. Three large exhaust fans operate as one unit, which pulls contaminated air from the laboratories. Because this air handler is a 100 percent outdoor air unit, a heat recover run-around loop transfers sensible heat from the exhaust fans to the air handler to either pre-heat or pre-cool the incoming outdoor air. All three air handlers are part of a variable air volume (VAV) system with terminal reheat coils.

The Life Sciences Building as well as the Nassau Community College campus is served by a campus-wide high temperature hot water and chilled water system. The high temperature hot water creates building hot water through several heat exchangers for the perimeter radiation, fan coils, cabinet unit heaters and air handler pre-heat coils. The 100 percent outdoor air unit’s pre-heat coil uses a glycol system, which is heated via heat exchanger by the high temperature hot water system. A primary/secondary system is utilized with the chilled water and high temperature hot water systems. Booster pumps have been designed for the chilled water system in the event that there is a decrease in pressure in the primary line. The majority of the



heat exchangers and pumps are located along with the service entrance in the basement mechanical equipment room.

The Central Utility Plant that serves Nassau Community College is operated by Suez Energy and is comprised of a boiler and chiller plant. This 60 MW cogeneration facility produces 250 psig steam, 270°F high temperature hot water and 42°F chilled water that are distributed to various surrounding facilities such as Nassau University Medical Center (NUMC), Nassau Veterans Memorial Coliseum and Long Island Marriott Hotel. Figure 1 below is a diagram provided by Parsons Brinckerhoff’s report that shows the location of the Central Utility Plant in red as well as the steam loads in blue stars and the high temperature hot water loads in yellow stars. Nassau Community College is denoted by the dotted yellow circle. Nassau Community College uses 50.6% of the high temperature hot water and chilled water produced by the Central Utility Plant compared to all buildings tapped into the high temperature hot water service.




Figure 1 – Location of Central Utility Plan (Red) and NCC (Yellow)

## ASHRAE Standard 62.1-2007 Analysis

### Section 5 Analysis

#### *Section 5.1 Natural Ventilation*

Exterior spaces have operable windows but all spaces are ventilated mechanically. Therefore, natural ventilation is not a method of ventilation for this building.

#### *Section 5.2 Ventilation Air Distribution*

The Life Sciences Building is able to meet the minimum ventilation requirement under and load condition. The construction documents specify explicitly a minimum airflow rate through each VAV terminal unit that complies with Section 6 of Standard 62.1. The discussion of Section 6 is discussed later in this report.

#### *Section 5.3 Exhaust Duct Location*

Chemistry laboratories, hazardous chemical storage, hazardous waste storage as well as general chemical storage rooms are all ducted and negatively pressurized relative to its surroundings and exhausted through laboratory exhaust fans located in the penthouse. General exhaust ducts are specified to be negatively pressurized to 2 in. Wg. relative to the surroundings and laboratory exhaust ducts are to be 3 in. Wg. relative to the surroundings. The laboratory exhaust fans are specified to maintain an exhaust intake velocity of 4,000 FPM through the stack in order to provide the proper clearance plume.

#### *Section 5.4 Ventilation System Controls*

The mechanical ventilation controls are designed to allow reduction in airflow when the spaces within each zone are unoccupied. Being that the Life Sciences Building is partly a VAV system, the VAV terminal units have been specified on the drawings to turn down to a minimum ventilation airflow rate that is greater than the minimum requirement given in Section 6 of Standard 62.1. Therefore, the Life Sciences Building complies with this section.

#### *Section 5.5 Airstream Surfaces*

Duct liners exposed to airstreams are specified to comply with ASTM C 1071 and UL 181. ASTM C 1071 incorporates ASTM C 1338. Therefore, the Life Sciences Building complies with this section.

#### *Section 5.6 Outdoor Air Intakes*

Noxious or dangerous exhausts are more than 30'. Therefore all outdoor air intakes are more than the minimum distance apart as per Table 5-1 in Standard 62.1. The main concern is the

laboratory exhausts fans, which are a minimum of 48 feet from an outdoor air intake louver. All louvers are specified to provide the appropriate rain entrainment resistance and contain a ½” bird screen mounted flush with the louver. Therefore, all outdoor air intakes comply with this section.

#### *Section 5.7 Local Capture of Contaminants*

The exhaust from spaces where contaminants could be an issue of indoor air quality in spaces such as the hazardous chemical storage or the chemical laboratory rooms are exhausted through the roof by dedicated laboratory exhaust fans.

#### *Section 5.8 Combustion Air*

The emergency generator exhaust flue is ducted and sized with the appropriate CFM through and exhaust vent on located on the roof. An adequate amount of outdoor air to ensure a complete combustion process is ducted into the emergency generator room directly from the exterior. Therefore, the Life Sciences Building complies with this section.

#### *Section 5.9 Particulate Matter Removal*

The filters located in the air handlers are specified to comply with ASHRAE Standard 52.2 and therefore comply with this section.

#### *Section 5.10 Dehumidification Systems*

The Life Sciences Building is specified to maintain a maximum relative humidity ratio of 60%. Therefore, the Life Sciences Building complies with this section. The volume of return air is specified to be less than the volume of outdoor air in order to assure a positive building pressurization.

#### *Section 5.11 Drain Pans*

Drain pans are specified to be of doubled-wall construction with the interior wall being stainless steel. The pan shall be pitched positively in two directions with a 2” minimum drain connection. Stacked cooling coils are specified to have intermediate drain pans or troughs to channel to main pan. The Life Sciences Building specifies that the drain pans to comply with ASHRAE Standard 62.1 and therefore complies with this section.

#### *Section 5.12 Finned-Tube Coils and Heat Exchangers*

Drain pans are provided beneath each cooling coil assembly as per Section 5.11. No specification has been stated regarding the minimum 18 in. access space for the perimeter finned-tube radiation.

*Section 5.13 Humidifiers and Water-Spray Systems*

The Life Sciences Building does not use humidifiers or water-spray systems. This section does not apply.

*Section 5.14 Access for Inspection, Cleaning and Maintenance*

Access doors for each air handler are specified to be at least 24" by 60" located in the proper sections to allow access to each element of the unit. Appropriate clearances have been designated on the drawings for the removal and maintenance of the coils in each air handler. Access doors have been located for variable air volume box re-heat coils. The Life Science Building complies with this section.

*Section 5.15 Building Envelope and Interior Surfaces*

A continuous moisture barrier is located behind exterior copper panels. For below grade walls, a continuous waterproof membrane will be used. Internal piping and ductwork that has the ability to fall below the local dew point temperature will be provided with preventative insulation. The Life Science Building complies with this section.

*Section 5.16 Buildings with Attached Parking Garages*

No parking structure is attached to the Life Sciences Building. This section does not apply.

*Section 5.17 Air Classification and Recirculation*

Part of the Life Sciences Building is Class 1 air, which is returned via plenum return from the offices, lecture rooms and general classrooms. This air can be re-circulated back into the building. Class 2 air from the restrooms and janitor's closets are ducted separately from other systems through a dedicated general exhaust system up through the roof. The chemistry laboratory, hazardous chemical storage, hazardous waste storage spaces contain Class 4 air by design and are isolated through a laboratory exhaust system up through the roof.

*Section 5.18 Requirements for Buildings Containing ETS Areas and ETS-Free Areas*

The Life Science Building is applying for LEED certification and therefore is a non-smoking facility. This section does not apply.



## Section 6 Analysis

For the purpose of verifying the ventilation and exhaust requirements of ASHRAE Standard 62.1 Section 6, all air handlers (AHU-1, AHU-2 and AHU-3) were selected for the analysis. Each air handler is not restricted to one floor of the building, and due to the variety of different spaces it was beneficial to analyze all spaces requiring ventilation. The following are the sets of equations based on ASHRAE Standard 62.1-2007 Section 6 that are required for this analysis.

### Ventilation Rate Procedure

*Note: All tables and equations in this section refer to those found in ASHRAE Standard 62.1-2007*

Breathing Zone Outdoor Airflow ( $V_{bz}$ ):

$$V_{bz} = R_{p+} \cdot P_z + R_a \cdot A_z \quad (\text{Eq. 6-1})$$

where,

$A_z$  = zone floor area (ft<sup>2</sup>)

$P_z$  = zone population, the largest number of people expected to occupy the zone during typical usage. (Estimated values found in Table 6-1)

$R_p$  = outdoor airflow rate per person (CFM/person) (Values found in Table 6.1)

$R_a$  = outdoor airflow rate per unit area (CFM/ft<sup>2</sup>) (Values found in Table 6.1)

Zone Air Distribution Effectiveness ( $E_z$ ):

$$E_z = 1 \quad (\text{Determined from Table 6-2})$$

Zone Outdoor Airflow ( $V_{oz}$ ):

$$V_{oz} = V_{bz} / E_z \quad (\text{Eq. 6-2})$$

Primary Outdoor Air Fraction ( $Z_p$ ):

$$Z_p = V_{oz} / V_{pz} \quad (\text{Eq. 6-5})$$

System Ventilation Efficiency ( $E_v$ ):

$E_v$  is found in Table 6-3 based on the maximum  $Z_p$  value

Uncorrected Outdoor Air Intake ( $V_{ou}$ ):

$$V_{ou} = D \cdot \sum_{\text{all zones}} (R_p \cdot P_z) + \sum_{\text{all zones}} (R_a \cdot A_z) \quad (\text{Eq. 6-6})$$

Occupant Diversity ( $D$ ):

$$D = P_s / \sum_{\text{all zones}} P_z \quad (\text{Eq. 6-7})$$

where,

$P_s$  = system population

Outdoor Air Intake ( $V_{ot}$ ):

$$V_{ot} = V_{ou} / E_v \quad (\text{Eq. 6-8})$$

Appendix A contains the spreadsheet for each air handler used to calculate the ventilation based on the method described. For the majority of spaces occupancies were not calculated based on ASHRAE Standard 62.1 Table 6-1. Rather the design assumptions for occupancies were used when known. Furthermore, restrooms were categorized as janitor closets for the purpose of the spreadsheet because of the high airflow rate per square foot that would be necessary for ventilation. The vending area was categorized as a coffee station based on the assumptions put forth by the design team.

Appendix B provides a summary of each space grouped by air handler and illustrates its compliance with ASHRAE Standard 62.1-2007 Section 6 based on design airflow rates and minimum required airflow rates. As specified by the drawings, air handlers AHU-1 and AHU-2 are to supply a minimum of 12,775 CFM of outdoor air, which equates to 40 percent of the total supply airflow at the design condition. The ventilation rate procedure of Section 6 requires a minimum of 9,700 and 4,850 CFM of outdoor air for air handlers AHU-1 and AHU-2 respectively. Air handler AHU-3 is a 100 percent outdoor air unit, which supplies the laboratory spaces. The ventilation requirements for these spaces are far surpassed by the quantity supply air that has been designed. This calculation illustrates that the cooling design load quantity of supply air is the determining factor for the amount of airflow delivered to each space being served by AHU-3.

### **ASHRAE Standard 62.1-2007 Summary**

The HVAC design of the Life Sciences Building surpasses the requirements of Section 5 where the Section is applicable. The Life Sciences Building is applying for LEED certification, which effects the design considerations from the beginning.

The minimum ventilation requirements of Section 6 are exceeded in the design of Life Sciences Building. Two of the air handlers provide 40 percent of the supply air as outdoor at the design condition, which is more than the required ratio mandated by Section 6. The third air handler is a 100 percent outdoor air unit, which is designed to meet both the ventilation requirements and the room cooling loads. The 100 percent outdoor air unit will provide the laboratory and hazardous storages spaces with a safer environment.

## ASHRAE Standard 90.1-2007 Analysis

### Section 5 – Building Envelope

#### 5.1.4 Climate Zone

The climate zone for Nassau Community College Life Sciences Building is located in Garden City, NY on Long Island, which corresponds to zone 4A. Zone 4A is defined by having mixed weather conditions as well as experiencing periods of high humidity. The climate zone was determined using Table B-1 in ASHRAE Standard 90.1-2007 or by viewing Figure 2 below.




Figure 2 – United States Climate Regions

#### 5.4 Mandatory Provisions

The exterior envelope of the Life Sciences Building is specified on the drawings to be sealed where exterior door frames, fenestration and the copper rain screen panels join in order to prevent infiltration of unconditioned air.

The two building entrance to the Life Sciences Building contain vestibules that provide a barrier between the interior conditioned space and the exterior. The smallest of the vestibules has a distance of 10 feet between the exterior and interior doors, which is greater than the mandated 7 feet.

#### 5.5 Prescriptive Building Envelope

The prescriptive building envelope method was used to determine the Life Sciences Building's compliance with Standard 90.1's building envelope requirements. Located in Table 5.5-4 in

Standard 90.1 are values corresponding to maximum U-values, R-values, C-values, F-values and SHGC for the appropriate assemblies. Standard 90.1 mandates that no more than 40% of a building’s façade may be comprised of vertical fenestration as compared to exterior wall area. The summary of Standard 90.1’s requirements and the Life Sciences Building’s design can be viewed in Tables 2 through 4 below.

	Glazing Area (ft <sup>2</sup> )	Wall Area (ft <sup>2</sup> )	Percent Glazing	Standard 90.1 Compliance (Y/N)
Life Science Building	16,901	42,084	40.16%	N

**Table 1 – Total Building Glazing Area**

The Life Sciences Building does not comply with Standard 90.1. This is due to the large storefront windows on the first floor that increase the aesthetic appeal of the building. Furthermore, the courtyard side of the building that houses the faculty offices contains a glass curtain wall that stretches from the ground to the third floor. This is to accommodate the faculty who contribute to the operations and education of the campus. The Life Sciences Building would only need a small adjustment in the windows for the smaller teaching classrooms in order to meet Standard 90.1 requirements

Exterior Materials		Prescribed Nonresidential		Prescribed Nonresidential		Standard 90.1 Compliance (Y/N)
Element	Element Construction	Assembly Maximum	Insulation Minimum	Assembly Maximum	Insulation Minimum	
Roof	Insulation Entirely above Deck	U-0.048	R-20.0 c.i.	U-0.06811	R-14.7	Y
Walls, Above Grade	Steel-Framed	U-0.064	R-9.5 c.i.	U-0.04678	R-21.4	N
Walls, Below Grade	Below-Grade Wall	C-1.140	NR	C-1.33	NR	N
Slab-On- Grade Floors	Unheated	F-0.730	NR	F-0.36	NR	Y

**Table 2 - Building Material Properties**

Two of the exterior façade elements do not meet the requirements of Standard 90.1. The walls above grade as well as the walls below grade do not have the resistance required. The walls below grade do not pass because of the lack of insulation required. The above grade walls do not meet Standard 90.1 because the composition was selected based on aesthetics rather than function. In order to compensate for the thermal loss through the above grade walls, the curtain walls and windows far surpass the requirements for maximum U-value and maximum SHGC as seen in Table 4 below.

Fenestration	Prescribed Nonresidential		Actual Design Assembly		Standard 90.1 Compliance (Y/N)
	Maximum U-Value	Maximum SHGC	Maximum U-Value	Maximum SHGC	
Metal Framing	U-0.50	SHGC-0.40	U-0.28	SHGC-0.27	Y

**Table 3 - Building Fenestration Properties**

## Section 6 – Heating, Ventilating, and Air Conditioning

### 6.2 Compliance Path

Two methods are described in Standard 90.1 in order to evaluate the efficiency of the overall building mechanical system – the Simplified Approach Option or the Mandatory Provisions method.

### 6.3 The Simplified Approach Option for HVAC Systems

The Simplified Approach Option can be used if the building is two stories or fewer in height and in the gross floor area is less than 25,000 square feet. Since the Life Sciences Building does not meet either of those conditions, the Mandatory Provisions method will be used in this analysis.

### 6.4 Mandatory Provisions

The Life Science building is has zone thermostats to control both the heating and cooling space temperature. The thermostatic controls respond with an accuracy ranging from  $\pm 2^{\circ}\text{F}$  to  $\pm 5^{\circ}\text{F}$ . In order to prevent setpoint overlap, the thermostat will call for heat when the outdoor air temperature falls below  $50^{\circ}\text{F}$ . An outdoor air temperature below  $50^{\circ}\text{F}$  will activate the perimeter finned tube radiation and decrease the quantity of CFM supplied from the air handler to the zone.

The thermostat is also controlled by periods of occupancy based on a carbon dioxide sensor. During occupied hours the space is to maintain a temperature of  $72^{\circ}\text{F}$ . When unoccupied, the setpoint is between  $68^{\circ}\text{F}$  and  $76^{\circ}\text{F}$  to keep the space occupant ready. When the air handler is off, the space temperature will be maintained at a  $55^{\circ}\text{F}$  minimum

In the event of a fire alarm emergency, the ventilation dampers at the top of the elevator shaft are programmed to open. During all other operating modes, the elevator shaft vent is normally closed. The air handlers will shut down upon receiving a fire alarm signal. In a smoke purge situation, the air handlers operate both the return and supply fan at full capacity in full exhaust, which draws in 100 percent outdoor air to purge smoke.

Insulation for supply and return ductwork is dependent on location and use. All exterior ductwork must be insulated regardless of its use. Return ductwork is insulated in mechanical equipment rooms. Supply ductwork is insulated between the fan discharge and terminal outlet.



The outdoor air intake ductwork between the air entrance and fan inlet shall be insulated. The emergency generator exhaust will be insulated for safety due to the extremely hot temperatures of combustion. Sizes for ductwork insulation can be viewed in Table 5. All piping supply and return lines are insulated regardless of service. Make-up water and condensate drain piping is also insulated. A summary of the Life Sciences Building's piping insulation thickness can be seen in Table 6.

Ductwork Insulation Thickness		
Duct Location	Insulation Material	
	Rigid Fiberglass	Flexible Fiberglass
Interior	2"	2"
Exterior	3"	N/A

**Table 4 - Ductwork Insulation Thickness**

Pipe Insulation Thickness				
Service	Material	<1"	1" – 1¼"	1½" – 6"
Chilled Water (40°F - Ambient)	Fiberglass	1"	2"	2"
	Cellular Glass	1"	2"	2"
Hot Water (<250°F)	Fiberglass	1"	2"	2"

**Table 5 – Pipe Insulation Thickness**

Duct seam and joint sealing is specified as per the Sheet Metal and Air Conditioning Contractors' National Association (SMACNA) and is also designed to meet the requirements of Standard 90.1.

### *6.5 Prescriptive Path*

Of the three air handlers serving the Life Sciences Building, one is a 100% outdoor air unit. The two remaining air handlers have the capability to provide up to 100% of the design supply air quantity as outdoor air for cooling. Outdoor air dampers are specified to return to minimum outdoor air position when the outside air is 55°F, which is not among the acceptable control types for high-limit shutoff. The normal outdoor air fraction of supply air is 50%.

Based on the Motor Nameplate Horsepower method of calculating fan system power limitations, Table 7 provides a summary of which fans in the Life Sciences Building comply with the maximum allowable motor horsepower for a given airflow rate. It is worth noting that E/F-9 A, B, C complies with Standard 90.1 even though it is a laboratory exhaust fan serving fume hoods on the second floor. Furthermore, E/F-9 A, B, C contains a heat recovery run-around loop that recovers sensible heat, which preconditions make-up air entering the air handler.

Fan Compliance				
Unit	HP	CFM	CFM x 0.0015	90.1 Compliance
AHU-1 Supply	40	25,550	38.32	N
AHU-2 Supply	40	25,550	38.32	N
AHU-3 Supply	30	24,000	36	Y
AHU-1 Return	15	25,550	38.32	Y
AHU-2 Return	15	25,550	38.32	Y
E/F-1	¼	1,367	2.05	Y
E/F-3	¼	1,367	2.05	Y
E/F-4	1/6	1,095	1.64	Y
E/F-5	1/6	1,095	1.64	Y
E/F-6	2	4,500	6.75	Y
E/F-7	3	6,500	9.75	Y
E/F-8	1 ½	4,050	6.08	Y
E/F-9 A,B,C	20	24,050	36.08	Y

**Table 6 – Life Sciences Building Fan**

### 6.7 Submittals

A complete set of construction documents including operating manuals and sequence of operation will be handed to Nassau Community College upon completion of the Life Sciences Building. There will also be a balancing report of both the air and hydronic systems. The Life Sciences Building has submitted an application for LEED certification, therefore commissioning will be completed at the end of construction.

### Section 7 – Service Water Heating

The Life Sciences Building does not contain combustion equipment for service water heating. Hot water that is supplied to the air handlers, perimeter radiation and to other various hydronic heating equipment is produced via heat exchanger by campus provided high temperature hot water. The sole combustion element of the mechanical system is the emergency generator that does not produce hot water in the event of an emergency.

### Section 8 – Power

The Life Sciences Building electrical system is specified to comply with the National Electric Code (NEC), which states that feeder conductors are to have a maximum voltage drop of 2% and a maximum branch voltage drop of 3% at the design load condition. Therefore, the Life Sciences Building complies with this section. Furthermore, the construction drawings, including the single-line diagrams of the building electrical distribution as well as the floor plans, along with operating and maintenance manuals will be turned over to Nassau Community College at the completion of construction.

## **Section 9 – Lighting**

### *9.2 Compliance Path*

In Standard 90.1 there are two different methods to determine the compliance of the Life Sciences Building with the maximum lighting power density: the Building Area Method or the Space-by-Space Method. The Building Area Method involves totaling up the power consumed by all lighting fixtures used in the building during normal operating hours and dividing by the total building area. The Building Area Method will be used for this analysis.

### *9.4 Mandatory Provisions*

The Life Sciences Building contains occupancy sensors in all spaces. The sensors are combined with locally controlled switches for each space.

### *9.5 Building Area Method Compliance Path*

The Life Sciences Building falls into the category of school/university on ASHRAE Standard 90.1 Table 9.5.1. The Lighting Power Density (LPD) is designated to be no higher than  $1.2 \text{ W/ft}^2$  for this category. Table 8 below gives a summary of the breakdown of the lighting density for the Life Sciences Building by providing the number of each fixture per floor and the number of Watts per each fixture. The calculated  $\text{W/ft}^2$  is 0.90, which is well below the mandated maximum of  $1.2 \text{ W/ft}^2$ .

Lighting Density Compliance							
Fixture	Basement	1 <sup>st</sup>	2 <sup>nd</sup>	3 <sup>rd</sup>	Penthouse	W/fixt.	Total W
FK1	-	29	32	32	-	63	5859
FK2	-	46	62	85	-	63	12159
FK3	-	-	-	101	-	63	6363
FL2	1	-	-	-	-	79	79
FL3	-	1	-	-	-	79	79
FL4	3	10	7	7	2	79	2291
FL5	-	-	-	-	1	63	63
FN1	-	22	22	22	-	63	4158
FN2	-	4	4	4	-	63	756
FN3	-	19	12	12	-	63	2709
FP1	-	30	-	-	-	63	1890
FP2	-	-	25	-	-	63	1575
FP5	-	24	-	-	-	63	1512
FP6	-	24	-	-	-	63	1512
FP7	-	-	26	-	-	63	1638
FP8	-	-	24	-	-	63	1512
FR4	15	-	-	-	-	79	1185
FR5	62	4	4	4	40	79	9006
FR6	-	4	-	-	-	79	316
FT6	-	-	7	-	-	117	819
PB1	-	36	38	20	-	26	2444
PU2	2	-	-	-	-	26	52
PU3	6	-	-	-	-	42	252
Total=							58229
Building Area =							64,563
W/SF =							0.90
Standard 90.1 Compliant (Y/N)							Y

Table 7 – Life Sciences Building Power Density

## Section 10 – Other Equipment

All other pieces of mechanical equipment that have electrical motors are subject to this section, which defines minimum efficiencies for motors based upon rated horsepower and motor speed. There are a series of pumps used in the Life Sciences Building, none of which comply with the required minimum efficiencies of this section. Of the motors listed in Table 9, all utilize variable frequency drives (VFD) except pumps P-5, P-6A, B and P-11. Heat recovery pump P-11 does not have a VFD due to the nature of its operation. Pump P-11 is specified to operate continuously at a constant speed whenever the outside air temperature is below 55°F or above 80°F. Furthermore, all pumps serving air handler pre-heat coils operate in the same manner; when the outside air temperature is below 55°F, they run at constant speed.

Pump Motor Efficiency Compliance						
Pump	Service	HP	Efficiency	RPM	Min. Efficiency	Standard 90.1 Compliance
P-1, 2	CHW Booster	15	82.4	1750	91	N
P-3, 4	CHW Service	15	82.8	1750	91	N
P-5	Glycol	1.5	66.5	1750	84	N
P-6A, B	AHU-Circulation	3/4	62.4	1750	-	N
P-7, 8	Radiation	5	65.8	1750	87.5	N
P-9, 10	Re-heat	3	62.6	1750	86.5	N
P-11	Heat Recovery	2	69.2	1750	84	N

**Table 8 – Life Sciences Building Pump Motor Efficiency Compliance**

### ASHRAE 90.1-2007 Summary

In order to determine compliance with ASHRAE Standard 90.1-2007, the prescriptive performance evaluation method was used for all sections. All things considered, the Life Sciences Building complies with this standard with some minor exceptions. The two major failures, according to Standard 90.1, are the overall glazing percentage of exterior wall area and exterior wall U-values and fan power usage.

The overall glazing percentage is over the acceptable limit by only a fraction of a percent and could be corrected with a slight sacrifice to aesthetics. The exterior walls, both above and below grade, have U-values that fall below the maximum. The walls above grade are constructed of copper rain screen panels and metal studs with a layer of insulation. This construction serves as a more aesthetic appeal rather than a functional thermal boundary. However, the large glazing areas have U-values and SHGC's that far surpass the requirements of this standard. The increase in thermal properties for the exterior glazing is to compensate for the below minimum requirements of the walls.

The supply fans for air handlers AHU-1 and AHU-2 are the only two fans that do not comply with this standard. These fans have a high external static pressure to overcome due to the long runs of ductwork to the building's extremities. A small adjustment in ductwork sizing and routing would allow for the supply fan to overcome a smaller external pressure drop. The return fans for these respective units are used for a plenum return, which is why their power requirements are much less.

The Life Sciences Building has submitted its application for LEED certification with a maximum of 69 potential points, which would yield a LEED Platinum rating. As a result, energy efficiency was a major design consideration where the majority of ASHRAE Standard 90.1 was followed. With a few minor adjustments, the Life Science Building would be compliant in all aspects of ASHRAE Standard 90.1.



## References

ANSI/ASHRAE. (2007). *Standard 62.1 – 2007, Ventilation for Acceptable Indoor Air Quality*. Atlanta, GA: American Society of Heating Refrigeration and Air Conditioning Engineers, Inc.

ANSI/ASHRAE. (2007). *Standard 90.1 – 2007, Energy Standard for Buildings Except Low-Rise Residential Buildings*. Atlanta, GA: American Society of Heating Refrigeration and Air Conditioning Engineers, Inc.

Cannon Design. Architectural Construction Documents. Cannon Design, New York, NY.

Cannon Design. Electrical Construction Documents. Cannon Design, New York, NY.

Cannon Design. Mechanical Construction Documents. Cannon Design, New York, NY.

# Appendix A - Minimum Ventilation Calculation

Building: Nassau Community College Life Sciences Building		System TagName: AHU-1	
Operating Condition Description: Units (selected from pull-down list)		Design Peak Cooling Load Condition	
<b>Inputs for System</b>			
Floor area served by system	Name	Units	System
Population of area served by system (including diversity)	As	SF	1905.3
Design primary supply fan airflow rate	Ps	P	328
OA req'd per unit area for system (Weighted average)	Vpsd	cfm	27.500
OA req'd per person for system area (Weighted average)	Rps	cfm/psf	0.09
OA req'd per person for system area (Weighted average)	Rps	cfm/psf	0.09
<b>Inputs for Potentially Critical Zones</b>			
Zone Name	Zone the turns purple (pink for critical zone(s))		
Zone Tag	Lobby		
Space type	Select from pull-down list		
Floor Area of zone	Az	SF	375
Design population of zone	Pz	P	10
Design total supply to zone (primary plus local recirculated)	Vztd	cfm	100
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?	Et	Select from pull-down list or leave blank if N/A	
Local recirc. air % representative of zone system return air	Er		
<b>Inputs for Operating Condition Analyzed</b>			
Percent of total design airflow rate at conditioned analyzed	Ds	%	100%
Air distribution type at conditioned analyzed	Ez	Select from pull-down list	CS
Zone air distribution effectiveness at conditioned analyzed	Ed		1.00
Primary air fraction of supply air at conditioned analyzed	Ep		1.00
<b>Results</b>			
Ventilation System Efficiency	Ey		0.42
Outdoor air intake required for system	Vot	cfm	9687
Outdoor air per unit floor area	Vou/as	cfm/psf	0.51
Outdoor air per person served by system (including diversity)	Vou/ps	cfm/psf	29.5
Outdoor air as a % of design primary supply air	Ypd	cfm	35%
<b>Calculated Calculations</b>			
<b>Initial Calculations for the System as a whole</b>			
Primary supply air flow to system at conditioned analyzed	Vps	cfm	27500
Uncorrected OA requirement for system	Vou	cfm	4113
Uncorrected OA req'd as a fraction of primary SA	Xs		0.15
<b>Initial Calculations for Individual Zones</b>			
OA rate per unit area for zone	Raz	cfm/psf	0.06
Total supply air to zone (at condition being analyzed)	Rzdz	cfm	5.00
Unused OA req'd to overstreng zone	Voz	cfm	100
Unused OA requirement for zone	Vozz	cfm	72.5
Fraction of zone supply not directly recirc. from zone	Fa		7.3
Fraction of zone supply from fully mixed primary air	Fb		2.7
Fraction of zone OA not directly recirc. from zone	Fc		1.00
Unused OA fraction required in supply air to zone	Zd		0.14
Unused OA fraction required in primary air to zone	Zp		0.14
<b>System Ventilation Efficiency</b>			
Zone Ventilation Efficiency (App A Method)	Ez		0.42
System Ventilation Efficiency (App A Method)	Ey		0.42
Ventilation System Efficiency (Table 6.3 Method)	Ev		n/a
<b>Minimum outdoor air intake airflow</b>			
Outdoor Air Intake Flow required to System	Vot	cfm	9687
OA Intake req'd as a fraction of primary SA	Y		0.35
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Vot	cfm	n/a
OA Intake req'd as a fraction of primary SA (Table 6.3 Method)	Y		n/a
OA Temp at which Min OA provides all cooling	Deq F		24
OA-T design with OA Intake flow is 0.0 minimum			

Zone	Zone Tag	Space type	Floor Area (Az)	Design Pop (Pz)	Design Total Supply (Vztd)	Local Recirc. Air % (Er)	Percent of Total Design Airflow Rate (Ds)	Air Distribution Type (Ez)	Zone Air Distribution Effectiveness (Ed)	Primary Air Fraction (Ep)	Zone Ventilation Efficiency (Ez)	System Ventilation Efficiency (Ey)	Outdoor Air Intake (Vot)	Outdoor Air per Unit Floor Area (Vou/as)	Outdoor Air per Person (Vou/ps)	Outdoor Air as % of Design Primary Supply (Ypd)
Lobby			375	10	100		100%	CS	1.00	1.00	0.42	0.42	9687	0.51	29.5	35%
Corridor #2			451	0	200		100%	CS	1.00	1.00	0.42	0.42	9687	0.51	29.5	35%
Classroom (age 9 plus)			1018	35.63	1600		100%	CS	1.00	1.00	0.42	0.42	9687	0.51	29.5	35%
General Classroom			1181	36	1950		100%	CS	1.00	1.00	0.42	0.42	9687	0.51	29.5	35%
General Classroom			755	24	1200		100%	CS	1.00	1.00	0.42	0.42	9687	0.51	29.5	35%
General Classroom			761	24	1100		100%	CS	1.00	1.00	0.42	0.42	9687	0.51	29.5	35%
Chem. Computer			939	25	1800		100%	CS	1.00	1.00	0.42	0.42	9687	0.51	29.5	35%

Building:		Nassau Community College Life Sciences Building									
System Tag/Name:		AHU-1									
Operating Condition Description:		Design Peak Cooling Load Condition									
Units (Selected from pull-down list)		P									
<b>Inputs for System</b>		Floor area served by system		Population of area served by system (including diversity)		Design primary supply fan airflow rate		OA req'd per unit area for system (Weighted average)		OA req'd per person for system area (Weighted average)	
Units		sf		P		cfm		cfm/sf		cfm/p	
System		19053		328		27500		0.08		8.0	
<b>Inputs for Potentially Critical Zones</b>		Zone Name		Zone Tag		Space type		Floor Area of zone		Design population of zone	
Units		sf		P		dm		sq ft		P	
System		19053		328		dm		622		109	
Zone Name		Zone Tag		Space type		Floor Area of zone		Design population of zone		Design total supply to zone (primary plus local recirculated)	
Units		sf		dm		sq ft		P		Vozd	
System		19053		328		dm		622		109	
Zone Name		Zone Tag		Space type		Floor Area of zone		Design population of zone		Design total supply to zone (primary plus local recirculated)	
Units		sf		dm		sq ft		P		Vozd	
System		19053		328		dm		622		109	
<b>Inputs for Operating Condition Analyzed</b>		Percent of total design airflow rate at conditioned analyzed		Air distribution type at conditioned analyzed		Zone air distribution effectiveness at conditioned analyzed		Primary air fraction of supply air at conditioned analyzed		Results	
Units		%		dm		dm		dm		EV	
System		100%		CS		1.00		1.00		9887	
Zone Name		Zone Tag		Space type		Floor Area of zone		Design population of zone		Design total supply to zone (primary plus local recirculated)	
Units		sf		dm		sq ft		P		Vozd	
System		19053		328		dm		622		109	
<b>Results</b>		Ventilation System Efficiency		Outdoor air intake required for system		Outdoor air per unit floor area		Outdoor air per person served by system (including diversity)		Outdoor air as a % of design primary supply air	
Units		dm		Vol/As		cfm/sf		Vol/p		dm	
System		0.42		9887		0.51		29.5		38%	
<b>Calculated Calculations</b>		Initial Calculations for the System as a whole									
Units		Vps									
System		27500									
<b>Initial Calculations for Individual Zones</b>		OA rate per unit area for zone		Total supply air to zone (at condition being analyzed)		Unused OA req'd to breathing zone		Unused OA requirement for zone		Fraction of zone supply not directly recirc. from zone	
Units		cfm/sf		cfm		cfm		cfm		Fz	
System		0.05		390		390		390		1.00	
Zone Name		Zone Tag		Space type		Floor Area of zone		Design population of zone		Design total supply to zone (primary plus local recirculated)	
Units		sf		dm		sq ft		P		Vozd	
System		19053		328		dm		622		109	
<b>System Ventilation Efficiency</b>		Zone Ventilation Efficiency (App A Method)		System Ventilation Efficiency (App A Method)		System Ventilation Efficiency (Table 6.3 Method)		Minimum outdoor air intake airflow		Outdoor Air Intake Flow required to System	
Units		dm		dm		dm		cfm		cfm	
System		0.42		0.42		n/a		9887		9887	
<b>Minimum outdoor air intake airflow</b>		Outdoor Air Intake Flow required to System		Outdoor Air Intake req'd as a fraction of primary SA		Outdoor Air Intake Flow required to System (Table 6.3 Method)		OA Intake req'd as a fraction of primary SA (Table 6.3 Method)		OA Temp at which Min OA provides all cooling	
Units		cfm		dm		cfm		dm		Deg F	
System		9887		0.35		9887		0.35		24	
<b>OA Temp at which Min OA provides all cooling</b>		Outdoor Air Intake Flow required to System		Outdoor Air Intake req'd as a fraction of primary SA		Outdoor Air Intake Flow required to System (Table 6.3 Method)		OA Intake req'd as a fraction of primary SA (Table 6.3 Method)		OA Temp at which Min OA provides all cooling	
Units		cfm		dm		cfm		dm		Deg F	
System		9887		0.35		9887		0.35		24	

Building:		Nassau Community College Life Sciences Building	
System Tag/Name:		LHJ-1	
Operating Condition Description:		Design Peak Cooling Load Condition	
Units tested from pull-down list:		IP	
<b>Inputs for System</b>			
Floor area served by system	Population of area served by system (including diversity)	AS	System
Design primary supply fan airflow rate	Design total supply to zone (primary plus local recirculated)	PS	328
OA req'd per unit area for system (Weighted average)	Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?	Vpsd	27.500
OA req'd per person for system area (Weighted average)	Local recirc. air % representative of ave system return air	Rps	0.09
		Rps	0.09
<b>Inputs for Potentially Critical Zones</b>			
Zone Name			
Zone Tag			
Space type			
Floor Area of zone			
Design population of zone			
Design total supply to zone (primary plus local recirculated)			
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?			
Local recirc. air % representative of ave system return air			
<b>Inputs for Operating Condition Analyzed</b>			
Percent of local design airflow rate at conditioned analyzed	D6	%	100%
Air distribution type at conditioned analyzed	EZ	Selected from pull-down list	
Zone air distribution effectiveness at conditioned analyzed	ED		
Primary air fraction of supply air at conditioned analyzed	EV		
<b>Results</b>			
Ventilation System Efficiency	EV	0.42	
Outdoor air intake required for system	Vot	9687	
Outdoor air per unit floor area	Vot/As	0.51	
Outdoor air per person served by system (including diversity)	Vot/As	29.5	
Outdoor air as a % of design primary supply air	Ypd	38%	
<b>Detailed Calculations</b>			
<b>Initial Calculations for the System as a whole</b>			
Primary supply air flow to system at conditioned analyzed	Vps	27500	
Uncorrected OA requirement for system	Vou	4113	
Uncorrected OA req'd as a fraction of primary SA	Xs	0.15	
<b>Initial Calculations for individual zones</b>			
OA rate per unit area for zone	Raz	dm <sup>3</sup> /sf	
OA rate per person	Rpz	dm <sup>3</sup> /p	
Total supply air to zone (at condition being analyzed)	Voz	dm <sup>3</sup>	
Unused OA req'd to breathing zone	Voz	dm <sup>3</sup>	
Unused OA requirement for zone	Voz	dm <sup>3</sup>	
Fraction of zone supply not directly recirc. from zone	Fa		
Fraction of zone supply from fully mixed primary air	Fd		
Fraction of zone OA not directly recirc. from zone	Fc		
Unused OA fraction required in supply air to zone	Zd		
Unused OA fraction required in primary air to zone	Zp		
<b>System Ventilation Efficiency</b>			
Zone Ventilation Efficiency (App A Method)	EVZ		
System Ventilation Efficiency (App A Method)	EV	0.42	
System Ventilation Efficiency (Table 6.3 Method)	EV	n/a	
<b>Minimum outdoor air intake airflow</b>			
Outdoor Air Intake Flow required to System	Vot	dm <sup>3</sup>	9687
OA intake req'd as a fraction of primary SA	Vot / Vps		0.35
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Vot	dm <sup>3</sup>	n/a
OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Vot / Vps		n/a
OA Temp at which Min OA provides all cooling	Deq F		24
OA T below which OA intake flow is at minimum			

Zone Name	Zone Tag	Space type	Floor Area of zone	Design population of zone	Design total supply to zone (primary plus local recirculated)	Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?	Local recirc. air % representative of ave system return air
Corr. #2							
Second 18 Corridors			598	0	0		
Second 20 Offices space			299	4	350		
Second 20A Director's Office			172	1	175		
Second 20C Conf. Room			247	12	500		
Second 20C Conference room setting			109	1	350		
Second 26 Fac. Office			105	1	325		
Second 27 Fac. Office			105	1	325		
Second 28 Fac. Office			105	1	325		

Building:		Nassau Community College Life Sciences Building	
System Tag/Name:		LH4U-1	
Operating Condition Description:		Design Peak Cooling Load Condition	
Units (select from pull-down list)		IP	
<b>Inputs for System</b>			
Floor area served by system	Name	Units	System
Population of area served by system (including diversity)	AS	sf	130633
Design primary supply fan airflow rate	PS	P	328
OA req'd per unit area for system (Weighted average)	Vpsd	cfm	27.500
OA req'd per person for system area (Weighted average)	Rps	cfm/sf	0.09
OA req'd per person for system area (Weighted average)	Rps	cfm/sf	6.0
<b>Inputs for Potentially Critical Zones</b>			
Zone Name	Zone title turns purple (pink for critical zone(s))		
Zone Tag	Zone title turns purple (pink for critical zone(s))		
Space type	Selected from pull-down list		
Floor Area of zone	Az	sf	Selected from pull-down list
Design population of zone	Pz	P	(default value listed, may be overridden)
Design total supply to zone (primary plus local recirculated)	Vztd	cfm	Selected from pull-down list or leave blank if N/A
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?	Et		
Local recirc. air % representative of ave system return air			
<b>Inputs for Operating Condition Analyzed</b>			
Percent of total design airflow rate at conditioned analyzed	D6	%	100%
Air distribution type at conditioned analyzed	Ez		Selected from pull-down list
Zone air distribution effectiveness at conditioned analyzed	Ez		
Primary air fraction of supply air at conditioned analyzed	Ed		
<b>Results</b>			
Ventilation System Efficiency	Ev		0.42
Outdoor air intake required for system	Vot	cfm	9687
Outdoor air per unit floor area	Vot/as	cfm/sf	0.51
Outdoor air per person served by system (including diversity)	Vot/ps	cfm/sf	29.5
Outdoor air as a % of design primary supply air	Yod	cfm	35%
<b>Detailed Calculations</b>			
<b>Initial Calculations for the System as a Whole</b>			
Primary supply air flow to system at conditioned analyzed	Vps	cfm	27500
Uncorrected OA requirement for system	Vou	cfm	4113
Uncorrected OA req'd as a fraction of primary SA	Xs		0.15
<b>Initial Calculations for Individual Zones</b>			
OA rate per unit area for zone	Raz	cfm/sf	
OA rate per person	Rpz	cfm/sf	
Total supply air to zone (at condition being analyzed)	Vz	cfm	
Unused OA req'd to breathing zone	Voz	cfm	
Unused OA requirement for zone	VozEz	cfm	
Fraction of zone supply not directly recirc. from zone	Fz		
Fraction of zone supply from fully mixed primary air	Fd		
Fraction of zone OA not directly recirc. from zone	Fc		
Unused OA fraction required in supply air to zone	Zd		
Unused OA fraction required in primary air to zone	Zp		
<b>System Ventilation Efficiency</b>			
Zone Ventilation Efficiency (App A Method)	Evz		
System Ventilation Efficiency (App A Method)	Ev		0.42
System Ventilation Efficiency (Table 6.3 Method)	Ev		N/A
<b>Minimum outdoor air intake airflow</b>			
Outdoor Air Intake Flow required to System	Vot	cfm	9687
OA intake req'd as a fraction of primary SA	Y		0.35
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Vot	cfm	N/A
OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Y		N/A
<b>OA Temp at which Min OA provides all cooling</b>			
OA Temp below which OA intake flow is at minimum	Deq F		24

Fac. Office	Fac. Office	Fac. Office	Fac. Office	Faculty Lounge	Prac. Skills Training Rm	Corr. #2
Second 36 Office space	Second 37 Office space	Second 38 Office space	Second 39 Office space	Third 15 Classrooms (age 9 plus)	Third 17 Lecture classroom	Third 18 Corridors
106	105	105	102	301	1423	1111
1	1	1	1	10.535	37	500
150	150	150	150	525	2100	500
100%	100%	100%	100%	100%	100%	100%
CS	CS	CS	CS	CS	CS	CS
1.00	1.00	1.00	1.00	1.00	1.00	1.00



Building:		Nassau Community College Life Sciences Building											
System TagName:		AHU-1											
Operating Condition Description:		Design Peak Cooling Load Condition											
Units (selected from pull-down list)		IP											
<b>Inputs for System</b>		Floor area served by system		Population of area served by system (including diversity)		Design primary supply fan airflow rate		OA req'd per unit area for system (Weighted average)		OA req'd per person for system area (Weighted average)		Inputs for Potentially Critical Zones	
Name		Units		System		1905.3		328		27,500		0.09	
As		sf		1905.3		328		27,500		0.09		6.0	
Ps		p		100%		diversity							
Vpsd		cfm											
Ras		cfm/sf											
Rps		cfm/ps											
Zone Name		Zone the bars purple text for critical zone(s)											
Zone Tag													
Space type													
Floor Area of zone		Select from pull-down list											
Design population of zone		Pz (default value listed; may be overridden)											
Design total supply to zone (primary plus local recirculated)		Vztd											
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?		E											
Local recirc. air % representative of zone system return air													
<b>Inputs for Operating Condition Analyzed</b>		Percent of total design airflow rate at conditioned analyzed		D6		%		100%		100%		100%	
Air distribution type at conditioned analyzed		E2		Select from pull-down list				100%		100%		100%	
Zone air distribution effectiveness at conditioned analyzed		Ez		CS		CS		1.00		1.00		1.00	
Primary air fraction of supply air at conditioned analyzed		Ez		CS		CS		1.00		1.00		1.00	
<b>Results</b>		Ventilation System Efficiency		Ez		cfm		9687		0.42			
Outdoor air intake required for system		Vot		cfm		9687		0.51		29.5			
Outdoor air per unit floor area		Vot/as		cfm/sf		0.51		29.5		35%			
Outdoor air per person served by system (including diversity)		Vot/ps		cfm/ps		29.5		35%					
Outdoor air as a % of design primary supply air		Ypd		cfm		35%							
<b>Detailed Calculations</b>		<b>Initial Calculations for the System as a whole</b>											
Primary supply air flow to system at conditioned analyzed		Vps		cfm		27500							
Unrecirculated OA requirement for system		Vou		cfm		4113							
Unrecirculated OA req'd as a fraction of primary SA		Xs				0.15							
<b>Initial Calculations for Individual Zones</b>		OA rate per unit area for zone		Raz		cfm/sf		0.05		0.12		0.05	
Total supply air to zone (at condition being analyzed)		Roz		cfm/ps		5.00		0.00		5.00		0.05	
Unused OA req'd to breathing zone		Voz		cfm		350		150		700		2100	
Unused OA requirement for zone		Voz		cfm		51.0		18.6		159.3		677.2	
Fraction of zone supply not directly recirc. from zone		Fz				1.00		1.00		1.00		1.00	
Fraction of zone supply from fully mixed primary air		Fz				1.00		1.00		1.00		1.00	
Fraction of zone OA not directly recirc. from zone		Fz				1.00		1.00		1.00		1.00	
Unused OA fraction required in supply air to zone		Zd				0.15		0.12		0.23		0.32	
Unused OA fraction required in primary air to zone		Zp				0.15		0.07		0.23		0.32	
<b>System Ventilation Efficiency</b>		Zone Ventilation Efficiency (App A Method)		Ez				1.00		1.03		1.04	
System Ventilation Efficiency (App A Method)		Ez				0.42							
Ventilation System Efficiency (App A Method)		Ez				n/a							
<b>Minimum outdoor air intake airflow</b>		Outdoor Air Intake Flow required to System		Vot		cfm		9687		0.35		n/a	
Outdoor Air Intake req'd as a fraction of primary SA		Y				0.35		n/a		n/a		n/a	
Outdoor Air Intake Flow required to system (Table 6.3 Method)		Vot		cfm		9687		0.35		n/a		n/a	
OA Intake req'd as a fraction of primary SA (Table 6.3 Method)		Y				n/a		n/a		n/a		n/a	
OA Temp at which Min OA provides all cooling		Deg F		- (17p-d)T(1-Y)11T+dt		24							
OA Temp below which OA Intake flow is 0.0 minimum		Deg F		- (17p-d)T(1-Y)11T+dt		24							

Building: Nassau Community College Life Sciences Building	
System TagName: ZHU-1	
Operating Condition Description: Design Peak Cooling Load Condition	
Units (select from pull-down list)	

Inputs for System	Name	Units	System
Floor area served by system	As	sf	19053
Population of area served by system (including diversity)	Ps	P	328
Design primary supply fan airflow rate	Vpsd	cfm	27500
OA req'd per unit area for system (Weighted average)	Rps	cfm/sf	0.03
OA req'd per person for system area (Weighted average)	Rps	cfm/ps	0.03

Inputs for Potentially Critical Zones	Zone Name	Zone Tag	Space type	Floor Area of zone	Design population of zone	Design total supply to zone (primary plus local recirculated)	Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?	Local recirc. air % representative of zone system return air

Inputs for Operating Condition Analyzed	Percent of total design airflow rate at conditioned analyzed	Air distribution type at conditioned analyzed	Zone air distribution effectiveness at conditioned analyzed	Primary air fraction of supply air at conditioned analyzed
	100%	CS	1.00	1.00

Results	EV	Vot	cfm	Vot/As	cfm/sf	Vot/ps	cfm/ps
Ventilation System Efficiency			0.42		9687		0.51
Outdoor air intake required for system			0.51		29.5		38%
Outdoor air per unit floor area							
Outdoor air per person served by system (including diversity)							
Outdoor air as a % of design primary supply air							

Detailed Calculations	Initial Calculations for the System as a whole	Primary supply air flow to system at conditioned analyzed	Unrecirculated OA requirement for system	Unrecirculated OA req'd as a fraction of primary SA
		27500	4113	0.15

Initial Calculations for Individual Zones	OA rate per unit area for zone	OA rate per person	Total supply air to zone (at condition being analyzed)	Unused OA req'd to breathing zone	Unused OA requirement for zone	Fraction of zone supply not directly recirc. from zone	Fraction of zone supply from fully mixed primary air	Fraction of zone OA not directly recirc. from zone	Unused OA fraction required in supply air to zone	Unused OA fraction required in primary air to zone
	Raz	cfm/sf	Rpz	cfm/ps	Voz	cfm	Fz	Fz	Zz	Zz

System Ventilation Efficiency	Zone Ventilation Efficiency (App A Method)	System Ventilation Efficiency (App A Method)	Ventilation System Efficiency (Table 6.3 Method)
	EV	EV	EV
	0.42	0.42	0.42

Minimum outdoor air intake airflow	Outdoor Air Intake Flow required to System	OA Intake req'd as a fraction of primary SA	Outdoor Air Intake Flow required to System (Table 6.3 Method)	OA Intake req'd as a fraction of primary SA (Table 6.3 Method)	OA Temp at which Min OA provides all cooling	OA T below which OA Intake flow is 0.0 minimum
	Vot	Y	cfm	Y	Req F	24

Building:		Nassau Community College Life Sciences Building				
System Tag/Name:		AHU-1				
Operating Condition Description:		Design Peak Cooling Load Condition				
Units (selected from pull-down list)		IP				
<b>Inputs for System</b>		<b>Name</b>	<b>Units</b>	<b>System</b>		
Floor area served by system	As	SF		19063		
Population of area served by system (including diversity)	Ps	P	100%	329		
Design primary supply fan airflow rate	Vpsd	cfm		27,500		
OA req'd per unit area for system (Weighted average)	Ras	cfm/sf		0.08		
OA req'd per person for system area (Weighted average)	Rps	cfm/ps		6.0		
<b>Inputs for Potentially Critical Zones</b>						
Zone Name						
Zone Tag	Zone tag turns purple italic for critical zone(s)					
Space type						
Floor Area of zone	Az	SF	Selected from pull-down list			
Design population of zone	Pz	P	(default value listed; may be overridden)			
Design total supply to zone (primary plus local recirculated)	Vztd	cfm	Selected from pull-down list or leave blank if N/A			
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?	Et					
Local recirc. air % representative of ave system return air	Er	%				
<b>Inputs for Operating Condition Analyzed</b>		Ds	%	Selected from pull-down list		
Percent of total design airflow rate at conditioned analyzed	Ez					
Air distribution type at conditioned analyzed	Ed					
Zone air distribution effectiveness at conditioned analyzed						
Primary air fraction of supply air at conditioned analyzed						
<b>Results</b>		Ev	0.42			
Ventilation System Efficiency	Volvs	cfm	9687			
Outdoor air intake required for system	Volvs	cfm	0.51			
Outdoor air per unit floor area	Vol/ps	cfm/ps	28.5			
Outdoor air per person served by system (including diversity)	Vol/ps	cfm/ps	35%			
Outdoor air as a % of design primary supply air						
<b>Detailed Calculations</b>						
<b>Initial Calculations for the System as a whole</b>		Vps	cfm	VpODs	27500	
Primary supply air flow to system at conditioned analyzed	Vou	cfm		Rps Ps + Ras As	4113	
Uncorrected OA requirement for system	Xs			Vou / Vps	0.15	
Uncorrected OA req'd as a fraction of primary SA						
<b>Initial Calculations for Individual Zones</b>		Raz	cfm/sf			
OA rate per unit area for zone	Rz	cfm/ps		VpODs		
OA rate per person	Voz	cfm		Rps Ps + Ras As		
Total supply air to zone (at condition being analyzed)	Voz	cfm		Vou / Vps		
Unused OA req'd to breathing zone	Voz	cfm				
Unused OA requirement for zone	Voz	cfm				
Fraction of zone supply not directly recirc. from zone	Fa					
Fraction of zone supply from fully mixed primary air	Fb					
Fraction of zone OA not directly recirc. from zone	Fc					
Unused OA fraction required in primary air to zone	Zd					
Unused OA fraction required in primary air to zone	Zp					
<b>System Ventilation Efficiency</b>		Evz		(Fa + Fb)Xs - Fcz) / Fa	1.09	
Zone Ventilation Efficiency (App A Method)	Ev			min (Evz)	1.08	0.42
System Ventilation Efficiency (App A Method)	Ev			Value from Table 6.3	n/a	n/a
<b>Minimum outdoor air intake airflow</b>		Vot	cfm	Vou / Ev	9687	
Outdoor Air Intake Flow required to System	Vot	cfm		Vot / Vps	0.35	
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Vot	cfm		Vou / Ev	n/a	
OA Intake req'd as a fraction of primary SA (Table 6.3 Method)	Y			Vot / Vps	n/a	
OA Intake req'd as a fraction of primary SA (Table 6.3 Method)	Y					
OA Temp at which Min OA provides all cooling	Deg F				24	
OA Temp below which OA Intake flow is at minimum	Deg F					

Fac. Office	Fac. Office	Fac. Office	Fac. Office	Fac. Office	Fac. Office
Third 35 Office space	Third 36 Office space	Third 37 Office space	Third 38 Office space	Third 39 Office space	Third 40 Office space
102	105	105	105	105	102
1	1	1	1	1	1
175	175	175	175	175	175
100%	100%	100%	100%	100%	100%
CS	CS	CS	CS	CS	CS
1.00	1.00	1.00	1.00	1.00	1.00

Building: Nassau Community College Life Sciences Building System Tag/Name: AHU-1 Operating Condition Description: Design Peak Cooling Load Condition Units (select from pull-down list) P																																																						
<b>Inputs for System</b> Floor area served by system Population of area served by system (including diversity) Design primary supply fan airflow rate OA req'd per unit area for system (Weighted average) OA req'd per person for system area (Weighted average) Inputs for Potentially Critical Zones		<table border="1"> <thead> <tr> <th>Name</th> <th>Units</th> <th>System</th> <th>Units</th> </tr> </thead> <tbody> <tr> <td>As</td> <td>sf</td> <td>19053</td> <td></td> </tr> <tr> <td>Ps</td> <td>P</td> <td>328</td> <td>P/1000 sf</td> </tr> <tr> <td>Vpsd</td> <td>cfm</td> <td>27500</td> <td>cfm</td> </tr> <tr> <td>Fps</td> <td>cfm/sf</td> <td>0.03</td> <td>ave cfm/sf</td> </tr> <tr> <td>Fpps</td> <td>cfm/p</td> <td>8.0</td> <td>ave cfm/p</td> </tr> </tbody> </table>	Name	Units	System	Units	As	sf	19053		Ps	P	328	P/1000 sf	Vpsd	cfm	27500	cfm	Fps	cfm/sf	0.03	ave cfm/sf	Fpps	cfm/p	8.0	ave cfm/p																												
Name	Units	System	Units																																																			
As	sf	19053																																																				
Ps	P	328	P/1000 sf																																																			
Vpsd	cfm	27500	cfm																																																			
Fps	cfm/sf	0.03	ave cfm/sf																																																			
Fpps	cfm/p	8.0	ave cfm/p																																																			
Zone Name Zone Tag Space type Floor Area of zone Design population of zone Design total supply to zone (primary plus local recirculated) Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan? Local recirc. air % representative of ave system return air		Select from pull-down list Az sf Pz P (default value listed; may be overridden) Vzdtd cfm Et Select from pull-down list or leave blank if N/A	make that primary over design average average																																																			
<b>Inputs for Operating Condition Analyzed</b> Percent of total design airflow rate at conditioned analyzed Air distribution type at conditioned analyzed Zone air distribution effectiveness at conditioned analyzed Primary air fraction of supply air at conditioned analyzed		Ds % Ez Ed Select from pull-down list	100% average average																																																			
<b>Results</b> Ventilation System Efficiency Outdoor air intake required for system Outdoor air per unit floor area Outdoor air per person served by system (including diversity) Outdoor air as a % of design primary supply air		Ev Vot Vol/As Vot/ps Ypd cfm cfm/sf cfm/p cfm	0.42 9687 0.51 29.5 38%																																																			
<b>Detailed Calculations</b> Initial Calculations for the System as a whole Primary supply air flow to system at conditioned analyzed Uncorrected OA requirement for system Uncorrected OA req'd as a fraction of primary SA Initial Calculations for Individual Zones OA rate per unit area for zones OA rate per person Total supply air to zone (at condition being analyzed) Unused OA req'd to breathing zone Unused OA requirement for zone Fraction of zone supply not directly recirc. from zone Fraction of zone supply from fully mixed primary air Fraction of zone OA not directly recirc. from zone Unused OA fraction required in supply air to zone Unused OA fraction required in primary air to zone System Ventilation Efficiency Zone Ventilation Efficiency (App A Method) System Ventilation Efficiency (App A Method) Ventilation System Efficiency (Table 6.3 Method) Minimum outdoor air intake airflow Outdoor Air Intake Flow required to System OA intake req'd as a fraction of primary SA Outdoor Air Intake Flow required to System (Table 6.3 Method) OA intake req'd as a fraction of primary SA (Table 6.3 Method) OA Temp at which Min OA provides all cooling OAT below which OA Intake flow is @ minimum																																																						
<table border="1"> <thead> <tr> <th>Vps</th> <th>Vou</th> <th>Xs</th> <th>Raz</th> <th>Rpz</th> <th>Voz</th> <th>Voz</th> <th>Fa</th> <th>Fb</th> <th>Fg</th> <th>Zd</th> <th>Ev</th> <th>Vot</th> <th>Vol/As</th> <th>Vot/ps</th> <th>Ypd</th> <th>Eq F</th> </tr> </thead> <tbody> <tr> <td>-</td> <td>-</td> <td>-</td> <td>-</td> <td>-</td> <td>-</td> <td>-</td> <td>-</td> <td>-</td> <td>-</td> <td>-</td> <td>-</td> <td>-</td> <td>-</td> <td>-</td> <td>-</td> <td>-</td> </tr> <tr> <td>27500</td> <td>4113</td> <td>0.15</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>24</td> </tr> </tbody> </table>				Vps	Vou	Xs	Raz	Rpz	Voz	Voz	Fa	Fb	Fg	Zd	Ev	Vot	Vol/As	Vot/ps	Ypd	Eq F	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	27500	4113	0.15														24
Vps	Vou	Xs	Raz	Rpz	Voz	Voz	Fa	Fb	Fg	Zd	Ev	Vot	Vol/As	Vot/ps	Ypd	Eq F																																						
-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-																																						
27500	4113	0.15														24																																						



Building: Nassau Community College Life Sciences Building																			
System Tag/Name: AHU-2																			
Operating Condition Description: Design Peak Cooling Load Condition																			
Units (select from pull-down list)	IP																		
<table border="1"> <tr> <th>Name</th> <th>Units</th> <th>System</th> </tr> <tr> <td>As</td> <td>sf</td> <td>18401</td> </tr> <tr> <td>Ps</td> <td>P</td> <td>320</td> </tr> <tr> <td>Vpsd</td> <td>cfm</td> <td>27,850</td> </tr> <tr> <td>Ras</td> <td>cfm/sf</td> <td>0.08</td> </tr> <tr> <td>Rps</td> <td>cfm/p</td> <td>7.3</td> </tr> </table>		Name	Units	System	As	sf	18401	Ps	P	320	Vpsd	cfm	27,850	Ras	cfm/sf	0.08	Rps	cfm/p	7.3
Name	Units	System																	
As	sf	18401																	
Ps	P	320																	
Vpsd	cfm	27,850																	
Ras	cfm/sf	0.08																	
Rps	cfm/p	7.3																	
<b>Inputs for System</b> Floor area served by system Population of area served by system (including diversity) Design primary supply fan airflow rate OA req'd per unit area for system (Weighted average) OA req'd per person for system area (Weighted average) Inputs for Potentially Critical zones																			
Zone Name	Zone file turns purple tabs for critical zone(s)																		
Zone Tag																			
Space type	Select from pull-down list																		
Floor Area of zone	Az	sf																	
Design population of zone	Pz	P																	
Design total supply to zone (primary plus local recirculated)	Vzsd	cfm																	
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?		Select from pull-down list or leave blank if N/A																	
Local recirc. air % representative of zone system return air	Er																		
<b>Inputs for Operating Condition Analyzed</b> Percent of total design airflow rate at conditioned analyzed Air distribution type at conditioned analyzed Zone air distribution effectiveness at conditioned analyzed Primary air fraction of supply air at conditioned analyzed																			
	Ds	%																	
	Ez	Select from pull-down list																	
	Ep																		
<b>Results</b> Ventilation System Efficiency Outdoor air intake required for system Outdoor air per unit floor area Outdoor air per person served by system (including diversity) Outdoor air as a % of design primary supply air																			
	Ev	0.78																	
	VoiA	4844																	
	VoiPs	0.26																	
	VoiPp	15.1																	
	Ypd	18%																	
<b>Detailed Calculations for the System as a whole</b> Primary supply air flow to system at conditioned analyzed Unrecirculated OA requirement for system Unrecirculated OA req'd as a fraction of primary SA																			
Vps	cfm	=	VoiDds	=	27850														
Vou	cfm	=	Rps Ps + Ras As	=	3783														
Xs		=	Vou / Vps	=	0.14														
<b>Initial Calculations for Individual Zones</b> OA rate per unit area for zone Total supply air to zone (at condition being analyzed) Unused OA req'd to breathing zone Unused OA requirement for zone Fraction of zone supply not directly recirc. from zone Fraction of zone supply from fully mixed primary air Fraction of zone OA not directly recirc. from zone Unused OA fraction required in supply air to zone Unused OA fraction required in primary air to zone																			
Raz	cfm/sf	=	Roz Pz + Raz Az	=	0.06														
Rpz	cfm/p	=	VoiZz	=	0.00														
Vaz	cfm	=	1-(1-Ez)(1-EP)(1-ER)	=	7.50														
Voz	cfm	=	VoiZz - Vaz	=	1600														
Fz	cfm	=	VoiZz / Vps	=	88.5														
Fb		=	Ep + (1-EP)Er	=	90														
Fc		=	EP	=	1.00														
Fd		=	1-(1-Ez)(1-EP)(1-ER)	=	1.00														
Fz		=	VoiZz / Vaz	=	1.00														
Fb		=	VoiZz / Vps	=	0.12														
Fc		=	(Fa + PzXs - FzZ) / Fa	=	0.21														
Fd		=	mn (EzZ)	=	0.20														
Zp		=	Value from Table 6.3	=	0.21														
EzZ		=	(Fa + PzXs - FzZ) / Fa	=	1.02														
Ev		=	mn (EzZ)	=	0.93														
Ev		=	Value from Table 6.3	=	0.93														
<b>Minimum outdoor air intake airflow</b> Outdoor Air Intake Flow required to System OA Intake req'd as a fraction of primary SA Outdoor Air Intake Flow required to System (Table 6.3 Method) OA Intake req'd as a fraction of primary SA (Table 6.3 Method) OA Intake req'd as a fraction of primary SA (Table 6.3 Method) OAT below which OA Intake flow is @ minimum																			
Voi	cfm	=	Voi / Ev	=	4844														
Y		=	Voi / Vps	=	0.18														
Voi	cfm	=	Voi / Ev	=	4786														
Y		=	Voi / Vps	=	0.17														
Deg F		=	((Tb-d)h/(1-Y)(T+d)Tr	=	-25														

Building: Nassau Community College Life Sciences Building	
System Tag/Name: AHU-2	
Operating Condition Description: Design Peak Cooling Load Condition	
Units (select from pull-down list)	IP

<b>Inputs for System</b>	
Floor area served by system	System 18401
Population of area served by system (including diversity)	As sf 320
Design primary supply fan airflow rate	Ps P 100% diversity
OA req'd per unit area for system (Weighted average)	Vosd cfm 27.650
OA req'd per person for system area (Weighted average)	Ras cfm/sf 0.08
OA req'd per person for system area (Weighted average)	Rps cfm/sf 7.3
<b>Inputs for Potentially Critical Zones</b>	
Zone Name	
Zone Tag	
Space type	
Floor Area of zone	Az sf
Design population of zone	Pz P (default value listed; may be overridden)
Design total supply to zone (primary plus local recirculated)	Vozd cfm
Induction Terminal Unit, Dual Fan Dual Duct or Transfer-Fan?	Vozd Select from pull-down list or leave blank if N/A
Local recirc. air, % representative of ave system return air	Er
<b>Inputs for Operating Condition Analyzed</b>	
Percent of total design airflow rate at conditioned analyzed	Ds % 100%
Air distribution type at conditioned analyzed	Ez Select from pull-down list
Zone air distribution effectiveness at conditioned analyzed	Ez
Primary air fraction of supply air at conditioned analyzed	Ed

<b>Results</b>	
Ventilation System Efficiency	Ev 0.78
Outdoor air intake required for system	Voc cfm 4844
Outdoor air per unit floor area	Voz/Az cfm/sf 0.26
Outdoor air per person served by system (including diversity)	Voz/Ps cfm/sf 15.1
Outdoor air as a % of design primary supply air	Ypd cfm 18%

<b>Detailed Calculations for the System as a Whole</b>	
Primary supply air flow to system at conditioned analyzed	Vps cfm 27650
Unrecircled OA requirement for system	Vou cfm 3783
Unrecircled OA req'd as a fraction of primary SA	Xs = Vos/Vps = 0.14
<b>Initial Calculations for Individual Zones</b>	
OA rate per unit area for zone	Raz cfm/sf
Total supply air to zone (at condition being analyzed)	Roz cfm/sf
Unhusd OA req'd to breathing zone	Voz cfm
Unhusd OA requirement for zone	Vozz cfm
Fraction of zone supply not directly recirc. from zone	Fz = (Roz - Vozz) / Roz
Fraction of zone supply from fully mixed primary air	Fp = 1 - Fz
Fraction of zone OA not directly recirc. from zone	Fo = Fz * Fp
Unhusd OA fraction required in supply air to zone	Zd = Fz * Fp * Xs
Unhusd OA fraction required in primary air to zone	Zp = Fz * Fp * Xs / Fz
<b>System Ventilation Efficiency</b>	
Zone Ventilation Efficiency (App A Method)	Ez = (Voz - Vos) / Vos = 0.78
System Ventilation Efficiency (App A Method)	Ev = min(Ez)
Ventilation System Efficiency (Table 6.3 Method)	Ev = Value from Table 6.3 = 0.80
<b>Minimum outdoor air intake airflow</b>	
Outdoor Air Intake Flow required to System	Voc cfm 4844
OA intake req'd as a fraction of primary SA	Ypd = Voc/Vps = 0.18
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Voc cfm 4798
OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Ypd = Voc/Vps = 0.17
<b>OA Temp at which Min. OA provides all cooling</b>	
OAT below which OA intake flow is @ minimum	Deg F = ((Tpd-Ts)-(1-Ypd)(Trad-Tr)) = -26

Room	Elect.	Tele.	Vending	Fac. Office	Fac. Office	Fac. Office	Fac. Office	Fac. Office
First 10	1.00							
Electrical equipment rooms								
First 15	1.00							
Electrical equipment rooms								
First 40	1.00							
Coffee Stations								
First 41	1.00							
Office space								
First 42	1.00							
Office space								
First 43	1.00							
Office space								
First 44	1.00							
Office space								



Building: Nassau Community College Life Sciences Building	
System Tag Name: AHU2	
Operating Condition Description: Design Peak Cooling Load Condition	
Units (Select from pull-down list)	IP

Inputs for System	Name	Units	System
Floor area served by system	As	sf	18401
Population of area served by system (including diversity)	Ps	P	320
Design primary supply fan airflow rate	Vpsd	cfm	27890
OA req'd per unit area for system (Weighted average)	Ras	cfm/sf	0.08
OA req'd per person for system area (Weighted average)	Rps	cfm/p	7.3

Inputs for Potentially Critical zones	Zone Name	Units	System
Zone Tag	Az	sf	105
Space type	Pz	P	1
Floor Area of zone	Vozd	cfm	325
Design population of zone			
Design total supply to zone (primary plus local recirculated)			
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?			
Local recirc. air, % representative of zone system return air	Er		

Inputs for Operating Condition Analyzed	Units	System
Percent of total design airflow rate at conditioned analyzed	Ds	%
Air distribution type at conditioned analyzed	Ez	Select from pull-down list
Zone air distribution effectiveness at conditioned analyzed	Ep	
Primary air fraction of supply air at conditioned analyzed		

Results	Units	System
Ventilation System Efficiency	Ev	0.78
Outdoor air intake required for system	Vor	cfm
Outdoor air per unit floor area	Vor/As	cfm/sf
Outdoor air per person served by system (including diversity)	Vor/Ps	cfm/p
Outdoor air as a % of design primary supply air	Vpd	cfm

Detailed Calculations for the System as a whole	Units	System
Primary supply air flow to system at conditioned analyzed	Vps	cfm
Unrecircled OA requirement for system	Vou	cfm
Unrecircled OA req'd as a fraction of primary SA	Xs	
OA rate per unit area for zone	Raz	cfm/sf
OA rate per person	Rpz	cfm/p
Total supply air to zone (at condition being analyzed)	Voz	cfm
Unused OA req'd to breathing zone	Voz	cfm
Unused OA requirement for zone	Voz	cfm
Fraction of zone supply not directly recirc. from zone	Fa	
Fraction of zone supply from fully mixed primary air	Fb	
Fraction of zone OA not directly recirc. from zone	Fc	
Unused OA fraction required in supply air to zone	Zp	
Unused OA fraction required in primary air to zone	Zp	
Zone Ventilation Efficiency (App A Method)	Evz	
System Ventilation Efficiency (App A Method)	Ev	
Ventilation System Efficiency (Table 6.3 Method)	Ev	
Minimum outdoor air intake airflow	Vor	cfm
Outdoor Air Intake Flow required to System	Vor	cfm
OA intake req'd as a fraction of primary SA	Vor / Vps	
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Vor	cfm
OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Vor / Vps	
OA Temp at which Min OA provides all cooling	Deg F	
OAT below which OA intake flow is @ minimum		

Initial Calculations for Individual Zones	Units	System
Zone Tag	Zone Tag	
Floor Area of zone	Az	sf
Design population of zone	Pz	P
Design total supply to zone (primary plus local recirculated)	Vozd	cfm
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?		
Local recirc. air, % representative of zone system return air	Er	

Initial Calculations for the System as a whole	Units	System
Primary supply air flow to system at conditioned analyzed	Vps	cfm
Unrecircled OA requirement for system	Vou	cfm
Unrecircled OA req'd as a fraction of primary SA	Xs	
OA rate per unit area for zone	Raz	cfm/sf
OA rate per person	Rpz	cfm/p
Total supply air to zone (at condition being analyzed)	Voz	cfm
Unused OA req'd to breathing zone	Voz	cfm
Unused OA requirement for zone	Voz	cfm
Fraction of zone supply not directly recirc. from zone	Fa	
Fraction of zone supply from fully mixed primary air	Fb	
Fraction of zone OA not directly recirc. from zone	Fc	
Unused OA fraction required in supply air to zone	Zp	
Unused OA fraction required in primary air to zone	Zp	
Zone Ventilation Efficiency (App A Method)	Evz	
System Ventilation Efficiency (App A Method)	Ev	
Ventilation System Efficiency (Table 6.3 Method)	Ev	
Minimum outdoor air intake airflow	Vor	cfm
Outdoor Air Intake Flow required to System	Vor	cfm
OA intake req'd as a fraction of primary SA	Vor / Vps	
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Vor	cfm
OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Vor / Vps	
OA Temp at which Min OA provides all cooling	Deg F	
OAT below which OA intake flow is @ minimum		

Building:		Nassau Community College Life Sciences Building											
System Tag/Name:		AHU-2											
Operating Condition Description:		Design Peak Cooling Load Condition											
Units (Select from pull-down list)		IP											
<b>Inputs for System</b>													
Floor area served by system	Name	Units	System										
Population of area served by system (including diversity)	As	sf	18401										
Design primary supply fan airflow rate	Ps	P	320										
OA req'd per unit area for system (Weighted average)	Vpsd	cfm	27.650										
OA req'd per person for system area (Weighted average)	Rps	cfm/sf	0.09										
	Rps	cfm/p	7.3										
<b>Inputs for Potentially Critical Zones</b>													
Zone Name	Zone size turns purple italic for critical zone(s)												
Zone Tag													
Space Type													
Floor Area of zone	Az	sf	Select from pull-down list										
Design population of zone	Pz	P	(default value listed; may be overridden)										
Design total supply to zone (primary plus local recirculated)	Pzd	cfm	Select from pull-down list or leave blank if N/A										
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?	Er												
Local recirc. air % representative of zone system return air													
<b>Inputs for Operating Condition Analyzed</b>													
Percent of total design airflow rate at conditioned analyzed	Ds	%	100%										
Air distribution type at conditioned analyzed	Ez		Select from pull-down list										
Zone air distribution effectiveness at conditioned analyzed	Ep												
Primary air fraction of supply air at conditioned analyzed													
<b>Results</b>													
Ventilation System Efficiency	Ev	cfm	0.78										
Outdoor air make required for system	Vor	cfm	48.44										
Outdoor air per unit floor area	Vor/As	cfm/sf	0.26										
Outdoor air per person served by system (including diversity)	Vor/Ps	cfm/p	15.1										
Outdoor air as a % of design primary supply air	Ypd	cfm	18%										
<b>Detailed Calculations for the System as a whole</b>													
Primary supply air flow to system at conditioned analyzed	Vps	cfm	=	VpsDs	=	27650							
Unrecircled OA requirement for system	Vou	cfm	=	Rps Ps + Ras As	=	3783							
Unrecircled OA req'd as a fraction of primary SA	Xs		=	Vou / Vps	=	0.14							
<b>Initial Calculations for individual zones</b>													
OA rate per unit area for zone	Raz	cfm/sf		0.06	0.06	0.12	0.12	0.06	0.06	0.06	0.06	0.06	0.06
Total supply air to zone (at condition being analyzed)	Rpz	cfm/p		5.00	5.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.00
Unused OA req'd to breathing zone	Voz	cfm	=	Rpz Pz + Raz Az	=	325	350	225	50	100	50	32.1	32.1
Unused OA requirement for zone	Voz	cfm	=	Voz/Ez	=	11.3	11.5	28.2	37.2	6.6	4.1	3.2	3.2
Fraction of zone supply not directly recirc. from zone	Fa		=	Ep + (1-Ep)Er	=	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
Fraction of zone supply from fully mixed primary air	Fb		=	Ep	=	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
Fraction of zone OA not directly recirc. from zone	Fc		=	1-(1-Ez)(1-Ep)(1-Er)	=	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
Unused OA fraction required in supply air to zone	Zp		=	Voz / Vpz	=	0.03	0.03	0.13	0.11	0.07	0.08	0.14	0.14
Unused OA fraction required in primary air to zone	Zp		=	Voz / Vps	=	0.03	0.03	0.13	0.11	0.07	0.08	0.14	0.14
<b>System Ventilation Efficiency</b>													
Zone Ventilation Efficiency (App A Method)	Evz		=	(Fa + Fb)Xs - Fcz) / Fa	=	1.10	1.10	1.01	1.02	1.07	1.05	0.99	0.99
System Ventilation Efficiency (App A Method)	Ev		=	min (Evz)	=	0.78							
Ventilation System Efficiency (Table 6.3 Method)	Ev		=	Value from Table 6.3	=	0.90							
<b>Minimum outdoor air intake airflow</b>													
Outdoor Air Intake Flow required to System	Vot	cfm	=	Vou / Ev	=	48.44							
OA intake req'd as a fraction of primary SA	Y		=	Vot / Vps	=	0.18							
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Vot	cfm	=	Vou / Ev	=	4.799							
OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Y		=	Vot / Vps	=	0.17							
<b>OA Temp at which Min OA provides all cooling</b>													
OAT below which OA intake flow is @ minimum													
Deg F = (Tpd-Tsf)(1-Y)(T-r+dr) = -26													

Building: Nassau Community College Life Sciences Building	
System Tag/Name: AHU-2	
Operating Condition Description: Design Peak Cooling Load Condition	
Units (Select from pull-down list)	

Inputs for System	Name	Units	System
Floor area served by system	As	sf	18401
Population of area served by system (including diversity)	Ps	P	320
Design primary supply fan airflow rate	Vpsd	cfm	27,650
OA req'd per unit area for system (Weighted average)	Ras	cfm/sf	0.08
OA req'd per person for system area (Weighted average)	Rps	cfm/p	7.3

Inputs for Potentially Critical Zones	Zone Name	Zone Type	Local recirc. air % representative of zone system return air	Ds	Ez	Ep	Potentially Critical Zones
Zone Tag	Zone 1A1	Space Type					Fac. Office
							Second 41
							Office space
							Second 42
							Office space
							Second 43
							Office space
							Second 44
							Office space
							Second 45
							Office space
							Second 46
							Office space
							Second 47
							Office space

Inputs for Operating Condition Analyzed	Percent of total design airflow rate at conditioned analyzed	Air distribution type at conditioned analyzed	Zone air distribution effectiveness at conditioned analyzed	Primary air fraction of supply air at conditioned analyzed	Ev	Vor	Vor/As	Vor/As	Vor/As	Vor/As	Vor/As	Vor/As	Vor/As	Vor/As	Vor/As	Vor/As	Vor/As
Ds	100%	Select from pull-down list	Ez	100%	0.78	48.44	0.26	15.1	18%								
Ep																	

Results	Ventilation System Efficiency	Outdoor air make required for system	Outdoor air per unit floor area	Outdoor air per person served by system (including diversity)	Outdoor air as a % of design primary supply air
Ev	0.78				
Vor	48.44				
Vor/As	0.26				
Vor/As	15.1				
Vor/As	18%				

Detailed Calculations for the System as a whole	Vps	Vps	Vps	Vps	Vps	Vps	Vps	Vps	Vps	Vps	Vps	Vps	Vps	Vps	Vps	Vps	Vps
Primary supply air flow to system at conditioned analyzed		27650															
Unrecircled OA requirement for system	Vou	3783															
Unrecircled OA req'd as a fraction of primary SA	Xs	0.14															

Initial Calculations for Individual Zones	Raz	Rpz	Voz	Voz	Voz	Fa	Fb	Fc	Zd	Zp	Ez	Ev	Ev	Ev	Ev	Ev	Ev
OA rate per unit area for zone	cfm/sf																
OA rate per person	cfm/p																
Total supply air to zone (at condition being analyzed)	cfm																
Unused OA req'd to breathing zone	cfm																
Unused OA requirement for zone	cfm																
Fraction of zone supply not directly recirc. from zone																	
Fraction of zone supply from fully mixed primary air																	
Fraction of zone OA not directly recirc. from zone																	
Unused OA fraction required in supply air to zone																	
Unused OA fraction required in primary air to zone																	

System Ventilation Efficiency	Zone Ventilation Efficiency (App A Method)	System Ventilation Efficiency (App A Method)	System Ventilation Efficiency (App A Method)	System Ventilation Efficiency (Table 6.3 Method)	Vor	Vor	Vor	Vor	Vor	Vor	Vor	Vor	Vor	Vor	Vor	Vor	Vor
Ev	0.78	0.78	0.78	0.90	48.44	0.18	4.798	0.17									
Ev	0.90																

Minimum outdoor air intake airflow	Outdoor Air Intake Flow required to System	Outdoor Air Intake Flow required to System (Table 6.3 Method)	Outdoor Air Intake Flow required to System (Table 6.3 Method)	Outdoor Air Intake Flow required to System (Table 6.3 Method)	Vor	Vor	Vor	Vor	Vor	Vor	Vor	Vor	Vor	Vor	Vor	Vor	Vor
Ev	48.44	0.18	4.798	0.17													
Ev																	

OA Temp at which Min OA provides all cooling	Deg F	Ev	Ev	Ev	Ev	Ev	Ev	Ev	Ev	Ev	Ev	Ev	Ev	Ev	Ev	Ev	Ev
OAT below which OA intake flow is minimum	-26																

Building: Nassau Community College Life Sciences Building	
System TagName: AHU-2	
Operating Condition Description: Design Peak Cooling Load Condition	
Units (Select from pull-down list)	hp

Inputs for System	Name	Units	System
Floor area served by system	As	sf	19401
Population of areas served by system (including diversity)	Ps	P	320
Design primary supply fan airflow rate	Vpsd	cfm	27,630
OA req'd per unit area for system (Weighted average)	Ras	cfm/sf	0.09
OA req'd per person for system area (Weighted average)	Rps	cfm/p	7.3

Inputs for Potentially Critical zones	Zone Name	Zone file turns purple (note for critical zone(s))
Zone Tag		
Space type		
Floor Area of zone	Az	Select from pull-down list
Design population of zone	Pz	P (default value listed; may be overridden)
Design total supply to zone (primary plus local recirculated)	Vzsd	cfm
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?		Select from pull-down list or leave blank if N/A
Local recirc. air % representative of zone system return air	Er	

Inputs for Operating Condition Analyzed	Parameter	Value
Percent of total design airflow rate at conditioned analyzed	Ds	100%
Air distribution type at conditioned analyzed	Ez	Select from pull-down list
Zone air distribution effectiveness at conditioned analyzed	Ep	
Primary air fraction of supply air at conditioned analyzed	Ev	0.78
Ventilation System Efficiency	Vor	48.44
Outdoor air intake required for system	Vor/As	0.26
Outdoor air per unit floor area	Vor/Ps	15.1
Outdoor air per person served by system (including diversity)	Vor/Ps	18%
Outdoor air as a % of design primary supply air	Ypd	

Results	Parameter	Value
Ventilation System Efficiency	Ev	0.78
Outdoor air intake required for system	Vor	48.44
Outdoor air per unit floor area	Vor/As	0.26
Outdoor air per person served by system (including diversity)	Vor/Ps	15.1
Outdoor air as a % of design primary supply air	Ypd	18%

Initial Calculations for the System as a whole	Parameter	Value
Primary supply air flow to system at conditioned analyzed	Vps	27,630
Unrecircled OA requirement for system	Vou	3,793
Unrecircled OA req'd as a fraction of primary SA	Xs	0.14

Initial Calculations for Individual zones	Parameter	Value
OA rate per unit area for zone	Raz	cfm/sf
Total supply air to zone (at condition being analyzed)	Rpz	cfm/p
Unused OA req'd to breathing zone	Vbz	cfm
Unused OA requirement for zone	Voz	cfm
Fraction of zone supply not directly recirc. from zone	Fa	
Fraction of zone supply from fully mixed primary air	Fb	
Fraction of zone OA not directly recirc. from zone	Fc	
Unused OA fraction required in supply air to zone	Zp	
Unused OA fraction required in primary air to zone	Zp	

System Ventilation Efficiency	Parameter	Value
Zone Ventilation Efficiency (App A Method)	Ez	
System Ventilation Efficiency (App A Method)	Ev	0.78
Ventilation System Efficiency (Table 6.3 Method)	Ev	0.80

Minimum outdoor air intake airflow	Parameter	Value
Outdoor Air Intake Flow required to System	Vor	cfm
OA intake req'd as a fraction of primary SA	Vor/As	0.18
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Vor	cfm
OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Vor/Vps	0.17

OA Temp. at which Min OA provides all cooling	Parameter	Value
OAT below which OA Intake flow is @ minimum	Deg F	-25

Fac. Office	Second 48	Second 49	Second 50	Second 51	Second 52	Second 53	Third 01
Office space	Office space	Office space	Office space	Office space	Office space	Office space	Corridors
105	105	105	105	105	105	105	1501
1	1	1	1	1	1	1	0
325	325	325	325	325	325	360	700
100%	100%	100%	100%	100%	100%	100%	100%
CS	CS	CS	CS	CS	CS	CS	CS
1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00



Building:		Nassau Community College Life Sciences Building										
System Tag/Name:		AHU-2										
Operating Condition Description:		Design Peak Cooling Load Condition										
Units (select from pull-down list)		IP										
<b>Inputs for System</b>		Floor area served by system	Name		Units		System					
Population of area served by system (including diversity)		As	sf	Ps	P	100%	diversity	18401	320	27,860	0.08	
Design primary supply fan airflow rate		Vpsd	cfm	Ras	cfm/sf	7.3						
OA req'd per unit area for system (Weighted average)		Rps	cfm/sf									
OA req'd per person for system area (Weighted average)		Rps	cfm/p									
<b>Inputs for Potentially Critical Zones</b>		Zone Name										
Zone Tag		Zone file turns purple italic for critical zone(s)										
Space type		Select from pull-down list										
Floor Area of zone		Az	sf	Pz	P	(default value listed; may be overridden)	100%					
Design total supply to zone (primary plus local recirculated)		Vzsd	cfm				100%					
Air distribution type at conditioned analyzed		Induction Terminal Unit, Dual Fan Duct or Transfer-Fan?	Select from pull-down list or leave blank if N/A									
Local recirc. air % representative of ave system return air		Er	100%									
<b>Inputs for Operating Condition Analyzed</b>		Percent of total design airflow rate at conditioned analyzed		Ds	%	100%						
Air distribution type at conditioned analyzed		Ez	100%									
Zone air distribution effectiveness at conditioned analyzed		Ep	1.00									
Primary air fraction of supply air at conditioned analyzed		Ypd	18%									
<b>Results</b>		Ventilation System Efficiency		Ev	0.78							
Outdoor air intake required for system		Vot	cfm	4844								
Outdoor air per unit floor area		Vot/Az	cfm/sf	0.26								
Outdoor air per person served by system (including diversity)		Vot/Ps	cfm/p	15.1								
Outdoor air as a % of design primary supply air		Ypd	cfm	18%								
<b>Detailed Calculations</b>		Initial Calculations for the System as a whole										
Primary supply air flow to system at conditioned analyzed		Vps	cfm	27650								
Uncorrected OA requirement for system		Vou	cfm	3783								
Uncorrected OA req'd as a fraction of primary SA		Xs		0.14								
<b>Initial Calculations for Individual Zones</b>		OA rate per unit area for zone										
OA rate per person		Raz	cfm/sf	0.12								
Total supply air to zone (at condition being analyzed)		Roz	cfm/p	10.00								
Unused OA req'd to breathing zone		Voz	cfm	1500								
Unused OA requirement for zone		Voz	cfm	631.1								
Fraction of zone supply not directly recirc. from zone		Fa		1.00								
Fraction of zone supply from fully mixed primary air		Fb		1.00								
Fraction of zone OA not directly recirc. from zone		Fc		1.00								
Unused OA fraction required in primary air to zone		Zd		0.35								
Unused OA fraction required in supply air to zone		Zp		0.35								
<b>System Ventilation Efficiency</b>		Zone Ventilation Efficiency (App A Method)										
System Ventilation Efficiency (App A Method)		Ev		0.78								
Ventilation System Efficiency (Table 6.3 Method)		Ev		0.90								
<b>Minimum outdoor air intake airflow</b>		Outdoor Air Intake Flow required to System										
OA intake req'd as a fraction of primary SA		Vot	cfm	4844								
Outdoor Air Intake Flow required to System (Table 6.3 Method)		Vot	cfm	0.18								
OA intake req'd as a fraction of primary SA (Table 6.3 Method)		Y		0.17								
<b>OA Temp at which Min OA provides all cooling</b>		OAT below which OA Intake flow is @ minimum		Deg F	-25							

Building: Nassau Community College Life Sciences Building																																																																									
System Tag Name: AHU-2																																																																									
Operating Condition Description: Design Peak Cooling Load Condition																																																																									
Units (Select from pull-down list)																																																																									
<table border="1"> <thead> <tr> <th>Name</th> <th>Units</th> <th>System</th> </tr> </thead> <tbody> <tr> <td>As</td> <td>sf</td> <td>18401</td> </tr> <tr> <td>Ps</td> <td>P</td> <td>320</td> </tr> <tr> <td>Vpzd</td> <td>cfm</td> <td>27,850</td> </tr> <tr> <td>Ras</td> <td>cfm/sf</td> <td>0.08</td> </tr> <tr> <td>Rps</td> <td>cfm/p</td> <td>7.3</td> </tr> </tbody> </table>		Name	Units	System	As	sf	18401	Ps	P	320	Vpzd	cfm	27,850	Ras	cfm/sf	0.08	Rps	cfm/p	7.3																																																						
Name	Units	System																																																																							
As	sf	18401																																																																							
Ps	P	320																																																																							
Vpzd	cfm	27,850																																																																							
Ras	cfm/sf	0.08																																																																							
Rps	cfm/p	7.3																																																																							
<b>Inputs for System</b> Floor area served by system Population of areas served by system (including diversity) Design primary supply fan airflow rate OA req'd per unit area for system (Weighted average) OA req'd per person for system area (Weighted average)																																																																									
<b>Inputs for Potentially Critical Zones</b> Zone Name Zone Tag Space Type Floor Area of zone Design population of zone Design total supply to zone (primary plus local recirculated) Air distribution type at conditioned analyzed Zone air distribution effectiveness at conditioned analyzed Local recirc. air % representative of zone system return air																																																																									
<table border="1"> <thead> <tr> <th>Zone Name</th> <th>Zone Tag</th> <th>Space Type</th> <th>Floor Area (sf)</th> <th>Design Pop (P)</th> <th>Design Total Supply (Vpd)</th> <th>Air Dist. Type</th> <th>Zone Effectiveness (Ez)</th> <th>Local Recirc. Air % (Er)</th> </tr> </thead> <tbody> <tr> <td>Zone 14</td> <td>Third 14</td> <td>Electrical equipment rooms</td> <td>692</td> <td>0</td> <td>106</td> <td>CS</td> <td>100%</td> <td>100%</td> </tr> <tr> <td>Zone 41</td> <td>Third 41</td> <td>Coffee Stations</td> <td>202</td> <td>4</td> <td>1</td> <td>CS</td> <td>100%</td> <td>100%</td> </tr> <tr> <td>Zone 42</td> <td>Third 42</td> <td>Office space</td> <td>106</td> <td>1</td> <td>350</td> <td>CS</td> <td>100%</td> <td>100%</td> </tr> <tr> <td>Zone 43</td> <td>Third 43</td> <td>Office space</td> <td>106</td> <td>1</td> <td>350</td> <td>CS</td> <td>100%</td> <td>100%</td> </tr> <tr> <td>Zone 44</td> <td>Third 44</td> <td>Office space</td> <td>106</td> <td>1</td> <td>350</td> <td>CS</td> <td>100%</td> <td>100%</td> </tr> <tr> <td>Zone 45</td> <td>Third 45</td> <td>Office space</td> <td>106</td> <td>1</td> <td>350</td> <td>CS</td> <td>100%</td> <td>100%</td> </tr> <tr> <td>Zone 46</td> <td>Third 46</td> <td>Office space</td> <td>106</td> <td>1</td> <td>350</td> <td>CS</td> <td>100%</td> <td>100%</td> </tr> </tbody> </table>		Zone Name	Zone Tag	Space Type	Floor Area (sf)	Design Pop (P)	Design Total Supply (Vpd)	Air Dist. Type	Zone Effectiveness (Ez)	Local Recirc. Air % (Er)	Zone 14	Third 14	Electrical equipment rooms	692	0	106	CS	100%	100%	Zone 41	Third 41	Coffee Stations	202	4	1	CS	100%	100%	Zone 42	Third 42	Office space	106	1	350	CS	100%	100%	Zone 43	Third 43	Office space	106	1	350	CS	100%	100%	Zone 44	Third 44	Office space	106	1	350	CS	100%	100%	Zone 45	Third 45	Office space	106	1	350	CS	100%	100%	Zone 46	Third 46	Office space	106	1	350	CS	100%	100%
Zone Name	Zone Tag	Space Type	Floor Area (sf)	Design Pop (P)	Design Total Supply (Vpd)	Air Dist. Type	Zone Effectiveness (Ez)	Local Recirc. Air % (Er)																																																																	
Zone 14	Third 14	Electrical equipment rooms	692	0	106	CS	100%	100%																																																																	
Zone 41	Third 41	Coffee Stations	202	4	1	CS	100%	100%																																																																	
Zone 42	Third 42	Office space	106	1	350	CS	100%	100%																																																																	
Zone 43	Third 43	Office space	106	1	350	CS	100%	100%																																																																	
Zone 44	Third 44	Office space	106	1	350	CS	100%	100%																																																																	
Zone 45	Third 45	Office space	106	1	350	CS	100%	100%																																																																	
Zone 46	Third 46	Office space	106	1	350	CS	100%	100%																																																																	
<b>Inputs for Operating Condition Analyzed</b> Percent of total design airflow rate at conditioned analyzed Air distribution type at conditioned analyzed Zone air distribution effectiveness at conditioned analyzed Primary air fraction of supply air at conditioned analyzed																																																																									
<table border="1"> <thead> <tr> <th>Condition</th> <th>Percent of Total Design Airflow Rate (%)</th> <th>Air Dist. Type</th> <th>Zone Effectiveness (Ez)</th> <th>Primary Air Fraction (Ep)</th> </tr> </thead> <tbody> <tr> <td>Condition 1</td> <td>100%</td> <td>Select from pull-down list</td> <td>1.00</td> <td>1.00</td> </tr> </tbody> </table>		Condition	Percent of Total Design Airflow Rate (%)	Air Dist. Type	Zone Effectiveness (Ez)	Primary Air Fraction (Ep)	Condition 1	100%	Select from pull-down list	1.00	1.00																																																														
Condition	Percent of Total Design Airflow Rate (%)	Air Dist. Type	Zone Effectiveness (Ez)	Primary Air Fraction (Ep)																																																																					
Condition 1	100%	Select from pull-down list	1.00	1.00																																																																					
<b>Results</b> Ventilation System Efficiency Outdoor air intake required for system Outdoor air per unit floor area Outdoor air per person served by system (including diversity) Outdoor air as a % of design primary supply air																																																																									
<table border="1"> <thead> <tr> <th>Parameter</th> <th>Value</th> </tr> </thead> <tbody> <tr> <td>Ventilation System Efficiency (Ev)</td> <td>0.78</td> </tr> <tr> <td>Outdoor air intake required for system (Vpd/As)</td> <td>48.44</td> </tr> <tr> <td>Outdoor air per unit floor area (Vpd/Ps)</td> <td>0.26</td> </tr> <tr> <td>Outdoor air per person served by system (Vpd/Ps)</td> <td>15.1</td> </tr> <tr> <td>Outdoor air as a % of design primary supply air (Vpd/Vps)</td> <td>18%</td> </tr> </tbody> </table>		Parameter	Value	Ventilation System Efficiency (Ev)	0.78	Outdoor air intake required for system (Vpd/As)	48.44	Outdoor air per unit floor area (Vpd/Ps)	0.26	Outdoor air per person served by system (Vpd/Ps)	15.1	Outdoor air as a % of design primary supply air (Vpd/Vps)	18%																																																												
Parameter	Value																																																																								
Ventilation System Efficiency (Ev)	0.78																																																																								
Outdoor air intake required for system (Vpd/As)	48.44																																																																								
Outdoor air per unit floor area (Vpd/Ps)	0.26																																																																								
Outdoor air per person served by system (Vpd/Ps)	15.1																																																																								
Outdoor air as a % of design primary supply air (Vpd/Vps)	18%																																																																								
<b>Detailed Calculations for the System as a whole</b> Primary supply air flow to system at conditioned analyzed Unrecircled OA requirement for system Unrecircled OA req'd as a fraction of primary SA																																																																									
<table border="1"> <thead> <tr> <th>Parameter</th> <th>Value</th> <th>Equation</th> </tr> </thead> <tbody> <tr> <td>Vps</td> <td>27850</td> <td><math>Vps = VpdDs</math></td> </tr> <tr> <td>Vou</td> <td>3783</td> <td><math>Vou = Rps + Ras + Vps</math></td> </tr> <tr> <td>Xs</td> <td>0.14</td> <td><math>Xs = Vou / Vps</math></td> </tr> </tbody> </table>		Parameter	Value	Equation	Vps	27850	$Vps = VpdDs$	Vou	3783	$Vou = Rps + Ras + Vps$	Xs	0.14	$Xs = Vou / Vps$																																																												
Parameter	Value	Equation																																																																							
Vps	27850	$Vps = VpdDs$																																																																							
Vou	3783	$Vou = Rps + Ras + Vps$																																																																							
Xs	0.14	$Xs = Vou / Vps$																																																																							
<b>Initial Calculations for Individual Zones</b> OA rate per unit area for zone Total supply air to zone (at condition being analyzed) Unused OA req'd to breathing zone Unused OA requirement for zone Fraction of zone supply not directly recirc. from zone Fraction of zone supply from fully mixed primary air Fraction of zone OA not directly recirc. from zone Unused OA fraction required in supply air to zone Unused OA fraction required in primary air to zone																																																																									
<table border="1"> <thead> <tr> <th>Zone</th> <th>Raz</th> <th>Rpz</th> <th>Voz</th> <th>Fa</th> <th>Fb</th> <th>Fc</th> <th>Zp</th> </tr> </thead> <tbody> <tr> <td>Zone 14</td> <td>0.06</td> <td>0.00</td> <td>5.00</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>0.08</td> </tr> <tr> <td>Zone 41</td> <td>4.1</td> <td>175</td> <td>32.1</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>0.18</td> </tr> <tr> <td>Zone 42</td> <td>4</td> <td>32.1</td> <td>11.4</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>0.03</td> </tr> <tr> <td>Zone 43</td> <td>11</td> <td>11.3</td> <td>11.3</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>0.03</td> </tr> <tr> <td>Zone 44</td> <td>11</td> <td>11.3</td> <td>11.3</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>0.03</td> </tr> <tr> <td>Zone 45</td> <td>11</td> <td>11.3</td> <td>11.3</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>0.03</td> </tr> <tr> <td>Zone 46</td> <td>11</td> <td>11.3</td> <td>11.3</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>0.03</td> </tr> </tbody> </table>		Zone	Raz	Rpz	Voz	Fa	Fb	Fc	Zp	Zone 14	0.06	0.00	5.00	1.00	1.00	1.00	0.08	Zone 41	4.1	175	32.1	1.00	1.00	1.00	0.18	Zone 42	4	32.1	11.4	1.00	1.00	1.00	0.03	Zone 43	11	11.3	11.3	1.00	1.00	1.00	0.03	Zone 44	11	11.3	11.3	1.00	1.00	1.00	0.03	Zone 45	11	11.3	11.3	1.00	1.00	1.00	0.03	Zone 46	11	11.3	11.3	1.00	1.00	1.00	0.03								
Zone	Raz	Rpz	Voz	Fa	Fb	Fc	Zp																																																																		
Zone 14	0.06	0.00	5.00	1.00	1.00	1.00	0.08																																																																		
Zone 41	4.1	175	32.1	1.00	1.00	1.00	0.18																																																																		
Zone 42	4	32.1	11.4	1.00	1.00	1.00	0.03																																																																		
Zone 43	11	11.3	11.3	1.00	1.00	1.00	0.03																																																																		
Zone 44	11	11.3	11.3	1.00	1.00	1.00	0.03																																																																		
Zone 45	11	11.3	11.3	1.00	1.00	1.00	0.03																																																																		
Zone 46	11	11.3	11.3	1.00	1.00	1.00	0.03																																																																		
<b>System Ventilation Efficiency (App A Method)</b> System Ventilation Efficiency (App A Method) Ventilation System Efficiency (Table 6.3 Method)																																																																									
<table border="1"> <thead> <tr> <th>Method</th> <th>Value</th> </tr> </thead> <tbody> <tr> <td>System Ventilation Efficiency (App A Method)</td> <td>0.78</td> </tr> <tr> <td>Ventilation System Efficiency (Table 6.3 Method)</td> <td>0.80</td> </tr> </tbody> </table>		Method	Value	System Ventilation Efficiency (App A Method)	0.78	Ventilation System Efficiency (Table 6.3 Method)	0.80																																																																		
Method	Value																																																																								
System Ventilation Efficiency (App A Method)	0.78																																																																								
Ventilation System Efficiency (Table 6.3 Method)	0.80																																																																								
<b>Minimum outdoor air intake airflow</b> Outdoor Air Intake Flow required to System OA intake req'd as a fraction of primary SA Outdoor Air Intake Flow required to System (Table 6.3 Method) OA intake req'd as a fraction of primary SA (Table 6.3 Method) OA Temp at which Min OA provides all cooling OAT below which OA intake flow is @ minimum																																																																									
<table border="1"> <thead> <tr> <th>Parameter</th> <th>Value</th> </tr> </thead> <tbody> <tr> <td>Outdoor Air Intake Flow required to System (Vot)</td> <td>48.44</td> </tr> <tr> <td>OA intake req'd as a fraction of primary SA (Vot/Vps)</td> <td>0.18</td> </tr> <tr> <td>Outdoor Air Intake Flow required to System (Vot)</td> <td>4788</td> </tr> <tr> <td>OA intake req'd as a fraction of primary SA (Vot/Vps)</td> <td>0.17</td> </tr> <tr> <td>OAT below which OA intake flow is @ minimum</td> <td>-26</td> </tr> </tbody> </table>		Parameter	Value	Outdoor Air Intake Flow required to System (Vot)	48.44	OA intake req'd as a fraction of primary SA (Vot/Vps)	0.18	Outdoor Air Intake Flow required to System (Vot)	4788	OA intake req'd as a fraction of primary SA (Vot/Vps)	0.17	OAT below which OA intake flow is @ minimum	-26																																																												
Parameter	Value																																																																								
Outdoor Air Intake Flow required to System (Vot)	48.44																																																																								
OA intake req'd as a fraction of primary SA (Vot/Vps)	0.18																																																																								
Outdoor Air Intake Flow required to System (Vot)	4788																																																																								
OA intake req'd as a fraction of primary SA (Vot/Vps)	0.17																																																																								
OAT below which OA intake flow is @ minimum	-26																																																																								



Building: Nassau Community College Life Sciences Building																																																																									
System Tag/Name: AHU-2																																																																									
Operating Condition Description: Design Peak Cooling Load Condition																																																																									
Units (Select from pull-down list)	IP																																																																								
<table border="1"> <tr> <th>Name</th> <th>Units</th> <th>System</th> </tr> <tr> <td>As</td> <td>sf</td> <td>18401</td> </tr> <tr> <td>Ps</td> <td>P</td> <td>320</td> </tr> <tr> <td>Vpsd</td> <td>cfm</td> <td>27,650</td> </tr> <tr> <td>Ras</td> <td>cfm/sf</td> <td>0.08</td> </tr> <tr> <td>Rps</td> <td>cfm/sf</td> <td>7.3</td> </tr> </table>		Name	Units	System	As	sf	18401	Ps	P	320	Vpsd	cfm	27,650	Ras	cfm/sf	0.08	Rps	cfm/sf	7.3																																																						
Name	Units	System																																																																							
As	sf	18401																																																																							
Ps	P	320																																																																							
Vpsd	cfm	27,650																																																																							
Ras	cfm/sf	0.08																																																																							
Rps	cfm/sf	7.3																																																																							
<b>Inputs for System</b> Floor area served by system Population of area served by system (including diversity) Design primary supply fan airflow rate OA req'd per unit area for system (Weighted average) OA req'd per person for system area (Weighted average)																																																																									
<b>Inputs for Potentially Critical Zones</b> Zone Name Zone Tag Space type Floor Area of zone Design population of zone Design total supply to zone (primary plus local recirculated) Induction Terminal Unit, Dual Fan Dual Duct or Transfer-Fan? Local recirc. air, % representative of ave system return air																																																																									
Zone title turns purple italic for critical zone(s)																																																																									
<table border="1"> <thead> <tr> <th>Zone Name</th> <th>Zone Tag</th> <th>Space type</th> <th>Floor Area (sf)</th> <th>Design Pop</th> <th>Design Total Supply (cfm)</th> <th>Induction Terminal Unit</th> <th>Local Recirc. Air (%)</th> </tr> </thead> <tbody> <tr> <td>Third 47</td> <td>Third 47</td> <td>Office space</td> <td>105</td> <td>1</td> <td>350</td> <td></td> <td></td> </tr> <tr> <td>Third 48</td> <td>Third 48</td> <td>Office space</td> <td>105</td> <td>1</td> <td>350</td> <td></td> <td></td> </tr> <tr> <td>Third 49</td> <td>Third 49</td> <td>Office space</td> <td>105</td> <td>1</td> <td>350</td> <td></td> <td></td> </tr> <tr> <td>Third 50</td> <td>Third 50</td> <td>Office space</td> <td>105</td> <td>1</td> <td>350</td> <td></td> <td></td> </tr> <tr> <td>Third 51</td> <td>Third 51</td> <td>Office space</td> <td>105</td> <td>1</td> <td>350</td> <td></td> <td></td> </tr> <tr> <td>Third 52</td> <td>Third 52</td> <td>Office space</td> <td>105</td> <td>1</td> <td>350</td> <td></td> <td></td> </tr> <tr> <td>Third 53</td> <td>Third 53</td> <td>Office space</td> <td>105</td> <td>1</td> <td>350</td> <td></td> <td></td> </tr> </tbody> </table>		Zone Name	Zone Tag	Space type	Floor Area (sf)	Design Pop	Design Total Supply (cfm)	Induction Terminal Unit	Local Recirc. Air (%)	Third 47	Third 47	Office space	105	1	350			Third 48	Third 48	Office space	105	1	350			Third 49	Third 49	Office space	105	1	350			Third 50	Third 50	Office space	105	1	350			Third 51	Third 51	Office space	105	1	350			Third 52	Third 52	Office space	105	1	350			Third 53	Third 53	Office space	105	1	350										
Zone Name	Zone Tag	Space type	Floor Area (sf)	Design Pop	Design Total Supply (cfm)	Induction Terminal Unit	Local Recirc. Air (%)																																																																		
Third 47	Third 47	Office space	105	1	350																																																																				
Third 48	Third 48	Office space	105	1	350																																																																				
Third 49	Third 49	Office space	105	1	350																																																																				
Third 50	Third 50	Office space	105	1	350																																																																				
Third 51	Third 51	Office space	105	1	350																																																																				
Third 52	Third 52	Office space	105	1	350																																																																				
Third 53	Third 53	Office space	105	1	350																																																																				
<b>Inputs for Operating Condition Analyzed</b> Percent of total design airflow rate at conditioned analyzed Air distribution type at conditioned analyzed Zone air distribution effectiveness at conditioned analyzed Primary air fraction of supply air at conditioned analyzed																																																																									
<table border="1"> <thead> <tr> <th>Parameter</th> <th>Value</th> </tr> </thead> <tbody> <tr> <td>Ds</td> <td>100%</td> </tr> <tr> <td>Ez</td> <td>Select from pull-down list</td> </tr> <tr> <td>Ed</td> <td></td> </tr> </tbody> </table>		Parameter	Value	Ds	100%	Ez	Select from pull-down list	Ed																																																																	
Parameter	Value																																																																								
Ds	100%																																																																								
Ez	Select from pull-down list																																																																								
Ed																																																																									
<b>Results</b> Ventilation System Efficiency Outdoor air intake required for system Outdoor air per unit floor area Outdoor air per person served by system (including diversity) Outdoor air as a % of design primary supply air																																																																									
<table border="1"> <thead> <tr> <th>Parameter</th> <th>Value</th> </tr> </thead> <tbody> <tr> <td>Ev</td> <td>0.78</td> </tr> <tr> <td>Vot</td> <td>4844</td> </tr> <tr> <td>Vot/As</td> <td>0.26</td> </tr> <tr> <td>Vot/Ps</td> <td>15.1</td> </tr> <tr> <td>Ypd</td> <td>18%</td> </tr> </tbody> </table>		Parameter	Value	Ev	0.78	Vot	4844	Vot/As	0.26	Vot/Ps	15.1	Ypd	18%																																																												
Parameter	Value																																																																								
Ev	0.78																																																																								
Vot	4844																																																																								
Vot/As	0.26																																																																								
Vot/Ps	15.1																																																																								
Ypd	18%																																																																								
<b>Detailed Calculations for the System as a Whole</b> Primary supply air flow to system at conditioned analyzed Unrecircled OA requirement for system Unrecircled OA req'd as a fraction of primary SA																																																																									
<table border="1"> <thead> <tr> <th>Parameter</th> <th>Value</th> </tr> </thead> <tbody> <tr> <td>Vps</td> <td>27650</td> </tr> <tr> <td>Vou</td> <td>3783</td> </tr> <tr> <td>Xs</td> <td>0.14</td> </tr> </tbody> </table>		Parameter	Value	Vps	27650	Vou	3783	Xs	0.14																																																																
Parameter	Value																																																																								
Vps	27650																																																																								
Vou	3783																																																																								
Xs	0.14																																																																								
<b>Initial Calculations for Individual Zones</b> OA rate per unit area for zone Total supply air to zone (at condition being analyzed) Unhusd OA req'd to breathing zone Unhusd OA requirement for zone Fraction of zone supply not directly recirc. from zone Fraction of zone supply from fully mixed primary air Fraction of zone OA not directly recirc. from zone Unhusd OA fraction required in supply air to zone Unhusd OA fraction required in primary air to zone																																																																									
<table border="1"> <thead> <tr> <th>Zone</th> <th>Raz</th> <th>Roz</th> <th>Voz</th> <th>Fz</th> <th>Fd</th> <th>Fo</th> <th>Zd</th> <th>Zp</th> </tr> </thead> <tbody> <tr> <td>Third 47</td> <td>0.06</td> <td>5.00</td> <td>11.3</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>0.03</td> <td>0.03</td> </tr> <tr> <td>Third 48</td> <td>0.06</td> <td>5.00</td> <td>11.3</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>0.03</td> <td>0.03</td> </tr> <tr> <td>Third 49</td> <td>0.06</td> <td>5.00</td> <td>11.3</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>0.03</td> <td>0.03</td> </tr> <tr> <td>Third 50</td> <td>0.06</td> <td>5.00</td> <td>11.3</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>0.03</td> <td>0.03</td> </tr> <tr> <td>Third 51</td> <td>0.06</td> <td>5.00</td> <td>11.3</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>0.03</td> <td>0.03</td> </tr> <tr> <td>Third 52</td> <td>0.06</td> <td>5.00</td> <td>11.3</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>0.03</td> <td>0.03</td> </tr> <tr> <td>Third 53</td> <td>0.06</td> <td>5.00</td> <td>11.3</td> <td>1.00</td> <td>1.00</td> <td>1.00</td> <td>0.03</td> <td>0.03</td> </tr> </tbody> </table>		Zone	Raz	Roz	Voz	Fz	Fd	Fo	Zd	Zp	Third 47	0.06	5.00	11.3	1.00	1.00	1.00	0.03	0.03	Third 48	0.06	5.00	11.3	1.00	1.00	1.00	0.03	0.03	Third 49	0.06	5.00	11.3	1.00	1.00	1.00	0.03	0.03	Third 50	0.06	5.00	11.3	1.00	1.00	1.00	0.03	0.03	Third 51	0.06	5.00	11.3	1.00	1.00	1.00	0.03	0.03	Third 52	0.06	5.00	11.3	1.00	1.00	1.00	0.03	0.03	Third 53	0.06	5.00	11.3	1.00	1.00	1.00	0.03	0.03
Zone	Raz	Roz	Voz	Fz	Fd	Fo	Zd	Zp																																																																	
Third 47	0.06	5.00	11.3	1.00	1.00	1.00	0.03	0.03																																																																	
Third 48	0.06	5.00	11.3	1.00	1.00	1.00	0.03	0.03																																																																	
Third 49	0.06	5.00	11.3	1.00	1.00	1.00	0.03	0.03																																																																	
Third 50	0.06	5.00	11.3	1.00	1.00	1.00	0.03	0.03																																																																	
Third 51	0.06	5.00	11.3	1.00	1.00	1.00	0.03	0.03																																																																	
Third 52	0.06	5.00	11.3	1.00	1.00	1.00	0.03	0.03																																																																	
Third 53	0.06	5.00	11.3	1.00	1.00	1.00	0.03	0.03																																																																	
<b>System Ventilation Efficiency (App A Method)</b> Zone Ventilation Efficiency (App A Method) System Ventilation Efficiency (App A Method)																																																																									
<table border="1"> <thead> <tr> <th>Parameter</th> <th>Value</th> </tr> </thead> <tbody> <tr> <td>Ez</td> <td>0.78</td> </tr> <tr> <td>Ev</td> <td>0.80</td> </tr> </tbody> </table>		Parameter	Value	Ez	0.78	Ev	0.80																																																																		
Parameter	Value																																																																								
Ez	0.78																																																																								
Ev	0.80																																																																								
<b>Ventilation System Efficiency (Table 6.3 Method)</b> Minimum outdoor air intake airflow Outdoor Air Intake Flow required to System OA Intake req'd as a fraction of primary SA Outdoor Air Intake Flow required to System (Table 6.3 Method) OA Intake req'd as a fraction of primary SA (Table 6.3 Method)																																																																									
<table border="1"> <thead> <tr> <th>Parameter</th> <th>Value</th> </tr> </thead> <tbody> <tr> <td>Vot</td> <td>4844</td> </tr> <tr> <td>Y</td> <td>0.18</td> </tr> <tr> <td>Vot/As</td> <td>0.18</td> </tr> <tr> <td>Vot/Ps</td> <td>4798</td> </tr> <tr> <td>Ypd</td> <td>0.17</td> </tr> </tbody> </table>		Parameter	Value	Vot	4844	Y	0.18	Vot/As	0.18	Vot/Ps	4798	Ypd	0.17																																																												
Parameter	Value																																																																								
Vot	4844																																																																								
Y	0.18																																																																								
Vot/As	0.18																																																																								
Vot/Ps	4798																																																																								
Ypd	0.17																																																																								
<b>OA Temp at which Min. OA provides all cooling</b> OAT below which OA Intake flow is @ minimum Deg F = ((Tpd-Tsf)/(1-Y)) / (Trad-Tr) = -26																																																																									

Building: Nassau Community College Life Sciences Building System Tag Name: AHU2 Operating Condition Description: Design Peak Cooling Load Condition Units (Selected from pull-down list)			
<b>Inputs for System</b> Floor area served by system Population of area served by system (including diversity) Design primary supply fan airflow rate OA req'd per unit area for system (Weighted average) OA req'd per person for system area (Weighted average)		Name Units As sf Ps P P Vpsd cfm Rps cfm/sf Rps cfm/p	System 18401 320 27650 0.08 7.3
<b>Inputs for Potentially Critical Zones</b> Zone Name Zone Tag Space type Floor Area of zone Design population of zone Design total supply to zone (primary plus local recirculated) Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan? Local recirc. air, % representative of ave system return air		Zone title turns purple (color for critical zone(s)) Selected from pull-down list P (default value listed; may be overridden) Selected from pull-down list or leave blank if N/A	Fac. Office Third S4 Office space 102 1 375
<b>Inputs for Operating Condition Analyzed</b> Percent of total design airflow rate at conditioned analyzed Air distribution type at conditioned analyzed Zone air distribution effectiveness at conditioned analyzed Primary air fraction of supply air at conditioned analyzed		Ds % Ez Selected from pull-down list Ed	100% CS 1.00
<b>Results</b> Ventilation System Efficiency Outdoor air intake required for system Outdoor air per unit floor area Outdoor air per person served by system (including diversity) Outdoor air as a % of design primary supply air		EV cfm Vex cfm/sf Vex/As cfm/p Vex/As cfm Ypd 18%	0.78 4844 0.26 15.1 18%
<b>Detailed Calculations for the System as a whole</b> Primary supply air flow to system at conditioned analyzed Unrecirculated OA requirement for system Unrecirculated OA req'd as a fraction of primary SA <b>Initial Calculations for Individual Zones</b> OA rate per unit area for zone OA rate per person Total supply air to zone (at condition being analyzed) Unused OA, req'd to breathing zone Unused OA, requirement for zone Fraction of zone supply not directly recirc. from zone Fraction of zone supply from fully mixed primary air Fraction of zone OA not directly recirc. from zone Unused OA fraction required in supply air to zone Unused OA fraction required in primary air to zone			
<b>System Ventilation Efficiency</b> Zone Ventilation Efficiency (App A Method) System Ventilation Efficiency (App A Method) System Ventilation Efficiency (Table 6.3 Method) Ventilation System Efficiency (Table 6.3 Method)			
<b>Minimum outdoor air intake airflow</b> Outdoor Air Intake Flow required to System OA intake req'd as a fraction of primary SA Outdoor Air Intake Flow required to System (Table 6.3 Method) OA intake req'd as a fraction of primary SA (Table 6.3 Method) OA Temp at which Min. OA provides all cooling OAT below which OA intake flow is @ minimum			
Vps cfm = VpdDs Vpu cfm = Rps Ps + Ras As Xs = Vpu / Vps Raz cfm/sf Rpz cfm/p Vzx cfm Vzx cfm Vzx cfm Fz = Ep + (1-Ep)Er Fz = 1-(1-Ez)(1-Ep)(1-Er) Zp = Vex / Vpz Ez = (Fa + FB)Xs - FzZ / Fa EV = min (Ezv) EV = Value from Table 6.3		27650 3793 0.14 0.08 5.00 27650 3793 11.5 1.2 1.00 1.00 0.03 0.03 0.78 0.80	
Vex cfm = Vex / Vps Vex/As cfm/sf = Vex / Vps Vex/As cfm/p = Vex / Vps Ypd = ((Tpd-Tsf)(1+Y)/(T+dt)Tr) = -25		4844 0.18 4796 0.17 -25	
320 System population without diversity 1.00 System population diversity, D		Check Figures 17.4 P/1000 sf 1.50 cfm/sf 0.08 ave cfm/sf 7.30 ave cfm/p Totals/Averages	
Primary airflow rate to zones 27650 cfm make that primary over design			

Building:		Nassau Community College Life Sciences Building											
System Tag/Name:		AHJ-3											
Operating Condition Description:		Design Peak Cooling Load Condition											
Units (select from pull-down list)		IP											
<b>Inputs for System</b>		Floor area served by system		Population of area served by system (including diversity)		Design primary supply fan airflow rate		OA req'd per unit area for system (Weighted average)		OA req'd per person for system area (Weighted average)		Inputs for Potentially Critical Zones	
Zone Name		Zone Tag		Space type		Floor Area of zone		Design population of zone		Design total supply to zone (primary plus local recirculated)		Induction Terminal Unit, Dual Fan Dual Duct or Transfer-Fan?	
Local recirc. air % representative of ave system return air		Az		Pz		Vozd		Er		Ds		Ez	
Zone title turns purple/blue for critical zone(s)		Selected from pull-down list		(default value listed; may be overridden)		Selected from pull-down list or leave blank if N/A		Selected from pull-down list		%		Selected from pull-down list	
<b>Inputs for Operating Condition Analyzed</b>		Percent of total design airflow rate at conditioned analyzed		Air distribution type at conditioned analyzed		Zone air distribution effectiveness at conditioned analyzed		Primary air fraction of supply air at conditioned analyzed		Ev		Vot	
Ventilation System Efficiency		Outdoor air intake required for system		Outdoor air per unit floor area		Outdoor air per person served by system (including diversity)		Outdoor air as a % of design primary supply air		Vot/As		Vot/Ps	
Results		0.95		0.23		19.3		12%		0.95		0.23	
<b>Detailed Calculations</b>		Initial Calculations for the System as a whole											
Primary supply air flow to system at conditioned analyzed		Vps		= Vpods		= 23005		Unrecirculated OA requirement for system		You		= 2822	
Uncorrected OA req'd as a fraction of primary SA		Xs		= Vot/Vps		= 0.11		<b>Initial Calculations for Individual Zones</b>		Raz		= RpsPs + RasAs	
OA rate per unit area for zone		Raz		= RpsPs + RasAs		= 0.11		OA rate per person		Roz		= Vot/Vps	
Total supply air to zone (at condition being analyzed)		Roz		= Vot/Vps		= 0.11		Unused OA req'd to breathing zone		Voz		= RpsPs + RasAs	
Unused OA requirement for zone		Voz		= RpsPs + RasAs		= 0.11		Fraction of zone supply not directly recirc. from zone		Fz		= Voz/Vps	
Fraction of zone supply from fully mixed primary air		Fz		= Voz/Vps		= 0.11		Fraction of zone OA not directly recirc. from zone		Fp		= Voz/Vps	
Unused OA fraction required in primary air to zone		Zp		= Voz/Vps		= 0.11		Zone Ventilation Efficiency (App A Method)		Ez		= (Fa + Fz) / Fa	
Zone Ventilation Efficiency (App A Method)		Ez		= (Fa + Fz) / Fa		= 0.95		System Ventilation Efficiency (App A Method)		Ev		= min(Ez)	
System Ventilation Efficiency (Table 6.3 Method)		Ev		= min(Ez)		= 0.88		Minimum outdoor air intake airflow		Vot		= Vot/Vps	
Outdoor Air Intake Flow required to System (Table 6.3 Method)		Vot		= Vot/Vps		= 2765		Outdoor Air Intake Flow required to System (Table 6.3 Method)		Vot		= Vot/Vps	
OA Intake req'd as a fraction of primary SA (Table 6.3 Method)		Y		= Vot/Vps		= 0.12		OA Intake req'd as a fraction of primary SA (Table 6.3 Method)		Y		= Vot/Vps	
OA Temp at which Min OA provides all cooling		Deg F		= (TD-DT)^(1-Y)/T+DT		= -89		OAT below which OA Intake flow is @ minimum		Deg F		= (TD-DT)^(1-Y)/T+DT	

Building:		Nassau Community College Life Sciences Building	
System Tag/Name:		AHU-3	
Operating Condition Description:		Design Peak Cooling Load Condition	
Units (Select from pull-down list)		IP	
<b>Inputs for System</b>			
Floor area served by system	Name	Units	System
Population of area served by system (including diversity)	As	sf	12062
Design primary supply fan airflow rate	Ps	P	143
OA req'd per unit area for system (Weighted average)	Vpsd	cfm	23,005
OA req'd per person for system area (Weighted average)	Ras	cfm/sf	0.10
	Rps	cfm/p	9.8
<b>Inputs for Potentially Critical Zones</b>			
Zone Name	Zone file turns purple italic for critical zone(s)		
Zone Tag			
Space Type	Select from pull-down list		
Floor Area of zone	Az	sf	
Design population of zone	Pz	P	(default value listed; may be overridden)
Design total supply to zone (primary plus local recirculated)	Vzsd	cfm	
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?	Ez		Select from pull-down list or leave blank if N/A
Local recirc. air % representative of ave system return air	Er		
<b>Inputs for Operating Condition Analyzed</b>			
Percent of total design airflow rate at conditioned analyzed	Ds	%	
Air distribution type at conditioned analyzed	Ez		Select from pull-down list
Zone air distribution effectiveness at conditioned analyzed	Ep		
Primary air fraction of supply air at conditioned analyzed			
<b>Results</b>			
Ventilation System Efficiency	Ev		0.95
Outdoor air intake required for system	Vor	cfm	2765
Outdoor air per unit floor area	Vor/As	cfm/sf	0.23
Outdoor air per person served by system (including diversity)	Vor/Ps	cfm/p	19.3
Outdoor air as a % of design primary supply air	Ypd	cfm	12%
<b>Detailed Calculations</b>			
<b>Initial Calculations for the System as a whole</b>			
Primary supply air flow to system at conditioned analyzed	Vps	cfm	= Vpods = 23005
Uncorrected OA requirement for system	Vou	cfm	= Ros Ps + Ras As = 2622
Uncorrected OA req'd as a fraction of primary SA	Xs		= Vou / Vps = 0.11
<b>Initial Calculations for individual zones</b>			
OA rate per unit area for zone	Raz	cfm/sf	
Total supply air to zone (at condition being analyzed)	Rpz	cfm/p	
Unused OA req'd to breathing zone	Vbz	cfm	
Unused OA requirement for zone	Vbz	cfm	
Fraction of zone supply not directly recirc. from zone	Fa		= Ep + (1-Ep)Er
Fraction of zone supply from fully mixed primary air	Fb		= Ep
Fraction of zone OA not directly recirc. from zone	Fc		= 1-(1-Ez)(1-Ep)(1-Er)
Unused OA fraction required in supply air to zone	Zp		= Voz / Vz
Unused OA fraction required in primary air to zone	Zp		=
<b>System Ventilation Efficiency</b>			
Zone Ventilation Efficiency (App A Method)	Ez		= (Fa + FBx - Fcz) / Fa = 0.99
System Ventilation Efficiency (App A Method)	Ev		= mn (Ez) = 0.95
Ventilation System Efficiency (Table 6.3 Method)	Ev		= Value from Table 6.3 = 0.98
<b>Minimum outdoor air intake airflow</b>			
Outdoor Air Intake Flow required to System	Vot	cfm	= Vou / Ev = 2765
OA intake req'd as a fraction of primary SA	Y		= Vor / Vps = 0.12
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Vot	cfm	= Vou / Ev = 2064
OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Y		= Vor / Vps = 0.12
<b>OA Temp at which Min OA provides all cooling</b>			
OAT below which OA intake flow is @ minimum	DEg F		= ((Tb-dT)Sf)-(L-V)TTr-dTr = -69



Building: Nassau Community College Life Sciences Building System Tag/Name: AHU-3 Operating Condition Description: Design Peak Cooling Load Condition Units (select from pull-down list) IP					
<b>Inputs for System</b> Floor area served by system Population of area served by system (including diversity) Design primary supply fan airflow rate OA req'd per unit area for system (Weighted average) OA req'd per person for system area (Weighted average) Inputs for Potentially Critical zones		Name Units As sf Ps P Vpsd cfm Ras cfm/sf Rps cfm/p	System 12052 143 23,005 0.10 9.8		
Zone Name Zone Tag Space type Floor Area of zone Design population of zone Design total supply to zone (primary plus local recirculated) Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan? Local recirc. air % representative of ave system return air		Zone title turns purple (blue for critical zone(s)) Selected from pull-down list Selected from pull-down list Selected from pull-down list or leave blank if N/A	Main Telecom Custodial/Maintenance Rm Base 06 Base 15 Electrical Storage equipment rooms 211 101 0 0 100 100		
<b>Inputs for Operating Condition Analyzed</b> Percent of total design airflow rate at conditioned analyzed Air distribution type at conditioned analyzed Zone air distribution effectiveness at conditioned analyzed Primary air fraction of supply air at conditioned analyzed		Ds % Ez Selected from pull-down list Ep	100% CS 1.00 CS 1.00		
<b>Results</b> Ventilation System Efficiency Outdoor air intake required for system Outdoor air per unit floor area Outdoor air per person served by system (including diversity) Outdoor air as a % of design primary supply air		EV Vot cfm Vot/As cfm/sf Vot/Ps cfm/p Ypd cfm	0.95 2765 0.23 19.3 12%		
<b>Detailed Calculations</b> Initial Calculations for the System as a whole Primary supply air flow to system at conditioned analyzed Uncorrected/OA requirement for system Uncorrected OA req'd as a fraction of primary SA Initial Calculations for Individual Zones OA rate per unit area for zone OA rate per person Total supply air to zone (at condition being analyzed) Unused OA req'd to breathing zone Unused OA requirement for zone Fraction of zone supply not directly recirc. from zone Fraction of zone supply from fully mixed primary air Fraction of zone OA not directly recirc. from zone Unused OA fraction required in supply air to zone Unused OA fraction required in primary air to zone System Ventilation Efficiency Zone Ventilation Efficiency (App A Method) System Ventilation Efficiency (App A Method) Ventilation System Efficiency (Table 6.3 Method) Minimum outdoor air intake airflow Outdoor Air Intake Flow required to System Outdoor Air Intake Flow required to System (Table 6.3 Method) OA Intake req'd as a fraction of primary SA (Table 6.3 Method) OA Temp at which Min OA provides all cooling OAT below which OA intake flow is 0.0 minimum					
Vps	cfm	=	VpdDs	=	23005
You	cfm	=	Ros Ps + Ras As	=	2822
Xs		=	Vou / Vps	=	0.11
Raz	cfm/sf				0.06
Rpz	cfm/p				0.00
Vz	cfm	=	Rpz Ps + Raz Az	=	100
Vbz	cfm	=	VbzEz	=	12.7
Voz	cfm	=	Ep + (1-Ep)Er	=	13
Fz		=	Ep	=	1.00
Fp		=	1-(1-Ez)(1-Ep)(1-Er)	=	1.00
Fo		=	Voz / Vpz	=	1.00
Zd		=	Voz / Vps	=	0.13
Zp		=	(Fz + Fbz - Fz) / Fa	=	0.12
Ez		=	min (Ez)	=	0.99
EV		=	Value from Table 6.3	=	0.95
EV		=	Value from Table 6.3	=	0.98
Vot	cfm	=	Vou / Ev	=	2765
Y		=	Vot / Vps	=	0.12
Ypd	cfm	=	Vou / Ev	=	2864
Y		=	Vot / Vps	=	0.12
Deq F		=	(T-D) / (T-H) (1-Y) / (T+Tr)	=	-89
Check Figures 11.9 P/1000 sf 1.91 cfm/sf 0.10 ave cfm/sf 9.83 ave cfm/p Totals/Averages		12052 total sf 143 total P 23005 total cfm 1.00 average 100% average 100% average 1.00 average			
143 System population without diversity 1.00 System population diversity, D		Primary airflow rate to zones 23005 cfm make that primary ow			

## Appendix B – Minimum Ventilation Compliance Check

AHU-1						
Room Number	Room Name	Level	Area	Design Ventilation	Minimum Ventilation	Standard 62.1 Compliant (Y/N)
1-17	Lobby	Level 1	375 SF	100	73	Y
1-19	Corr. #2	Level 1	451 SF	200	27	Y
1-20	Group Study Area	Level 1	1018 SF	1600	478	Y
1-21	36-Person General Classroom	Level 1	1181 SF	1950	341	Y
1-22	24-Person General Classroom	Level 1	755 SF	1200	225	Y
1-23	24-Person General Classroom	Level 1	761 SF	1100	226	Y
1-24	Chemistry Computer Cluster	Level 1	989 SF	1800	369	Y
1-26	Corr. #3	Level 1	622 SF	350	37	Y
1-27	Fac. Office	Level 1	109 SF	350	12	Y
1-28	Fac. Office	Level 1	105 SF	325	11	Y
1-29	Fac. Office	Level 1	105 SF	325	11	Y
1-30	Fac. Office	Level 1	105 SF	325	11	Y
1-31	Fac. Office	Level 1	105 SF	325	11	Y
1-32	Fac. Office	Level 1	105 SF	325	11	Y
1-33	Fac. Office	Level 1	106 SF	325	11	Y
1-34	Elec.	Level 1	56 SF	100	3	Y
1-35	Fac. Office	Level 1	102 SF	150	11	Y
1-36	Fac. Office	Level 1	105 SF	150	11	Y
1-37	Fac. Office	Level 1	106 SF	150	11	Y
1-39	Seating Niche	Level 1	432 SF	300	12	Y
2-15	Faculty Lounge	Level 2	301 SF	500	96	Y
2-18	Corr.#2	Level 2	598 SF	250	36	Y
2-20	Chemistry Admin. Suite	Level 2	299 SF	350	38	Y
2-20A	Director's Office	Level 2	174 SF	175	15	Y
2-20C	Conf. Room	Level 2	247 SF	500	75	Y
2-26	Fac. Office	Level 2	109 SF	350	12	Y
2-27	Fac. Office	Level 2	105 SF	325	11	Y
2-28	Fac. Office	Level 2	105 SF	325	11	Y
2-29	Fac. Office	Level 2	105 SF	325	11	Y
2-30	Fac. Office	Level 2	105 SF	325	11	Y
2-31	Fac. Office	Level 2	105 SF	325	11	Y
2-32	Fac. Office	Level 2	106 SF	325	11	Y
2-33	Elec.	Level 2	56 SF	100	3	Y
2-34	Fac. Office	Level 2	102 SF	150	11	Y
2-35	Fac. Office	Level 2	105 SF	150	11	Y
2-36	Fac. Office	Level 2	106 SF	150	11	Y



2-37	Fac. Office	Level 2	105 SF	150	11	Y
2-38	Fac. Office	Level 2	105 SF	150	11	Y
2-39	Fac. Office	Level 2	102 SF	150	11	Y
3-15	Faculty Lounge	Level 3	301 SF	525	141	Y
3-17	Practical Skills Training Room	Level 3	1423 SF	2100	363	Y
3-18	Corr. #2	Level 3	1111 SF	500	67	Y
3-19	Nursing Admin. Suite	Level 3	517 SF	350	51	Y
3-20	Storage	Level 3	155 SF	150	19	Y
3-21	Director's Office/Conf. Room	Level 3	470 SF	500	33	Y
3-23	Nursing Learning Center/Media Stor.	Level 3	666 SF	700	160	Y
3-24	Nursing Computer Exam Room	Level 3	1643 SF	2100	677	Y
3-26	Corr. #3	Level 3	613 SF	350	37	Y
3-27	Fac. Office	Level 3	109 SF	375	12	Y
3-28	Fac. Office	Level 3	105 SF	350	11	Y
3-29	Fac. Office	Level 3	105 SF	350	11	Y
3-30	Fac. Office	Level 3	105 SF	350	11	Y
3-31	Fac. Office	Level 3	105 SF	350	11	Y
3-32	Fac. Office	Level 3	105 SF	350	11	Y
3-33	Fac. Office	Level 3	106 SF	350	11	Y
3-34	Elec.	Level 3	56 SF	100	3	Y
3-35	Fac. Office	Level 3	102 SF	175	11	Y
3-36	Fac. Office	Level 3	105 SF	175	11	Y
3-37	Fac. Office	Level 3	106 SF	175	11	Y
3-38	Fac. Office	Level 3	105 SF	175	11	Y
3-39	Fac. Office	Level 3	105 SF	175	11	Y
3-40	Fac. Office	Level 3	102 SF	175	11	Y

AHU-2						
Room Number	Room Name	Level	Area	Design Ventilation	Minimum Ventilation	Standard 62.1 Compliant (Y/N)
1-01	Corr. #1	Level 1	1492 SF	750	90	Y
1-03	36-Person General Classroom	Level 1	1074 SF	1600	334	Y
1-04	24-Person General Classroom	Level 1	755 SF	1100	225	Y
1-05	36-Person General Classroom	Level 1	1067 SF	1600	334	Y
1-06	36-Person General Classroom	Level 1	1056 SF	1300	333	Y
1-08	Men	Level 1	243 SF	225	29	Y
1-09	Women	Level 1	314 SF	325	38	Y
1-10	Elec.	Level 1	110 SF	100	7	Y
1-15	Tele.	Level 1	69 SF	50	4	Y
1-40	Vending	Level 1	203 SF	225	32	Y
1-41	Fac. Office	Level 1	106 SF	325	11	Y

1-42	Fac. Office	Level 1	105 SF	325	11	Y
1-43	Fac. Office	Level 1	105 SF	325	11	Y
1-44	Fac. Office	Level 1	105 SF	325	11	Y
1-45	Fac. Office	Level 1	105 SF	325	11	Y
1-46	Fac. Office	Level 1	105 SF	325	11	Y
1-47	Fac. Office	Level 1	105 SF	325	11	Y
1-48	Fac. Office	Level 1	105 SF	325	11	Y
1-49	Fac. Office	Level 1	105 SF	325	11	Y
1-50	Fac. Office	Level 1	105 SF	325	11	Y
1-51	Fac. Office	Level 1	105 SF	325	11	Y
1-52	Fac. Office	Level 1	105 SF	325	11	Y
1-53	Fac. Office	Level 1	109 SF	350	12	Y
2-07	Men	Level 2	243 SF	225	29	Y
2-08	Women	Level 2	310 SF	325	37	Y
2-09	Elec.	Level 2	110 SF	100	7	Y
2-14	Tele.	Level 2	69 SF	50	4	Y
2-40	Vending	Level 2	201 SF	225	32	Y
2-41	Fac. Office	Level 2	106 SF	325	11	Y
2-42	Fac. Office	Level 2	105 SF	325	11	Y
2-43	Fac. Office	Level 2	105 SF	325	11	Y
2-44	Fac. Office	Level 2	105 SF	325	11	Y
2-45	Fac. Office	Level 2	105 SF	325	11	Y
2-46	Fac. Office	Level 2	105 SF	325	11	Y
2-47	Fac. Office	Level 2	105 SF	325	11	Y
2-48	Fac. Office	Level 2	105 SF	325	11	Y
2-49	Fac. Office	Level 2	105 SF	325	11	Y
2-50	Fac. Office	Level 2	105 SF	325	11	Y
2-51	Fac. Office	Level 2	105 SF	325	11	Y
2-52	Fac. Office	Level 2	105 SF	325	11	Y
2-53	Fac. Office	Level 2	109 SF	350	12	Y
3-01	Corr. #1	Level 3	1501 SF	700	90	Y
3-03	Practical Skills Training Room	Level 3	1426 SF	1500	531	Y
3-04	Practical Skills Training Room	Level 3	1419 SF	1500	530	Y
3-05	Practical Skills Training Room	Level 3	1396 SF	1500	528	Y
3-06	Prep Room	Level 3	299 SF	300	28	Y
3-07	Men	Level 3	243 SF	225	29	Y
3-08	Women	Level 3	310 SF	325	37	Y
3-09	Elec.	Level 3	110 SF	100	7	Y
3-14	Tele.	Level 3	69 SF	50	4	Y
3-41	Vending	Level 3	202 SF	175	32	Y
3-42	Fac. Office	Level 3	106 SF	350	11	Y
3-43	Fac. Office	Level 3	105 SF	350	11	Y

3-44	Fac. Office	Level 3	105 SF	350	11	Y
3-45	Fac. Office	Level 3	105 SF	350	11	Y
3-46	Fac. Office	Level 3	105 SF	350	11	Y
3-47	Fac. Office	Level 3	105 SF	350	11	Y
3-48	Fac. Office	Level 3	105 SF	350	11	Y
3-49	Fac. Office	Level 3	105 SF	350	11	Y
3-50	Fac. Office	Level 3	105 SF	350	11	Y
3-51	Fac. Office	Level 3	105 SF	350	11	Y
3-52	Fac. Office	Level 3	105 SF	350	11	Y
3-53	Fac. Office	Level 3	105 SF	350	11	Y
3-54	Fac. Office	Level 3	109 SF	375	12	Y

AHU-3						
Room Number	Room Name	Level	Area	Design Ventilation	Minimum Ventilation	Standard 62.1 Compliant (Y/N)
2-01	Corr. #1	Level 2	1533 SF	1000	92	Y
2-03	Inorganic Chemistry Lab	Level 2	1283 SF	2500	414	Y
2-04	Inorganic Chemistry Lab	Level 2	1271 SF	2500	413	Y
2-05	Inorganic Chemistry Lab	Level 2	1275 SF	2500	413	Y
2-06	Chemical Stockroom	Level 2	533 SF	750	64	Y
2-06A	Chem. Stockroom Office	Level 2	87 SF	100	10	Y
2-17	Cart/Equipment Storage Room	Level 2	294 SF	350	35	Y
2-18	Corr. #2	Level 2	598 SF	300	36	Y
2-19	Inorganic Chemistry Lab	Level 2	1289 SF	2500	355	Y
2-21	Organic Chemistry Lab	Level 2	947 SF	3840	314	Y
2-22	Organic Instrumentation	Level 2	292 SF	350	55	Y
2-23	Organic Chemistry Lab	Level 2	947 SF	3840	314	Y
2-25	Corr. #3	Level 2	680 SF	350	41	Y
B-01	Corr. #2	Basement	711 SF	1925	43	Y
B-06	Main Telecom Room	Basement	221 SF	100	13	Y
B-15	Custodial/Maintenance	Basement	101 SF	100	12	Y