

Presentation Outline

Introduction

Building Overview

Proposed Redesigns

Load Reduction

DOAS & Chilled Beam Analysis

Floor-to-Floor Height Reduction – Breadth Topic

Chiller Plant Analysis

Conclusion



Zachary Polovchik
Mechanical Option
Advisor – Dustin Eplee

The Pennsylvania State University
Department of
Architectural Engineering

Presentation Outline

Introduction

Building Overview

Proposed Redesigns

Load Reduction

DOAS & Chilled Beam Analysis

Floor-to-Floor Height Reduction – Breadth Topic

Chiller Plant Analysis

Conclusion

DUVAL COUNTY UNIFIED COURTHOUSE FACILITY

JACKSONVILLE, FL



Proposed Depth & Breadth Topics:

- Building Envelope Load Reduction
- Dedicated Outdoor Air Systems with Active Chilled Beams
- Chiller Plant Implementation (MAE Course Work)
- Electrical Breadth – Solar Photovoltaic Analysis
- Construction Management – Floor-to-Floor Height Reduction

Zachary Polovchik
Mechanical Option
Advisor – Dustin Eplee

The Pennsylvania State University
Department of
Architectural Engineering

Presentation Outline

Introduction

Building Overview

Building Statistics

Existing Mechanical Systems

Proposed Redesigns

Load Reduction

DOAS & Chilled Beam Analysis

Floor-to-Floor Height Reduction – Breadth Topic

Chiller Plant Analysis

Conclusion



Use: Office/Courthouse
Cost: \$224 Million

Delivery: Design-Build
Construction Start: May 2009
Construction End: May 2012



Location: Downtown Jacksonville, Florida
Size: 798,000 s.f. with 7 Levels above grade

Zachary Polovchik
Mechanical Option
Advisor – Dustin Eplee

DUVAL COUNTY UNIFIED COURTHOUSE FACILITY

The Pennsylvania State University
Department of
Architectural Engineering

Presentation Outline

Introduction

Building Overview

Building Statistics

Existing Mechanical Systems

Proposed Redesigns

Load Reduction

DOAS & Chilled Beam Analysis


Floor-to-Floor Height Reduction – Breadth Topic

Chiller Plant Analysis

Conclusion

Airside Systems:

- 25 Variable Air Volume Air Handling Units (3,300 to 50,000 CFM)
 - 14 AHUs for 51 Courtrooms
 - 11 AHUs for remaining spaces
- 3 Make-Up Air Units (40,000 CFM each)
 - 2 MAUs use sensible energy wheels



Presentation Outline

Introduction

Building Overview

Building Statistics

Existing Mechanical Systems

Proposed Redesigns

Load Reduction

DOAS & Chilled Beam Analysis



Floor-to-Floor Height Reduction – Breadth Topic

Chiller Plant Analysis

Conclusion

Airside Systems:

- 25 Variable Air Volume Air Handling Units (3,300 to 50,000 CFM)
 - 14 AHUs for 51 Courtrooms
 - 11 AHUs for remaining spaces
- 3 Make-Up Air Units (40,000 CFM each)
 - 2 MAUs use sensible energy wheels



Presentation Outline

Introduction

Building Overview

Building Statistics

Existing Mechanical Systems

Proposed Redesigns

Load Reduction

DOAS & Chilled Beam Analysis



Floor-to-Floor Height Reduction – Breadth Topic

Chiller Plant Analysis

Conclusion

Waterside Systems:

- 2 Natural Gas Boiler (13,390 MBH each)
- Chilled water supplied by J.E.A. Public Utility Company
 - Pumped from central pumping room to coils with two 2,200 GPM 200 HP pumps



Presentation Outline

Introduction

Building Overview

Building Statistics

Existing Mechanical Systems

Proposed Redesigns

Load Reduction

DOAS & Chilled Beam Analysis

Floor-to-Floor Height Reduction – Breadth Topic

Chiller Plant Analysis

Conclusion

Zone Conditioning:

- Areas served by VAV AHUs
- Terminal VAV boxes with reheat in zones
- 872 VAV boxes (200 to 6,300 CFM)

Presentation Outline

Introduction

Building Overview

Building Statistics

Existing Mechanical Systems

Proposed Redesigns

Load Reduction

DOAS & Chilled Beam Analysis

Floor-to-Floor Height Reduction – Breadth Topic

Chiller Plant Analysis

Conclusion

Zone Conditioning:

- Areas served by VAV AHUs
- Terminal VAV boxes with reheat in zones
- 872 VAV boxes (200 to 6,300 CFM)

Energy Sources:

Utility Rates	
Utility	Unit Cost
Electricity	\$0.0292/MBTU
Chilled Water	\$0.0132MBTU
Natural Gas	\$0.0083/MBTU

Presentation Outline

Introduction

Building Overview

Building Statistics

Existing Mechanical Systems

Proposed Redesigns

Load Reduction

DOAS & Chilled Beam Analysis

Floor-to-Floor Height Reduction – Breadth Topic

Chiller Plant Analysis

Conclusion

Zachary Polovchik
 Mechanical Option
 Advisor – Dustin Eplee

Zone Conditioning:

- Areas served by VAV AHUs
- Terminal VAV boxes with reheat in zones
- 872 VAV boxes (200 to 6,300 CFM)

Energy Sources:

Utility Rates	
Utility	Unit Cost
Electricity	\$0.0292/MBTU
Chilled Water	\$0.0132MBTU
Natural Gas	\$0.0083/MBTU

Energy Use:

Energy Use Summary						
Electric		Natural Gas		Chilled Water		Total
Consumption (kWh)	Peak Demand (kW)	Consumption (MCF)	Peak Demand (MCF/hr)	Consumption (kGal)	Peak Demand (Gal/hr)	Consumption (MMBTU)
5,176,611	1,880	783	5.8	341	227.7	55,081

Energy Cost:

Energy Cost Summary					
Electric			Natural Gas	Chilled Water	Total
Consumption	Demand	Total	Consumption	Consumption	Consumption
\$517,661.10	205,690.00	\$723,351.10	\$6,696.44	\$483,274.44	\$1,213,321.98

DUVAL COUNTY UNIFIED COURTHOUSE FACILITY

The Pennsylvania State University
 Department of
 Architectural Engineering

Presentation Outline

Introduction

Building Overview

Building Statistics

Existing Mechanical Systems

Proposed Redesigns

Load Reduction

DOAS & Chilled Beam Analysis

Floor-to-Floor Height Reduction – Breadth Topic

Chiller Plant Analysis

Conclusion

Goals and Objectives:

- Reduce Cooling Loads on building
 - Climatic loads such as solar and dehumidification
- Reduce Energy Consumption
- Reduce Utility Costs

Presentation Outline

Introduction

Building Overview

Building Statistics

Existing Mechanical Systems

Proposed Redesigns

Load Reduction

DOAS & Chilled Beam Analysis

Floor-to-Floor Height Reduction – Breadth Topic

Chiller Plant Analysis

Conclusion

Goals and Objectives:

- Reduce Cooling Loads on building
 - Climatic loads such as solar and dehumidification
- Reduce Energy Consumption
- Reduce Utility Costs

Bases for Comparison:

- Initial Cost
- Life Cycle Cost
- Energy Use & Cost
- Simple Payback
- Environmental Impact
- LEED Applicability

Presentation Outline

Introduction

Building Overview

Proposed Redesigns

Load Reduction

Existing Loads

Internal Shading Technology

New Loads

Economics

DOAS & Chilled Beam Analysis

Floor-to-Floor Height Reduction – Breadth Topic

Chiller Plant Analysis

Conclusion

➤ Large amount of glazing contributes greatly to building cooling loads

➤ Solar gain through windows is large and has a significant impact on the building loads

Building Loads				
Total Cooling Load	Glazing Solar Load	Glazing Conduction Load	Total Glazing Load	Glazing Load Percentage of Total
(Tons)	(Tons)	(Tons)	(Tons)	
2030	164	110	274	13.5%

Presentation Outline

Introduction

Building Overview

Proposed Redesigns

Load Reduction

Existing Loads

Internal Shading Technology

New Loads

Economics


DOAS & Chilled Beam Analysis

Floor-to-Floor Height Reduction – Breadth Topic

Chiller Plant Analysis

Conclusion

Zachary Polovchik
Mechanical Option
Advisor – Dustin Eplee



*Images Courtesy of Multifilm® website



- Improves SHGC and U-Value of glazing system
- For ease of modeling the solar radiation reduction benefits, the glazing system's SHGC was modified instead of utilizing an internal shading model
- The Multifilm® *Film-Façade-Systems* product has been chosen for the DCUCF due to the large glazing areas
- This system allows for an electrically motorized operation system to adjust the vertical length of the blind
- The control of these internal shades will use photosensors on each main façade of the building to control the motors

- Normal blinds trap direct solar radiation between glazing and blind's surface
- Multifilm® blinds use multiple films, with a thin layer of reflective aluminum
- Allows solar radiation to be reflected back out glazing before it turns into heat in the trapped space
- Allows enough visible light in and out to allow for glare-free natural lighting and views out

DUVAL COUNTY UNIFIED COURTHOUSE FACILITY

The Pennsylvania State University
Department of
Architectural Engineering

Presentation Outline

Introduction

Building Overview

Proposed Redesigns

Load Reduction

Existing Loads

Internal Shading Technology

New Loads

Economics

DOAS & Chilled Beam Analysis


Floor-to-Floor Height Reduction – Breadth Topic

Chiller Plant Analysis

Conclusion

Zachary Polovchik
Mechanical Option
Advisor – Dustin Eplee

New Building Loads				
Total Cooling Load	Glazing Solar Load	Glazing Conduction Load	Total Glazing Load	Glazing Load Percentage of Total
(Tons)	(Tons)	(Tons)	(Tons)	
1873	49	70	119	6%



The Pennsylvania State University
DUVAL COUNTY UNIFIED COURTHOUSE FACILITY

Department of
Architectural Engineering

Presentation Outline


- Introduction
- Building Overview
- Proposed Redesigns*
 - Load Reduction*
 - Existing Loads
 - Internal Shading Technology
 - New Loads*
 - Economics
- DOAS & Chilled Beam Analysis
- Floor-to-Floor Height Reduction – Breadth Topic
- Chiller Plant Analysis
- Conclusion

➤ Total energy use reduced by 2,529 MMBTU

Energy Use Summary						
Electric		Natural Gas		Chilled Water		Total
Consumption (kWh)	Peak Demand (kW)	Consumption (MCF)	Peak Demand (MCF/hr)	Consumption (kGal)	Peak Demand (Gal/hr)	Consumption (MMBTU)
5,219,790	1,852	609	4.0	317	210	52,552

➤ Total energy cost reduced by \$32,940

Energy Cost Summary					
Electric			Natural Gas	Chilled Water	Total
Consumption	Demand	Total	Consumption	Consumption	Consumption
\$521,979.00	202,880.00	\$724,859.00	\$5,214.89	\$450,307.44	\$1,180,381.33



Presentation Outline

Introduction

Building Overview

Proposed Redesigns

Load Reduction

Existing Loads

Internal Shading Technology

New Loads

Economics

DOAS & Chilled Beam Analysis

Floor-to-Floor Height Reduction – Breadth Topic

Chiller Plant Analysis

Initial Cost: \$1,154,400

Annual Savings: \$32,940

Simple Payback: 35 Years

20 Year LCC: \$21,244,274

Conclusion

Presentation Outline

Introduction

➤ Current facility requires a total cooling airflow of 486,632 CFM with 137,099 CFM of ventilation air

Building Overview

➤ Ventilation Load of 504 tons

Proposed Redesigns

Load Reduction

DOAS & Chilled Beam Analysis

System Advantages

System Description

Resulting Cooling Loads

Economics

Floor-to-Floor Height Reduction – Breadth Topic

Chiller Plant Analysis

➤ DOAS/ACB take care of ventilation and zone cooling separately

➤ Allows for minimum airflow to be sent to space

- Reduces ductwork

- Handles only latent loads

➤ Active Chilled Beams are more efficient at cooling space

Conclusion

Presentation Outline

Introduction

Building Overview

Proposed Redesigns

Load Reduction

DOAS & Chilled Beam Analysis

System Advantages

System Description

Resulting Cooling Loads

Economics


Floor-to-Floor Height Reduction – Breadth Topic

Chiller Plant Analysis

Conclusion

Zachary Polovchik
Mechanical Option
Advisor – Dustin Eplee

- Remove 25 VAV AHUs and replace with 12 DOAS units and 7 new VAV units
 - 12 DOAS units for office, courtroom, hearing spaces, etc.
 - 7 VAV units for storage, restrooms, corridors, etc.



DUVAL COUNTY UNIFIED COURTHOUSE FACILITY

The Pennsylvania State University
Department of
Architectural Engineering

Presentation Outline

Introduction

Building Overview

Proposed Redesigns

Load Reduction

DOAS & Chilled Beam Analysis

System Advantages

System Description

Resulting Cooling Loads


Economics

Floor-to-Floor Height Reduction – Breadth Topic

Chiller Plant Analysis

Conclusion

- Zones served by DOAS units are equipped with **Active Chilled Beams**
- Minimal Ceiling Space Requirements



Presentation Outline

Introduction

Building Overview

Proposed Redesigns

Load Reduction

DOAS & Chilled Beam Analysis

System Advantages

System Description

Resulting Cooling Loads

Economics


Floor-to-Floor Height Reduction – Breadth Topic

Chiller Plant Analysis

Conclusion

Zachary Polovchik
Mechanical Option
Advisor – Dustin Eplee

New Building Loads			
Total Cooling Load	Ventilation Load	Total Cooling Supply Air	Ventilation Supply Air
(Tons)	(Tons)	(CFM)	(CFM)
1,431	322	208,986	127,526



The Pennsylvania State University
DUVAL COUNTY UNIFIED COURTHOUSE FACILITY

Department of
Architectural Engineering

Presentation Outline

Introduction

Building Overview

Proposed Redesigns

Load Reduction

DOAS & Chilled Beam Analysis

System Advantages

System Description

Resulting Cooling Loads

Economics

Floor-to-Floor Height Reduction – Breadth Topic

Chiller Plant Analysis


Conclusion

➤ Total energy use reduced by 17,054 MMBTU

Energy Use Summary						
Electric		Natural Gas		Chilled Water		Total
Consumption (kWh)	Peak Demand (kW)	Consumption (MCF)	Peak Demand (MCF/hr)	Consumption (kGal)	Peak Demand (Gal/hr)	Consumption (MMBTU)
4,262,701	1,283	1,219	4.0	206	159	38,027

➤ Total energy cost reduced by \$342,422.28

Energy Cost Summary					
Electric			Natural Gas	Chilled Water	Total
Consumption	Demand	Total	Consumption	Consumption	Consumption
\$426,270.10	\$140,820.00	\$567,080.10	\$10,427.46	\$293,382.14	\$870,899.70



Presentation Outline

Introduction

Building Overview

Proposed Redesigns

Load Reduction

DOAS & Chilled Beam Analysis

System Advantages

System Description

Resulting Cooling Loads

Economics

Floor-to-Floor Height Reduction – Breadth Topic

Chiller Plant Analysis

Conclusion

Initial Cost: \$5,128,882

Annual Savings: \$342,422

Simple Payback: 15 Years

20 Year LCC: \$17,880,987

Presentation Outline

Introduction

➤ DOAS/ACB system conversion frees up space in large plenums

Building Overview

➤ Allows plenum spaces to be reduced in height, therefore reducing overall floor-to-floor height

Proposed Redesigns

Load Reduction

➤ Analyzed for a 4 foot reduction in plenum height for each floor

DOAS & Chilled Beam Analysis

Floor-to-Floor Height Reduction – Breadth Topic

➤ Equates to a total building height reduction of 28 feet

Column Savings

Façade Savings

➤ Analyzed material and schedule savings for structural columns and façade materials.

Updated DOAS/ACB Economics

Chiller Plant Analysis

Conclusion

Presentation Outline

Introduction

Building Overview

Proposed Redesigns

Load Reduction

DOAS & Chilled Beam Analysis

Floor-to-Floor Height Reduction – Breadth Topic

Column Savings

Façade Savings

Updated DOAS/ACB Economics

Chiller Plant Analysis

Conclusion


Zachary Polovchik
Mechanical Option
Advisor – Dustin Eplee

Cast-in-Place Concrete Columns

Total Concrete Saved: 666 Cubic Yards

Total Column Cost Reduction: \$849,150.00

Construction Time Saved: 29.5 Days



DUVAL COUNTY UNIFIED COURTHOUSE FACILITY

The Pennsylvania State University
Department of
Architectural Engineering

Presentation Outline

Introduction

Building Overview

Proposed Redesigns

Load Reduction

DOAS & Chilled Beam Analysis

Floor-to-Floor Height Reduction – Breadth Topic

Column Savings

Façade Savings

Updated DOAS/ACB Economics

Chiller Plant Analysis

Conclusion

Precast Concrete Architectural Panels

Total Panel Façade Saved: 31,330 Square Feet

Total Panel Cost Reduction: \$1,366,298.51

Façade Glazing

Total Glazing Façade Saved: 23,635 Square Feet

Total Glazing Cost Reduction: \$2,138,955.19

Total Construction Time Saved: 81 Days

Presentation Outline

Introduction

Building Overview

Proposed Redesigns

Load Reduction

DOAS & Chilled Beam Analysis

Floor-to-Floor Height Reduction – Breadth Topic


Column Savings

Façade Savings

Updated DOAS/ACB Economics

Chiller Plant Analysis

Conclusion



Presentation Outline

Introduction

Building Overview

Proposed Redesigns

Load Reduction

DOAS & Chilled Beam Analysis

Floor-to-Floor Height Reduction – Breadth Topic

Column Savings

Façade Savings

Updated DOAS/ACB Economics

Chiller Plant Analysis

Conclusion

Total Cost Reduction: \$4,354,403

New DOAS/ACB Initial Cost: \$774,478

New Simple Payback: 2.3 Years

New 20 Year LCC: \$13,526,583

Presentation Outline

Introduction

Building Overview

Proposed Redesigns

Load Reduction

DOAS & Chilled Beam Analysis

Floor-to-Floor Height Reduction – Breadth Topic

Chiller Plant Analysis

Chiller Plant Equipment & Setup

Energy Consumption Results

Economics


Conclusion

➤ Variable Primary Flow Parallel Chiller Plant

- Three 750 ton two-stage centrifugal chillers
- Three 750 ton VFD controlled cooling towers
- Three 150 HP Variable Flow chilled water pumps

➤ Advantages of VPF system over primary/secondary

- Lower First Cost
- Lower energy and operating costs
- Better chiller optimization
- Less operation of chiller auxiliary equipment



Presentation Outline

Introduction

Building Overview

Proposed Redesigns

Load Reduction

DOAS & Chilled Beam Analysis

Floor-to-Floor Height Reduction – Breadth Topic

Chiller Plant Analysis

Chiller Plant Equipment & Setup

Energy Consumption Results

Economics


Conclusion

➤ Variable Primary Flow Parallel Chiller Plant

- Three 750 ton two-stage centrifugal chillers
- Three 750 ton VFD controlled cooling towers
- Three 150 HP Variable Flow chilled water pumps

➤ Advantages of VPF system over primary/secondary

- Lower First Cost
- Lower energy and operating costs
- Better chiller optimization
- Less operation of chiller auxiliary equipment



Presentation Outline


- Introduction
- Building Overview
- Proposed Redesigns*
 - Load Reduction
 - DOAS & Chilled Beam Analysis
 - Floor-to-Floor Height Reduction – Breadth Topic
 - Chiller Plant Analysis*
 - Chiller Plant Equipment & Setup
 - Energy Consumption Results*
 - Economics
- Conclusion

➤ Total energy use reduced by 32,958 MMBTU

Energy Use Summary				
Electric		Natural Gas		Total
Consumption (kWh)	Peak Demand (kW)	Consumption (MCF)	Peak Demand (MCF/hr)	Consumption (MMBTU)
6,115,746	2,363	1,219	4.0	22,123

➤ Total energy cost reduced by \$354,001.56

Energy Cost Summary					
Electric			Natural Gas	Chilled Water	Total
Consumption	Demand	Total	Consumption	Consumption	Consumption
\$611,574.56	\$226,460.00	\$838,034.56	\$10,427.46	\$293,382.14	\$859,320.34



Presentation Outline

Introduction

Building Overview

Proposed Redesigns

Load Reduction

DOAS & Chilled Beam Analysis

Floor-to-Floor Height Reduction – Breadth Topic

Chiller Plant Analysis

Chiller Plant Equipment & Setup

Energy Consumption Results

Economics

Conclusion

Initial Plant Cost: \$1,867,550
Additional DOAS/ACB Cost: \$5,003,482
Total Savings: \$354,001
Simple Payback: 19 Years
20 Year LCC: \$19,766,007

Presentation Outline

Introduction

Building Overview

Proposed Redesigns

Load Reduction

DOAS & Chilled Beam Analysis

Floor-to-Floor Height Reduction – Breadth Topic

Chiller Plant Analysis

Chiller Plant Equipment & Setup

Energy Consumption Results

Economics

Conclusion

With Construction Cost Reduction

New DOAS/ACB & Chiller Plant Initial Cost: \$2,516,628

New Simple Payback: 7.1 Years

New 20 Year LCC: \$15,411,603

Presentation Outline

- Introduction
- Building Overview
- Proposed Redesigns
 - Load Reduction
 - DOAS & Chilled Beam Analysis
 - Floor-to-Floor Height Reduction – Breadth Topic
 - Chiller Plant Analysis

Conclusion

Zachary Polovchik
 Mechanical Option
 Advisor – Dustin Eplee

Initial Cost Comparison		
Alternative	Initial Cost	Rating
Existing VAV System	\$2,608,539	3
Existing VAV System with Internal Shading	\$3,762,944	4
DOAS/ACB with Internal Shading	\$5,128,882	5
DOAS/ACB with Internal Shading and Height Reduction	\$774,478	1
Chiller Plant with DOAS/ACB with Internal Shading	\$6,871,032	6
Chiller Plant with DOAS/ACB with Internal Shading and Height Reduction	\$2,516,628	2

DUVAL COUNTY UNIFIED COURTHOUSE FACILITY

LCC Comparison		
Alternative	LCC	Rating
Existing VAV System	\$20,575,135	5
Existing VAV System with Internal Shading	\$21,244,274	6
DOAS/ACB with Internal Shading	\$17,880,987	3
DOAS/ACB with Internal Shading and Height Reduction	\$13,526,583	1
Chiller Plant with DOAS/ACB with Internal Shading	\$19,766,007	4
Chiller Plant with DOAS/ACB with Internal Shading and Height Reduction	\$15,411,603	2

The Pennsylvania State University
 Department of
 Architectural Engineering

Presentation Outline

- Introduction
- Building Overview
- Proposed Redesigns
 - Load Reduction
 - DOAS & Chilled Beam Analysis
 - Floor-to-Floor Height Reduction – Breadth Topic
 - Chiller Plant Analysis

Conclusion

Energy Use Comparison		
Alternative	Energy Use (MMBTU)	Rating
Existing VAV System	55,081	4
Existing VAV System with Internal Shading	52,552	3
DOAS/ACB with Internal Shading	38,027	2
DOAS/ACB with Internal Shading and Height Reduction	-	-
Chiller Plant with DOAS/ACB with Internal Shading	22,123	1
Chiller Plant with DOAS/ACB with Internal Shading and Height Reduction	-	-

Energy Cost Comparison		
Alternative	Energy Cost	Rating
Existing VAV System	\$1,213,321.98	4
Existing VAV System with Internal Shading	\$1,180,381.33	3
DOAS/ACB with Internal Shading	\$870,899.70	2
DOAS/ACB with Internal Shading and Height Reduction	-	-
Chiller Plant with DOAS/ACB with Internal Shading	\$859,320.34	1
Chiller Plant with DOAS/ACB with Internal Shading and Height Reduction	-	-

Presentation Outline

Introduction

Building Overview

Proposed Redesigns

Load Reduction

DOAS & Chilled Beam Analysis

Floor-to-Floor Height Reduction – Breadth Topic

Chiller Plant Analysis

Conclusion

Simple Payback Comparison

Alternative	SPB	Rating
Existing VAV System	-	-
Existing VAV System with Internal Shading	35	5
DOAS/ACB with Internal Shading	15	3
DOAS/ACB with Internal Shading and Height Reduction	2.3	1
Chiller Plant with DOAS/ACB with Internal Shading	19	4
Chiller Plant with DOAS/ACB with Internal Shading and Height Reduction	7.1	2

Presentation Outline

Introduction

Building Overview

Proposed Redesigns

Load Reduction

DOAS & Chilled Beam Analysis

Floor-to-Floor Height Reduction – Breadth Topic

Chiller Plant Analysis

Conclusion

Emissions Comparison		
Alternative	Emissions (lb _m CO _{2e})	Rating
Existing VAV System	13,294,874.11	4
Existing VAV System with Internal Shading	13,062,795.68	3
DOAS/ACB with Internal Shading	10,111,410.78	1
DOAS/ACB with Internal Shading and Height Reduction	-	-
Chiller Plant with DOAS/ACB with Internal Shading	10,791,278.39	2
Chiller Plant with DOAS/ACB with Internal Shading and Height Reduction	-	-

Zachary Polovchik
Mechanical Option
Advisor – Dustin Eplee

DUVAL COUNTY UNIFIED COURTHOUSE FACILITY

The Pennsylvania State University
Department of
Architectural Engineering

Presentation Outline

Introduction

Building Overview

Proposed Redesigns

Load Reduction

DOAS & Chilled Beam Analysis

Floor-to-Floor Height Reduction – Breadth Topic

Chiller Plant Analysis

Conclusion

LEED Comparison		
Alternative	LEED Credits	Rating
Existing VAV System	32	4
Existing VAV System with Internal Shading	33	3
DOAS/ACB with Internal Shading	39	1
DOAS/ACB with Internal Shading and Height Reduction	-	-
Chiller Plant with DOAS/ACB with Internal Shading	39	1
Chiller Plant with DOAS/ACB with Internal Shading and Height Reduction	-	-

Zachary Polovchik
Mechanical Option
Advisor – Dustin Eplee

DUVAL COUNTY UNIFIED COURTHOUSE FACILITY

The Pennsylvania State University
Department of
Architectural Engineering

Presentation Outline

Introduction

Building Overview

Proposed Redesigns

Load Reduction


DOAS & Chilled Beam Analysis

Floor-to-Floor Height Reduction – Breadth Topic

Chiller Plant Analysis

Conclusion

System Selection Scoring		
Alternative	Average Score	Rating
Existing VAV System	4.000	6
Existing VAV System with Internal Shading	3.857	5
DOAS/ACB with Internal Shading	2.428	3
DOAS/ACB with Internal Shading and Height Reduction	1.000	1
Chiller Plant with DOAS/ACB with Internal Shading	2.714	4
Chiller Plant with DOAS/ACB with Internal Shading and Height Reduction	2.000	2



Presentation Outline

Acknowledgements

Introduction

Building Overview

Proposed Redesigns

Load Reduction

DOAS & Chilled Beam Analysis

Floor-to-Floor Height Reduction – Breadth Topic

Chiller Plant Analysis

Conclusion

➤ Architectural Engineering Faculty and Mechanical Mentors

➤ Thesis Advisors: Dr. James Freihaut and Dustin Eplee

➤ Turner Construction for project sponsorship

➤ Lou Fiore of Turner Construction

➤ Mark Gelfo of TLC Engineering

➤ All my family and friends for their support!

Presentation Outline

Introduction

Building Overview

Proposed Redesigns

Load Reduction

DOAS & Chilled Beam Analysis

Floor-to-Floor Height Reduction – Breadth Topic

Chiller Plant Analysis

Conclusion

Questions?