

Technical Report Two

Building, Plant Energy and Emission Analysis Report

10/19/2011

New Castle Center for Delaware Hospice, Inc.



New Castle, DE

Image By: Skanska

Zachary Klixbull

Penn State University

Architectural Engineering

Advisor: Professor Bahnfleth

Mechanical Option

October 19,
2011

Zachary Klixbull
Mechanical Option

TECHICAL REPORT TWO

DE Hospice

Advisor: Professor Bahnfleth

Table of Contents

Executive Summary	3
Mechanical System Overview	3
Design Load Estimation	4
Energy Modeling Program Selection.....	4
Assumptions.....	5
Design Conditions	5
Load Sources and Scheduling.....	14
Annual Energy Consumption and Operations	15
Annual Energy Consumption.....	15
Energy Cost	16
Annual Emission Footprint.....	17
Conclusion	17

October 19,
2011

Zachary Klixbull

Mechanical Option

TECHICAL REPORT TWO

DE Hospice

Advisor: Professor Bahnfleth

Executive Summary

The purpose of this report is to see if New Castle Center for Delaware Hospice is compliance with ASHREA Standard 62.1-2007 and Standard 90.1-2007. New Castle Center for Delaware Hospice is a two story building of 65,000 SF medical and administration. Image 1 (page 4) shows the location of the site for Google maps. Throughout the report New Castle Center for Delaware Hospice may show as DE Hospice to shorten the name. The DE Hospice is divided into two buildings connected by a Lobby area. Building A is a one story building with the main entrance and patient area facilities for the DE Hospice. The support services and administration are in the two story building B. Building A has patient rooms open to an outside patio and a courtyard for the inner patient rooms. DE Hospice has aluminum curtain wall systems with manufactured stone for the lower part of the exterior wall for the first floor and manufactured stone for some exterior walls. The manufactured stone is also used chimney on the East side of building B. The building is topped with asphalt shingles on the gable roof and cupolas. Windows are cladwood windows with louvers for shading.

The first part of this report is to model the design load estimation in an energy modeling program. In this report Trane Trace 700 was used. In the design load estimation and OA ventilation rates are based on data from design documents. In the second part of this report the model is use for annual energy consumption and operating costs.

Mechanical System Overview

The DE Hospice is a geothermal based mechanical cooling and heating system. The geothermal wells are under the east parking lot and in to the mechanical room in the basement. Then it is piped up to the attic where heat pump units and energy recovery units are. The water to water geothermal heat pump exchanges the energy from 20% glycol source to the R410A refrigerant. The refrigerant goes to heat pump units throughout the attic and the three ventilation heat pumps. The mechanical system does use two energy recover units that are located in the attic with the heat pumps. There are eight mechanical rooms in the attic. One mechanical room in the attic is not in line with an energy recovery unit or ventilation heat pump unit, it receives outside air directly to a regular heat pump. (see ASHREA Standard 62.1-2007 section 6 and appendix for more information on the mechanical ventilation)

October 19,
2011

Zachary Klixbull
Mechanical Option

DE Hospice

Advisor: Professor Bahnfleth




Image 1: A is the location of site, Image by maps.google.com

Design Load Estimation

Energy Modeling Program Selection

For technical report two of the DE Hospice building, I used Trance Trace for modeling of the building. I chose Trane Trace because I have used it in the past for modeling design loads.

October 19,
2011

Zachary Klixbull

DE Hospice

Mechanical Option

Advisor: Professor Bahnfleth

Assumptions

Building spaces and elements are simplified into block loads.

Design Conditions

The weather data for the DE Hospice building was selected for the Wilmington, Delaware, the closest city on the weather date list of cities. A template for ten typical rooms' types was made for trace 700 modeling (Table 1. Internal Load and Table 2 Construction elements). The tenth typical room template is storage, which there are little information to show on it. Table 2 was used for the all of the building's envelope. The rooms are zoned into eight zones (see Fig. 1-8) Zones 2,3, and 4 are mostly hospice areas and zones 1,5,6,7, and 8 are more offices.

Table 1. Internal Load

Space Type	Density(ft ² /pp)	Internal Load			
		Sensible (Btu/h)	Latent (Btu/h)	Lighting (W/ft ²)	Ventilation (cfm/pp) or (cfm/ft ²)
Conference	20	245	155	1.3	20 pp
Corridor	0	250	250	1.4	.05 ft ²
Dinning	10	275	275	1.4	20 pp
Gen. Hospice Areas	100	250	200	1.0	15pp
Kitchen	75	250	250	1.4	7.5 pp
Lobby	17	250	250	1.4	15 pp
Office	143	250	200	1.1	20 pp
Patient Room	100	250	200	1	25 pp
Restroom	0	250	250	0.7	50 pp

October 19,
2011

Zachary Klixbull

Mechanical Option

TECHICAL REPORT TWO

DE Hospice

Advisor: Professor Bahnfleth

Table 2. Construction elements

Construction	Description	90.1 Zone 4		Building		Complies
		U Max	R Min	U- Factor	R- Value	
Roof	Insulation Entirely above Deck	0.048	20	0.020	49	Yes
Walls	Mass	0.104	9.5	0.067	15	Yes
Floors	Mass	0.087	8.3	0.087	8.3	Yes
Fenestration		U Max	SHGC Max	U- Factor	SHGC	
Metal Framing	Windows	0.55	0.4	0.28	0.40	Yes
Metal Framing	Doors	0.85	0.4	0.28	0.40	Yes

October 19,
2011

Zachary Klixbull

DE Hospice

Mechanical Option

Advisor: Professor Bahnfleth



Fig 1: Zone1

TECHICAL REPORT TWO

October 19,
2011

Zachary Klixbull

DE Hospice

Mechanical Option

Advisor: Professor Bahnfleth




Fig. 2 Zone 2

October 19,
2011

Zachary Klixbull

DE Hospice

Mechanical Option

Advisor: Professor Bahnfleth




Fig. 3. Zone 3

TECHICAL REPORT TWO

October 19,
2011

Zachary Klixbull

DE Hospice

Mechanical Option

Advisor: Professor Bahnfleth




Fig. 4 Zone 4

October 19,
2011

Zachary Klixbull

DE Hospice

Mechanical Option

Advisor: Professor Bahnfleth



Fig. 5 from left to right Zone 5, Zone 6

October 19,
2011

Zachary Klixbull
Mechanical Option

TECHICAL REPORT TWO

DE Hospice

Advisor: Professor Bahnfleth



Fig. 6 from left to right Zone 5, Zone 6

October 19,
2011

Zachary Klixbull
Mechanical Option

TECHICAL REPORT TWO

DE Hospice

Advisor: Professor Bahnfleth



Fig. 7 from left to right Zone 7, Zone 8

October 19,
2011

Zachary Klixbull
Mechanical Option

DE Hospice

Advisor: Professor Bahnfleth



Fig. 8 from left to right Zone 7, Zone 8

Load Sources and Scheduling

The building being a hospice and offices, I used a hospital typical scheduling for building A and an office typical scheduling for building B. Building A is zones 2-4 and Building B is zone 1, 5-8.

October 19,
2011

Zachary Klixbull

DE Hospice

Mechanical Option

Advisor: Professor Bahnfleth

Annual Energy Consumption and Operating Costs

The annual energy consumption was calculated with Trane Trace 700, the same for the load calculations.

Annual Energy Consumption

In Table 4 (Annual Energy Consumption), the energy for the building for the year is separated into load types, energy usage, and percentage of total energy. Table 4 shows that the highest percentages of total energy used in a year are the supply fans and the lighting. The ground source heat pump of the building has appeared to lower the typical high heating load on a typical building. The building being driven by the schedule of the hospice has increase the lighting load. A place for improvement will be replace some of the supply fan where the load is not driven by OA with chilled beams.

Table 4. Annual Energy Consumption

Annual Energy Consumption			
Load	Electricity (kWh)	Natural Gas (kWh)	Percent of Total Energy (%)
Heating		21,765	1.5%
Cooling	158,997		11.2%
Supply Fans	448,844		31.7%
Pumps	257,923		18.2%
Lighting	438,502		31%
Receptacle	88,126		6.2%

Total: 1,414,156 kWh

In Graph 1 and 2 below, it shows that the summer is the peak of cost for the building. With the heating load being 1.5% compare to cooling load this is expected.

October 19,
2011


Zachary Klixbull
Mechanical Option

TECHICAL REPORT TWO

DE Hospice


Advisor: Professor Bahnfleth

Graph 1. Monthly Energy Consumption



Energy Costs

Graph 2. Monthly Energy Cost



October 19,
2011

Zachary Klixbull

Mechanical Option

TECHICAL REPORT TWO

DE Hospice

Advisor: Professor Bahnfleth

Annual Emissions Footprint

Table 5 (Environment Impact Analysis) was calculated using Trane Trace 700.

Table 5 Environment Impact Analysis

Environmental Impact Analysis	
CO2	2,550,780 lbm/year
SO2	13,935 gm/year
NOX	4,274 gm/year

Conclusion

The building types are split into hospice and low-rise office buildings. After review of report this report and results of Trane Trace 700 modeling program, the data since to be skew to a cooling load profile and less of a heating load profile, which is typical in North America. My setting in Trane Trace 700 is off, farther view and reading is need to find the mistake in the trace modeling programs setting.