

ENVIROCENTER PHASE II

JESSUP, MD




PENN STATE AE SENIOR THESIS PROJECT
CHRIS LORENZ | MECHANICAL | DR. BAHNFLETH ADVISOR



ENVIROCENTER PHASE II

JESSUP, MD

- INTRODUCTION
- GOALS
- DISPLACEMENT VENTILATION
- RADIANT COOLING
- STRUCTURAL BREADTH
- CONCLUSION
- QUESTIONS



PENN STATE AE SENIOR THESIS PROJECT
CHRIS LORENZ | MECHANICAL | DR. BAHNFLETH ADVISOR



PRESENTATION OUTLINE

SLIDE 3

- INTRODUCTION

- **BUILDING INFORMATION**
- MECHANICAL SYSTEM
- GOALS
- DISPLACEMENT VENTILATION
- RADIANT COOLING
- STRUCTURAL BREADTH
- CONCLUSION
- QUESTIONS

BUILDING INFORMATION

SIZE: 24,000 SF

OCCUPANCY: Office Space


TEAM

ARCHITECT – ASG, Inc.

MEP ENGINEERING – JDB Engineering

STRUCTURAL ENGINEERING – JDB Engineering

CONTRACTOR – Forrester Construction



CHRISTOPHER LORENZ

ENVIROCENTER PHASE II

MECHANICAL

PRESENTATION OUTLINE

SLIDE 4

- **INTRODUCTION**

 - **BUILDING INFORMATION**

 - MECHANICAL SYSTEM

- GOALS

- DISPLACEMENT VENTILATION

- RADIANT COOLING

- STRUCTURAL BREADTH

- CONCLUSION

- QUESTIONS


BUILDING INFORMATION

ENVIRONMENTAL GOALS

Environmentally conscious tenants

Numerous sustainability features

LEED Platinum certification



CHRISTOPHER LORENZ

ENVIROCENTER PHASE II

MECHANICAL

- **INTRODUCTION**

- BUILDING INFORMATION

- **MECHANICAL SYSTEM**

- GOALS

- DISPLACEMENT VENTILATION

- RADIANT COOLING

- STRUCTURAL BREADTH

- CONCLUSION

- QUESTIONS

WATERSIDE

- Two Reversible Water-to-Water Heat Pumps

- One Main Cooling Coil

- Hot water to terminal units

- Hot water to radiant slabs and mass wall

AIRSIDE

- 13,500 CFM VAV with terminal reheat

- Earth Tubes for free pretreating



PRESENTATION OUTLINE


SLIDE 6

- INTRODUCTION
- **GOALS**
- DISPLACEMENT VENTILATION
- RADIANT COOLING
- STRUCTURAL BREADTH
- CONCLUSION
- QUESTIONS

GOALS

SYSTEM REDESIGNS

- Replace airside cooling with radiant cooling
- Replace mixing ventilation with displacement ventilation
- Evaluate changes based on changing loads



CHRISTOPHER LORENZ

ENVIROCENTER PHASE II

MECHANICAL

PRESENTATION OUTLINE

SLIDE 7

- INTRODUCTION
- GOALS
- **DISPLACEMENT VENTILATION**
 - **INTRO**
 - IMPACT
 - HUMIDITY CONTROL
- RADIANT COOLING
- STRUCTURAL BREADTH
- CONCLUSION
- QUESTIONS

DISPLACEMENT VENTILATION


Earth tubes pretreat air

- Design OA @ 97 ° F cooled to 67 ° F
- Design OA @ 11 ° F warmed to 37 ° F

Desiccant dehumidifies warm, humid air

Cooling coil cools AIR TO 65 ° F

Heating coil heats air to 70 ° F



- INTRODUCTION
- GOALS
- **DISPLACEMENT VENTILATION**
 - INTRO
 - **IMPACT**
 - HUMIDITY CONTROL
- RADIANT COOLING
- STRUCTURAL BREADTH
- CONCLUSION
- QUESTIONS

- Provides 100% Outside Air at minimum ventilation levels
- 75% reduction in supplied Air,
- Over 90% reduction in fan power
- Supplied closer to room temperature reducing coil load
 - 70° F vs. 75° F
 - 65 ° F vs. 55° F

COIL LOAD (BTU/HR-CFM)			
	VAV	DV	%RED.
HEATING	41	30	26
COOLING	13	2	84



PRESENTATION OUTLINE

SLIDE 9

- INTRODUCTION
- GOALS
- **DISPLACEMENT VENTILATION**
 - INTRO
 - IMPACT
 - **HUMIDITY CONTROL**
- RADIANT COOLING
- STRUCTURAL BREADTH
- CONCLUSION
- QUESTIONS

HUMIDITY CONTROL

LOW FLOW DESICCANT DEHUMIDIFICATION

- Experimental Technology (DOE, NREL)
- Air flows over thin film of liquid desiccant (44% LiBr)
- Desiccant is recharged by hot air flowing over regenerator
- Return water usable for conditioning
- Small electric water heater for regen, 5kW




IMAGE COURTESY OF NREL



CHRISTOPHER LORENZ

ENVIROCENTER PHASE II

MECHANICAL

PRESENTATION OUTLINE


SLIDE 10

- INTRODUCTION
- GOALS
- **DISPLACEMENT VENTILATION**
 - INTRO
 - IMPACT
 - **HUMIDITY CONTROL**
- RADIANT COOLING
- STRUCTURAL BREADTH
- CONCLUSION
- QUESTIONS

HUMIDITY CONTROL

LOW FLOW DESICCANT DEHUMIDIFICATION

- Capable of high levels of dehumidification per input energy
 - Input: 6000 CFM 95°F DB, 76°F WB (1)
 - Output: 92°F DB, 66°F WB, dewpoint = 49°F (2)
 - 196 MBH latent cooling
- Latent Load = 25 MBH



CHRISTOPHER LORENZ

ENVIROCENTER PHASE II

MECHANICAL

- INTRODUCTION
- GOALS
- DISPLACEMENT VENTILATION
- **RADIANT COOLING**
 - **INTRO**
 - IMPACT
- STRUCTURAL BREADTH
- CONCLUSION
- QUESTIONS

- Sensible Loads only
- Energy Efficient
- Architecturally Pleasing




IMAGE COURTESY OF PRICE INDUSTRIES



PRESENTATION OUTLINE

SLIDE 12

- INTRODUCTION
- GOALS
- DISPLACEMENT VENTILATION
- **RADIANT COOLING**
 - **INTRO**
 - IMPACT
- STRUCTURAL BREADTH
- CONCLUSION
- QUESTIONS

RADIANT COOLING

METHOD

- Account for DV sensible cooling
- Select Square Footage of CSA required for each zone

ZONE	ROOM SENSIBLE LOAD (BTUH)	DV RATE (CFM)	VENT COOLING (BTUH)	CSA LOAD (BTUH)
110	3291	310	1252.4	2038.6
120	2551	250	1010	1541
121	2041	220	888.8	1152.2
130	5091	570	2302.8	2788.2
210	3875	360	1454.4	2420.6
220	3061	420	1696.8	1364.2
221	3571	390	1575.6	1995.4
230	2041	240	969.6	1071.4
231	2551	280	1131.2	1419.8
310	4600	360	1454.4	3145.6
320	6632	220	888.8	5743.2



PRESENTATION OUTLINE

SLIDE 13

RADIANT COOLING

- INTRODUCTION
- GOALS
- DISPLACEMENT VENTILATION
- **RADIANT COOLING**
 - INTRO
 - **IMPACT**
- STRUCTURAL BREADTH
- CONCLUSION
- QUESTIONS

- Fewer GPM required.
Less Head Loss than VAV system (Heating)
- Less Energy Spent Chilling Water
- Less Coil Load
Chilled Sail = Zone Level Cooling Coil

	GPM	HEAD LOSS (FT)
VAV	46	28.4
CSA	30	24.8
% RED.	34.8%	12.7%

COOLING CAPACITY				
	T1 (°F)	T2 (°F)	Q (GPM)	q (MBH)
VAV	90	45	26	583
CSA	90	55	30	522
% RED.				10.4%




PRESENTATION OUTLINE

SLIDE 14

- INTRODUCTION
- GOALS
- DISPLACEMENT VENTILATION
- RADIANT COOLING
- **STRUCTURAL BREADTH**
 - **INTRO**
 - RESULTS
- CONCLUSION
- QUESTIONS

STRUCTURAL BREADTH

- Check Structure For Added Load
- 2 Beams, and 1 Girder
- Chosen as Worst Case Beams
- Check Maximum Moment, Shear, & Deflection



PLANS COURTESY OF JDB ENGINEERING



PRESENTATION OUTLINE

SLIDE 15

- INTRODUCTION
- GOALS
- DISPLACEMENT VENTILATION
- RADIANT COOLING
- **STRUCTURAL BREADTH**
 - INTRO
 - **RESULTS**
- CONCLUSION
- QUESTIONS

STRUCTURAL BREADTH

- After Adding Load, All Members Still Met Moment, Shear And Live Load Deflection Requirements
- Beam 2 Deflected Too Much Under Total Load
 - Required Moment of Inertia of $I \geq 226 \text{ in}^4$
 - Upsized Beam 2 to W14x26, $I = 245 \text{ in}^4$
 - Extra Depth Still Keeps Enough Ceiling Space

	Beam 1 W12x22	Beam 2 W12x26	Girder 1 W18x46
ϕM_p (ft-kip)	110	140	294
M_u (ft-kip)	73	78	215

ϕV_n (kip)	95.9	84	169
V_u (kip)	15.7	13.2	44.5

Max Allowable Δ (LL)	0.6166	0.7833	0.7583
Max Δ (LL)	0.3129	0.406	0.7338

Max Allowable Δ (TL)	0.925	1.175	1.1375
Max Δ (TL)	0.7189	1.2992	0.9144




PRESENTATION OUTLINE

SLIDE 16

- INTRODUCTION
- GOALS
- DISPLACEMENT VENTILATION
- RADIANT COOLING
- STRUCTURAL BREADTH
- **CONCLUSION**
- QUESTIONS

CONCLUSION

- 10% Reduction in Cooling Energy
- 25% Reduction in Heating Coil Load
- 75% Reduction in Air Flow
- Dehumidification technique may not be feasible
- Implementation would require an upgraded structure



CHRISTOPHER LORENZ

ENVIROCENTER PHASE II

MECHANICAL

PRESENTATION OUTLINE

SLIDE 17

- INTRODUCTION
- GOALS
- DISPLACEMENT VENTILATION
- RADIANT COOLING
- STRUCTURAL BREADTH
- CONCLUSION
- QUESTIONS


ACKNOWLEDGEMENTS

- Dr. William Bahnfleth
- Dr. James Freihaut
- Dr. Stephen Treado
- Dr. Moses Ling
- Tim Warren : JDB Engineering
- Stan Sersen : Owner / ASG, Inc.
- Family & Friends



CHRISTOPHER LORENZ

ENVIROCENTER PHASE II



MECHANICAL

PRESENTATION OUTLINE

SLIDE 18

- INTRODUCTION
- GOALS
- DISPLACEMENT VENTILATION
- RADIANT COOLING
- STRUCTURAL BREADTH
- CONCLUSION
- **QUESTIONS**


THANK YOU

ANY QUESTIONS?



CHRISTOPHER LORENZ

ENVIROCENTER PHASE II



MECHANICAL