

# NRUCFC Headquarters Building

Sterling, VA



**Architectural Engineering Senior Thesis**

Margaret McNamara | Mechanical Option

Advisor | Dr. Stephen Treado



## Introduction

### Project Overview

Systems Overview

Existing Mechanical System

Depth 1 | DOAS w. Chilled Beams

Depth 2 | Hybrid PVT Solar System

Breadth 1 | Electrical

Breadth 2 | Architectural

Conclusion

Acknowledgements

Questions





## Introduction

Project Overview

**Systems Overview**

Existing Mechanical System

Depth 1 | DOAS w. Chilled Beams

Depth 2 | Hybrid PVT Solar System

Breadth 1 | Electrical

Breadth 2 | Architectural

Conclusion

Acknowledgements

Questions





## Introduction

Project Overview

Systems Overview

**Existing Mechanical System**

Depth 1 | DOAS w. Chilled Beams

Depth 2 | Hybrid PVT Solar System

Breadth 1 | Electrical

Breadth 2 | Architectural

Conclusion

Acknowledgements

Questions





## Introduction

Project Overview

Systems Overview

Existing Mechanical System

**Depth 1 | DOAS w. Chilled Beams**

Depth 2 | Hybrid PVT Solar System

Breadth 1 | Electrical

Breadth 2 | Architectural

Conclusion

Acknowledgements

Questions





## Introduction

Project Overview

Systems Overview

Existing Mechanical System

Depth 1 | DOAS w. Chilled Beams

**Depth 2 | Hybrid PVT Solar System**

Breadth 1 | Electrical

Breadth 2 | Architectural

Conclusion

Acknowledgements

Questions





## Introduction

Project Overview

Systems Overview

Existing Mechanical System

Depth 1 | DOAS w. Chilled Beams

Depth 2 | Hybrid PVT Solar System

**Breadth 1 | Electrical**

Breadth 2 | Architectural

Conclusion

Acknowledgements

Questions





## Introduction

Project Overview

Systems Overview

Existing Mechanical System

Depth 1 | DOAS w. Chilled Beams

Depth 2 | Hybrid PVT Solar System

Breadth 1 | Electrical

**Breadth 2 | Architectural**

Conclusion

Acknowledgements

Questions







## Introduction

Project Overview

Systems Overview

Existing Mechanical System

Depth 1 | DOAS w. Chilled Beams

Depth 2 | Hybrid PVT Solar System

Breadth 1 | Electrical

Breadth 2 | Architectural

**Conclusion**

Acknowledgements

Questions





## Introduction

Project Overview

Systems Overview

Existing Mechanical System

Depth 1 | DOAS w. Chilled Beams

Depth 2 | Hybrid PVT Solar System

Breadth 1 | Electrical

Breadth 2 | Architectural

Conclusion

**Acknowledgements**

Questions





## Introduction

Project Overview

Systems Overview

Existing Mechanical System

Depth 1 | DOAS w. Chilled Beams

Depth 2 | Hybrid PVT Solar System

Breadth 1 | Electrical

Breadth 2 | Architectural

Conclusion

Acknowledgements

**Questions**



**Project Overview**

**Building Type** | Office Building

**Size** | 120,000 GSF

**Number of Stories** | 3 above grade

**Construction Dates** | Nov. 2009-Sept. 2011

**Project Cost** | \$45 million

**Project Delivery Method** | Design-Bid-Build



**Location | Sterling, VA**

**Project Team**

**Architect** | Kishimoto.Gordon.Dalaya PC

**Interior Architect** | Fox Architects

**Landscape Architect** | EDAW

**Site/Civil Engineers** | Dewberry

**Structural Engineers** | SK&A

**MEP Engineers** | WSP Flack + Kurtz

**LEED Consultants** | Sustainable Design Consulting

**General Contractor** | Whiting-Turner

## Electrical/Lighting System

**Generators** | Two pad-mounted 600kW generators serve emergency power and required standby service

**Microturbines** | Two 65 kW microturbines serve data center

**Lighting** | Daylight sensors and occupancy sensors control the lighting

## Architecture



## Structural System

**Foundation** | Combination of isolated columns and strip wall footings with a 5" slab-on grade

**Frame** | Steel Frame that utilizes composite beams and slabs

**Atrium** | Arched trusses made of HSS members form atrium dome with an oculus

### Air Side Summary

**Four Rooftop AHUs** | 18,000-24,000 CFM


**Fan Powered Boxes** | Perimeter Heating and Cooling

**VAV Boxes** | Interior Heating and Cooling

### Atrium Heating and Cooling

**Ground Source Heat Pumps**

**Radiant Flooring**



### Water Side Summary

**Cooling** | Two 210 ton electric centrifugal chillers  
located in first floor central plant

**Heating** | Two high efficiency natural gas boilers  
located in the penthouse


## Depth 1 | DOAS with Chilled Beams

### Redesign Proposal

- Replace four existing AHUs with DOAS unit
- Replace VAVs and FPBs with Chilled Beams

### Redesign Goal

- Reduce energy consumption
- Reduce airflow



Active Chilled Beams (ACBs)

### Active Chilled Beams Advantages

- Uses less air and allows for smaller duct work and AHUs
- Lower floor to floor height
- Requires minimum maintenance
- Reduces energy consumption

### Active Chilled Beam Disadvantages

- Higher initial cost
- Larger than tradition diffuser
- Sensitive to humidity

## Depth 1 | DOAS with Chilled Beams

### DOAS w. ACBs Design Conditions

	Supply Air	Outdoor Air	Space Design
T <sub>DB</sub> (F°)	64	93.2	75.2
Humidity (Grains)	44	154	65.7
Dew Point (F°)	45	-	-

CHW Supply | 57 °F | 1 gpm


### Chilled Beam Sizing and Selection

Latent and Sensible Load from TraneTRACE

ASHRAE Standard 62.1 | Ventilation Requirements

Ventilation Requirements to meet Latent Load

ExSel Air Chilled Beam Calculator



SEMCO IQID Series

### Chilled Beam Summary

Model	Quantity	Length	Total Cost
IQIC-4	85	4'	\$ 72,250.00
IQIC-6	98	6'	\$ 93,100.00
IQIC-8	68	8'	\$ 71,400.00
<b>Total</b>	<b>251</b>		<b>\$ 236,750.00</b>




## Depth 1 | DOAS with Chilled Beams

### DOAS Unit Selection

40,000 CFM


### SEMCO Pinnacle System (PVS)




### PVS Advantages

- Total Energy Wheel & Passive Dehumidification Wheel
- Delivers low dew points
- Provides high levels of OA and controls humidity
- Large latent load capacity


# Depth 1 | DOAS with Chilled Beams



PVS Cooling Mode



PVS Unoccupied Mode




PVS Heating Mode

## Depth 1 | DOAS with Chilled Beams

### First Cost Comparison

Existing System				
Quantity	Item	Equipment	Installation	Total
132	VAV/FPB Boxes	\$ 56,628.00	\$ 24,507.00	\$ 81,135.00
4	AHUs	\$ 700,000.00	\$ 48,000.00	\$ 748,000.00
			<b>Total</b>	<b>\$ 748,000.00</b>
Redesigned System				
251	Chilled Beams	\$ 236,750.00	\$ 32,881.00	\$ 269,631.00
1	Pinnacle DOAS Unit	\$ 278,874.00	\$ 18,000.00	\$ 296,874.00
			<b>Total</b>	<b>\$ 566,505.00</b>

### Energy Consumption Comparison



### Cost Savings


First Cost Savings	\$ 181,495.00
Utility Cost Savings	\$ 24,727.03
<b>Total</b>	<b>\$ 206,222.03</b>

## Depth 2 | Hybrid Photovoltaic/Thermal (PVT) Solar System

### Redesign Proposal and Goals

- Add hybrid PVT Collectors to the roof
- Produce heat and electricity from solar radiation

### PVTWINS Schematic Liquid Collector



### Advantages

- More efficient than traditional PV modules
- One unit instead of two | Installation, Materials, Energy

### Disadvantages

- Not used frequently
- Costly and little to no incentives

## Depth 2 | Hybrid Photovoltaic/Thermal (PVT) Solar System

### Design Information

# of Collectors | 10 Collectors

Area | 6.4 m<sup>2</sup> each collector

Tilt | 40°

PVTWIN Series 1025 | PVT Liquid Collector



### Solar Thermal Energy Output

Month	Solar Radiation (kWh/m <sup>2</sup> /day)	Energy Output (kWh)	Therms	Cost
January	3.59	4825.0	164.6	\$ 189.33
February	4.28	5752.3	196.3	\$ 225.72
March	4.80	6451.2	220.1	\$ 253.14
April	5.32	7150.1	244.0	\$ 280.57
May	5.52	7407.0	254.2	\$ 298.50
June	5.66	7607.0	259.6	\$ 287.95
July	5.46	7338.2	250.4	\$ 230.99
August	4.38	5886.7	200.9	\$ 267.38
September	5.07	6814.1	232.5	\$ 248.92
October	4.72	6343.7	216.5	\$ 187.75
November	3.56	4784.6	163.3	\$ 159.80
December	3.03	4072.3	139.0	
<b>Total Savings</b>				<b>\$ 2,911.66</b>

**Total Solar Thermal Savings | \$2,911.66**

## Depth 2 | Hybrid Photovoltaic/Thermal (PVT) Solar System

### Cost Summary

**Total Collector Cost | \$98,350**

**Total PVT Savings | \$7,544**

**Simple Payback | 13 Years**

**PVTWIN Series 1025 | PVT Liquid Collector**



### Solar Thermal Energy Output

Month	Solar Radiation (kWh/m <sup>2</sup> /day)	Energy Output (kWh)	Therms	Cost
January	3.59	4825.0	164.6	\$ 189.33
February	4.28	5752.3	196.3	\$ 225.72
March	4.80	6451.2	220.1	\$ 253.14
April	5.32	7150.1	244.0	\$ 280.57
May	5.52	7407.0	254.2	\$ 305.06
June	5.66	7607.0	259.6	\$ 298.50
July	5.46	7338.2	250.4	\$ 287.95
August	4.38	5886.7	200.9	\$ 230.99
September	5.07	6814.1	232.5	\$ 267.38
October	4.72	6343.7	216.5	\$ 248.92
November	3.56	4784.6	163.3	\$ 187.75
December	3.03	4072.3	139.0	\$ 159.80
<b>Total Savings</b>				<b>\$ 2,911.66</b>

**Total Solar Thermal Savings | \$2,911.66**

# Breadth 1 | Electrical

## Redesign Goals

- Condense Panel Boards | Remove FPBs
- Electrical Production of PVT Collectors

### Condense Panel Boards

### New Feeder Size

(4) #4 + (1) #8 G. in 1-1/4" C. [Type THHN/THWN]

BRANCH CIRCUIT PANELBOARD SCHEDULE													
PANEL: RP-1C-C		MOUNTING	SURFACE	X	MAIN LUGS ONLY		AMP MAIN CB		100				
277/480V, 3 PHASE, 4 WIRE		FLUSH			SHUNT TRIP MAIN		AMPS LB		100				
10,000 A.I.C. SYM		IN MCC			FEED THRU LUG		GROUND BUS		X				
NEUTRAL: 100%		NUMBER OF POLES		4E	ISOLATED GROUND BUS:								
CKT NO.	LOAD	TRIP (AMP)	KW/PHASE			POLES			TRIP (AMP)			CKT NO.	
1			A	B	C	A	B	C	A	B	C	2	
3	HP-1-1	20		2.80		3	3	1.20				TRANSFORMER FOR RP-1C-E	4
5			2.80				1.20	1.20					6
7			2.80					2.80					
9	HP-1-2	20		2.80		3	3	2.80				HP-2-1	10
11			2.80				2.80	2.80					12
13			2.80					2.80					
15	HP-1-3	20		2.80		3	3	2.80				HP-2-2	16
17			2.80				2.80	2.80					18
19			2.80					2.80					
21	HP-3-1	20		2.80		3	3	2.80				HP-3-2	22
23			2.80				2.80						24
25			2.80					2.80					
27												28	
29												30	
31												32	
33												34	
35												36	
37												38	
39												40	
41												42	
SUBTOTALS			11.20	11.20	11.20			9.60	9.60	9.60	SUBTOTALS		
TOTAL LOADS (KVA)			20.80	PHASE A									
			20.80	PHASE B									
			20.80	PHASE C									
TOTAL CONN. LOAD			62.40	KVA									

$$A = \frac{VA}{V} = \frac{62.4 \text{ kVA}}{\sqrt{3} * 480V} * 1000 = 75 \text{ Amps}$$

## Breadth 1 | Electrical

### Redesign Goals


Condense Panel Boards | Remove FPBs

Electrical Production of PVT Collectors

### PVT Collector Electric Energy Output


Month	Solar Radiation (kWh/m <sup>2</sup> /day)	AC Energy (kWh)	Energy Value (\$)
January	3.59	4,164	\$ 333.12
February	4.28	4,370	\$ 349.60
March	4.80	5,278	\$ 422.24
April	5.34	5,457	\$ 436.56
May	5.32	5,328	\$ 426.24
June	5.66	5,495	\$ 439.60
July	5.46	5,354	\$ 428.32
August	4.38	5,369	\$ 429.52
September	5.07	5,004	\$ 400.32
October	4.72	4,967	\$ 397.36
November	3.56	3,767	\$ 301.36
December	3.03	3,354	\$ 268.32
<b>Total</b>		<b>57,907</b>	<b>\$ 4,632.56</b>

### PV Schematic





## Conclusion



### Depth 1 | DOAS w. Chilled Beams

**Total Savings** | \$206,222.03

**Simple Payback** | 4 years


**Recommendations**

### Depth 2 | Hybrid PVT Solar System

**Total Savings** | \$7,544.22

**Simple Payback** | 13 years

**Recommendations**



## Acknowledgements

### **Penn State University Architectural Engineering Faculty**

Dr. Stephen Treado | Thesis Advisor

Robert Holland | Course Coordinators

M. Kevin Parfitt | Course Coordinators

### **National Rural Utilities Cooperative Finance Corporation**

John L. Moone CPM, CFM

### **Industry Professionals**

Darren Bruce, PE, LEED AP BD+C | Sebesta Blomberg

Trevor Boz, LEED AP | WSP Flack+Kurtz

Alexandra Parris | KGD Architecture

### **Penn State AE Class of 2012**

### **Friends & Family**



**Thank you!**  
**Questions?**

