

# Technical Report Two

Building and Plant Energy Analysis Report

**National Rural Utilities Cooperative  
Finance Corporation (NRUCFC)  
Headquarters Building  
Sterling, VA**



Prepared by | Margaret McNamara | Mechanical  
Advisor | Dr. Stephen Treado  
10.26.2011

## Table of Contents

Executive Summary.....	3
Mechanical Systems Overview .....	4
Design Load Estimation.....	5
Block Assumptions.....	5
Weather Data.....	5
Occupancy.....	5
Lighting Loads .....	5
Electrical Loads.....	5
Ventilation.....	5
Wall Construction .....	5
Schedules .....	6
System Load Analysis Results.....	6
Annual Energy Consumption and Operating Costs.....	7
Energy Consumption.....	7
Building Energy Costs.....	8
Monthly Utility Costs .....	8
Annual Energy Costs .....	9
Building Emission Rates .....	9
Resources.....	10
Appendix A   TRANE Trace Templates.....	11
Appendix B   CBECS Energy Consumption Tables .....	14
Appendix C   Emission Factor Data.....	16

## Executive Summary

The purpose of Technical Assignment Two is to perform a block load and energy use estimate of the National Rural Utilities Cooperative Finance (NRUCFC) Headquarters Building using a computer-based method. The new headquarters building is 120,000 square foot office building that will also house a fitness center, café, and executive lounge. The three-story above grade building is located on a 42-acre lot in Sterling, VA, about 10 miles north of the Dulles International Airport, at the intersection of Route 28 & 7. The headquarters is LEED® Gold certified.

To determine the loads and the energy use of the building, TRANE Trace 700 was used. A block load method was used to determine both the loads and energy consumption. The building loads were compared to ASHRAE Pocket Guide values and were found to be much lower than the standard's values. The large difference is believed to be because of errors in modeling the systems as they are designed and because block load method was used as opposed to a space-by-space method, which would have been more accurate.

Using the same model, energy consumption, operating costs and emissions were calculated. The calculated values were compared to national average of buildings with similar square footage and function. The electrical consumption exceeded the national average while the natural gas consumption was roughly half the national average.

## Mechanical Systems Overview

### Primary Cooling

Two 210 ton electric centrifugal chillers are located in the first floor central plant. They incorporate oil-free compressors to increase part-load efficiency. Six “ice on coil” storage tanks will circulate 25% ethylene glycol solution through the chillers. Two induced draft cooling towers are located on the roof. The central plant and piping has been configured to allow for future expansion and serve as the central plant for other buildings.

### Primary Heating

Two high efficiency natural gas-fired condensing boilers are located in the mechanical penthouse and serve as the primary heating source. They will circulate water to the terminal units with a hot water heat feature. The heating plant is also configured for future expansion.

### Atrium Heating and Cooling

A combination of radiant flooring and ventilation units serve as the heating and cooling for the three story atrium. A water to water heat pump serves the radiant flooring while three ground source heat pumps ventilate the space. Both systems are connected to the geothermal well located in the parking lot.

### Office Space Heating and Cooling

Four central air handling units, located on the roof, serve as the heating and cooling for the office spaces, supplying to the zones shown in Figure 1. The perimeter spaces are ventilated by fan powered boxes with a hot water coil. Interior spaces are ventilated by VAV boxes.




Figure 1 | AHU Zones

## Design Load Estimation

### Block Assumptions

#### Weather Data

Weather data from the ASHRAE Handbook of Fundamentals for Washington, D.C. was used for the load and energy simulation. The project location of Sterling, VA is approximately 30 miles from Washington D.C. and experiences similar weather conditions. Table 1 provides a summary of the weather design conditions used in the simulation.

ASHRAE Values	Outdoor DB (°F)	Outdoor WB (°F)	Design Indoor DB (°F)
Summer Design Cooling (0.4%)	93.2	75.1	75.2
Winter Design Heating (99.6%)	9.6	-	71.8

#### Occupancy

Occupancy for each space was determined from the design documents provided by the project team and therefore the ASHRAE Occupant Densities were not used.

#### Lighting Loads

Lighting loads were assumed on a Watt per square foot basis. Because of the variety in lighting fixtures used throughout the building, the lighting power densities were taken from ASHRAE Standard 90.1-2007 to simplify the model. If exact values based on the fixtures were used for each space, a more accurate model could be generated.

#### Electrical Loads

Electrical Loads were assumed on a Watt per square foot basis. For spaces with large equipment loads, a larger density was assumed.

#### Ventilation

The ventilation rates were assumed on cfm per person rate for regularly occupied spaces like offices or conference rooms or a cfm per square foot rate for spaces such as corridors and storage areas. The occupancy classifications from ASHRAE Standard 62.1-2007 were used to determine the rates for the different spaces.

#### Wall Construction

The wall type for exterior walls was generalized to save time. It was assumed that all walls were face brick, 4" light weight concrete and 6" insulation. From this TRACE output a U-factor of .0403. The walls however do vary. On the east side and part of the north and south walls are mainly brick while the west walls and the other part of the north and south walls are primarily glass with shading devices. The glazing was also assumed to be consistent throughout the building and was given an assumed U-factor of .214. The glazing percentage was assumed to be 40%, the maximum allowed by ASHRAE Standards. It was also assumed that shading devices were used on the glazing.

## Schedules

Schedules were not assigned in TRACE to be able to find the max load that the building would consume if they were to operate continuously for 24 hours.

A summary of the TRANE Trace templates with all assumptions can be found in Appendix A.

## System Load Analysis Results

Table 2 summarizes the results of the load analysis performed in TRANE Trace 700. The values of the design loads from the engineer were unknown so the results are compared to the ASHRAE Pocket Guide check figures. The calculated values are roughly four times lower than the average check figure for refrigeration. Loads for each space could have been underestimated for each piece of equipment was not accounted for within each space. The percentage of glass used for the exterior spaces was assumed and modeled as 40%, based on ASHRAE's maximum requirement, but there is more glazing used on the exterior walls but the exact value was unknown, which could have led to the discrepancy in the results. In order to get the most accurate results, each room would have to be modeled with all its design conditions and not with the block load assumptions used. Additionally, all the systems used in the NRUCFC Headquarters building were not modeled. The four main air handlers and the heat pump that serves the atrium and main lobby were modeled but the heat pump that serves the stairways and the radiant flooring in the atrium was not modeled.

<b>Table 2   System Load Results</b>			
<b>System</b>	<b>Cooling (ft<sup>2</sup>/ton)</b>	<b>Heating (BTU/h-ft<sup>2</sup>)</b>	<b>Total Supply Air (cfm/ft<sup>2</sup>)</b>
<b>AHU-1</b>	1020.88	28.78	0.80
<b>AHU-2</b>	897.80	31.80	1.06
<b>AHU-3</b>	1088.00	26.93	0.75
<b>AHU-4</b>	843.10	32.52	0.90
<b>HP-3</b>	70.40	110.84	1.77
<b>ASHRAE Guide</b>	280.00	-	1.0-1.6


## Annual Energy Consumption and Operating Costs

The annual energy consumption and operating costs were modeled using the same TRANE Trace model used for the heating and cooling loads. The cooling plant was modeled as two water cooled chillers with cooling towers for absorption chillers. The ice storage tank was neglected. The heating plant was modeled as two natural gas fired boilers. An energy analysis was performed by the design engineer using a combination of eQUEST, TRANE Trace, and Excel. The analysis was unavailable for comparison. No schedule was provided so it was assumed that everything was operating 24 hours a day, 7 days a week.

### Energy Consumption

Table 3 below shows a breakdown of energy consumption by system. Figure 1 shows the same results. The lighting and receptacle loads appear to consume the most energy annually and the cooling energy consumption appears to be larger than the heating load. The results are inaccurate. The primary heating should be the largest consumer of energy. The lighting and receptacle values could be off because they are scheduled to be 100% available when in reality the lighting would be on occupancy schedules and the receptacle load would consume the most energy during normal work hours. Also, due to unfamiliarity with the modeling software the heating and cooling plants may not be modeled as designed. Microturbines and a photovoltaic array were not modeled as part of the energy analysis. They would have led to a reduction in energy consumption for the lighting and receptacle loads.

Table 3   Energy Consumption					
System	Electric Consumption (kWh)	Gas Consumption (kBtu)	Water Consumption (1000 gallons)	Total Building Energy (kBtu/yr)	% of Total Building Energy
<b>Primary Heating</b>		<b>1,601,655</b>		<b>1,601,655</b>	<b>15.4%</b>
<b>Primary Cooling</b>	<b>504,574</b>		<b>1,616</b>	<b>1,722,111</b>	<b>16.6%</b>
Cooling Compressor	349,405			1,192,518	11.5%
Tower/Cond Fans	41,552		1,616	141,818	1.4%
Condenser Pump	104,857			357,878	3.5%
Other Clg Accessories	8,760			29,898	0.3%
<b>Auxiliary</b>	<b>98,576</b>			<b>336,439</b>	<b>3.2%</b>
Supply Fans	17,633			60,182	0.6%
Pumps	80,942			276,257	2.7%
<b>Lighting</b>	<b>891,231</b>			<b>3,041,772</b>	<b>29.3%</b>
<b>Receptacle</b>	<b>1,075,234</b>			<b>3,669,774</b>	<b>35.4%</b>
<b>Totals</b>	<b>2,569,615</b>	<b>1,601,655</b>	<b>1,616</b>	<b>10,371,751</b>	<b>100.0%</b>



**Figure 1 | Energy Consumption**


### Building Energy Costs

The energy and natural gas rates for Virginia were used and are shown in Table 4 below. The values were taken from the US Energy Information Administration because no actual utilities bills were available.

Table 4   Utility Rates	
Electricity (\$/kWh)	.0821
Natural Gas (\$/1000 ft <sup>3</sup> )	10.63

### Monthly Utility Costs

Based on the utility rates in Table 4, monthly operating costs were generated. Figure 2 below shows the monthly operating cost for both electricity and natural gas. The natural gas peaks during the winter months when the heating load is the greatest. The electric load peaks during the summer months when the cooling load is the greatest.



**Figure 2 | Monthly Utility Costs**



## Annual Energy Costs

The annual total operating cost is approximately \$229,191.44 per year and \$2.38 per square foot. The annual operating cost is higher than it should be due to modeling errors. As previously mentioned, if the additional on-site energy producing systems were modeled the utility costs would be lower both annually and monthly. Compared to Commercial Buildings Energy Consumption Survey (CBECS) tables (found in Appendix B) provided by the U.S. Energy Information Administration (EIA), the NRUCFC Headquarters building exceeds the national averages in terms of electrical energy use but is well under the average for natural gas as shown in Table 5 below.

Table 5   Energy Consumption (kBtu/ft <sup>2</sup> )	
<b>Electricity</b>	
Calculated	91.2
100,001 to 200,000 ft <sup>2</sup> Buildings	57.7
Office Buildings	58.9
<b>Gas</b>	
Calculated	16.6
100,001 to 200,000 ft <sup>2</sup> Buildings	36.5
Office Buildings	32.8

## Building Emission Rates

The emission rates for pollutants have been calculated based on the total energy consumption determined from the block load model previously discussed. The results for the NRUCFC Headquarters building pollutants can be found in Table 6 below. The emission factors were taken from tables provided by the National Renewable Energy Laboratory (NREL) which can be found in Appendix C.

Table 6   Pollution Emission Rates							
Pollutant	Electricity			Natural Gas			Total Pollutants (lbs/yr)
	Emission Factor (lb/kWh)	Electric Consumption (kWh/yr)	Electric Total (lb/yr)	Emission Factor (lb/1000 ft <sup>3</sup> )	Gas Consumption (1000 ft <sup>3</sup> /yr)	Gas Total (lbs/yr)	
CO <sub>2e</sub>	1.40E+00	2,569,615	3,597,461	1.97E+00	1,560	3,072	3,600,533
<b>CO<sub>2</sub></b>	<b>1.33E+00</b>	<b>2,569,615</b>	<b>3,417,588</b>	<b>1.96E+00</b>	<b>1,560</b>	<b>3,057</b>	<b>3,420,645</b>
CH <sub>4</sub>	2.52E-02	2,569,615	64,754	4.00E-05	1,560	0	64,754
N <sub>2</sub> O	2.81E-05	2,569,615	72	4.00E-05	1,560	0	72
<b>NO<sub>x</sub></b>	<b>2.67E-03</b>	<b>2,569,615</b>	<b>6,861</b>	<b>1.78E-03</b>	<b>1,560</b>	<b>3</b>	<b>6,864</b>
<b>SO<sub>x</sub></b>	<b>8.04E-03</b>	<b>2,569,615</b>	<b>20,660</b>	<b>1.01E-05</b>	<b>1,560</b>	<b>0</b>	<b>20,660</b>
CO	9.74E-04	2,569,615	2,503	1.50E-03	1,560	2	2,505
TNMOC	8.77E-05	2,569,615	225	9.82E-05	1,560	0	226
Lead	1.02E-07	2,569,615	0	9.01E-09	1,560	0	0
Mercury	3.24E-08	2,569,615	0	4.16E-09	1,560	0	0
<b>PM-10</b>	<b>7.25E-05</b>	<b>2,569,615</b>	<b>186</b>	<b>1.35E-04</b>	<b>1,560</b>	<b>0</b>	<b>187</b>
Solid Waste	1.47E-01	2,569,615	377,733	-	-	-	377,733

## Resources

ANSI/ASHRAE. (2007). Standard 62.1 - 2007, Ventilation for Acceptable Indoor Air Quality. Atlanta, GA: American Society of Heating Refrigeration and Air Conditioning Engineers, Inc.

ANSI/ASHRAE. (2007). Standard 90.1 - 2007, Energy Standard for Buildings Except Low-Rise Residential Buildings. Atlanta, GA: American Society of Heating Refrigeration and Air Conditioning Engineers, Inc.

ASHRAE. Handbook of Fundamentals. Atlanta: ASHRAE, 2009.

ASHRAE. Pocket Guide. Atlanta: ASHRAE, 1997.

Previous Senior Thesis Reports 2008-2010

Sebesta Blomberg. Design Documents. Sebesta Blomberg, Arlington, VA

U.S. Energy Information Administration. "Table E2A. Major Fuel Consumption (Btu) Intensities by End Use for All Buildings, 2003." 2003. U.S. Energy Information Administration - EIA - Independent Statistics and Analysis. 24 October 2010  
<[http://www.eia.doe.gov/emeu/cbecs/cbecs2003/detailed\\_tables\\_2003/2003set19/2003pdf](http://www.eia.doe.gov/emeu/cbecs/cbecs2003/detailed_tables_2003/2003set19/2003pdf)

WSP Flack + Kurtz. Mechanical Design Documents. WSP Flack + Kurtz, New York City, NY

## Appendix A | TRANE Trace Templates

Internal Load Templates - Project

Alternative: Alternative 1  
Description: OFFICE-1

People...

Type: General Office Space  
Density: 1 People  
Schedule: Available (100%)  
Sensible: 250 Btu/h  
Latent: 200 Btu/h

Workstations...

Density: 1 workstation/person

Lighting...

Type: Recessed fluorescent, not vented, 80% load to space  
Heat gain: 1.1 W/sq ft  
Schedule: Available (100%)

Miscellaneous loads...

Type: Std Office Equipment  
Energy: 0.5 W/sq ft  
Schedule: Available (100%)  
Energy meter: Electricity

Buttons: Apply, Close, New, Copy, Delete, Add Global

Internal Load | Airflow | Thermostat | Construction | Room

**Airflow Templates - Project**

Alternative: Alternative 1  
 Description: OFFICE

Main supply...  
 Cooling: To be calculated  
 Heating: To be calculated

Auxiliary supply...  
 Cooling: To be calculated  
 Heating: To be calculated

Ventilation...  
 Apply ASHRAE Std62.1-2004/2007: No  
 Type: General Office Space  
 Cooling: 5 cfm/person  
 Heating: 5 cfm/person  
 Schedule: Available (100%)

Infiltration...  
 Type: Neutral, Tight Const.  
 Cooling: 0.3 air changes/hr  
 Heating: 0.3 air changes/hr  
 Schedule: Available (100%)

Std 62.1-2004/2007...  
 Clg Ez: Ceiling clg supply, ceiling retu %  
 Htg Ez: Ceiling supply > trm+15°F(8°C) %  
 Er: Default based on system type %  
 DCV Min OA Intake: None

Room exhaust...  
 Rate: 0 air changes/hr  
 Schedule: Available (100%)

VAV minimum...  
 Rate: % Clg Airflow  
 Schedule: Available (100%)  
 Type: Default

Buttons: Apply, Close, New, Copy, Delete, Add Global

Internal Load | **Airflow** | Thermostat | Construction | Room

**Thermostat Templates - Project**

Alternative: Alternative 1  
 Description: Default

Thermostat settings...  
 Cooling dry bulb: 75.2 °F  
 Heating dry bulb: 71.8 °F  
 Relative humidity: 50 %  
 Cooling driftpoint: 81 °F  
 Heating driftpoint: 64 °F  
 Cooling schedule: None  
 Heating schedule: None

Sensor Locations...  
 Thermostat: Room  
 CO2 sensor: Room

Humidity...  
 Moisture capacitance: Medium  
 Humidistat location: Room

Buttons: Apply, Close, New, Copy, Delete, Add Global

Internal Load | Airflow | **Thermostat** | Construction | Room

Create Rooms - Single Worksheet

Alternative 1

Room description: ADMIN AREA-294

Templates...

Room: Default Floor: 133 ft Width: 1 ft

Internal: OFFICE-2 Roof: 0 ft 0 ft

Airflow: OFFICE

Tstat: Default

Constr: 2ND

Wall...

Description	Length (ft)	Height (ft)	Direction	% Glass or Qty	Length (ft)	Height (ft)	Window
	0	14	0	0	0	0	<input type="checkbox"/>
	0	14	0	0	0	0	<input type="checkbox"/>
	0	14	0	0	0	0	<input type="checkbox"/>

Internal loads...

People: 2 People

Lighting: 1.1 W/sq ft

Misc loads: 0.5 W/sq ft

Airflows...

Cooling vent: 5 cfm/person

Heating vent: 5 cfm/person

VAV minimum: % Clg Airflow

Single Sheet Rooms Roofs Walls Int Loads Airflows Partn/Floors

Create Rooms - Walls

Alternative 1

Room description: BC-3-145

Templates...

Room: Default Wall: Wall - 1 Tag: Wall - 1 Construct: Face Brick, 4" LW Concrete, 6" Ins

Internal: DATA Wall: Wall - 2 Length: 17 ft U-factor: 0.0403 Btu/h-ft<sup>2</sup>-F

Airflow: DATA Height: 17 ft Tilt: 0 deg

Tstat: Default Grnd reflect multiplier: 1 Direction: 0 deg

Constr: 1ST Pct wall area to underfloor plenum: %

Openings...

Opening - 1 Tag: Opening - 1  Window  Door

Wall area: 40 % Type: 6mm Tpl Low-E Film (44) Tint 13mm Air

Length: 0 ft Height: 0 ft Quantity: 0

U-factor: 0.214 Btu/h-ft<sup>2</sup>-F Sh. Coef: 0.22 Ld to RA: 0 %

Shading...

Internal: None

External: Combined Horz. & Vert. Fins - Sample

Single Sheet Rooms Roofs Walls Int Loads Airflows Partn/Floors

## Appendix B | CBECS Energy Consumption Tables

Released: September, 2008

**Table E7A. Natural Gas Consumption (Btu) and Energy Intensities by End Use for All Buildings, 2003**

	Total Natural Gas Consumption (trillion Btu)					Natural Gas Energy Intensity (thousand Btu/square foot)				
	Total	Space Heating	Water Heating	Cooking	Other	Total	Space Heating	Water Heating	Cooking	Other
<b>All Buildings</b> .....	2,100	1,420	348	164	168	43.3	29.3	7.2	3.4	3.5
<b>Building Floorspace (Square Feet)</b>										
1,001 to 5,000 .....	257	161	36	42	18	81.0	50.6	11.3	13.3	5.8
5,001 to 10,000 .....	224	152	33	32	7	56.5	38.3	8.4	8.1	1.7
10,001 to 25,000 .....	353	273	35	26	19	45.2	34.9	4.5	3.3	2.4
25,001 to 50,000 .....	278	202	43	14	Q	42.2	30.6	6.5	2.1	3.0
50,001 to 100,000 .....	277	192	47	14	25	36.9	25.6	6.2	1.8	3.3
100,001 to 200,000 .....	275	187	58	10	20	36.5	24.8	7.7	1.3	2.7
200,001 to 500,000 .....	211	138	44	11	17	35.8	23.4	7.5	1.9	2.9
Over 500,000 .....	224	115	52	14	42	37.5	19.3	8.7	2.4	7.0
<b>Principal Building Activity</b>										
Education .....	268	207	37	5	19	38.1	29.5	5.2	0.7	2.7
Food Sales .....	39	27	2	8	Q	51.7	35.6	3.2	11.2	Q
Food Service .....	203	54	56	91	Q	145.6	39.0	40.0	65.4	Q
Health Care .....	243	136	74	10	23	95.3	53.6	28.9	3.8	9.1
Inpatient .....	204	103	71	9	21	113.2	56.8	39.4	5.2	11.9
Outpatient .....	38	34	3	Q	Q	51.8	45.6	3.5	Q	Q
Lodging .....	215	64	124	14	Q	50.4	15.0	29.2	3.3	Q
Mercantile .....	264	188	19	24	33	33.5	23.9	2.4	3.1	4.1
Retail (Other Than Mall) .....	91	84	3	3	2	31.9	29.3	1.0	0.9	0.7
Enclosed and Strip Malls .....	172	104	16	22	31	34.4	20.9	3.1	4.3	6.1
Office .....	269	230	13	3	23	32.8	28.1	1.6	0.3	2.8
Public Assembly .....	102	92	2	3	Q	37.5	33.8	0.9	1.0	Q
Public Order and Safety .....	29	15	10	Q	Q	45.0	24.1	15.1	Q	Q
Religious Worship .....	82	77	2	3	Q	31.2	29.1	0.9	1.0	Q
Service .....	139	119	2	Q	17	55.8	47.8	0.9	Q	Q
Warehouse and Storage .....	132	111	4	Q	Q	24.1	20.2	0.7	Q	Q
Other .....	87	72	2	Q	12	69.7	57.9	1.7	Q	9.4
Vacant .....	28	26	Q	Q	Q	23.7	22.0	Q	Q	Q
<b>Year Constructed</b>										
Before 1920 .....	143	114	12	15	Q	51.7	41.0	4.4	5.5	Q
1920 to 1945 .....	232	152	24	18	38	48.6	31.8	5.1	3.8	7.9
1946 to 1959 .....	223	163	35	11	14	45.9	33.5	7.2	2.4	2.8
1960 to 1969 .....	276	200	47	12	17	44.9	32.6	7.6	2.0	2.7
1970 to 1979 .....	402	272	72	28	30	45.7	31.0	8.2	3.1	3.4
1980 to 1989 .....	339	207	72	28	31	43.3	26.4	9.2	3.6	4.0
1990 to 1999 .....	345	226	58	33	27	37.5	24.6	6.3	3.6	3.0
2000 to 2003 .....	140	86	28	17	9	34.3	21.0	6.9	4.2	2.2
<b>Census Region and Division</b>										
Northeast .....	462	332	51	34	45	45.5	32.7	5.1	3.3	4.4
New England .....	87	69	Q	Q	5	46.8	36.9	4.3	2.8	2.9
Middle Atlantic .....	375	263	44	29	39	45.2	31.7	5.2	3.5	4.7
Midwest .....	751	589	82	32	47	53.1	41.7	5.8	2.3	3.3
East North Central .....	567	452	62	23	30	54.8	43.7	6.0	2.2	2.9
West North Central .....	184	137	20	9	Q	48.5	36.2	5.4	2.4	4.5
South .....	527	291	129	68	38	34.5	19.1	8.4	4.5	2.5
South Atlantic .....	246	132	60	32	22	33.7	18.1	8.2	4.4	3.0
East South Central .....	107	69	25	8	5	42.6	27.4	10.0	3.3	1.8
West South Central .....	174	90	44	28	12	31.8	16.5	8.0	5.1	2.2
West .....	360	208	85	29	38	40.5	23.4	9.6	3.3	4.3
Mountain .....	190	132	35	6	17	58.4	40.5	10.8	2.0	5.1
Pacific .....	170	76	50	23	21	30.1	13.5	8.9	4.0	3.8

Released: September, 2008

**Table E4A. Electricity Consumption (Btu) Intensities by End Use for All Buildings, 2003**

	Electricity Energy Intensity (thousand Btu/square foot)										
	Total	Space Heating	Cooling	Ventilation	Water Heating	Lighting	Cooking	Refrigeration	Office Equipment	Computers	Other
<b>All Buildings</b> .....	50.7	2.4	6.9	6.2	1.3	19.1	0.3	5.4	1.0	2.2	6.0
<b>Building Floorspace (Square Feet)</b>											
1,001 to 5,000 .....	60.6	2.9	6.8	2.8	1.7	14.8	1.1	21.2	1.2	1.8	6.0
5,001 to 10,000 .....	44.0	2.6	5.7	2.8	1.1	14.3	0.7	8.6	0.9	1.4	5.8
10,001 to 25,000 .....	38.8	2.1	4.4	4.1	1.1	14.7	0.2	4.5	0.8	1.6	5.1
25,001 to 50,000 .....	43.7	2.0	6.8	6.1	1.3	15.4	0.2	4.0	0.8	1.9	5.3
50,001 to 100,000 .....	50.9	2.7	7.5	7.6	1.4	19.6	0.3	3.4	0.7	2.0	5.8
100,001 to 200,000 .....	57.7	2.3	8.0	8.9	1.1	23.0	0.1	2.9	1.3	3.2	6.7
200,001 to 500,000 .....	51.8	1.5	7.4	7.5	0.8	23.0	0.2	1.3	1.1	2.7	6.2
Over 500,000 .....	65.4	3.0	9.0	8.8	1.5	28.7	0.3	2.4	1.2	3.2	7.3
<b>Principal Building Activity</b>											
Education .....	37.6	1.5	7.5	8.4	1.1	11.5	0.2	1.6	0.4	3.3	2.1
Food Sales .....	168.5	5.1	9.9	6.0	Q	37.2	1.9	96.1	1.6	1.5	8.1
Food Service .....	130.9	6.3	17.0	14.8	6.3	25.4	8.1	42.1	1.0	1.0	8.9
Health Care .....	78.3	1.9	10.6	13.3	0.8	33.1	0.2	2.6	1.2	3.2	11.3
Inpatient .....	93.7	1.6	13.0	20.0	1.1	40.1	0.4	2.0	1.1	3.6	10.9
Outpatient .....	55.0	2.3	7.0	3.3	0.3	22.6	0.1	3.5	1.3	2.6	12.0
Lodging .....	46.1	2.8	4.7	2.7	2.3	24.3	0.4	2.3	Q	1.2	4.7
Mercantile .....	65.5	5.2	9.7	6.0	3.4	27.5	0.2	4.4	0.7	1.0	7.4
Retail (Other Than Mall) .....	48.8	1.5	5.9	3.7	0.4	25.7	0.1	5.0	0.6	0.9	5.1
Enclosed and Strip Malls .....	76.0	7.5	12.2	7.5	5.2	28.6	0.3	4.0	0.8	1.1	8.8
Office .....	58.9	2.7	8.3	5.2	0.6	23.1	0.1	2.9	2.6	6.1	7.5
Public Assembly .....	42.6	1.3	8.9	15.9	0.1	7.0	0.1	2.2	Q	0.8	5.8
Public Order and Safety .....	52.3	1.6	7.2	9.5	3.0	16.5	0.1	2.9	0.6	1.5	9.2
Religious Worship .....	16.6	0.8	2.8	1.4	0.1	4.4	0.1	1.7	0.1	0.2	4.9
Service .....	37.5	1.4	3.8	6.1	0.1	15.8	Q	2.2	0.3	0.8	7.0
Warehouse and Storage .....	25.9	0.5	1.4	2.2	0.2	14.0	Q	3.8	0.2	0.5	3.2
Other .....	76.8	1.4	9.3	6.1	0.3	34.3	Q	6.0	Q	2.9	12.6
Vacant .....	8.3	0.5	0.8	0.5	Q	2.4	Q	0.2	Q	0.1	3.7
<b>Year Constructed</b>											
Before 1920 .....	24.2	0.5	1.7	2.9	Q	9.2	0.3	4.5	0.6	0.9	3.2
1920 to 1945 .....	32.1	0.7	2.5	4.5	0.4	13.8	0.2	3.9	0.4	1.2	4.6
1946 to 1959 .....	35.0	1.5	4.0	5.1	0.8	13.3	0.3	3.8	0.6	1.6	4.2
1960 to 1969 .....	41.8	1.6	5.4	6.2	0.9	14.8	0.1	4.8	0.8	2.2	5.0
1970 to 1979 .....	57.1	3.3	7.4	7.1	1.5	22.0	0.3	5.3	1.1	2.4	6.7
1980 to 1989 .....	64.2	3.4	9.6	6.7	2.0	24.2	0.4	6.0	1.4	3.2	7.4
1990 to 1999 .....	60.1	2.7	9.0	7.3	1.6	21.4	0.5	6.7	1.3	2.7	6.8
2000 to 2003 .....	57.6	2.9	8.9	6.2	1.2	22.5	0.5	6.7	0.7	1.6	6.3
<b>Census Region and Division</b>											
Northeast .....	42.2	2.4	3.1	5.5	0.9	17.2	0.2	4.5	0.9	2.3	5.3
New England .....	41.1	2.9	2.4	4.5	1.3	16.1	0.3	6.1	0.7	2.0	4.9
Middle Atlantic .....	42.6	2.2	3.4	5.8	0.7	17.5	0.1	4.0	1.0	2.4	5.4
Midwest .....	45.1	3.0	3.2	6.2	0.9	17.7	0.3	5.2	0.9	2.0	5.8
East North Central .....	47.0	2.7	3.1	6.8	0.8	18.9	0.3	5.1	1.0	2.2	6.1
West North Central .....	40.8	3.6	3.4	4.8	0.9	15.0	0.2	5.4	0.7	1.6	5.1
South .....	59.3	2.0	11.5	6.9	1.8	20.9	0.5	6.4	0.8	2.2	6.3
South Atlantic .....	62.5	2.2	11.1	7.2	2.1	22.5	0.6	6.9	0.9	2.7	6.4
East South Central .....	55.2	2.4	7.5	6.9	1.5	20.4	Q	7.1	0.6	1.6	6.8
West South Central .....	55.7	1.3	13.7	6.3	1.5	18.5	0.4	5.5	0.7	1.7	6.0
West .....	50.3	2.3	6.5	5.7	1.1	19.5	0.3	4.7	1.6	2.4	6.2
Mountain .....	55.7	3.1	7.3	6.5	1.1	22.6	0.2	4.8	Q	2.2	6.4
Pacific .....	47.7	2.0	6.1	5.4	1.1	18.0	0.3	4.6	1.7	2.5	6.0

## Appendix C | Emission Factor Data

### Total Emission Factors for Delivered Electricity by State (lb of pollutant per kWh of electricity)

Pollutant (lb)	RI	SC	SD	TN	TX	UT	VA	VT	WA	WI	WV	WY
CO <sub>2e</sub>	1.18E+00	1.00E+00	1.45E+00	1.46E+00	1.99E+00	2.62E+00	1.40E+00	1.88E-02	4.11E-01	2.03E+00	2.41E+00	2.67E+00
CO <sub>2</sub>	1.04E+00	9.57E-01	1.36E+00	1.40E+00	1.85E+00	2.51E+00	1.33E+00	1.78E-02	3.82E-01	1.92E+00	2.31E+00	2.52E+00
CH <sub>4</sub>	5.65E-03	1.72E-03	3.02E-03	2.43E-03	5.80E-03	4.21E-03	2.52E-03	2.25E-05	1.13E-03	4.13E-03	3.85E-03	5.42E-03
N <sub>2</sub> O	2.04E-05	2.12E-05	3.91E-05	3.28E-05	4.37E-05	5.53E-05	2.81E-05	1.70E-06	1.05E-05	5.32E-05	5.08E-05	7.30E-05
NO <sub>x</sub>	7.91E-04	1.90E-03	2.45E-03	2.77E-03	2.42E-03	5.00E-03	2.67E-03	1.38E-04	6.13E-04	3.51E-03	4.62E-03	4.58E-03
SO <sub>x</sub>	9.90E-03	5.73E-03	3.97E-03	7.32E-03	1.05E-02	1.47E-02	8.04E-03	1.13E-04	1.70E-03	6.60E-03	1.35E-02	7.05E-03
CO	8.52E-04	3.22E-04	5.26E-04	4.14E-04	9.77E-04	6.89E-04	9.74E-04	5.90E-05	1.80E-04	7.13E-04	6.50E-04	9.00E-04
TNMOC	9.92E-05	4.89E-05	4.12E-05	4.17E-05	8.22E-05	5.78E-05	8.77E-05	1.02E-04	3.74E-05	8.26E-05	5.26E-05	7.43E-05
Lead	6.87E-09	7.66E-08	1.47E-07	1.24E-07	1.49E-07	2.08E-07	1.02E-07	6.33E-10	3.21E-08	1.97E-07	1.92E-07	2.77E-07
Mercury	4.09E-09	1.62E-08	3.01E-08	2.50E-08	2.96E-08	4.15E-08	3.24E-08	1.03E-09	6.62E-09	4.01E-08	3.87E-08	5.54E-08
PM10	7.02E-05	4.61E-05	8.12E-05	6.75E-05	1.37E-04	1.14E-04	7.25E-05	7.67E-06	2.46E-05	1.11E-04	1.05E-04	1.49E-04
Solid Waste	1.31E-02	1.17E-01	2.26E-01	1.91E-01	1.82E-01	3.20E-01	1.47E-01	2.83E-04	4.96E-02	3.03E-01	2.95E-01	4.26E-01

### Emission Factors for On-Site Combustion in a Commercial Boiler (lb of pollutant per unit of fuel)

Pollutant (lb)	Commercial Boiler					
	Bituminous Coal *	Lignite Coal **	Natural Gas	Residual Fuel Oil	Distillate Fuel Oil	LPG
	1000 lb	1000 lb	1000 ft <sup>3</sup> ***	1000 gal	1000 gal	1000 gal
CO <sub>2e</sub>	2.74E+03	2.30E+03	1.23E+02	2.56E+04	2.28E+04	1.35E+04
CO <sub>2</sub>	2.63E+03	2.30E+03	1.22E+02	2.55E+04	2.28E+04	1.32E+04
CH <sub>4</sub>	1.15E-01	2.00E-02	2.50E-03	2.31E-01	2.32E-01	2.17E-01
N <sub>2</sub> O	3.68E-01	ND <sup>†</sup>	2.50E-03	1.18E-01	1.19E-01	9.77E-01
NO <sub>x</sub>	5.75E+00	5.97E+00	1.11E-01	6.41E+00	2.15E+01	1.57E+01
SO <sub>x</sub>	1.66E+00	1.29E+01	6.32E-04	4.00E+01	3.41E+01	0.00E+00
CO	2.89E+00	4.05E-03	9.33E-02	5.34E+00	5.41E+00	2.17E+00
VOC	ND <sup>†</sup>	ND <sup>†</sup>	6.13E-03	3.63E-01	2.17E-01	3.80E-01
Lead	1.79E-03	6.86E-02	5.00E-07	1.51E-06	ND <sup>†</sup>	ND <sup>†</sup>
Mercury	6.54E-04	6.54E-04	2.60E-07	1.13E-07	ND <sup>†</sup>	ND <sup>†</sup>
PM10	2.00E+00	ND <sup>†</sup>	8.40E-03	4.64E+00	1.88E+00	4.89E-01