

Northfield Mental Healthcare Center Northfield, Ohio



Advisor: Dr. Stephen Treado


Ji Won Park
Mechanical Option

Senior Thesis 2013

Northfield Mental Healthcare Center

Building Information

Site Map



- Introduction
 - Northfield Mental Healthcare
 - Mechanical System
 - Design Goals
- Alternative 1: Cogeneration
- Alternative 2: Tri-generation
- Comparison
- Breadth: Electrical Breadth
- Summary
- Acknowledgements
- Questions

Function: mental clinic


SIZE: ~260,000 SF


(Additional 200,000 SF to existing 60,000 SF)

Overall Cost: ~62.5 million

Delivery Method: design-bid-build (multiple prime)

Construction Date: approx. April, 2013 – January, 2014





Northfield Mental Healthcare Center


- Introduction
 - Northfield Mental Healthcare
 - Mechanical System
 - Design Goals
- Alternative 1: Cogeneration
- Alternative 2: Tri-generation
- Comparison
- Breadth: Electrical Breadth
- Summary
- Acknowledgements
- Questions


Project Team

- Owner: Ohio Department of Mental Health
- Architects: Hasenstab Architects, Inc.
- Landscape: Bedell-Tucci, LLC (N/A)
- MEP and Fire Protection: Scheeser Buckley Mayfield, LLC
- Structural Engineers: Thorson Baker & Associates

Project Overview

- Provided high quality for care and safety
- Designed to respect surrounding facilities
- Provided additional recreation areas and therapeutic spaces
- Used face brick exterior walls to match the existing building
- Used smooth CMU, textured CMU, and curtain walls to highlight the new design





Northfield Mental Healthcare Center

- Introduction
 - Northfield Mental Healthcare
 - Mechanical System
 - Design Goals
- Alternative 1: Cogeneration
- Alternative 2: Tri-generation
- Comparison
- Breadth: Electrical Breadth
- Summary
- Acknowledgements
- Questions

Existing Mechanical System

Existing:

Existing Constant Volume AHU (70,000 CFM)
Existing Constant Volume AHU (14,000 CFM)

Patient Wing Left / Right:

2 Custom AHUs (65,000 CFM Each) w/ DDC-VAV terminals

Clinic / Admin:

Variable Air Volume AHU (7,950 CFM) w/ DDC-VAV terminals

Dietary:

Variable Air Volume AHU (8,400 CFM) w/ DDC-VAV terminals

Gym:


Constant Volume AHU (3,700 CFM) w/ Sensible Wheel


Boiler Plant & Chiller Plant & Electrical Room


2 Constant Volume AHUs (5,000 CFM Each)

Variable Air Volume AHU (6,000 CFM)

Air Side







Northfield Mental Healthcare Center

- Introduction
 - Northfield Mental Healthcare
 - Mechanical System
 - Design Goals
- Alternative 1: Cogeneration
- Alternative 2: Tri-generation
- Comparison
- Breadth: Electrical Breadth
- Summary
- Acknowledgements
- Questions

Existing Mechanical System

Air Side

Existing:

Existing Constant Volume AHU (70,000 CFM)

Existing Constant Volume AHU (14,000 CFM)

Patient Wing Left / Right:

2 Custom AHUs (65,000 CFM Each) w/ DDC-VAV terminals

Clinic / Admin:

Variable Air Volume AHU (7,950 CFM) w/ DDC-VAV terminals

Dietary:

Variable Air Volume AHU (8,400 CFM) w/ DDC-VAV terminals


Gym:


Constant Volume AHU (3,700 CFM) w/ Sensible Wheel

Boiler Plant & Chiller Plant & Electrical Room

2 Constant Volume AHUs (5,000 CFM Each)

Variable Air Volume AHU (6,000 CFM)





Northfield Mental Healthcare Center

- Introduction
 - Northfield Mental Healthcare
 - Mechanical System
 - Design Goals
- Alternative 1: Cogeneration
- Alternative 2: Tri-generation
- Comparison
- Breadth: Electrical Breadth
- Summary
- Acknowledgements
- Questions

Existing Mechanical System

Existing:

Existing Constant Volume AHU (70,000 CFM)
Existing Constant Volume AHU (14,000 CFM)

Patient Wing Left / Right:

2 Custom AHUs (65,000 CFM Each) w/ DDC-VAV terminals

Clinic / Admin:

Variable Air Volume AHU (7,950 CFM) w/ DDC-VAV terminals

Dietary:

Variable Air Volume AHU (8,400 CFM) w/ DDC-VAV terminals

Gym:


Constant Volume AHU (3,700 CFM) w/ Sensible Wheel

Boiler Plant & Chiller Plant & Electrical Room

2 Constant Volume AHUs (5,000 CFM Each)

Variable Air Volume AHU (6,000 CFM)

Air Side



Northfield Mental Healthcare Center

by-product
called buildings also
advoc available
same
tion
contin
biggest companies
close
either Europe
combin distribu
hour engine good Develop
ereration cogeneration
electricity
decentralized energy must
Lovins District kilogra hot
heat inc pro
GW
temperatures heat
power
pounds
used plants Unit
states steam the utility

- | | |
|--------------------------------|------------------------|
| Introduction | Existing: |
| • Northfield Mental Healthcare | Existing |
| • Mechanical System | Existing |
| • Design Goals | Patient Wing 2 Cus |
| Alternative 1: Cogeneration | Clinic / Admin Vari |
| Alternative 2: Tri-generation | Dietary: Vari |
| Comparison | Gym: Cons |
| Breadth: Electrical Breadth | Boiler Plant 2 Co |
| Summary | Vari |
| Acknowledgements | |
| Questions | |

Mechanical System

A

The AHU (70,000 CFM)

The AHU (14,000 CFM)

(65,000 CFM Each) w/ DDC-VAV terminals

Volume AHU (7,950 CFM) w/ DDC-VAV terminals


Volume AHU (8,400 CFM) w/ DDC-VAV terminals


The AHU (3,700 CFM) w/ Sensible Wheel


Plant & Electrical Room


ame AHUs (5,000 CFM Each)


Volume AHU (6,000 CFM)












Northfield Mental Healthcare Center



• Introduction

- Northfield Mental Healthcare
- Mechanical System
- Design Goals
- Alternative 1: Cogeneration
- Alternative 2: Tri-generation
- Comparison
- Breadth: Electrical Breadth
- Summary
- Acknowledgements
- Questions


Annual Energy Consumption Summary

| Summary of Annual Energy Consumption | |
|--------------------------------------|----------------|
| Total Electricity Consumption | 14,127,906 KWh |
| Total Natural Gas Consumption | 636,589 Therms |
| Total Energy Consumption | 32,779,801 KWh |

| EUI Value Calculated | |
|----------------------|---------------|
| Electricity EUI | 185 kBtu / SF |
| Natural Gas EUI | 250 kBtu / SF |
| EUI | 435 kBtu / SF |

| EUI Value of Typical Hospital (Baseline Model) | |
|--|---------------|
| EUI | 388 kBtu / SF |

Existing Water Flow Diagram





Northfield Mental Healthcare Center

CHP System

Spark Spread

- Introduction
- Alternative 1: Cogeneration
 - CHP System
 - CHP Module Simple Payback
 - Cogeneration Schematic
 - Cogeneration Energy Saving
- Alternative 2: Tri-generation
- Comparison
- Breadth: Electrical Breadth
- Summary
- Acknowledgements
- Questions

Combined Heat and Power (CHP) system

CHP supplies energy in two forms:

- Electricity
- Heat

| Spark Spread | |
|---|-------|
| Determine the Average Annual Electric Cost (\$/MMBtu) | 29.30 |
| Determine the Average Gas Cost (\$/MMBtu) | 7.550 |
| Spark Spread | |
| 22 | |

Northfield Mental Healthcare Center

- Introduction
- Alternative 1: Cogeneration
 - CHP System
 - CHP Module Simple Payback
 - Cogeneration Schematic
 - Cogeneration Energy Saving
- Alternative 2: Tri-generation
- Comparison
- Breadth: Electrical Breadth
- Summary
- Acknowledgements
- Questions

| T/P Ratio | |
|--|--------------------|
| 1. Determine Thermal Use | |
| Total Thermal Energy Delivered/Used | 63,658,920,000 Btu |
| 2. Determine Electrical Use | |
| Total Electric | 48,218,544,000 Btu |
| 3. Determine T/P Ratio | |
| T/P Ratio - Divide Total Thermal (Btu) by Total Electric (Btu): | 1.32 |

| | Capacity | Installation Costs | O&M Costs |
|------------------------------|------------------|---------------------------|----------------------------|
| Reciprocating Engines | 5 kWe - 20 MWe | \$1,000 to \$1,800 per kW | \$0.010 to \$0.015 per kWh |
| Gas Turbines | 25 kWe – 500 kW | \$800 to \$1,500 per kW | \$0.005 to \$0.008 per kWh |
| Microturbines | 500 kWe – 100 kW | \$1,000 to \$2,000 per kW | \$0.010 to \$0.015 per kWh |

Recommended Prime Mover Technology Based on T/P Ratio

| If T/P = | |
|------------|-------------------------|
| 0.5 to 1.5 | Consider engines |
| 1 to 10 | Consider gas turbines |
| 3 to 20 | Consider steam turbines |

Northfield Mental Healthcare Center

called buildings also
by-product
advocacy available
chemical
close
continuing
biggest companies
either Europe
combining
distribution
hour engine
good Develop
centralized energy must
kilo
Lovins District hot
heat inc pro
temperatures heat
power u
pounds plants Unit
used steam the utility
States steam the utility

- Introduction
- Alternative 1: Cogeneration
 - CHP System
 - CHP Module Simple Payback
 - Cogeneration Schematic
 - Cogeneration Energy Saving
- Alternative 2: Tri-generation
- Comparison
- Breadth: Electrical Breadth
- Summary
- Acknowledgements
- Questions

CHP Module Sizing

| Primary Design | | |
|--|------------------------|--------------------|
| Building Size (SF) | Heating Baseline (MBH) | Heating Load (MBH) |
| 260,000 | 5,640 | 11,180 |
| Heating Baseline = Total Heating Load X 50% | | |

$$5,640 \text{ MBH} \times \frac{1,000 \text{ Btu/h}}{1 \text{ MBH}} \times \frac{1 \text{ kW}}{3,413 \text{ Btu/h}} = 1,653 \text{ kW}$$

| CHP COGENERATION MODULE - 2G 1540 NG | |
|--------------------------------------|--------------------------|
| Reciprocating engine MWM® TCG2020 | |
| Configuration | Natural Gas |
| Electrical Output | 1540 kW |
| Thermal Output | 1778 kW |
| Electrical Efficiency | 42.00% |
| Thermal Efficiency | 44.06% |
| Total efficiency | 80.06% |
| Thermal Heat | 6,066,787 Btu/h (Usable) |
| Water Flow rate High Temp | 17,100 Gph |
| Water Temp | 194F |
| Fuel Consumption | 12508 MBtu/h |
| Energy Consumption | 8,122 Btu / kW |

CHP Module Selection

Northfield Mental Healthcare Center

called buildings also
by-product
advocacy available
chemical
close
continuing
biggest companies
either Europe
combining
distribution
hour engine
good Develop
centralized energy must
kilojoules Lovins District hot
heat inc pro
GW on temperatures heat
power u
pounds plants Unit
used steam the utility
States steam the utility


- Introduction
- Alternative 1: Cogeneration
 - CHP System
 - CHP Module Simple Payback
 - Cogeneration Schematic
 - Cogeneration Energy Saving
- Alternative 2: Tri-generation
- Comparison
- Breadth: Electrical Breadth
- Summary
- Acknowledgements
- Questions


CHP Module Sizing

| Primary Design | | |
|---|------------------------|--------------------|
| Building Size (SF) | Heating Baseline (MBH) | Heating Load (MBH) |
| 260,000 | 5,640 | 11,180 |
| Heating Baseline = Total Heating Load X 50% | | |

$$5,640 \text{ MBH} \times \frac{1,000 \text{ Btu/h}}{1 \text{ MBH}} \times \frac{1 \text{ kW}}{3,413 \text{ Btu/h}} = 1,653 \text{ kW}$$

| CHP COGENERATION MODULE - 2G 1540 NG | |
|--------------------------------------|--------------------------|
| Reciprocating engine MWM® TCG2020 | Natural Gas |
| Configuration | 1540 KW |
| Electrical Output | 1778 KW |
| Thermal Output | 42.00% |
| Electrical Efficiency | 44.06% |
| Thermal Efficiency | 80.06% |
| Total efficiency | 6,066,787 Btu/h (Usable) |
| Thermal Heat | 17,100 Gph |
| Water Flow rate High Temp | 194F |
| Water Temp | 12508 MBtu/h |
| Fuel Consumption | 8,122 Btu / kW |
| Energy Consumption | |






- Introduction
- Alternative 1: Cogeneration
 - CHP System
 - CHP Module Simple Payback
 - Cogeneration Schematic
 - Cogeneration Energy Saving
- Alternative 2: Tri-generation
- Comparison
- Breadth: Electrical Breadth
- Summary
- Acknowledgements
- Questions

| Heat Recovery | |
|--------------------------------|-------------------|
| Heat Recovery | 6,068,314 Btu/hr |
| Heating Load | 11,180,000 Btu/hr |
| Heat Recovery Basis Efficiency | 60% |

| Energy Generation & Fuel Consumption | |
|--------------------------------------|----------------|
| Annual Electric Generation | 13,490,400 kWh |
| Annual Thermal Generation | 53,158 MMBtu |
| Annual Fuel Consumption | 109,570 MMBtu |


| Revenue | |
|------------------|-------------|
| Electric Revenue | \$1,349,040 |
| Thermal Revenue | \$401,346 |
| Total Revenue | \$1,750,386 |
| Expenses | |
| Fuel Expenses | \$827,254 |
| O&M Costs | \$168,630 |
| Standby Charge | \$55,440 |
| Total Expenses | \$1,051,324 |
| Saving | |
| Total Saving | \$699,062 |



- Introduction
- Alternative 1: Cogeneration
 - CHP System
 - CHP Module Simple Payback
 - Cogeneration Schematic
 - Cogeneration Energy Saving
- Alternative 2: Tri-generation
- Comparison
- Breadth: Electrical Breadth
- Summary
- Acknowledgements
- Questions

| Heat Recovery | | |
|---------------------|-------------------|------------|
| Heat Recovery | 6,068,314 Btu/hr | |
| Heating Load | 11,180,000 Btu/hr | |
| Heat Recovery Basis | | Efficiency |
| | | 60% |

| Revenue | |
|------------------|-------------|
| Electric Revenue | \$1,349,040 |
| Thermal Revenue | \$401,346 |
| Total Revenue | \$1,750,386 |
| Expenses | |
| Fuel Expenses | \$827,254 |
| O&M Costs | \$168,630 |
| Standby Charge | \$55,440 |
| Total Expenses | \$1,051,324 |
| Saving | |
| Total Saving | \$699,062 |




- Introduction
- Alternative 1: Cogeneration
 - CHP System
 - CHP Module Simple Payback
 - Cogeneration Schematic
 - Cogeneration Energy Saving
- Alternative 2: Tri-generation
- Comparison
- Breadth: Electrical Breadth
- Summary
- Acknowledgements
- Questions

| Payback | |
|----------------|-------------|
| First Cost | \$2,310,000 |
| Total Saving | \$699,062 |
| Simple Payback | 3.30 Yrs |

| Revenue | |
|------------------|-------------|
| Electric Revenue | \$1,349,040 |
| Thermal Revenue | \$401,346 |
| Total Revenue | \$1,750,386 |

| Expenses | |
|----------------|-------------|
| Fuel Expenses | \$827,254 |
| O&M Costs | \$168,630 |
| Standby Charge | \$55,440 |
| Total Expenses | \$1,051,324 |

| Saving | |
|--------------|-----------|
| Total Saving | \$699,062 |



Northfield Mental Healthcare Center Annual Report

Consumption

Annual Net Sav


- | Introduction | | | | | | | | | |
|--|---|----------|---------|--|---------|---------------|---------|--|---------|
| Alternative 1: Cogeneration | <ul style="list-style-type: none">• CHP System• CHP Module Simple Payback• Cogeneration Schematic• Cogeneration Energy Saving | | | | | | | | |
| Alternative 2: Tri-generation Comparison | <table border="1"><thead><tr><th>Existing</th><th>Heating</th></tr></thead><tbody><tr><td></td><td>Cooling</td></tr><tr><th>Alternative 1</th><th>Heating</th></tr><tr><td></td><td>Cooling</td></tr></tbody></table> | Existing | Heating | | Cooling | Alternative 1 | Heating | | Cooling |
| Existing | Heating | | | | | | | | |
| | Cooling | | | | | | | | |
| Alternative 1 | Heating | | | | | | | | |
| | Cooling | | | | | | | | |
| Breadth: Electrical Breadth | | | | | | | | | |
| Summary | | | | | | | | | |
| Acknowledgements | | | | | | | | | |
| Questions | | | | | | | | | |

| Annual Energy Generated | | Annual Energy Consumption (Space Heating & Space Cooling) | |
|-------------------------|-------------------|---|-------------------|
| Thermal Btu | Electricity (KWh) | Thermal (MMBtu) | Electricity (KWh) |
| - | - | 103,091 | - |
| - | - | - | 4,204,800 |
| 138 | 13,490,400 | 78,840 | - |
| | | - | 4,204,800 |

| | Annual Net Saving | | | | |
|------------------------------|--------------------|----------------------|--------------|---------------------|------------|
| | Thermal (MMBtu) | Electricity (KWh) | Thermal (\$) | Electricity (\$) | Total (\$) |
| Existing vs. Alternative1 | 24,251 | 13,490,400 | 183,098 | 1,349,040 | 1,532,138 |

| Northfield Mental Healthcare Center | CHPC System | Absorption Chiller Selection | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|--|--|--|--------------|----------------------------|------|-----------------------------|--|-----------------------------|--|------|------|------|------|------|------|---------------|-------|-------|------|------|------|------|---------------|-------|-------|------|------|------|------|------------------|----------|--------------------|-----------|--------------------|-----------|----------------|-------------|-----|-----|
| called buildings also adv. available chemic. by-product same name close cont. biggest companies either Europe combin. hour engine good Develop. cogeneration electricity energy must Lovins District kilogram hot inc. pro. temperatures heat inc. gw. unit pounds plants Unit used steam the utility | Combined Heat, Power and Cooling (CHPC) system | Absorption Chiller Selection | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <ul style="list-style-type: none"> • Introduction • Alternative 1: Cogeneration • Alternative 2: Tri-generation • CHPC System • Tri-generation Schematic • Tri-generation Energy Saving • Comparison • Breadth: Electrical Breadth • Summary • Acknowledgements • Questions | <p>CHPC supplies energy in three forms:</p> <ul style="list-style-type: none"> • Electricity • Heat • Chilled water | <table border="1"> <thead> <tr> <th rowspan="2">Chiller Type</th><th colspan="2">Heat Production (Brtu/kWh)</th><th colspan="2">Absorber COP</th><th colspan="2">Cooling Available (Tons/kW)</th></tr> <tr> <th>Min.</th><th>Max.</th><th>Min.</th><th>Max.</th><th>Min.</th><th>Max.</th></tr> </thead> <tbody> <tr> <td>Single Effect</td><td>3,800</td><td>6,000</td><td>0.70</td><td>0.78</td><td>0.22</td><td>0.35</td></tr> <tr> <td>Double Effect</td><td>1,500</td><td>2,000</td><td>1.10</td><td>1.30</td><td>0.15</td><td>0.20</td></tr> </tbody> </table> <p>Absorption Chiller Selection Carrier 16JLR 47 (Single Effect Lithium Bromide - Water Absorption Chiller)</p> <table border="1"> <tbody> <tr> <td>Cooling Capacity</td><td>450 Tons</td></tr> <tr> <td>Chilled Water Temp</td><td>54 / 44 F</td></tr> <tr> <td>Cooling Water Temp</td><td>85 / 95 F</td></tr> <tr> <td>Hot Water Temp</td><td>203 / 185 F</td></tr> <tr> <td>COP</td><td>0.7</td></tr> </tbody> </table> | Chiller Type | Heat Production (Brtu/kWh) | | Absorber COP | | Cooling Available (Tons/kW) | | Min. | Max. | Min. | Max. | Min. | Max. | Single Effect | 3,800 | 6,000 | 0.70 | 0.78 | 0.22 | 0.35 | Double Effect | 1,500 | 2,000 | 1.10 | 1.30 | 0.15 | 0.20 | Cooling Capacity | 450 Tons | Chilled Water Temp | 54 / 44 F | Cooling Water Temp | 85 / 95 F | Hot Water Temp | 203 / 185 F | COP | 0.7 |
| Chiller Type | Heat Production (Brtu/kWh) | | | Absorber COP | | Cooling Available (Tons/kW) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | Min. | Max. | Min. | Max. | Min. | Max. | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Single Effect | 3,800 | 6,000 | 0.70 | 0.78 | 0.22 | 0.35 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Double Effect | 1,500 | 2,000 | 1.10 | 1.30 | 0.15 | 0.20 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Cooling Capacity | 450 Tons | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Chilled Water Temp | 54 / 44 F | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Cooling Water Temp | 85 / 95 F | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Hot Water Temp | 203 / 185 F | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| COP | 0.7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

| Northfield Mental Healthcare Center | CHPC System | Absorption Chiller Selection | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|--|---|---|--------------|----------------------------|------|-----------------------------|--|-----------------------------|--|------|------|------|------|------|------|---------------|-------|-------|------|------|------|------|---------------|-------|-------|------|------|------|------|------------------|----------|--------------------|-----------|--------------------|-----------|----------------|-------------|-----|-----|
| called buildings also adv. available chemic. by-product same name close cont. biggest companies either Europe combin. distribution hour engine good Develop. cogeneration electricity energy must centralized Lovins District kilogram hot inc. pro. heat inc. pro. temperatures heat ant. power u. pounds plants Unit used steam the utility | CHPC System | Absorption Chiller Selection | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <ul style="list-style-type: none"> • Introduction • Alternative 1: Cogeneration • Alternative 2: Tri-generation • CHPC System • Tri-generation Schematic • Tri-generation Energy Saving • Comparison • Breadth: Electrical Breadth • Summary • Acknowledgements • Questions | <p>Combined Heat, Power and Cooling (CHPC) system</p> <p>CHPC supplies energy in three forms:</p> <ul style="list-style-type: none"> • Electricity • Heat • Chilled water | <table border="1"> <thead> <tr> <th rowspan="2">Chiller Type</th> <th colspan="2">Heat Production (Brtu/kWh)</th> <th colspan="2">Absorber COP</th> <th colspan="2">Cooling Available (Tons/kW)</th> </tr> <tr> <th>Min.</th> <th>Max.</th> <th>Min.</th> <th>Max.</th> <th>Min.</th> <th>Max.</th> </tr> </thead> <tbody> <tr> <td>Single Effect</td><td>3,800</td><td>6,000</td><td>0.70</td><td>0.78</td><td>0.22</td><td>0.35</td></tr> <tr> <td>Double Effect</td><td>1,500</td><td>2,000</td><td>1.10</td><td>1.30</td><td>0.15</td><td>0.20</td></tr> </tbody> </table> <p>Absorption Chiller Selection</p> <p>Carrier 16JLR 47</p> <p>(Single Effect Lithium Bromide - Water Absorption Chiller)</p> <table border="1"> <tbody> <tr> <td>Cooling Capacity</td><td>450 Tons</td></tr> <tr> <td>Chilled Water Temp</td><td>54 / 44 F</td></tr> <tr> <td>Cooling Water Temp</td><td>85 / 95 F</td></tr> <tr> <td>Hot Water Temp</td><td>203 / 185 F</td></tr> <tr> <td>COP</td><td>0.7</td></tr> </tbody> </table> | Chiller Type | Heat Production (Brtu/kWh) | | Absorber COP | | Cooling Available (Tons/kW) | | Min. | Max. | Min. | Max. | Min. | Max. | Single Effect | 3,800 | 6,000 | 0.70 | 0.78 | 0.22 | 0.35 | Double Effect | 1,500 | 2,000 | 1.10 | 1.30 | 0.15 | 0.20 | Cooling Capacity | 450 Tons | Chilled Water Temp | 54 / 44 F | Cooling Water Temp | 85 / 95 F | Hot Water Temp | 203 / 185 F | COP | 0.7 |
| Chiller Type | Heat Production (Brtu/kWh) | | | Absorber COP | | Cooling Available (Tons/kW) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | Min. | Max. | Min. | Max. | Min. | Max. | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Single Effect | 3,800 | 6,000 | 0.70 | 0.78 | 0.22 | 0.35 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Double Effect | 1,500 | 2,000 | 1.10 | 1.30 | 0.15 | 0.20 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Cooling Capacity | 450 Tons | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Chilled Water Temp | 54 / 44 F | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Cooling Water Temp | 85 / 95 F | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Hot Water Temp | 203 / 185 F | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| COP | 0.7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |



Northfield Mental Healthcare Center Tri-ge

Block Diagram Schematic

Cooling Side Schematic

by-product
called buildings also
same
t
g
eneration
hour engine
decentralized
Lovins
ak
g
on
nt
power
used
states
pounds
buildings
biggest
companies
close
either
Europe
combin
distribu
good
Develop
must
District
kilogra
hot
inc
pro
temperatures
heat
plants
Unit
the
utility

Cogeneration

CHP

electricity

heat

power

steam

- CHPC System
 - Tri-generation Schematic
 - Tri-generation Energy Saving Comparison



breadth: Electrical Breadth


summary


cknowledgements

uestions

The diagram illustrates a tri-generation system. A central vertical pipe represents the primary energy source. At the top, a dashed red box indicates 'HWR 177°F 285 GPM' exiting. Below it is a 'COOLING TOWER' represented by a trapezoid. A blue line labeled 'HWS 180°F 285 GPM' exits from the right side of the tower. From the bottom of the central pipe, two horizontal lines branch off: one purple line labeled 'AIR & NG' exits to the right, and one green line labeled 'ELECTRICITY 1310 KW' exits downwards.







Northfield Mental Healthcare Center

Comparison- Annual Net Saving

Comparison- First Cost


- Introduction
- Alternative 1: Cogeneration
- Alternative 2: Tri-generation
- Comparison
 - Annual Energy Cost
 - Emission
- Breadth: Electrical Breadth
- Summary
- Acknowledgements
- Questions


| | Annual Net Saving | | | | |
|--------------------------------|-------------------|-------------------|--------------|------------------|------------|
| | Thermal (MMBtu) | Electricity (KWh) | Thermal (\$) | Electricity (\$) | Total (\$) |
| Existing vs. Alternative1 | 24,251 | 13,490,400 | 183,098 | 1,349,040 | 1,532,138 |
| Existing vs. Alternative2 | 22,794 | 14,804,400 | 172,098 | 1,480,440 | 1,652,538 |
| Alternative2 vs. Alternative 1 | (1,457) | 1,314,000 | (11,000) | 131,400 | 120,400 |

| First Cost | Existing | Alternative 1 | Alternative 2 |
|----------------------|-------------|---------------|---------------|
| Boilers | \$2,280,000 | \$1,387,000 | \$1,900,000 |
| Electric Chiller | \$304,000 | \$304,000 | \$152,000 |
| Absorption Chiller | \$0 | \$0 | \$180,000 |
| Pumps | \$400,000 | \$400,000 | \$400,000 |
| Total | \$2,984,000 | \$2,091,000 | \$2,632,000 |
| Saving On First Cost | \$0 | \$893,000 | \$352,000 |


Alternative 1: More Saving on First Cost

Alternative 2: More Saving on Annual Energy Consumption





- Introduction
- Alternative 1: Cogeneration
- Alternative 2: Tri-generation
- Comparison
- Breadth: Electrical Breadth
 - Code Analysis
 - Load Distribution Analysis
 - Sizing Conductors
- Summary
- Acknowledgements
- Questions



NEC 517.31 and NFPA 99 3-4.3.1



Emergency generator Startup time (Healthcare facility) < 10 s
CHP system cannot serve for the life safety load & critical load.

Replacing existing emergency generator with
CHP generator


Northfield Mental Healthcare Center Emergency

Generator - Existing

Load Distribution - Existing



PARALLELING SWITCHGEAR DISTRIBUTION DIAMETER



Northfield Mental Healthcare Center Load Data

by-product
called buildings also
same
name
t
g
eneration
hour engine
decentralized
Lovins
GW
nt
heat
temperatures
power
pounds
used plants Unit
States steam the utility

advoc
avail
chemic
contin
close
either
Europe
good
Develop
must
District
kilogra
hot
inc
pro

CHP
combin
distribu
cogeneratio
electricity
energy
heat
heat
heat
power
plants Unit
the utility

- Code Analysis
 - Load Distribution Analysis
 - Sizing Conductors

Each
50% of
Gen #
load a
Gen #

on Analysis


| Percentage (%) |
|----------------|
| 50.2 |
| 49.8 |
| 100 |


generators serves


e as the life safety


The CHP generator.

Load Distribution – New Design









- Introduction
- Alternative 1: Cogeneration
- Alternative 2: Tri-generation
- Comparison
- Breadth: Electrical Breadth
- Summary
- Acknowledgements
- Questions



Questions?

Special Thanks to:

James D. Freihaut, PhD – Professor of AE Dept.
Moses D. F. Ling, PE, RA – Associate Professor of AE Dept.
Stephen Treado, Ph.D., P.E. –Associate Professor of AE Dept.
William P. Bahnfleth, PhD, PE - Professor, AE Dept.
Doug Smelker – Scheeser Buckley Mayfield LLC
Jason Wilson – Scheeser Buckley Mayfield LLC
Josh Roehm – Scheeser Buckley Mayfield LLC