



# S.T.E.P.S. Building



Joseph Murray  
Structural Option  
Senior Thesis Presentation  
The Pennsylvania State University  
Advisor: Linda Hanagan

# Building Statistics


- ▣ Building Statistics
- ▣ Structural System
- ▣ Depth Proposal
  - Floor Design
  - Lateral System
  - Moment Connections
  - Braced Connections
- ▣ Electrical Breadth
- ▣ Construction Breadth



- ▣ S.T.E.P.S.: Science, Technology, Environment, and Policy Building
- ▣ Education, laboratory, and research
- ▣ Owner: Lehigh University
- ▣ Location: Bethlehem, PA
- ▣ 5 story, 135,000 s.f. project
- ▣ 80' to roofline of Wing C
- ▣ Cost: \$62 million
- ▣ Construction: Aug. 2008 – Aug. 2010

# Building Statistics

- ▣ Building Statistics
- ▣ Structural System
- ▣ Depth Proposal
  - Floor Design
  - Lateral System
  - Moment Connections
  - Braced Connections
- ▣ Electrical Breadth
- ▣ Construction Breadth




## Project Team:


- |               |                      |                  |
|---------------|----------------------|------------------|
| ▣ CM:         | Alvin H. Butz        | Allentown, PA    |
| ▣ Architect:  | BCJ Architects       | Philadelphia     |
| ▣ Structural: | CVM Structures       | Oaks, PA         |
| ▣ Civil:      | Barry Isett & Assoc. | Trexlerstown, PA |
| ▣ MEP/Fire:   | Flack & Kurtz        | New York, NY     |
| ▣ Landscape:  | Lager Raabe Skafte   | Philadelphia     |

# Existing Floor Plans


- ▣ Building Statistics
  - Existing Floor Plans
- ▣ Structural System
- ▣ Depth Proposal
  - Floor Design
  - Lateral System
  - Moment Connections
  - Braced Connections
- ▣ Electrical Breadth
- ▣ Construction Breadth



Wing C




Wing B



# Existing Structural System

- ▣ Building Statistics
- ▣ Structural System
- ▣ Depth Proposal
  - ▣ Floor Design
  - ▣ Lateral System
  - ▣ Moment Connections
  - ▣ Braced Connections
- ▣ Electrical Breadth
- ▣ Construction Breadth



- ▣ 3" roof deck with varying topping
- ▣ 3" composite floor deck with 4.5" topping
- ▣ W24 beams framing into W21 girders
- ▣ Beam spacing: 10'-8" on center
- ▣ Beam span: 42'-3"
- ▣ Girder span: 21'-4"
- ▣ LFRD: semi-rigid wind clips
- ▣ Columns: W14x90 up to W14x192
- ▣ Foundation: square footings

# Depth Proposal

## Project Goals

- ▣ Building Statistics
  - ▣ Structural System
  - ▣ Depth Proposal
    - Floor Design
    - Lateral System
    - Moment Connections
    - Braced Connections
  - ▣ Electrical Breadth
  - ▣ Construction Breadth
- ▣ 1. Analyze the existing floor system for vibration resistance with AISC Design Guide 11
  - ▣ 2. Redesign the floor to allow for 400x microscopes at moderate walking speeds
  - ▣ 3. Redesign the lateral system with full moment frames and braced frames
  - ▣ 4. Design a typical moment connection in detail
  - ▣ 5. Design a typical braced connection in detail

- ▣ Building Statistics
- ▣ Structural System
- ▣ Depth Proposal
  - Floor Design
  - Lateral System
  - Moment Connections
  - Braced Connections
- ▣ Electrical Breadth
- ▣ Construction Breadth



## Floor Design

- ▣ Floor vibration criteria were incorporated in design
- ▣ Laboratory and research sections designed for sensitive equipment
- ▣ Establish what equipment exist in the laboratories
- ▣ Design the floor for specific equipment

# Floor Design

- ▣ Building Statistics
- ▣ Structural System
- ▣ Depth Proposal
  - Floor Design
  - Lateral System
  - Moment Connections
  - Braced Connections
- ▣ Electrical Breadth
- ▣ Construction Breadth

Owner	Building	Material	Criteria	Opening
Cornell	Nanotechnology Laboratory	RC	1000 $\alpha^2/s$	Fall 2003
Harvard	Institute of Medicine	SS	2000 $\alpha^2/s$	Summer 2005
MIT	Brain and Cognitive Science Center	SS	2000 $\alpha^2/s$	Spring 2005
Duke	Science Center	RC	2000 $\alpha^2/s$	Fall 2006
U. Chicago	Interdivisional Research Center	SS	750 $\alpha^2/s$	Summer 2005
U. Mass Worcester	Research Institute	SS	2000 $\alpha^2/s$	Fall 2000

**Table 6.1  
Vibration Criteria for Sensitive Equipment**

Facility Equipment or Use	Vibrational Velocity*	
	( $\mu$ in./sec)	( $\mu$ m/sec)
Computer systems; Operating Rooms**; Surgery; Bench microscopes at up to 100x magnification;	8,000	200
Laboratory robots	4,000	100
Bench microscopes at up to 400x magnification; Optical and other precision balances; Coordinate measuring machines; Metrology laboratories; Optical comparators; Microelectronics manufacturing equipment—Class A***	2,000	50
Micro surgery, eye surgery, neuro surgery; Bench microscopes at magnification greater than 400x; Optical equipment on isolation tables; Microelectronics manufacturing equipment—Class B***	1,000	25



## Means & Methods

- ▣ AISC Design Guide 11: Floor Vibrations Due to Human Activity
- ▣ Chapter 6: Sensitive Equipment
- ▣ Based on natural frequency of floor
- ▣ Current floor allows for 100x magnitude microscopes at “slow walking”
- ▣ 2000 microinches/second was chosen as the design criterion at “moderate walking” pace



# Floor Design

- ▣ Building Statistics
- ▣ Structural System
- ▣ Depth Proposal
  - Floor Design
  - Lateral System
  - Moment Connections
  - Braced Connections
- ▣ Electrical Breadth
- ▣ Construction Breadth





## Impact of Redesign

- ▣ Beam spacing decreased from 10'-8" to 7'-11" on center
- ▣ Bay frequency rose from 3.7 to 5.3 Hz
  - Allows use of different equation
- ▣ Bay floor weight increased by 21 psf
  - Only in sensitive laboratories
- ▣ Floor depth could be increased
  - Move labs to one floor
- ▣ Columns could be moved to decrease span


# Lateral System

- ▣ Building Statistics
- ▣ Structural System
- ▣ Depth Proposal
  - Floor Design
  - Lateral System
  - Moment Connections
  - Braced Connections
- ▣ Electrical Breadth
- ▣ Construction Breadth



# Moment Connection

- ▣ Building Statistics
- ▣ Structural System
- ▣ Depth Proposal
  - Floor Design
  - Lateral System
  - Moment Connections
  - Braced Connections
- ▣ Electrical Breadth
- ▣ Construction Breadth




## Means & Methods

- ▣ Wind clips in N/S direction replaced with full moment connections
- ▣ AISC 14<sup>th</sup> Edition and AE 534 notes
- ▣ 2 rows of 7 moment frames
- ▣  $1.2D + .5L + .5S + 1.6W$
- ▣ Portal method to distribute loads
- ▣ Frame analyzed for lowest story

# Moment Connection

- ▣ Building Statistics
- ▣ Structural System
- ▣ Depth Proposal
  - Floor Design
  - Lateral System
  - Moment Connections
  - Braced Connections
- ▣ Electrical Breadth
- ▣ Construction Breadth




## Details

- ▣ Flange Welded/ Web Bolted
- ▣ Flange Connection
  - Full penetration welds with backers
- ▣ Web Connection
  - 5/16" plate with (4) 3/4" A325-N bolts
- ▣ Column Reinforcement
  - Full depth 1/2" stiffeners required
  - (2) 3/4" doubler plates required

# Moment Connection

- ▣ Building Statistics
- ▣ Structural System
- ▣ Depth Proposal
  - Floor Design
  - Lateral System
  - Moment Connections
  - Braced Connections
- ▣ Electrical Breadth
- ▣ Construction Breadth




## Impact of Redesign

- ▣ Number of moment connections reduced
- ▣ Field welds limited in connection
- ▣ Column stiffening can be prefabricated
- ▣ A stronger column could eliminate stiffeners and doubler plates

# Braced Connection

- ▣ Building Statistics
- ▣ Structural System
- ▣ Depth Proposal
  - Floor Design
  - Lateral System
  - Moment Connections
  - Braced Connections
- ▣ Electrical Breadth
- ▣ Construction Breadth




## Means & Methods

- ▣ Wind clips in E/W direction to be replaced with 5 braced frames
- ▣ AISC 14<sup>th</sup> Edition and AE 534 notes
- ▣  $1.2D + .5L + .5S + 1.6W$
- ▣ Concentric braces initially selected
- ▣ Eccentric braces chosen due to span
- ▣ HSS 4x4x1/2 selected as brace

# Braced Connection

- ▣ Building Statistics
- ▣ Structural System
- ▣ Depth Proposal
  - Floor Design
  - Lateral System
  - Moment Connections
  - Braced Connections
- ▣ Electrical Breadth
- ▣ Construction Breadth




## Corner Brace Connection

- ▣ 1/2" gusset plate with 30x6.5x12 dimensions
- ▣ HSS to Gusset: 3/16" field welds
- ▣ Gusset to Column: 2-L 4x4x3/8x6
  - 3/16" fillet welds to gusset
  - (2) 3/4" bolts to column
- ▣ Gusset to Beam: 3/16" fillet welds
- ▣ Beam to Column: L 5x3x1/2
  - 1/4" fillet weld to column
  - (3) 3/4" bolts to beam

# Braced Connection

- ▣ Building Statistics
- ▣ Structural System
- ▣ Depth Proposal
  - Floor Design
  - Lateral System
  - Moment Connections
  - Braced Connections
- ▣ Electrical Breadth
- ▣ Construction Breadth




## Center of Beam Connection

- ▣ 1/2" gusset plate with 24x6.5x12 dimensions on both sides
- ▣ HSS to Gusset: 3/16" field welds
  - 12" minimum length
- ▣ Gusset to Beam: 3/16" fillet welds
  - 24" minimum length



# Braced Connection

- ▣ Building Statistics
- ▣ Structural System
- ▣ Depth Proposal
  - Floor Design
  - Lateral System
  - Moment Connections
  - Braced Connections
- ▣ Electrical Breadth
- ▣ Construction Breadth



## Impact of Redesign

- ▣ Wind clips were eliminated in the E/W direction of the building
- ▣ Field welds limited in connection
- ▣ Shorter brace spans could create more efficient braces
  - Would require adjusting interior columns
- ▣ Impact on lateral loads seen by foundations in these frames

# Electrical Breadth

- ▣ Building Statistics
- ▣ Structural System
- ▣ Depth Proposal
  - Floor Design
  - Lateral System
  - Moment Connections
  - Braced Connections
- ▣ Electrical Breadth
- ▣ Construction Breadth



BRANCH CIRCUIT PANELBOARD SCHEDULE														
<b>Typical Lab</b>		MOUNTING: SURFACE			X		MAIN LUGS ONLY			125 AMP MAIN CB				
120/208V, 3 PHASE, 4 WIRE		FLUSH					SHUNT TRIP MAIN			150 AMP BUS				
10 ,000MIN A.I.C. SYM		IN MCC					FEED THROUGH			GROUND BUS: X				
NEUTRAL: 200%		NUMBER OF POLES:			42					ISOLATED GROUND BUS:				
CKT No.	LOAD	TRIP (AMP)	KW / PHASE			POLES			KW / PHASE			TRIP (AMP)	LOAD	CKT No.
			A	B	C		A	B	C					
1	FUME HOOD RM 191	20	1.80			1	2	1.80			20	FUME HOOD RM 181	2	
3	FUME HOOD RM 191	20		1.80		3	4		1.80		20	FUME HOOD RM 181	4	
5	FUME HOOD RM 191	20			1.80	5	6			1.80	20	FUME HOOD RM 181	6	
7	FUME HOOD RM 191	20	1.80			7	8	1.80			20	FUME HOOD RM 181	8	
9	FUME HOOD RM 191	20		1.80		9	10		1.80		20	FUME HOOD RM 181	10	
11	FUME HOOD RM 191	20			1.80	11	12			1.80	20	FUME HOOD RM 181	12	
13	FUME HOOD RM 171	20	1.80			13	14	1.80			20	FUME HOOD RM 191A	14	
15	FUME HOOD RM 171	20		1.80		15	16		1.50		20	ICEMAKER	16	
17	FUME HOOD RM 171	20			1.80	17	18			0.50	20	SPARE	18	
19	FUME HOOD RM 171	20	1.80			19	20	0.50			20	SPARE	20	
21	FUME HOOD RM 171	20		1.80		21	22		1.80		20	EXT. BLUE LIGHTS	22	
23	FUME HOOD RM 171	20			1.80	23	24				20	SPARE	24	
25	SPARE	20	0.50			25	26	0.60			20	SPARE	26	
27	SPARE	20		0.50		27	28		0.60		20	SPARE	28	
29	SPARE	20			0.50	29	30			0.60	20	SPARE	30	
31	SPARE	20	0.50			31	32				20	RM 181 GAS SHUT OFF	32	
33	RM 191 GAS SHUT OFF	20				33	34		0.50		20	EAV (5)	34	
35	SPARE	20				35	36				20	RM 171 GAS SHUT OFF	36	
37	SIEMENS PANELS	20				37	38				20	SPARE	38	
39	SPARE	20				39	40				20	SPARE	40	
41	SPARE	20				41	42				20	SPARE	42	
SUBTOTALS			8.20	7.70	7.70				6.50	8.00	4.70	SUBTOTALS		
TOTAL LOADS		14.7	KVA PHASE A					DEMAND FACTOR		65%				
		15.7	KVA PHASE B					DEMAND LOAD		27.82		KVA		
		12.4	KVA PHASE C					LOAD X 125%		34.78		KVA		
TOTAL CONN. LOAD		42.8	KVA					AMP		96.60				

## Electrical System Details

- ▣ 1500 KVA Service Transformer
- ▣ 480 / 277V 3-Phase 4-Wire Secondary Feed to 3000-amp Distribution Panel
- ▣ 2 – 150 KVA Emergency Generators
- ▣ 277V T8, T5 and Compact Fluorescent Light Sources with Ballasts


# Construction Breadth

- ▣ Building Statistics
- ▣ Structural System
- ▣ Depth Proposal
  - Floor Design
  - Lateral System
  - Moment Connections
  - Braced Connections
- ▣ Electrical Breadth
- ▣ Construction Breadth



# Construction Breadth

- ▣ Building Statistics
- ▣ Structural System
- ▣ Depth Proposal
  - Floor Design
  - Lateral System
  - Moment Connections
  - Braced Connections
- ▣ Electrical Breadth
- ▣ Construction Breadth



- ▣ Project Start: 8/2008
- ▣ Utilities: 8/2008 8/2008
- ▣ Foundations: 9/2008 2/2009
- ▣ Superstructure: 11/2008 6/2009
- ▣ Exterior: 4/2009 11/2009
- ▣ Interior: 4/2009 4/2010
- ▣ Mech./Plumbing: 4/2009 3/2010
- ▣ Electrical: 1/2009 5/2010
- ▣ Commissioning: 5/2010 7/2010
- ▣ Completion: 8/2010

# Acknowledgements

- ▣ Advisors:
  - Dr. Linda Hanagan
  - Dr. Kevin Parfitt
- ▣ Contacts:
  - Ms. Patricia Chase – Lehigh University
  - Jeff Pritchford – CVM Engineering
  - Eric Holland – Alvin Butz
- ▣ Family: Father, Mother, and Sisters

