





REFERENCES



- American Institute of Steel Construction (AISC). (2005). *Manual of Steel Construction, 14th ed. Design Supplement (AISC XIV)*. Chicago, IL: AISC.
- Berengo, Gianni. *Il Sole 24 Ore Lobby Exterior*. N.d. Photograph. RPBW. Renzo Piano Building Workshop. Web. 17 Mar. 2013. <www.rbpw.com>.
- Berengo, Gianni. *Il Sole 24 Ore Lobby Interior*. N.d. Photograph. RPBW. Renzo Piano Building Workshop. Web. 17 Mar. 2013. <www.rbpw.com>.
- Boothby, Thomas. "A E 401: Design of Steel and Wood Structures for Buildings." 2011. University Park, PA. Lecture.
- "Cement & Concrete Basics: High Strength Concrete." *Cement.org*. Portland Cement Association (PCA). <http://www.cement.org/basics/concreteproducts_histrength.asp>.
- Das, Braja. *Principles of Foundation Engineering, 7th ed.* Stamford, CT: Cengage Learning, 2011. Print.
- Geotechnical Investigation*. Rep. 2nd ed. Wayne, NJ: URS Corporation, 2011. Print.
- Hanagan, Linda. "A E 403: Advanced Steel Design for Buildings." University Park, PA. 2012. Lecture.
- International Code Council, Inc. (ICC). (2009). *International Building Code (IBC)*. Country Club Hills, IL: ICC.
- Lepage, Andres. "A E 530: Computer Modeling of Building Structures." University Park, PA. 2012. Lecture.
- Geschwindner, Louis F. *Unified Design of Steel Structures*. Hoboken, NJ: Wiley, 2008. Print.
- Minimum Design Loads for Buildings and Other Structures (ASCE7-05) and Commentary*. American Society of Civil Engineers, 2005. Print.
- RSMMeans Building Construction Cost Data*. 70th ed. R.S. Means, 2012. Print.



APPENDIX A: TECHNICAL DRAWINGS


ARCHITECTURAL DRAWINGS

















FOUNDATION DRAWINGS





STRUCTURAL DRAWINGS









SECTION NOTES:

1. 所有构件均应按现行规范要求进行配筋。

2. 所有构件均应按现行规范要求进行抗震设计。

3. 所有构件均应按现行规范要求进行防火设计。

4. 所有构件均应按现行规范要求进行防腐设计。

5. 所有构件均应按现行规范要求进行防水设计。

6. 所有构件均应按现行规范要求进行保温设计。

7. 所有构件均应按现行规范要求进行隔声设计。

8. 所有构件均应按现行规范要求进行无障碍设计。

9. 所有构件均应按现行规范要求进行无障碍设计。

10. 所有构件均应按现行规范要求进行无障碍设计。

DHITNEY

RPBW

Structural Engineering

1000 17th Street, NW

Washington, DC 20036

Phone: 202-462-7000

Fax: 202-462-7001

www.dhitney.com

柱截面配筋表	
柱号	配筋
1	...
2	...
3	...
4	...
5	...
6	...
7	...
8	...
9	...
10	...

柱截面配筋表	
柱号	配筋
1	...
2	...
3	...
4	...
5	...
6	...
7	...
8	...
9	...
10	...

SECTION NOTES:

1. 所有构件均应按现行规范要求进行配筋。

2. 所有构件均应按现行规范要求进行抗震设计。

3. 所有构件均应按现行规范要求进行防火设计。

4. 所有构件均应按现行规范要求进行防腐设计。

5. 所有构件均应按现行规范要求进行防水设计。

6. 所有构件均应按现行规范要求进行保温设计。

7. 所有构件均应按现行规范要求进行隔声设计。

8. 所有构件均应按现行规范要求进行无障碍设计。

9. 所有构件均应按现行规范要求进行无障碍设计。

10. 所有构件均应按现行规范要求进行无障碍设计。

DHITNEY

RPBW

Structural Engineering

1000 17th Street, NW

Washington, DC 20036


Phone: 202-462-7000

Fax: 202-462-7001


www.dhitney.com

柱截面配筋表	
柱号	配筋
1	...
2	...
3	...
4	...
5	...
6	...
7	...
8	...
9	...
10	...

柱截面配筋表	
柱号	配筋
1	...
2	...
3	...
4	...
5	...
6	...
7	...
8	...
9	...
10	...



GEOTECHNICAL DOCUMENTS



LEGEND

- ⊙ NB-7 Number and approximate location of additional boring drilled by URS in December 2010
- ⊗ NB-1 Number and approximate location of previous boring drilled by URS in July - August 2009
- ⊙ BS-1 Number and approximate location of URS boring drilled in October 2008 for crosshole seismic test
- B-1 Number and approximate location of previous boring drilled by Langan Engineering in 2006
- B1 Number and approximate location of previous boring drilled by URS in July - August 2007
- ▲ CB-1 Number and approximate location of boring for Cooler Box drilled by URS in March 2008


For 38,800 SF footprint:

Total # borings required by code: 16 (up to 8 can be outside but within 25 ft of footprint)

Total qualifying to date: 16



Boring Location Plan Whitney Museum Chelsea Site New York, New York			
URS WARREN, NEW JERSEY			
DR. BY: CO	SCALE:	PROJ: 11100032	
CHK'D BY: JR	DATE: Jan. 05, 2011	FIG NO: 3	



GEOLOGIC SECTION A-A'
SCALE: HORIZONTAL 1"=40'
VERTICAL 1"=30'

LEGEND


- B1** GEOTECHNICAL BORING DRILLED BY CRAIG TEST BORING AND WARREN GEORGE, INC. UNDER URS SUPERVISION.
- CORE RUN NUMBER**
- ROCK CORE RECOVERY**, EXPRESSED AS A RATIO OF TOTAL LENGTH OF RECOVERED CORE TO THE LENGTH CORED, IN PERCENT
- ROCK QUALITY DESIGNATION** DEFINED AS THE TOTAL LENGTH OF ALL THE PIECES OF CORE 4-INCH OR LARGER DIVIDED BY TOTAL LENGTH OF CORE RUN, IN PERCENT
- N-VALUE**, DEFINED AS NUMBER OF BLOWS OF A 140-LB HAMMER FREE FALLING FOR 30 INCHES REQUIRED TO ADVANCE A STANDARD SPLIT SPOON SAMPLER 12 INCHES AFTER INITIAL 6 INCH PENETRATION
- APPROXIMATE STRATA BOUNDARY**
- WATER LEVEL IN THE OBSERVATION WELL AND DATE OF OBSERVATION**

GENERALIZED SOIL AND ROCK DESCRIPTIONS:

- GENERALIZED SOIL/ROCK DESCRIPTIONS**
- F** - FILL: BROWN, COARSE TO FINE SAND WITH ROCK FRAGMENTS AND TRACE SILT AND BRICK FRAGMENTS. [7]
- O** - ORGANIC SILTY CLAY: SOFT BLACK TO GRAY ORGANIC SILTY CLAY WITH OCCASIONAL SHELLS. [6]
- SC** - CLAYEY SAND: GRAY CLAYEY FINE TO COARSE SAND, WITH OCCASIONAL SHELLS. [6]
- S/G** - SANDS AND GLACIAL TILL: SANDS WITH SOME SILTS AND GRAVELS. [3a TO 3b]
- R** - BEDROCK: BLACK GRAY FINE GRAINED MICA SCHIST, MODERATELY TO HIGHLY WEATHERED, MODERATELY FRACTURED, INTERMEDIATE TO MEDIUM HARD. [1a TO 1d]

GENERAL NOTES:

1. MATERIAL DESCRIPTIONS ARE GENERALIZED AND INCLUDE SAMPLES WITH A NATURAL DEGREE OF VARIATION. SEE BORING LOGS FOR MORE DETAILED DESCRIPTIONS OF THE INDIVIDUAL SAMPLES.
2. DEPTH AND THICKNESS OF SOIL STRATA BOUNDARIES ARE BASED ON INTERPRETATION OF BORINGS AND LABORATORY TEST RESULTS AND ARE SHOWN ONLY TO AID IN VISUALIZING GENERALIZED SUBSURFACE CONDITIONS. BOUNDARIES BETWEEN BORINGS MAY DIFFER FROM THE CONDITIONS SHOWN HEREIN.
3. FOR LOCATION OF PROFILE, SEE FIGURE 3.



GENERALIZED SUBSURFACE PROFILE A-A' WHITNEY MUSEUM-CHelsea SITE NEW YORK, NEW YORK			
URS WARREN, NEW JERSEY			
DR. BY: LH	SCALE: AS SHOWN	FIG. NO. 100032-001	PROJ. NO. 11100032
CHK'D BY: CH	DATE: JANUARY 13, 2011	FIG. NO. 5	

APPENDIX B: INTRODUCTION CALCULATIONS

BUILDING DEAD LOAD CALCULATIONS

Total Dead Load Calculations						
Level	Type	SQ in	SQ ft	Wt/SFt	Wt/flr (k)	
Roof N	31	431080	2994	102	305.35	
483	32	220480	1531	116	177.61	
Roof S	33	154530	1073	161	172.77	
628	34	128723	894	118	105.48	
	35	598722	4158	84	349.25	
Level 9	16	96701	672	99	66.48	
500	37	495578	3442	126	433.63	
Level 8	3	877728	6095	121	737.54	
2002	6	119746	832	98	81.49	
	7	225656	1567	118	184.91	
	8	271800	1888	116	218.95	
	16	415454	2885	99	285.62	
	23	75238	522	112	58.52	
	27	334730	2325	187	434.68	
Level 7	3	1498650	10407	121	1259.28	
2342	6	535436	3718	98	364.39	
	8	69584	483	116	56.05	
	12	123266	856	98	83.89	
	16	40078	278	99	27.55	
	20	83450	580	94	54.47	
	21	103600	719	84	60.43	
	27	335340	2329	187	435.48	
Level 6	2	1897600	13178	136	1792.18	
4188	4	460080	3195	107	341.87	
	12	49612	345	98	33.76	
	13	79600	553	166	91.76	
	16	40078	278	99	27.55	
	19	103640	720	154	110.84	
	28	156520	1087	214	232.61	
	29	988974	6868	203	1394.18	
	30	149084	1035	158	163.58	


Total Dead Load Calculations						
Level		Type	SQ in	SQ ft	Wt/SFt	Wt/flr (k)
Level 5		1	2830400	19656	109	2142.46
	2915	5	172000	1194	158	188.72
		11	84200	585	133	77.77
		16	40078	278	99	27.55
		22	564400	3919	122	478.17
Level 4		6	2801124	19452	98	1906.32
	2589	8	90400	628	116	72.82
		10	93800	651	109	71.00
		12	98340	683	98	66.93
		16	591510	4108	99	406.66
		23	84280	585	112	65.55
Level 3		6	949600	6594	98	646.26
	2155	7	93200	647	118	76.37
		8	205328	1426	116	165.40
		9	458320	3183	181	576.08
		12	26000	181	98	17.69
		16	704038	4889	99	484.03
		23	243288	1690	112	189.22
Level 2		16	265600	1844	99	182.60
	419	36	448300	3113	76	236.60
Level 1		14	1434000	9958	126	1254.75
	4863	15	371600	2581	148	381.92
		16	222000	1542	99	152.63
		24	1222800	8492	186	1579.45
		25	384200	2668	191	509.60
		26	839400	5829	169	985.13
				Totals		
				Sq. ft		Weight (k)
				183882		23084

DL Schedule Summary (S-200.01)			
Floor Type	DL PSF	Floor Type	DL PSF
1	109	21	84
2	136	22	122
3	121	23	112
4	107	24	186
5	158	25	191
6	98	26	169
7	118	27	187
8	116	28	214
9	181	29	203
10	109	30	158
11	133	31	102
12	98	32	116
13	166	33	161
14	126	34	118
15	148	35	84
16	99	36	76
17	124	37	126
18	135		
19	154		
20	94		

SNOW LOAD CALCULATIONS

	ASCE 7-05 SNOW LOADS	1/1
<p>GROUND SNOW LOAD: 7.2</p> <p>$p_g = 25 \text{ PSF}$ (FIGURE 7-1) - verified by structural notes, city BC</p> <p>FLAT ROOF SNOW LOADS 7.3</p> <p>$p_f = 0.7 C_e C_t I p_g$, $p_{f, \min} = \begin{cases} I p_g & (p_g \leq 20 \text{ PSF}) \\ 20 I & (p_g > 20 \text{ PSF}) \end{cases}$</p> <p>EQN 7-1</p> <p>EXPOSURE FACTOR 7.3.1</p> <p>TERRAIN CATEGORY "C" (WIND CALCS p1, ASCE 7-05 6.5.6) PARTIALLY EXPOSED ROOF</p> <p>$C_e = 1.0$ (TABLE 7-2) - verified by structural notes</p> <p>THERMAL FACTOR 7.3.2</p> <p>$C_t = 1.0$ (TABLE 7-3) - verified by structural notes</p> <p>IMPORTANCE FACTOR 7.3.3</p> <p>OCCUPANCY III</p> <p>$I = 1.15$ - verified by structural notes</p> <p>$p_f = 0.7 \cdot 1.0 \cdot 1.0 \cdot 1.15 \cdot 25 = 21 \text{ PSF}$</p> <p>$p_{f, \min} = 20 I = 20 \cdot 1.15 = 23 \text{ PSF}$ * CONTROLS</p> <p>* DRAWINGS DENOTE 22 PSF FOR p_f. LIKELY ASSUME LL WILL CONTROL</p>		

WIND LOAD CALCULATIONS



Wall Pressures								
E-W				qGfCp	qiGCpi	WW	LW	Pressure
Level	ht	Kz	qz	Cp	-0.55	0.8	-0.3	PSF
RN	160	1.39	33.41	23.793	-18.37	42.17	-7.72	49.89
RS	142	1.36	32.68	23.279	-17.98	41.26	-7.72	48.98
9	140	1.36	32.68	23.279	-17.98	41.26	-7.72	48.98
8	124	1.32	31.72	22.595	-17.45	40.04	-7.72	47.76
7	102	1.26	30.28	21.568	-16.65	38.22	-7.72	45.94
6	78	1.21	29.08	20.712	-15.99	36.71	-7.72	44.43

Equivalent Point Loads					
E-W	Pressure	hi	Dist Ld	Bx	Px
Level	PSF	ft	plf	ft	k
RN	49.89	10	498.9	55.8	27.9
RS	48.98	9	1348.3	53.8	72.5
9	48.98	18	1789.1	55.8	99.9
8	47.76	19	1964.3	113.7	223.3
7	45.94	23	1589.9	118.3	188.1
Vb =	611.6 k		Mover =	27902.3 kft	

Wall Pressures								
N-S				qGfCp	qiGCpi	WW	LW	Pressure
Level	ht	Kz	qz	Cp	-0.55	0.8	-0.5	PSF
RN	160	1.39	33.41	22.631	-18.37	41.00	-13.38	54.38
RS	142	1.36	32.68	22.143	-17.98	40.12	-13.38	53.50
9	140	1.36	32.68	22.143	-17.98	40.12	-13.38	53.50
8	124	1.32	31.72	21.491	-17.45	38.94	-13.38	52.32
7	102	1.26	30.28	20.515	-16.65	37.17	-13.38	50.55
6	78	1.21	29.08	19.700	-15.99	35.69	-13.38	49.07

Equivalent Point Loads					
N-S	Pressure	ht	Dist Ld	By	Py
Level	PSF	ft	plf	ft	k
RN	54.38	10	543.8	150.3	81.7
RS	53.50	9	1527.9	143.8	219.8
9	53.50	18	2009.4	150.3	301.9
8	52.32	20	2209.0	191.2	422.3
7	50.55	23	1162.6	229.2	266.4
Vb =	1292.1 k		Mover =	65303.3 kft	

Wind Factors		
	E - W	N - S
Gf =	0.89	0.85
GC pi =	0.55	-
Cp =	-0.3	-0.5
Kd =	0.85	-
Kzt =	1.0	-
l =	1.15	-

Inherent Moments						
	Bx	ex	Mtx	By	ey +	Mt +
Level	ft	ft	k-in	ft	ft	k-in
RN	55.8	8.4	2799	150.3	22.5	22099
RS	53.8	8.1	7014	143.8	21.6	56896
9	55.8	8.4	10039	150.3	22.5	81651
8	113.7	17.1	45681	191.2	28.7	145310
7	118.3	17.8	40072	229.2	34.4	109905

SEISMIC LOAD CALCULATIONS

	Seismic Loads						E-W Direction				N-S Direction							
	Ht (ft)	hi	W (k)	wh ^k	Cvx	fi	Vi	Bx	5%Bx	Ax	RS	Mz (ft-k)	By	5%By	Ay	RS	Mzy (ft-k)	
RN	160	20	841	21539881	0.2278	192	192	150	7.5	22.7		32649	56	2.8	7.1		3809	
RS	142	18	649	13092727	0.1385	90	282	144	7.2	70.2	13.2	8558	54	2.7	278.9	1.0	242	
9	140	16	678	13281336	0.1405	95	377	150	7.5	11.6		8326	56	2.8	11.4		3040	
8	124	22	1674	25746066	0.2723	456	833	191	9.6	2.3		9942	114	5.7	2.8		7333	
7	102	24	2007	20876383	0.2208	443	1276	229	11.5	1.0		5077	118	5.9	1.0		2622	
k		2	Σ 5849	94536394			Vb = 1276											
T		1.53 s					Mov = 158514											




FIGURE 12.8-1 TORSIONAL AMPLIFICATION FACTOR, A_t

Amplification Factor Analysis							RS Alternative					
E-W	$(\delta_{xe})_1$	Δ_{x1}	$(\delta_{xe})_2$	Δ_{x2}	Δ_{avg}	$\Delta_{max}/\Delta_{avg}$	$(\delta_{xe})_1$	Δ_{x1}	$(\delta_{xe})_2$	Δ_{x2}	Δ_{avg}	$\Delta_{max}/\Delta_{avg}$
RN	1.057	0.236	1.054	0.134	0.1850	1.28 *						
RS	0.821	0.041	0.920	0.142	0.0915	1.55 *	0.556	0.128	0.705	0.195	0.1615	1.21
9	0.780	0.191	0.778	0.19	0.1905	1.00						
8	0.589	0.32	0.588	0.33	0.3250	1.02	0.428		0.510			
7	0.269	0.269	0.258	0.258	0.2635	1.02						
	$(\delta_{ye})_1$	Δ_{y1}	$(\delta_{ye})_2$	Δ_{y2}	Δ_{avg}	$\Delta_{max}/\Delta_{avg}$	$(\delta_{ye})_1$	Δ_{y1}	$(\delta_{ye})_2$	Δ_{y2}	Δ_{avg}	$\Delta_{max}/\Delta_{avg}$
RN	0.183	0.053	-0.238	-0.102	-0.0245	4.16 *						
RS	0.130	0.01	-0.136	-0.016	-0.0030	5.33 *	0.308	0.135	0.274	0.100	0.1175	1.15
9	0.120	0.041	-0.120	-0.061	-0.0100	6.10 *						
8	0.079	0.042	-0.059	-0.043	-0.0005	86.00 *	0.173		0.174			
7	0.037	0.037	-0.016	-0.016	0.0105	3.52 *						
N-S	$(\delta_{xe})_1$	Δ_{x1}	$(\delta_{xe})_2$	Δ_{x2}	Δ_{avg}	$\Delta_{max}/\Delta_{avg}$	$(\delta_{xe})_1$	Δ_{x1}	$(\delta_{xe})_2$	Δ_{x2}	Δ_{avg}	$\Delta_{max}/\Delta_{avg}$
RN	0.185	0.032	0.183	0.032	0.0320	1.00						
RS	0.153	0.007	0.151	0.006	0.0065	1.08	0.062	0.023	-0.045	-0.004	0.0095	2.42
9	0.146	0.03	0.145	0.03	0.0300	1.00						
8	0.116	0.038	0.115	0.037	0.0375	1.01	0.039		-0.041			
7	0.078	0.078	0.078	0.078	0.0780	1.00						
	$(\delta_{ye})_1$	Δ_{y1}	$(\delta_{ye})_2$	Δ_{y2}	Δ_{avg}	$\Delta_{max}/\Delta_{avg}$	$(\delta_{ye})_1$	Δ_{y1}	$(\delta_{ye})_2$	Δ_{y2}	Δ_{avg}	$\Delta_{max}/\Delta_{avg}$
RN	0.123	-0.829	0.978	0.218	-0.3055	2.71 *						
RS	0.952	0.053	0.760	0.042	0.0475	1.12	1.039	0.284	1.087	0.341	0.3125	1.09
9	0.899	0.245	0.718	0.198	0.2215	1.11						
8	0.654	0.342	0.520	0.306	0.3240	1.06	0.755		0.746			
7	0.312	0.312	0.214	0.214	0.2630	1.19						

Seismic Design Criteria			
S-200.01		ASCE 7-05	
S _{ds}	0.65	T _a (s)	0.9
S _{d1}	0.13	C _u	1.7
I	1.25	T (s)	1.53
R	3	T _L (s)	6
W (k)	5849		
C _s	0.0602		

Amp Factor Maximums				RS Alternative		
	δ_{EW}	Δ_{avg}	$\Delta_{max}/\Delta_{avg}$	δ_{EW}	Δ_{avg}	$\Delta_{max}/\Delta_{avg}$
RN	1.057	0.185	5.71			
RS	0.920	0.092	10.05	0.705	0.1615	1.21
9	0.780	0.191	4.09			
8	0.589	0.325	1.81			
7	0.269	0.264	1.02			
	δ_{NS}	Δ_{avg}	$\Delta_{max}/\Delta_{avg}$	δ_{NS}	Δ_{avg}	$\Delta_{max}/\Delta_{avg}$
RN	0.978	-0.31	3.20			
RS	0.952	0.05	20.04	1.087	0.3125	1.09
9	0.899	0.22	4.06			
8	0.654	0.32	2.02			
7	0.312	0.26	1.19			

APPENDIX C: CUSTOM MEMBER STRENGTHS

MEMBERS SPECIFIED IN CURRENT DESIGN

PLATE GIRDERS

Plate Element Dimensions (in)						
Shape	B	tf	nf	D	tw	h
32.5	18	4	1	32.5	2	24.5
33-1	18	4	1	33	2	25
44-1	18	4	1	44	2	36
46-1	18	2	1	46	1	42
46-2	20	4	2	46	2	30
46-3	18	4	1	46	2	38
72-1	16	3	1	72	2	66
L	20 ft					
Weld size	0.5 in					

Material Properties	
ϕ	0.9
E	29000 ksi
Fy	50 ksi
G	11200 ksi
K	1.0

Note: Dimensions taken from drawing S-211

Section Properties																
	Individual Flange								Web		Total					
	A	x	Ax	Ax2	y	Ay2	Iox	Ioy	A	Ax	A	Ixx	Iyy	rx	ry	WT (plf)
32.5	72	14.25	1026	14620.5	5	1458.0	96.0	1944.0	49	600	193	29433	6804	12	6	656
33-1	72	14.5	1044	15138.0	5	1458.0	96.0	1944.0	50	625	194	30468	6804	13	6	659
44-1	72	20	1440	28800.0	5	1458.0	96.0	1944.0	72	1296	216	57792	6804	16	6	734
46-1	36	22	792	17424.0	5	729.0	12.0	972.0	42	882	114	34872	3402	17	5	388
46-2	160	19	3040	57760.0	5	4000.0	853.3	5333.3	60	900	380	117227	18667	18	7	1291
46-3	72	21	1512	31752.0	5	1458.0	96.0	1944.0	76	1444	220	63696	6804	17	6	748
72-1	48	34.5	1656	57132.0	4	768.0	36.0	1024.0	132	4356	228	114336	3584	22	4	775

Tensile Strength	
	ϕT_n (k)
32.5	8685
33-1	8730
44-1	9720
46-1	5130
46-2	17100
46-3	9900
72-1	10260

Flexural Strength													
	Flange Compactness				Web Compactness				Yielding		Max Unbr Length (Lp)		
	bf/2tf	λ_p	λ_r		h/tw	λ_p	λ_r		Z	ϕM_n (ft-k)	in	ft	
32.5	2.25	9.2	24.1	C	12.3	90.6	137.3	C	3252.5	12197	214	18	
33-1	2.25	9.2	24.1	C	12.5	90.6	137.3	C	3338	12518	214	18	
44-1	2.25	9.2	24.1	C	18.0	90.6	137.3	C	5472	20520	202	17	
46-1	4.50	9.2	24.1	C	42.0	90.6	137.3	C	3348	12555	197	16	
46-2	2.50	9.2	24.1	C	15.0	90.6	137.3	C	7880	29550	253	21	
46-3	2.25	9.2	24.1	C	19.0	90.6	137.3	C	5912	22170	201	17	
72-1	2.67	9.2	24.1	C	33.0	90.6	137.3	C	12024	45090	143	12	

	Compressive Strength																			
	Flange Slenderness				Web Slenderness				Flexural Buckling				Torsional Buckling				Compressive Strength			
	b/2tf	Kc'	Kc	λ_r	h/tw	λ_r	KL/r	KL/r Limit	Fe flex	Fcr flex	ho	Cw	J	Fe tors	Fcr tors	Fcr	Ph	ϕP_n		
32.5	2.25	1.14	0.76	13.44	NS	12.25	35.88	NS	19.4	113	758	48.6	29	1381637	460	332	46.9	46.9	9060	8154
33-1	2.25	1.13	0.76	13.44	NS	12.50	35.88	NS	19.2	113	780	48.7	29	1430541	461	329	46.9	46.9	9103	8193
44-1	2.25	0.94	0.76	13.44	NS	18.00	35.88	NS	14.7	113	1330	49.2	40	2721600	491	294	46.6	46.6	10059	9053
46-1	4.50	0.62	0.62	12.11	NS	42.00	35.88	S	-	-	-	-	-	-	-	-	-	-	-	-
46-2	1.25	1.03	0.76	13.44	NS	15.00	35.88	NS	13.7	113	1533	49.3	38	6738667	3515	536	48.1	48.1	18273	16445
46-3	2.25	0.92	0.76	13.44	NS	19.00	35.88	NS	14.1	113	1439	49.3	42	3000564	496	290	46.5	46.5	10235	9211
72-1	2.67	0.70	0.70	12.86	NS	33.00	35.88	NS	10.7	113	2492	49.6	69	4265856	328	211	45.3	45.3	10323	9291

HSS ROUND SECTIONS

22R

Section Properties										AISC Chapter I			
Concrete		Reinforcement		Pipe				Compression Capacity					
wt	145 pcf	fy	150 ksi	fy	46 ksi	Do	22 in	NO SLENDER ELEMENTS					
f'c	8000 psi	Esr	29000 ksi	Es	29000 ksi	t	1.25 in	FyAs	3471				
				wt	490 pcf			C2	0.95				
		Callout	11			td	1.16	AsrEs/Ec	17.75				
Ag	299 in2	Ai	1.56 in2	Isx	64638.9 in4	Di	19.5 in						
Ec	5098 ksi	n	2	Zx	496.8 in3	Dd	21.8	Pno	5852				
Ig	7098 in4	Asr	3.12 in2	ρ	0.202 OK	Ast	75.5 in2	φPn	4389 k				
Slenderness Checks										Tensile Capacity			
AISC XIV Chapter I										Asfy 3471 k			
Pipe Slenderness λ _p λ _r Max										AsrFysr 468 k			
D/t	18.92 <	95	120	195	C	Compression				Tno 3939			
		57	195	195	C	Flexure				φTn 3545 k			
ACI 318-11 Chapter 10										Flexural Capacity			
Composite Shape Slenderness										SLENDERNESS NOT CONSIDERED			
Eclg	36184968	rcomp	27.5							Yielding			
EcAg	1522576	K	1.0							Mp=FyZ 22855 in-k			
EsIsx	1874528059	L	45							φMn 1714 ft-k			
EsAsx	2188385	KL/r	19.7	22	KL/r Limit								
SLENDERNESS NOT CONSIDERED													

15A

Section Properties										AISC Chapter I			
Concrete		Reinforcement		Pipe				Compression Capacity					
wt	145 pcf	fy	150 ksi	fy	46 ksi	Do	15 in	NO SLENDER ELEMENTS					
f'c	8000 psi	Esr	29000 ksi	Es	29000 ksi	t	1.25 in	FyAs	2295				
				wt	490 pcf			C2	0.95				
		Callout	11			td	1.16	AsrEs/Ec	0.00				
Ag	123 in2	Ai	1.56 in2	Isx	18763 in4	Di	12.5 in						
Ac	123 in2	n	0	Zx	217.5 in3	Dd	14.83	Pno	3228				
Ec	5098 ksi	Asr	0 in2	ρ	0.289 OK	Ast	49.9 in2	φPn	2421 k				
Ig	1198 in4												
Slenderness Checks										Tensile Capacity			
AISC XIV Chapter I										Asfy 2295 k			
Pipe Slenderness λ _p λ _r Max										AsrFysr 0 k			
D/t	12.90 <	95	120	195	C	Compression				Tno 2295			
		57	195	195	C	Flexure				φTn 2066 k			
ACI 318-11 Chapter 10										Flexural Capacity			
Composite Shape Slenderness										SLENDERNESS NOT CONSIDERED			
Eclg	6109839	rcomp	18.6							Yielding			
EcAg	625648	K	1.0							Mp=FyZ 10006 in-k			
EsIsx	544119416	L	25							φMn 750 ft-k			
EsAsx	1447008	KL/r	16.1	22	KL/r Limit								
SLENDERNESS NOT CONSIDERED													

15B

Section Properties										AISC Chapter I				
Concrete			Reinforcement			Pipe				Compression Capacity				
wt	145 pcf		fy	150 ksi		fy	46 ksi	Do	15 in	NO SLENDER ELEMENTS				
f'c	8000 psi		Esr	29000 ksi		Es	29000 ksi	t	1 in	FyAs	1872			
						wt	490 pcf			C2	0.95			
Ag	133 in2	Callout	11					td	0.93	AsrEs/Ec	0.00			
Ac	133 in2	Ai	1.56 in2			Isx	15865 in4	Di	13 in					
Ec	5098 ksi	n	0			Zx	180.7 in3	Dd	14.86	Pno	2881			
Ig	1402 in4	Asr	0 in2			p	0.235 OK	Ast	40.7 in2	φPn	2161 k			
Slenderness Checks										Tensile Capacity				
AISC XIV Chapter I										Asfy				1872 k
Pipe Slenderness		λp	λr	Max						AsrFysr	0 k			
D/t	16.13 <	95	120	195	C	Compression								
		57	195	195	C	Flexure				Tno	1872			
ACI 318-11 Chapter 10										φTn				1685 k
Composite Shape Slenderness										Flexural Capacity				
Eclg	7147648	rcomp	18.7							SLENDERNESS NOT CONSIDERED				
EcAg	676700	K	1.0							Yielding				
EsIsx	460092980	L	25							Mp=FyZ	8314 in-k			
EsAsx	1180272	KL/r	16.0	22	KL/r Limit					φMn	624 ft-k			
SLENDERNESS NOT CONSIDERED														

PG56-1 EQUIVALENT CROSS SECTION


Material Properties		Section Properties				Flexure Design		
fy	50 ksi	Single Flange		Web		Total		
E	29000 ksi	A	160	A	120	A	440 in ²	Flange Compactness
G	11200 ksi	x	34	x	0.5	Ixx	185813 in ⁴	B/2tf λp λr
dens	490 PCF	Ax	5440	Ax	60	rx	20.6 in	1.25 9.2 24.1 C
	0.284 pci	Ax2	184960			Zx	10940 in ³	Web Compactness
Plate Properties		Ixo	853.33			Iyy	9333.33 in ⁴	hw/tw λp λr
Lb	15 ft	y	5			ry	4.6 in	30 90.6 137.3 C
D	76 in	Ay	800			J	6986.67	SLENDERNESS NOT CONSIDERED
B	20 in	Ay2	4000			Weight	1497 PLF	Limit State 1 Yielding
tf	8 in	Iyo	5333.3					Mp 547000 in-k
tw	2 in							Limit State 2 LTB
hw	60 in							Lb 180 in
ho	68 in							Lp 195.2 in
Compression Design								LTB DOES NOT APPLY
Flange Slenderness								φMn 41025 ft-k
B/2tf	K'c	Kc	λr					
1.25	0.730	0.7303	13.2	NS				
Web compactness								Tension Design
hw/tw	λr							Yielding
30	35.9	NS						φTn 19800 k
SLENDERNESS NOT CONSIDERED								RUPTURE MUST BE CONSIDERED
Limit State 1		Flexural Buckling						Shear Design
K		1.0						Traverse Stiffeners
L		180						hw/tw hw/tw Limit
KL/r		8.8	113.4	KL/r Limit				30 59.2
Fe		3731 ksi		E3-2				NO STIFFENERS REQUIRED
Fcr		49.7 ksi						kv 5
Limit State 2		Torsional Buckling						Cv = 1.0
Cw		1E+07 in ⁶						hw/tw Limit 59.2
Fe		889 ksi						Cv 1.0
Fcr		48.8 ksi						Vn 4560
φPn		21488 k						φVn 4104 k


24R-1

Section Properties							AISC Chapter I				
Concrete		Reinforcement		Pipe			Compression Capacity				
wt	145 pcf	fy	150 ksi	fy	46 ksi	Do	24 in	NO SLENDER ELEMENTS			
f'c	15000 psi	Esr	29000 ksi	Es	29000 ksi	t	1.75 in	FyAs	5204		
				wt	490 pcf			C2	0.95		
		Callout	11			td	1.63	AsrEs/Ec	103.69		
Ag	330 in2	Ai	1.56 in2	Isx	111388.7 in4	Di	20.5 in				
Ec	6981 ksi	n	16	Zx	798.3 in3	Dd	23.755	Pno	11030		
Ig	8669 in4	Asr	24.96 in2	ρ	0.255 OK	Ast	113.1 in2	φPn	8272 k		
Slenderness Checks							Tensile Capacity				
AISC XIV Chapter I							Asfy	5204 k			
Pipe Slenderness							AsrFysr	3744 k			
		λp	λr	Max							
D/t	13.71	<	95	120	195	C	Compression	Tno	8948		
			57	195	195	C	Flexure	φTn	8053 k		
ACI 318-11 Chapter 10							Flexural Capacity				
Composite Shape Slenderness							SLENDERNESS NOT CONSIDERED				
Eclg	60520963	rcomp	29.4								
EcAg	2304189	K	1.0								
EsIsx	3230271344	L	25								
EsAsx	3280962	KL/r	10.2	22	KL/r Limit						
SLENDERNESS NOT CONSIDERED							Yielding				
							Mp=FyZ	36722 in-k			
							φMn	2754 ft-k			


APPENDIX D: ETABS VERIFICATION

HAND CALCULATIONS





MEMBER SELECTION TABLE



Truss Loads												Trial Member Selection					
	L	Pdx	Pdy	Plx	Ply	Pd	PL	1.2Pd	1.6Pl	Pu	T/C	p max	L	p	Trial Size	ϕP_n	
D	1	33.8	703	909	512	662	1149	837	1379	1339	2718	C	0.368	18	0.325	W14x 283	3077
	2	32.2	892	1124	635	800	1435	1021	1722	1634	3356	C	0.298	18	0.266	W14x 342	3759
	3	29.7	751	845	726	817	1130	1093	1357	1749	3105	T	0.322	0	0.271	W14x 342	3690
	4	23.3	844	1780	421	894	1970	988	2364	1581	3945	T	0.253	0	0.204	W14x 455	4902
T	1	20	703		512		703	512	843.6	819.2	1663	T	0.601	0	0.521	W27x 178	1919
	2	20	1595		1147		1595	1147	1914	1835	3749	T	0.267	0	0.172	W27x 539	5814
	3	20	844		421		844	421	1013	673.6	1686	T	0.593	0	0.575	W27x 161	1739
	4	10	468		146		468	146	561.6	233.6	795.2	T	1.258	0	0.575	W27x 161	1739
B	1	20.05	0		0		0	0	0	0	0	C	0.597	22	0.552	W27x 217	1812
	2	20.16	703	88	512	64	708	516	850.2	825.6	1676	C	0.597	22	0.552	W27x 217	1812
	3	20.16	1595	200	1147	150	1607	1157	1929	1851	3780	C	0.265	22	0.205	W27x 539	4878
	4	10.08	844	105	421	64	851	426	1021	681.3	1702	C	0.588	12	0.54	W27x 161	1852
V	1	28	880		618		880	618	1056	988.8	2045	T	0.489	0	0.482	W14x 193	2075
	2	27.3	1069		712		1069	712	1283	1139	2422	T	0.413	0	0.399	W14x 233	2506
	3	25.2	874		773		874	773	1049	1237	2286	C	0.438	14	0.406	W14x 211	2463
	4	22	885		585		885	585	1062	936	1998	C	0.501	14	0.487	W14x 176	2053
	5	21.1	1865		954		1865	954	2238	1526	3764	C	0.266	14	0.247	W14x 342	4049

APPENDIX E: TRUSS DESIGN CALCULATIONS

EXTERIOR WALL ALLOCATION

TRUSS 0.9

Truss 0.9																
Wt	15	PSF	G		H		I		J		K		L		L.5	
L	Elev.	Ht	W	Wt	W	Wt	W	Wt	W	Wt	W	Wt	W	Wt	W	Wt
9	151.67	9.1	20	2.73	20	2.73	11.5	1.57								
8	133.5	19.9	20	5.98	20	5.98	20	5.98	17.1	5.11	8.67	2.59				
7	111.83	22.7	20	6.80	20	6.80	20	6.80	20	6.80	20	6.80	14.33	4.87	5	1.70
6	88.17	23.7	20	7.10	20	7.10	20	7.10	20	7.10	20	7.10	14.33	5.09	5	1.78
Loads Applied			22.6 k		22.6 k		21.4 k		19.0 k		16.5 k		10.0 k		3.5 k	
L	Elev.	Ht.	KLF													
5	64.5	11.8	0.18													

TRUSS X

Truss X								
AREA		H	I	J	K	L	M	M.5
L	Elev.	20	40	60	80	100	120	130
5	64.5	138.3	138.3	138.3	138.3	138.3	172.9	34.6
4	50.67	283.4	283.4	283.4	283.4	283.4	283.4	283.4
3	36.5	245.0	245.0	219.6	165.2	110.8	56.4	29.2
2	24.25	83.4	29.0					
Bottom		20.08	22.8	25.52	28.24	30.96	33.68	35.04
LOAD		Wt = 15		PSF				
L	Elev.	H	I	J	K	L	M	M.5
5	24.25	2.1	2.1	2.1	2.1	2.1	2.6	0.5
4	50.67	4.3	4.3	4.3	4.3	4.3	4.3	4.3
3	36.5	3.7	3.7	3.3	2.5	1.7	0.8	0.4
2	24.25	1.3	0.4					

TRUSS 0.9

LEVEL 6 LOADS

Z*-G									
Level	Area	DL	DW	DC	LL	SL	D	L	S
9	520	84	2.73	2	50	22	48.4	26.0	11.4
8	590	121	5.98	2	150	0	79.4	88.5	0.0
7	660	121	6.80	2	100	0	88.7	66.0	0.0
6	390	148	7.10	2	130	4.4	66.8	50.7	1.7
Total = 283 231 13									

G.5									
Level	Area	DL	DW	DC	LL	SL	D	L	S
6	390	152.1	0	0	130	4.4	59.3	50.7	1.7

W*-H									
Level	Area	DL	DW	DC	LL	SL	D	L	S
9	470	84	2.73	2	50	22	44.2	23.5	10.3
8	530	121	5.98	2			72.1	0.0	0.0
7	580	121	6.80	2	100		79.0	58.0	0.0
6	390	156	7.10	2	130	4.4	70.0	50.7	1.7
Total = 265 132 12									

H.5									
Level	Area	DL	DW	DC	LL	SL	D	L	S
6	390	157.8	0	0	140	2.2	61.5	54.6	0.9

W*-I									
Level	Area	DL	DW	DC	LL	SL	D	L	S
9	280	84	1.57	2	50	22	27.1	14.0	6.2
8	500	154	5.98	2	125	0	85.0	62.5	0.0
7	550	121	6.80	2	100	0	75.3	55.0	0.0
6	390	159	7.10	2	150	0	71.3	58.5	0.0
Total = 259 190 6									

I.5									
Level	Area	DL	DW	DC	LL	SL	D	L	S
6	390	162.8	0	0	150	0	63.5	58.5	0.0

W*-J									
Level	Area	DL	DW	DC	LL	SL	D	L	S
8	365	187	5.11	2	100	0	75.4	36.5	0.0
7	530	121	6.80	2	100	0	72.9	53.0	0.0
6	390	166	7.10	2	150	0	73.9	58.5	0.0
Total = 222 148 0									

J.5									
Level	Area	DL	DW	DC	LL	SL	D	L	S
6	390	168	0	0	150	0	65.5	58.5	0.0

W*-K									
Level	Area	DL	DW	DC	LL	SL	D	L	S
8	245	187	2.59	2	100	0	50.4	24.5	0.0
7	520	146	6.80	2	100	0	84.8	52.0	0.0
6	390	170	7.10	2	150	0	75.2	58.5	0.0
Total = 210 135 0									

K.5									
Level	Area	DL	DW	DC	LL	SL	D	L	S
6	390	173	0	0	150	0	67.4	58.5	0.0

W*-L									
Level	Area	DL	DW	DC	LL	SL	D	L	S
7	370	183	4.87	2	100	0	74.6	37.0	0.0
6	364	176	5.09	2	150	0	71.2	54.6	0.0
Total = 146 92 0									

W*-L5									
Level	Area	DL	DW	DC	LL	SL	D	L	S
7	150	183	1.70	2	100	0	31.1	15.0	0.0
6	372	183	1.78	2	150	0	71.9	55.9	0.0
Total = 103 71 0									

W*-M									
Level	Area	DL	DW	DC	LL	SL	D	L	S
6	411	203	0.00	2	150	0	85.5	61.7	0.0

M.5									
Level	Area	DL	DW	DC	LL	SL	D	L	S
6	390	203	33.00	2	150	0	114.2	58.5	0.0

LEVEL 5 LOADS

Load Information		
Wall Load	0.18	KLF
Dead Load	109	PSF
Live Load	200	PSF
Grid Angle	9	deg
	0.157	rad
Trib Angle	0.079	rad

Grid	X	X Trib			Y Trib				Load Components					Loads	
		Start	End	Dx	Base	Start	End	Dy	At	AD	PW	PC	AL	PD	PL
F	0	0	5	5	0.31	0.31	0.70	0.39	2.5	0.3	3.6	2	0.5	5.8	0.5
F.5	10	5	15	10	1.09	0.70	1.49	0.79	10.9	1.2			2.2	1.2	2.2
G	20	15	25	10	1.88	1.49	2.27	0.79	18.8	2.0	3.6	2	3.8	7.6	3.8
G.5	30	25	35	10	2.67	2.27	3.06	0.79	26.7	2.9			5.3	2.9	5.3
H	40	35	45	10	3.45	3.06	3.85	0.79	34.5	3.8	3.6	2	6.9	9.3	6.9
H.5	50	45	55	10	4.24	3.85	4.63	0.79	42.4	4.6			8.5	4.6	8.5
I	60	55	65	10	5.03	4.63	5.42	0.79	50.3	5.5	3.6	2	10.1	11.0	10.1
I.5	70	65	75	10	5.81	5.42	6.21	0.79	58.1	6.3			11.6	6.3	11.6
J	80	75	85	10	6.60	6.21	7.00	0.79	66.0	7.2	3.6	2	13.2	12.7	13.2
J.5	90	85	95	10	7.39	7.00	7.78	0.79	73.9	8.1			14.8	8.1	14.8
K	100	95	105	10	8.18	7.78	8.57	0.79	81.8	8.9	3.6	2	16.4	14.5	16.4
K.5	110	105	115	10	8.96	8.57	9.36	0.79	89.6	9.8			17.9	9.8	17.9
L	120	115	125	10	9.75	9.36	10.14	0.79	97.5	10.6	3.6	2	19.5	16.2	19.5
L.5	130	125	135	10	10.54	10.14	10.93	0.79	105.4	11.5			21.1	11.5	21.1
M	140	135	145	10	11.32	10.93	11.72	0.79	113.2	12.3	3.8	2	22.6	18.2	22.6
M.5	150	145	155.75	10.8	12.11	11.72	12.56	0.85	130.5	14.2			26.1	14.2	26.1
N.2	162	155.8	161.5	5.75	13.02	12.56	13.02	0.45	73.5	8.0	2.0	2	14.7	12.1	14.7

REACTIONS

Reactions (k)		
Level 6	H	N.2
D	0	340
L	0	244
S	0	0.5
Level 5		
D	1112	404
L	747	295
S	18	0.5

TRUSS N.2

Load Properties			
	Level 6	Level 5	
Trib W	6.5	6.5	ft
DL	203	109	PSF
LL	150	200	PSF
Distributed Loads			
wD	1.3	0.7	k/ft
wL	1.0	1.3	k/ft
Point Loads			
Pd	340	404	k
Pl	244	295	k
Reactions			
	N.2	6	
D	1340	-350	
L	945	-252	
S	2	-1	

TRUSS X

LOAD SUMMARY

Level	J	J.5	K	K.5	L	L.5	M	M.5	N.2
5 D	2.1	24.0	26.1	24.0	2.1	32.7	50.9	51.6	1340.0
L		44.0	44.0	44.0		60.0	85.0	90.0	945.0
S									2.0
4 D	17.5		31.7		22.6		45.9	16.9	
L	6.8		14.0		10.3		18.4	5.0	
3 D	19.2		34.1		9.1		3.6	1.5	
L	6.8		12.1		9.0		0.0	0.0	

Load	Reaction (k)	
	J	L
D	-1072	3392
L	-787	2419
S	-2	4
Pu	-2547	7943

AREA TAKEOFF

X-H							X-J.5							X-M							
Level	Area	DL	DW	DC	LL	L	Level	Area	DL	DW	DC	LL	L	Level	Area	DL	DW	DC	LL	L	
2	170	20	1.3	0.5	0	5.2	5	220	109	0	0	200	24.0	5	425	109	2.6	2	200	50.9	85.0
						0.0	4	120	98	0	0	50	11.8	4	250	98	4.3	2	50	34.4	12.5
							3	125	118	0	0	50	14.8	4(3)	350	15	0.0	0	0	5.3	0.0
														3	100	15	0.8	0.5	0	2.8	0.0
X-H.5							X-K							X-M.5							
Level	Area	DL	DW	DC	LL	L	Level	Area	DL	DW	DC	LL	L	Level	Area	DL	DW	DC	LL	L	
5	220	109	0	0	200	24.0	5	220	109	2.1	0	200	26.1	5	450	109	0.5	2	200	51.6	90.0
4	170	98	0	0	50	16.7	4	130	98	4.3	2	50	19.0	4	100	98	4.3	2	50	16.9	5.0
3	200	118	0	0	50	23.6	3	135	115	2.5	2	100	20.0	4(3)	85	15	0	0	0	1.3	0.0
2	80	20	0.0	0.5	0	2.1								3	40	15	0.4	0.5	0	1.5	0.0
						0.0	X-K.5							X-L.5							
Level	Area	DL	DW	DC	LL	L	Level	Area	DL	DW	DC	LL	L	Level	Area	DL	DW	DC	LL	L	
5	220	109	2.1	0	200	26.1	5	220	109	0	0	200	24.0	5	300	109	0	0	200	32.7	60.0
4	160	98	4.3	2	50	21.9	4	115	98	0	0	50	13.7	4	235	98	0	0	50	23.0	11.8
3	215	118	3.7	2	50	33.3	4(3)	85	112	0	0	150	9.5	3	95	15	0	0	0	1.4	0.0
3(2)	160	20	0	0	0	3.2	3	120	112	0	0	150	13.4	2	50	20	0	0.5	0	1.5	0.0
2	66	20	0.4	0.5	0	2.3								X-I.5							
Level	Area	DL	DW	DC	LL	L	Level	Area	DL	DW	DC	LL	L								
5	220	109	0	0	200	24.0	5	220	109	0	0	200	24.0	4	150	98	0	0	50	14.7	7.5
4	150	98	0	0	50	14.7	3	145	118	0	0	50	17.1	2	50	20	0	0.5	0	1.5	0.0
3	145	118	0	0	50	17.1	2	50	20	0	0.5	0	1.5								

TRUSS J

Area Takeoff								
Dead Loads				4			0.9	
	w	D	wD (klf)	A	PD	PC	PD	
5	10	109	1.1	445	48.5	0.0	1072	
4	10	98	1.0	445	43.6	2.0		
3	10	118	1.2	445	52.5	2.0		
Live Loads				4			0.9	
	w	D	wD (klf)	A	PL	PC	PL	
5	10	200	2.0	445	89.0		787	
4	10	50	0.5	445	22.3			
3	10	50	0.5	445	22.3			
Level 5				Reactions (k)				
	w	0.9	X	4		3	4	
D	1.1	1072	-18.7	48.5	D	-973	429	
L	2.0	787	-6.8	89.0	L	-22	179	
S			-4		S	-6	2	
Level 4								
D	1.0		-361.7					45.6
L	0.5		283.6					22.3
Level 3								
D	1.2		-419.7					54.5
L	0.5		-333.9	22.3				

TRUSS H

Level 5					Reactions (k)		
	0.9	X	4	w	Load	3	4
D	1112	-19	35	2.2	D	2479	-906
L	747	-7	64	4	L	1661	-572
S	18				S	34	-16
Level 4					Pu	5646	-2008.8
	0.9	X	4	w	Column	24R-1	15A
D		780	31	2.0			
L		568	19	1			
Level 3							
	0.9	X	4	w			
D		-640	38	2.36			
L		-464	32	1			

APPENDIX F: FOUNDATION IMPACT

4-H									
Loads In			Exterior			Point Loads			
Pd	PI	Ps	Area	DL	LL	Pd1	PI1	Ps1	Design Loads
-898 k	-572 k	-16 k	56 sft	198 PSF	200 PSF	70 k	58 k	0 k	
8 k			Interior						
			Area	470 sft		-820 k			
			DL	126 PSF		-514 k			
			LL	100 PSF		-16 k			
Pu =	-1814 k								

4-J									
Loads In			Exterior			Point Loads			
Pd	PI	Ps	Area	DL	LL	Pd1	PI1	Ps1	Design Loads
429 k	179 k	2 k	112 sft	198 PSF	200 PSF	74 k	64 k	0 k	
8 k			Interior						
			Area	414 sft		511 k			
			DL	126 PSF		243 k			
			LL	100 PSF		2 k			
Pu =	1003 k								

3-H									
Loads In			Exterior			Point Loads			
Pd	PI	Ps	Area	DL	LL	Pd1	PI1	Ps1	Design Loads
2479 k	1661 k	34 k	470 sft	198 PSF	200 PSF	100 k	100 k	0 k	
8 k			Interior						
			Area	56 sft		2587 k			
			DL	126 PSF		1761 k			
			LL	100 PSF		34 k			
Pu =	5938 k								

6-N-2									
Loads In			Exterior			Point Loads			
Pd	PI	Ps	Area	DL	LL	Pd1	PI1	Ps1	Design Loads
-350 k	-252 k	-1 k	250 sft	198 PSF	200 PSF	50 k	50 k	0 k	
8 k			Interior						
			Area	0 sft		-293 k			
			DL	126 PSF		-202 k			
			LL	100 PSF		-1 k			
Pu =	-675 k								

3-L									
Loads In			Exterior			Point Loads			
Pd	PI	Ps	Area	DL	LL	Pd1	PI1	Ps1	Design Loads
3392 k	2419 k	4 k	526 sft	198 PSF	200 PSF	104 k	105 k	0 k	
20 k			Interior						
			Area	0 sft		3516 k			
			DL	126 PSF		2524 k			
			LL	100 PSF		4 k			
Pu =	8260 k								

APPENDIX G: DEFLECTION CALCULATIONS

I.D.	Truss Information						Itemized Deflections (in)				Live Load Deflection				Total Load Deflection			
	Condition	Lsimple		Ls	Lcant		Lc	D	L	T	Support		Mid/End	Max	Support		Mid/End	Max
		ft	in		in	ft					in	1			2	1		
J	Cantilever	0	0	0	6	4	76	-0.46	-0.03	-0.49	0.00	0.00	0.03	0.03	0	0	0.49	0.49
X	Cantilever	40	6	486	42	1	505	2.12	1.50	3.62	0.03	0.00	1.50	1.53	0.49	0	3.62	4.13
N.2	Cantilever	43	11	527	26	1	313	0.58	0.41	0.99	0.00	1.53	0.41	2.85	0	4.129	0.99	7.57
H	Cantilever	0	0	0	19	6	234	1.13	0.76	1.89	0.00	0.00	0.76	0.76	0	0	1.89	1.89
0.9	Simple	121	6	1458	0	0	0	1.21	0.875	2.09	0.76	2.85	0.88	2.68	1.89	7.572	2.085	6.82
X:0.9	Simple	13	0	156	0	0	0	1.05	0.75	1.80	0.03	1.80	-	1.83	0.49	6.82	-	7.31

Allowable Deflection at Cantilever					
X	Y	dX	dY	L	L/180
3-L	2664	222	498	-234	550.2
0.9-N.2	3162	-12			3.06
					L/120
					4.59

Allowable Deflection for X:0.9					
X	Y	dX	dY	L	L/360
3-J	2184	222	0	-234	234
0.9-J	2184	-12			0.65
					L/240
					0.98

Truss N.2												
Member Size	Diagonal			Vertical			Horizontal			Lin ft.	Weight (k)	Weight (t)
	Li	n	n	Li	n	n	Li	n	n			
W14x48				24	2					48	2.3	1.2
W14x120				24	1					24	2.9	1.4
W14x159				36	1					36	5.7	2.9
W14x211				29	1					29	6.1	3.1
W14x233				24	1					24	5.6	2.8
W14x257				34	1					34	8.7	4.4
W18x211							70	1		70	14.8	7.4
W24x370							70	1		70	25.9	13.0
											36.0 tons	

Truss X												
Member Size	Diagonal			Vertical			Horizontal			Lin ft.	Weight (k)	Weight (t)
	Li	n	n	Li	n	n	Li	n	n			
W10x15										20.25	0.5	0.1
W14x61				28	1					28	1.7	0.9
W14x90				28	1					28	2.5	1.3
W16x31							20.25	1		20.25	0.6	0.3
W16x84							20.25	1		20.25	1.7	0.9
W18x60							20.25	2		40.5	2.4	1.2
W27x84							20.25	1		20.25	1.7	0.9
W36x135							20.25	1.5		30.38	4.1	2.1
W44x335							20.25	3.5		70.88	23.7	11.9
											19.3 tons	

Truss N.2												
Member Size	Diagonal			Vertical			Horizontal			Lin ft.	Weight (k)	Weight (t)
	Li	n	n	Li	n	n	Li	n	n			
W14x68				25	2					50	3.4	1.7
W14x159				33.82	1					33.82	5.4	2.7
W14x211				34.5	1					34.5	7.3	3.6
W14x233				34.5	1					34.5	8.0	4.0
W14x311				32.2	1					32.2	10.0	5.0
W14x342				54	1					54	18.5	9.2
W14x398				57	1					57	22.7	11.3
W14x455				21.25	1					21.25	9.7	4.8
W27x129							10.2	1		10.2	1.3	0.7
W14x146							17	1		17	2.5	1.2
W14x539							20.25	2		40.5	21.8	10.9
PG46-3 748							44.18	1		44.18	33.0	16.5
PG56-1 2369							42	1		42	99.5	49.7
											121.6 tons	

FOUNDATIONS REINFORCEMENT

DYWIDAG Prestressing Steel Threadbar System

DYWIDAG Prestressing Steel Threadbar is a high tensile alloy steel bar which features a coarse right-hand thread over its full length. The system is proven worldwide and offers versatility in a range of applications.

Manufactured in accordance with the German Certificate of Approval (Deutsches Institut für Bautechnik), the system also offers general conformance with BS 4486 : High Tensile Steel Bars for Prestressing of Concrete. During the steel making process, the threadbars are hot rolled, quenched and tempered, followed by cold working and further tempering, to achieve the necessary performance.

DYWIDAG Prestressing Steel Threadbars, 15mm - 75mmØ are suitable for all static loading applications. Additionally, for post-tensioning and dynamic applications, DYWIDAG Prestressing Steel Threadbars 26.5mm - 40mmØ, see note (c) below, offer a fatigue resistance in excess of 2 million load cycles over a tensile range of 630 - 682N/mm² as specified in the European Technical Approval No. ETA - 05/0123 and ETAG 013. Stress relaxation when loaded to 70% fpu is less than 3.5% over a 1000 hour period in accordance with BS4486.

Key features of the system are:

- Fully threaded bar – can be cut and coupled at any point.
- Coarse pitch threadform (d/2), right-hand, with two faces ensuring the thread is self cleaning. Ideal for construction site use.
- Low relaxation steel – minimum relaxation during service life.
- Prestressing grade steel – high strength offers weight savings and reduced working diameters.

Technical Data for Prestressing Steel Threadbar

Nominal Diameter	Steel Grade	Ultimate Strength fpu	0.1% (a) Proof Strength	70% (b) Ultimate Strength	50% Ultimate Strength	Cross Sectional Area	Diameter Over Threads	Thread Pitch	Bar Weight
mm	N/mm ²	kN	kN	kN	kN	mm ²	mm	mm	kg/m
15	900/1100	195	159	136	98	177	17	10	1.44
20	900/1100	345	283	241	173	314	23	10	2.56
26.5	950/1050	579	523	405	290	551	30	13	4.48
32	950/1050	844	764	591	422	804	36	16	6.53
36	950/1050	1069	967	748	535	1018	40	18	8.27
40	950/1050	1320	1194	924	660	1257	45	20	10.21
47	950/1050	1822	1648	1275	911	1735	52	21	14.10
57	835/1035	2671	2155	1870	1335	2581	64	21	20.95
65	835/1035	3447	2771	2413	1724	3318	71	23	27.10
75	835/1035	4572	3645	3200	2286	4418	82	24	35.90


(a) 0.1% Proof Stress also referred to, in general terms, as Yield Strength - f_y (b) For geotechnical applications 75% fpu may be used for proof testing.
 (c) Approval Standards: Ø 26.5 - 47mm (grade 950/1050N/mm²) ETA 05/0123 and ETAG 013. Øs 15 & 20mm (grade 900/1100N/mm²) formite approvals. Øs 57 - 75mm (grade 835/1035 N/mm²) system approval.

Modulus of Elasticity: E = 205,000 N/mm² +/- 5%.
 Stock Lengths: 15mm - 20mmØ bars, 6.0m; 26.5mm - 75mmØ bars, 12.0m. Tolerances +/- 50mm.
 All bar diameters can be cut to length to suit customer requirements.

Couplers for Threadbars

Couplers enable prestressing steel threadbars to be coupled or extended, reliably and efficiently. Coupler strength (for bar Øs 26.5 - 47mm) = 1.27 x Yield Strength, which equates to 1.15 x Ultimate Strength, in accordance with German Approval Certificates. Coupler strengths for other prestressing steel bar grades (bar Øs 15 & 20mm, and 57 - 75mm) exceed the published Ultimate Bar Strengths and are covered by separate approvals (see note C, Technical Data).

Precautions should be taken to ensure that the coupler remains centrally located. This can be achieved through the use of grub screws and/or a centre pin. Marking the two bars with paint or similar at half a coupler length prior to engagement provides visual confirmation of centralisation and is recommended as good working practice.



DSI Prestressing Steel Threadbar

DRIVEN PILES

Depth	68	ft	Type	Do (in)	t (in)	Di	Astl	p/f	Embd.(ft)	L
fy	80	ksi	1	13.375	0.5	12.375	20.2	68.8	11	79 ft
f'c	5000	psi	2	13.375	0.5	12.375	20.2	68.8	16	84 ft
dstl	490	PCF								
	0.284	pci								

Diameter	Area
75 mm	4418 mm ²
2.95 in	6.848 in ²

RS Means p 290					
Dia	Mat'l	Sales	Labor	Equip	O&P
12	32.00	5%	6.80	4.41	15%
13.375	33.72	5%	7.59	4.92	15%
14	34.5	5%	7.95	5.15	15%
Thick Wall Addition					
+	0.93	5%	0	0	15%
Reinforcement					
+	0.83	5%	0.34	0	15%
Final Cost Figures					
Dia	Mat'l	Sales	Labor	Equip	O&P
13.38	154.84	5%	30.99	4.92	15%
Loc	1.042		1.670	1.319	
Time					1.01
			Total		\$ 238.75

Current	Type	n	Cost
	1	2	37722.01
	2	10	200547.39
	Total		\$ 238269.40
Proposed	Type	n	Cost
	1	5	94305.02
	2	12	240656.87
	Total		\$ 334961.90
Difference			\$ 96692.49