

mattise



nicholas w. mattise | mechanical option

senior



thesis final presentation | april 15, 2014

thesis



penn state | ae 482

mattise
senior
thesis

advisor Dr. Laura Miller

nicholas w. mattise | mechanical option



thesis final presentation | april 15, 2014

201 Rouse
The Navy Yard
Philadelphia PA, 19112

penn state | ae 482

introduction

about 201 rouse

location

building statistics

existing systems

performance

thesis proposal

mechanical depth


electrical breadth

conclusion

nicholas w. mattise | mechanical option



thesis final presentation | april 15, 2014



penn state | ae 482

introduction

about 201 rouse
location

building statistics
existing systems
performance

thesis proposal

mechanical depth

electrical breadth

conclusion

nicholas w. mattise | mechanical option

201 Rouse

84,500 square feet

4 stories

high end office space

Franklin Square Capital Partners

September 2013 to Q1 2015

\$19.4 million

thesis final presentation | april 15, 2014



introduction

about 201 rouse

location

building statistics

existing systems

performance

thesis proposal

mechanical depth

electrical breadth

conclusion

nicholas w. mattise | mechanical option

architecture

zinc clad exterior facade

glass walled ground floor pedestal

floor to ceiling windows

premium materials

solar shading fins

thesis final presentation | april 15, 2014



introduction

about 201 rouse
location
building statistics
existing systems
performance

thesis proposal

mechanical depth

electrical breadth

conclusion

nicholas w. mattise | mechanical option

mechanical system

dual 125 ton packaged AHUs

67,200 CFM | 24% min OA


DX coil cooling | electric heating

two vertical risers for supply & return

4 sizes of VAV with reheat terminals

separate HVAC for restrooms and core

thesis final presentation | april 15, 2014



Packaged Unit	Airflow (Max/Min) [SCFM]	Cooling Capacity (MBH)	Heating Capacity (MBH)	Unit Specified
1 & 2	33,600/8,230	1501.5	748.5	McQuay RPS130D
3	1,600/165	48.6	65.5	McQuay MSH04B

Unit	Inlet Dia. (in)	Primary Air (Max/Min) (CFM)	Electric Reheat Coil Capacity (BTU/hr)
A	6	420/210	10239
B	8	800/400	20478
C	10	1400/700	34310
D	12	1800/900	42663

penn state | ae 482

introduction

about 201 rouse

location

building statistics

existing systems

performance

thesis proposal

mechanical depth

electrical breadth

conclusion

nicholas w. mattise | mechanical option

building loads

electrical plug density - 0.75 W/ft^2

lighting intensity - 1.0 W/ft^2

task lighting - 0.75 W/ft^2

equipment density - 0.229 W/ft^2

HVAC - 0.709 W/ft^2

thesis final presentation | april 15, 2014

design conditions

outdoor

summer - 90.6°F dry bulb

summer - 74.3°F wet bulb

winter - 16.9°F

indoor

cooling - 75°F

heating - 70°F

54% relative humidity

penn state | ae 482

introduction

about 201 rouse
location
building statistics
existing systems
performance

thesis proposal

mechanical depth

electrical breadth

conclusion

nicholas w. mattise | mechanical option

building performance

envelope driven performance

HVAC is 36% of annual electricity usage


all electric equipment | uniform demand rate

\$181,191 yearly utility cost

31% EUI performance gain

thesis final presentation | april 15, 2014

Electricity Consumption



penn state | ae 482

introduction

about 201 rouse
location
building statistics
existing systems
performance

thesis proposal

mechanical depth

electrical breadth

conclusion

nicholas w. mattise | mechanical option

building performance

envelope driven performance

HVAC is 36% of annual electricity usage


all electric equipment | uniform demand rate

\$181,191 yearly utility cost

31% EUI performance gain

thesis final presentation | april 15, 2014

Annual Electricity Usage (1,000 kWh)



penn state | ae 482

introduction

about 201 rouse
location
building statistics
existing systems
performance

thesis proposal

mechanical depth

electrical breadth

conclusion

nicholas w. mattise | mechanical option

building performance

envelope driven performance

HVAC is 36% of annual electricity usage


all electric equipment | uniform demand rate

\$181,191 yearly utility cost

31% EUI performance gain

thesis final presentation | april 15, 2014

Monthly Utility Bills



penn state | ae 482

introduction

about 201 rouse
location
building statistics
existing systems
performance

thesis proposal

mechanical depth

electrical breadth

conclusion

nicholas w. mattise | mechanical option

building performance

envelope driven performance

HVAC is 36% of annual electricity usage

all electric equipment | uniform demand rate

\$181,191 yearly utility cost

31% EUI performance gain

thesis final presentation | april 15, 2014

Building	Site EUI (kBtu/sqft)	Source EUI (kBtu/sqft)	Performance Gain
201 Rouse	46.4	139.2	31% Site 6% Source
CBECS National Average	67.3	148.1	-

penn state | ae 482

introduction

about 201 rouse

thesis proposal


mechanical depth

electrical breadth

conclusion

mechanical depth

geothermal heat pumps
active chilled beams
dedicated outdoor air




goals

testbed of geothermal application
lower annual energy use
increase LEED rating

structural breadth

analyze roof structural support



electrical breadth

electrical equipment and wires for new HVAC equipment

about 201 rouse

thesis proposal

mechanical depth

selection

geothermal calculations

well layout

equipment

dedicated outdoor air system

active chilled beams


performance

electrical breadth


conclusion

nicholas w. mattise | mechanical option

standing column well




open loop



thesis final presentation | april 15, 2014

closed loop



penn state | ae 482

about 201 rouse

thesis proposal

mechanical depth

selection

geothermal calculations

well layout

equipment

dedicated outdoor air system

active chilled beams

performance

electrical breadth

conclusion

nicholas w. mattise | mechanical option

ground coupled heat pump

constant thermal properties

reduced pump energy


lowest level of maintenance

maintains usable site space

expensive

thesis final presentation | april 15, 2014

closed loop



penn state | ae 482

about 201 rouse

thesis proposal

mechanical depth selection

geothermal calculations

well layout

equipment

dedicated outdoor air system

active chilled beams

performance

electrical breadth

conclusion

nicholas w. mattise | mechanical option

site characteristics


bedrock mix of sand and gravel

conductivity of 1.6 Btu/hr*ft*°F

constant ground temperature of 55°F

long term thermal performance with diffusivity and Potomac-Raritan-Magothy aquifer penetration

thesis final presentation | april 15, 2014



about 201 rouse

thesis proposal

mechanical depth
selection

geothermal calculations

well layout

equipment

dedicated outdoor air system

active chilled beams

performance

electrical breadth

conclusion

nicholas w. mattise | mechanical option

well sizing

bedrock mix of sand and gravel

conductivity of 1.6 Btu/hr* $ft^{\circ}F$

constant ground temperature of 55 $^{\circ}F$

long term thermal performance with diffusivity and Potomac-Raritan-Magothy aquifer penetration

thesis final presentation | april 15, 2014

Ingersoll and Zobel Bore Length Equations

	Cooling	Heating	Units
Short Circuit Heat Loss Factor, Fsc	1.04	1.04	-
Part Load Factor , PFLm	1.00	1.00	-
Net annual heat transfer to ground, Qa	700,000	700,000	btu/hr
Building Design Block Load Cooling, Qlc	3,000,000	-	btu/hr
Building Design Block Load Heating, Qlh	-	2,300,000	btu/hr
Effective thermal resistance of ground annual pulse, Rga	0.24	0.24	ft*hr $^{\circ}F$ / Btu
Effective thermal resistance of ground daily pulse, Rgd	0.13	0.13	ft*hr $^{\circ}F$ / Btu
Effective thermal resistance of ground monthly pulse, Rgm	0.21	0.21	ft*hr $^{\circ}F$ / Btu
Effective thermal resistance of bore, Rb	0.10	0.10	ft*hr $^{\circ}F$ / Btu
Undisturbed ground Temperature, tg	55.00	55.00	$^{\circ}F$
Temp penalty for interference of adjacent bores, tp	2.00	2.00	$^{\circ}F$
Liquid temp at HP inlet, twi	75.00	35.00	$^{\circ}F$
Liquid temp at HP outlet, two	85.90	30.00	$^{\circ}F$
System power input at design cooling load, Wc	100,000	-	W
System power input at design heating load, Wh	-	100,000	W
Required Length	48,617	50,096	ft

penn state | ae 482

about 201 rouse

thesis proposal

mechanical depth

selection

geothermal calculations

well layout

equipment

dedicated outdoor air system

active chilled beams

performance

electrical breadth

conclusion

nicholas w. mattise | mechanical option

well layout

grid of 8x16 wells

128 wells

400 foot well depth


20 ft well spacing

surface area of 51,200 ft²

reverse return piping setup

underneath 201 rouse parking lot

thesis final presentation | april 15, 2014



about 201 rouse

thesis proposal

mechanical depth

selection

geothermal calculations

well layout

equipment

dedicated outdoor air system

active chilled beams


performance

electrical breadth

conclusion

nicholas w. mattise | mechanical option

thes



nn state | ae 482

about 201 rouse

thesis proposal

mechanical depth

selection

geothermal calculations

well layout

equipment

dedicated outdoor air system

active chilled beams

performance

electrical breadth

conclusion

nicholas w. mattise | mechanical option

well layout

6" header pipe


2" row header pipe

1" thermally fused HDPE well piping

6" bore diameter

thermally conductive fill material

thesis final presentation | april 15, 2014



about 201 rouse

thesis proposal

mechanical depth

selection

geothermal calculations

well layout

equipment

dedicated outdoor air system

active chilled beams

performance

electrical breadth

conclusion

nicholas w. mattise | mechanical option

well field pump


3 GPM/ton design flow

750 GPM pipe requirement

96 feet head loss

25 bhp pump operating at 2,700 RPM

thesis final presentation | april 15, 2014



Section	Pipe Size (in)	Head Loss
Header	6.00	18.75
Bore Loop	2.00	21.51
Well	1.00	23.47
Sub Total	-	63.73
Multiplier		1.50
Total		95.59

penn state | ae 482

about 201 rouse

thesis proposal

mechanical depth

selection

geothermal calculations

well layout

equipment

dedicated outdoor air system

active chilled beams

performance

electrical breadth

conclusion

nicholas w. mattise | mechanical option

heat pump

20 ton water to water units

iterative design between delta T of heat pump and well requirements

13 total units

laid out on roof

247 tons cooling | 342 ft²/ton cooling

2,352 Mbtu heating | 431 ft²/ton heating

thesis final presentation | april 15, 2014



heating

Source			Load							
EWT (deg F)	Flow (GPM)	Head Loss	EWT	Source LWT	HC (MBtuh)	Power (kW)	HA (MBtuh)	LWT	COP	Head Loss
35	50	9.9	110	30.3	180.9	18.9	116.4	117.2	2.8	7.4

cooling

Source			Load							
EWT (°F)	Flow (GPM)	Head Loss	EWT	Source LWT (°F)	TC (MBH)	Power (kW)	HR (MBH)	LWT (°F)	EER	Head Loss
75	50	6.75	57	85.9	228.8	12.52	271.55	50.85	18.35	8.4

penn state | ae 482

about 201 rouse

thesis proposal

mechanical depth

selection

geothermal calculations

well layout

equipment

dedicated outdoor air system

active chilled beams

performance

electrical breadth

conclusion

nicholas w. mattise | mechanical option

dedicated outdoor air system (DOAS)

handles air ventilation requirement and space latent loads

increases indoor air quality (IAQ)


60% relative humidity for spaces

downsizes air flow requirements for space conditioning

delivers conditioned "cold" air directly to the active chilled beams

reduces duct size

thesis final presentation | april 15, 2014



penn state | ae 482

about 201 rouse

thesis proposal

mechanical depth

selection

geothermal calculations

well layout

equipment

dedicated outdoor air system

active chilled beams

performance

electrical breadth

conclusion

nicholas w. mattise | mechanical option

dedicated outdoor air system (DOAS)

sized based upon ACBs and peak wet bulb

12,500 CFM

73 tons cooling | chilled water from GCHP


hot water sensible heating

Space	# of Typical	Latent Load
WNW (office)	4	7.45 kBtu/hr
SE (office)	4	11.4 kBtu/hr
Total	8	75,400 Btu/hr

thesis final presentation | april 15, 2014



PSYCHROMETRIC CHART
© 2003 AMERICAN STANDARD INC.
BAROMETRIC PRESSURE: 29.921 in. HG



penn state | ae 482

about 201 rouse

thesis proposal

mechanical depth

selection

geothermal calculations

well layout

equipment

dedicated outdoor air system

active chilled beams

performance

electrical breadth

conclusion

nicholas w. mattise | mechanical option


active chilled beams (ACB)

active chilled beams are effective at cooling large spaces at low primary airflow rates

coupled with a “cold” primary air DOAS unit saves on required ACB capacity

required airflow for ACB must be sufficient to maintain latent load of space to avoid condensate

thesis final presentation | april 15, 2014



penn state | ae 482

about 201 rouse

thesis proposal

mechanical depth

selection

geothermal calculations

well layout

equipment

dedicated outdoor air system

active chilled beams

performance

electrical breadth

conclusion


nicholas w. mattise | mechanical option

active chilled beams (ACB)

selected Trox 8ft active chilled beam

covers an area of 300 ft²

requires 60 per floor to condition space



Selected ACB	V	Q _{cw}	Q _h	GPM	Head Loss
8 ft DID632 Z Nozzle	50 CFM	4,305 Btu/hr	7,803 Btu/hr	1	5.8 ft H ₂ O

Space	# ACBs	Airflow	Sensible Cooling	Heating	GPM
SE	26	1,300 CFM	112.3 kBtu/hr	202 kBtu/hr	26
WNW	34	1,700 CFM	146 kBtu/hr	265 kBtu/hr	34
Total	60	2,950 CFM	258.3 kBtu/hr	467 kBtu/hr	60

thesis final presentation | april 15, 2014

penn state | ae 482

about 201 rouse

thesis proposal

mechanical depth

selection

geothermal calculations

well layout

equipment

dedicated outdoor air system

active chilled beams

performance

electrical breadth

conclusion

nicholas w. mattise | mechanical option

energy modeling complexities



with the complexity of the designed system modeling was a hurdle

accurate modeling of advanced HVAC systems is limited by the components that different modeling programs support

many solutions do not offer all three components or they are not fully realized

ended up using eQUEST

thesis final presentation | april 15, 2014



penn state | ae 482

about 201 rouse

thesis proposal

mechanical depth

selection

geothermal calculations

well layout

equipment

dedicated outdoor air system

active chilled beams

performance

electrical breadth

conclusion

nicholas w. mattise | mechanical option

geothermal model

ground source vertical well system

water to air heat pumps based upon water to water HP
capacity

packaged fan unit based upon DOAS unit fan CFM and energy
performance

yields an energy model representative of the designed
system's energy use

thesis final presentation | april 15, 2014

powered induction unit model

uses powered induction units

packaged fan unit sized to the DOAS unit

but induction units are supplied HW and CHW by boiler and
cooling tower respectively

creates a representative model of building thermal
performance

penn state | ae 482

about 201 rouse

thesis proposal

mechanical depth

selection

geothermal calculations

well layout

equipment

dedicated outdoor air system

active chilled beams

performance


electrical breadth

conclusion

nicholas w. mattise | mechanical option

monthly performance


Electricity Consumption-DOAS/Ground Loop/ACBs



thesis final presentation | april 15, 2014

annual energy usage

Annual Electricity Usage (1,000 kWh)



penn state | ae 482

about 201 rouse

thesis proposal


mechanical depth
selection
geothermal calculations
well layout
equipment
dedicated outdoor air system
active chilled beams
performance

electrical breadth

conclusion


nicholas w. mattise | mechanical option

monthly utility cost



thesis final presentation | april 15, 2014

energy comparison



saves 270,000 kWh

penn state | ae 482

about 201 rouse

thesis proposal

mechanical depth

selection

geothermal calculations

well layout

equipment

dedicated outdoor air system

active chilled beams

performance

electrical breadth

conclusion

nicholas w. mattise | mechanical option

cost comparison

Building	Mechanical Systems Cost	Total Building Cost	Mechanical %
201 Rouse Initial	\$1,513,000	\$19,402,000	7.80%
201 Rouse Thesis Revised	\$2,193,132	\$20,082,132	10.92%
Difference	-	\$680,132	3.12%

thesis final presentation | april 15, 2014

new HVAC system cost

Component	Unit Cost	Unit	Units	Cost
Heat Pumps	\$41,387	each	13	\$538,031
Geothermal Wells and Headers	\$16	per foot	51200	\$819,200
DOAS	\$209,958	each	1	\$209,958
Ducts	\$12.82	linear foot	2800	\$35,896.00
Return Grills	\$30.02	each	120	\$3,602.40
Building Side Pumps	\$10,163	each	2	\$20,326
Well Field Pumps	\$21,050	each	2	\$42,100
Core HVAC Unit	\$14.90	sqft	5312	\$79,148.80
Active Chilled Beams	\$1,404	each	240	\$336,960
Piping	\$16.35	linear foot	6600	\$107,910.00
Total				\$2,193,132

penn state | ae 482

about 201 rouse

thesis proposal

mechanical depth

selection

geothermal calculations

well layout

equipment

dedicated outdoor air system

active chilled beams

performance

electrical breadth

conclusion

nicholas w. mattise | mechanical option

payback period

saves on average **\$3,600** a month in utility bills

187 months | 15.5 years

using uniform electricity charge of \$0.162 per kWh

thesis final presentation | april 15, 2014

EUI comparison

Building	Site EUI (kBtu/sqft)	Source EUI (kBtu/sqft)	Performance Gain Over Benchmark	Performance Gain over Initial
201 Rouse Initial	46.4	139.2	31% Site, 6% Source	-
201 Rouse Redesigned	35.2	105.6	48% Over Site, 28% Source	24% Site, 24% Source
CBECS National Average	67.3	148.1	-	-

penn state | ae 482

about 201 rouse

thesis proposal

mechanical depth

selection

geothermal calculations

well layout

equipment

dedicated outdoor air system

active chilled beams

performance

electrical breadth

conclusion

nicholas w. mattise | mechanical option

initial LEED certification standing

seeking LEED new construction certification

as of October 2013 the building only qualified for 54 of the
110 LEED points

owner's goal was gold

silver is 50-59

gold threshold is 60



thesis final presentation | april 15, 2014

revised LEED certification standing

the geothermal system reaffirmed 3 points for "green power"

the DOAS added 1 LEED point for indoor air quality

the whole building energy reduction yield an additional 10
points

new LEED score | 65



penn state | ae 482

introduction

about 201 rouse

thesis proposal

mechanical depth

electrical breadth

existing

new loads

panel boards

conclusion

existing electrical system

electrical utility via PECO and local microgrid

600 amp high voltage connection

4000 amp main distribution board (mdb)

~1650 FLA of existing and future HVAC equipment

removed electrical loads

Equipment	Quantity	Full Load Amps	MCA	Volts	Phase	KW
Rooftop Air Handling Unit	2	369.2	400	460	3	294.2
VAV-A	8	10.83032491	15	277	1	3
VAV-B	8	21.66064982	25	277	1	6
VAV-C	8	36.10108303	40	277	1	10
VAV-D	8	45.12635379	50	277	1	12.5
Total		1648.147292	1840			840.4

~1650 full load amps removed from mdb

introduction

about 201 rouse

thesis proposal

mechanical depth

electrical breadth

existing

new loads

panel boards

conclusion

new electrical wiring

Equipment	Quantity	Amps	Wire Type	Wires	Wire Size	Ground Size	Conduit
Well Field Pump	2	23.3	THHW	3 Current 1 Neutral 1 Ground	10 AWG	14 AWG	1" EMT
Heat Pump	13	22.73	THHW	3 Current 1 Neutral 1 Ground	10 AWG	14 AWG	(3) 1 1/2" EMT
Hot/Chilled Water Pump	4	4.04	THHW	1 Current 1 Neutral 1 Ground	14 AWG	14 AWG	1" EMT
DOAS Unit	1	37.8	THHW	3 Current 1 Neutral 1 Ground	8 AWG	12 AWG	3/4" EMT
Panelboard HVH1	1	350	THHW	3 Current 1 Neutral 1 Ground	(2) 2/0 AWG	4 AWG	2" EMT

new electrical loads

Equipment	Quantity	Full Load Amps	MCA	Voltage	Phase	KW
Well Field Pump	2	23.3	30	460	1	18.6
Heat Pump	13	33.4	40	460	3	18.9
Hot/Chilled Water Pump	4	4.04	15	230	1	1.12
DOAS Unit	1	37.8	50	460	3	37.8

~540 full load amps added to mdb

introduction

about 201 rouse

thesis proposal

mechanical depth

electrical breadth

existing
new loads

panel boards

conclusion

nicholas w. mattise | mechanical option

electrical breadth

removal of 1,100 full load amps from main distribution

no change in panel quantity

circuit location optimized to equipment

reduction in wiring costs

owner choice between electrical panel savings or additional future capacity

thesis final presentation | april 15, 2014

new panelboard

DESCRIPTION	LTG. VA	EQUIP. VA	HVAC VA	BREAKER AMPS	BUS	BREAKER	HVAC VA	EQUIP.	LTG. VA	DESCRIPTION																														
<table border="1"> <tr><td>PANEL:</td><td>HH1</td><td>VOLTAGE:</td><td>277/480</td></tr> <tr><td>FOR:</td><td>COMMON HVAC AND PUMPS</td><td>PHASE:</td><td>3 PH-4W</td></tr> <tr><td>LOCATION:</td><td>MAIN ELECTRICAL ROOM</td><td>MAIN:</td><td>225 A MLO</td></tr> <tr><td>AIC:</td><td>25,000 A</td><td>MOUNTING:</td><td>SURFACE</td></tr> </table>											PANEL:	HH1	VOLTAGE:	277/480	FOR:	COMMON HVAC AND PUMPS	PHASE:	3 PH-4W	LOCATION:	MAIN ELECTRICAL ROOM	MAIN:	225 A MLO	AIC:	25,000 A	MOUNTING:	SURFACE														
PANEL:	HH1	VOLTAGE:	277/480																																					
FOR:	COMMON HVAC AND PUMPS	PHASE:	3 PH-4W																																					
LOCATION:	MAIN ELECTRICAL ROOM	MAIN:	225 A MLO																																					
AIC:	25,000 A	MOUNTING:	SURFACE																																					
#EF-1 EXHAUST FAN			3,980	15	1 A 2 3 B 4 5 C 6	25 15 15	5,010 1,180 1,180			#CUH-C UNIT HEATER #FTU-A1 FAN TERMINAL #FTU-A2 FAN TERMINAL																														
#FTU-B TERMINAL UNIT			10,180	20	7 A 8 9 B 10 11 C 12	15 15 20	1,180 1,120 3,000			#FTU-A3 FAN TERMINAL CHW PUMP 1 #CUH-C UNIT HEATER																														
#UH-A1 UNIT HEATER			5,000	15	13 A 14 15 B 16 17 C 18					SPARE #CUH-C UNIT HEATER #CUH-C UNIT HEATER																														
#UH-A2 UNIT HEATER			5,000	15	19 A 20 21 B 22 23 C 24					SPARE SPARE SPARE																														
HW PUMP 1			1,120	15	25 A 26					SPARE																														
HW PUMP 2			1,120	15	27 B 28					SPARE																														
CHW PUMP 2			1,120	15	29 C 30					SPARE																														
WELL FIELD PUMP 1			18,600	40	31 A 32 33 B 34 35 C 36					SPARE SPARE SPARE																														
WELL FIELD PUMP 2			18,600	40	37 A 38 39 B 40 41 C 42	60	10,880	18,860		PANEL "HP1" TRANSFORMER																														
Totals	0	0	64,720				29,550	18,860	0	Totals																														
<table border="1"> <thead> <tr> <th>LOAD DESCRIPTION</th> <th>CONN.</th> <th>DEMAND VA.</th> <th colspan="2">PHASE VA</th> </tr> </thead> <tbody> <tr> <td>LIGHTING</td> <td>0</td> <td>0</td> <td>A</td> <td>37,677</td> </tr> <tr> <td>GENERAL POWER</td> <td>18,860</td> <td>9,430</td> <td>B</td> <td>36,787</td> </tr> <tr> <td>HVAC EQUIPMENT</td> <td>94,270</td> <td>94,270</td> <td>C</td> <td>38,667</td> </tr> <tr> <td>TOTAL</td> <td>113,130</td> <td>103,700</td> <td>TOTAL</td> <td>113,130</td> </tr> <tr> <td>PERCENT LOADED</td> <td>90.50%</td> <td>82.96%</td> <td></td> <td></td> </tr> </tbody> </table>											LOAD DESCRIPTION	CONN.	DEMAND VA.	PHASE VA		LIGHTING	0	0	A	37,677	GENERAL POWER	18,860	9,430	B	36,787	HVAC EQUIPMENT	94,270	94,270	C	38,667	TOTAL	113,130	103,700	TOTAL	113,130	PERCENT LOADED	90.50%	82.96%		
LOAD DESCRIPTION	CONN.	DEMAND VA.	PHASE VA																																					
LIGHTING	0	0	A	37,677																																				
GENERAL POWER	18,860	9,430	B	36,787																																				
HVAC EQUIPMENT	94,270	94,270	C	38,667																																				
TOTAL	113,130	103,700	TOTAL	113,130																																				
PERCENT LOADED	90.50%	82.96%																																						

penn state | ae 482

introduction

about 201 rouse

thesis proposal

mechanical depth

electrical breadth

conclusion

nicholas w. mattise | mechanical option

conclusion

GCHP | DOAS | ACB

costs \$680,000

24% EUI reduction

\$3,600 average monthly savings

15.5 year payback for HVAC system

electrical panel savings or future capacity

LEED gold

thesis final presentation | april 15, 2014



introduction

about 201 rouse

thesis proposal

mechanical depth

electrical breadth

conclusion

nicholas w. mattise | mechanical option

acknowledgements

Liberty Property Trust

Turner Construction

In Posse

Dr. Laura Miller

Penn State University

friends | family | co-workers

thesis final presentation | april 15, 2014



introduction

about 201 rouse

thesis proposal

mechanical depth

electrical breadth

conclusion

questions

recommendations



