

SSM – St. Clare Health Center: Fenton, Missouri

# Technical Report 2

Dr. Linda Hanagan, Advisor



Christopher J Brandmeier, Structural Option  
9-26-2014

# Executive Summary

SSM St. Clare Health Center is a 420,000 square foot hospital located in a residential area of Fenton, Missouri. The building's site was previously a golf course, and the combination of sub-par soil conditions and proximity to the New Madrid fault line make the site a seismic design category D.

Structurally, the hospital is a composite steel frame building resting on massive concrete drilled piers which are connected by grade beams. The structure is broken up into several smaller buildings isolated by construction joints. These individual buildings each contain their own lateral force resisting systems which include special moment frames (SMF), special concentrically braced frames (SCBF), special reinforced concrete shear walls (SRCSW), and ordinary concentrically braced frames (OCBF).

The building was designed in 2004 and uses the 2003 Edition of the International Building Code and ASCE 7-02 as a reference standard. Design loads were determined based on these codes, additional St. Louis County Codes and Ordinances, and practical engineering judgments.

# SSM St. Clare Health Center

Fenton, Missouri: St. Louis County

## General Information

Full Height:	90 feet
Number of Stories:	6
Size:	427,000 square feet
Cost:	\$223.5 million
Date of Construction:	Sept. 2006 – March 2009
Project Delivery Method:	Integrated “Lean” Project Delivery



## Project Team

Owner:	SSM Health Care, St. Louis
Owner's Program Manager:	Hammes Company
Architect of Record:	HGA Architects and Engineers
Associate Architect:	Mackey Mitchel Associates
Structural Engineers:	HGA Architects and Engineers
MEP Engineers:	KJWW Engineering
Construction Manager:	Alberici Construction
Elevator Consultants:	Lerch, Bates & Associates Inc.

## Architecture

The hospital program contains a wide variety of medical use spaces, including 158 emergency supported inpatient beds, diagnostic and surgical services, administrative offices, dietary facilities, and pharmaceutical dispensaries. The floor plans were developed using Lean process principles classically used in manufacturing facilities.

## Structural Systems

Framing:	Steel framing, composite deck and lightweight concrete over composite wide flange members
Foundation:	Slab on grade, drilled concrete column piers connected by grade beams
Lateral:	Various systems including special moment frames (SMF), special concentrically braced frames (SCBF), special reinforced concrete shear walls (SRCSW), and ordinary concentrically braced frames (OCBF)



## Mechanical Systems

Fan coil units in each patient room fed by central boiler and chiller system for heating and cooling. VAV dedicated outside air for ventilation.

## Lighting and Electrical Systems

Electrical system supported by back up generators designed to power the entire hospital for at least 90 minutes. Lighting controls include ultrasonic ceiling sensors and infrared wall switch sensors for energy savings.



## Construction

Noise control procedures were specified to mitigate problems with surrounding residents. Smoking was prohibited on the site to comply with hospital policies and avoid contaminating the patient rooms.

Christopher Brandmeier | Structural Option

<https://www.engr.psu.edu/ae/thesis/portfolios/2015/aqb5205/index.html>

Photos compliments of HGA  
Architects and Engineers

# TABLE OF CONTENTS

---

1	General Information .....	4
1.1	Purpose .....	4
1.2	Scope .....	4
1.3	Site Location and Plan .....	4
1.4	List of Preparatory Documents .....	6
2	Gravity Loads.....	6
2.1	Dead and Live Loads.....	7
2.2	Snow Loads .....	8
3	Wind Loads.....	9
3.1	Calculations.....	9
4	Seismic Loads .....	11
4.1	Calculations.....	11
5	Conclusion.....	12
6	Appendix A: Gravity Loads .....	13
7	Appendix B: Wind Loads .....	17
8	Appendix C: Seismic Loads .....	19

# 1 GENERAL INFORMATION

---

## 1.1 PURPOSE

This report is a detailed analysis of the loading conditions on SSM St. Clare Health Center. These loads will be used in subsequent reports to investigate the design of the gravity and lateral force resisting systems.

## 1.2 SCOPE

The major sections of this document discuss the gravity, wind, and seismic loads applied to the building. The building's location and relevant resource documents used in its design are also presented. The appendices to this document contain the original load calculations from HGA Architects and Engineers. The analysis focuses on the bed tower, labelled sections "A" and "B" on the record drawings.

## 1.3 SITE LOCATION AND PLAN

SSM St. Clare Health Center is located in Fenton, Missouri in a relatively open residential area. The site was previously a golf course, which provided open space and gently sloping terrain. Figure 1 shows the relative placement of the site in Missouri, while Figures 2 through 4 show the building's location on the site as dictated by zoning codes and city ordinances.





Figure 1: Building Location



*Figure 2: Original Site, Golf Course*



*Figure 3: Building Orientation on Site*




Figure 4: Site Landscaping

#### 1.4 LIST OF PREPARATORY DOCUMENTS

- SSM St. Clare Health Center Site Development Plan
  - Produced by Stock & Associates Consulting Engineers Inc.
- SSM St. Clare Health Center Replacement Hospital Project Manual
  - CP-11 E/T Document Issuance
- IBC
  - 2003 Edition (as reference)
  - 2012 Edition (for further design studies)
- ASCE 7
  - ASCE 7-02 (as reference)
  - ASCE 7-10 (for further design studies and load calculations)
- Vulcraft Steel Deck Catalogue, 2008 Edition
- AISC Steel Manual 14<sup>th</sup> Edition
- USGS Seismic Design Maps


## 2 GRAVITY LOADS

This section examines the dead, live, and snow loads used to design the building's gravity system. The original design calculations for gravity loads can be found in Appendix A.

## Gravity Loads

ROOF CONSTRUCTION DEAD:  
SEE A431

MBIT-1



### PENTHOUSE ROOF

$$\begin{aligned}
 \text{3PLY: } & 1 \text{ psf} \\
 \text{5\frac{3}{4}} \text{ Ins: } & 1.5(5.75) = 8.625 \\
 \text{3.5" Conc: } & 48 \text{ psf} \\
 \text{3" Deck: } & \\
 \text{FRAMING: } & 6 \text{ psf} \\
 \text{MISC: } & \underline{\quad 6 \quad} \\
 & \underline{\quad 70 \quad} \text{ psf}
 \end{aligned}$$

BEAMS	$26 \times 4 \times 30' = 3120$
GIRDERS	$26 \times 1 \times 30' = 780$
AREA	$\frac{900 \text{ sf}}{900 \text{ sf}}$
= 6 psf	

### LOW ROOF

$$\begin{aligned}
 \text{3PLY: } & 1 \text{ psf} \\
 \text{11" Ins: } & 1.5(11) = 16.5 \text{ psf} \\
 \text{3.5" Conc: } & 48 \text{ psf} \\
 \text{3" Deck: } & \\
 \text{FRAMING: } & 6 \text{ psf} \\
 \text{MISC: } & \underline{\quad 6 \quad} \\
 & \underline{\quad 78 \quad} \text{ psf}
 \end{aligned}$$


### ROOF LIVE:

20 PSF (REQUIRED BY ASCE 7-10)

NOTE: LESS THAN SNOW LOAD

FLOOR CONSTRUCTION DEAD:

DECK 1



FINISHES

3 1/2" LW CONC


18G 3" Metal Deck

FRAMING

ACOUSTICAL CEILING OR GYPSUM  
(TAKEN AS MISC)

FINISHES:	2	psf
DECK:	48	psf
FRAMING:	6	psf
CEILING:	5	psf
MISC/EQUIP	15	psf
	76	psf

DECK 2:



FINISHES

5" NW CONC


18G 3" METAL DECK

FRAMING

ACOUSTICAL CEILING OR GYPSUM

FINISHES:	2	psf
DECK:	80	psf
FRAMING:	6	psf
CEILING:	5	psf
MISC/EQUIP:	15	psf
	108	psf

## EXTERIOR ENCLOSURE



5/8" Gyp	:	2.75	psf
6" STL STUD	:	3	psf
5/8" GYP	:	2.75	psf
VAP	:	0.5	psf
2" RGD INS	:	3.0	psf
AIR	:	0	psf
BRICK	:	39	psf

51 psf

Wall is supported at each floor by a steel angle. Vertical loads are transferred through the steel structure into the foundations.

## 2.1 DEAD AND LIVE LOADS

*Table 1: Typical Live Loads*

Live Load	Value (psf)
<b>Operating Room</b>	60
<b>Offices</b>	50
<b>Private Rooms</b>	40
<b>Corridors (1<sup>st</sup> Floor)</b>	100
<b>Corridors (other)</b>	80
<b>Stairs and Exits</b>	100
<b>Equipment Rooms</b>	125

*Table 2: Non-Typical Floor Dead Loads*

Dead Load	Value (psf)
<b>Hospital Floor</b>	60
<b>Hospital Roof</b>	78
<b>Power Plant Roof</b>	133
<b>Penthouse Floor</b>	60
<b>Penthouse Roof</b>	28
<b>Rooftop Mech. Unit Supp.</b>	75
<b>Piping Zone</b>	115
<b>MRI Zone</b>	78
<b>Piping and MRI Zone</b>	103
<b>MOB Floor</b>	36
<b>MOB Roof</b>	28
<b>Exterior Brick Wall</b>	50
<b>Exterior Curtain Wall</b>	20
<b>Exterior Metal Panel</b>	15

## 2.2 SNOW LOADS

## Snow Loads

- FLAT ROOF SNOW LOADS

$$p_f = 0.7 C_e C_t I_s p_g$$

Terrain Category: B

$$C_e : 1.0$$

$$C_t : 1.0$$

$$I_s : 1.2 \rightarrow OC IV$$

$$\text{SNOW LOAD} : 20 \text{ psf}$$

$$p_f = 0.7(1.0)(1.0)(1.2)(20)$$

$$= 16.8 \text{ psf}$$

NOTE: RAIN ON SNOW SURCHARGE  
OF 5 psf APPLIES.

$$p_m = I_s p_g \quad \text{for } p_g \leq 20 \text{ psf}$$

$$= 24 \text{ psf}$$

- DRIFTS ON LOWER ROOFS

PENTHOUSE ROOF:

$$\gamma = 0.13(20) + 14 = 16.6 \text{ psf}$$

$$h_b = 24/16.6 = 1.4457'$$



$$l_u = 34.33' \sim 50'$$

$$hd = 2'$$

$$h_c = 16.75'$$

$$w = 8$$

NOTE: N-S direction drifts truncated  
at 4'


$$l_u = 97' \sim 100'$$

$$hd = 3'$$


$$h_c = 16.75'$$

$$w = 12$$

N-S ELEVATION



## GARDEN LEVEL ROOFS:



Area ① = Area ②

$$l_u = 77' \sim 100'$$

$$h_d = 3'$$

$$h_c = 53'$$

$$\begin{aligned} \text{drift max} &= \frac{24}{16.6} (16.6) + 3(16.6) \\ &= 73.8 \text{ psf} \end{aligned}$$

Area ③


$$l_u = 52' \sim 50'$$

$$h_d = 2'$$

$$h_c = 54'$$

$$\begin{aligned} \text{drift max} &= \frac{24}{16.6} (16.6) + 2(16.6) \\ &= 57.2 \text{ psf} \end{aligned}$$

## PARAPET DRIFT



$$\begin{aligned} 1) \quad l_u &= 400' \\ h_d &= 6.5' \\ h_c &= -4.3' \\ \text{drift max} &= 24 + 6.5(0.75)16.6 \\ &= 104.93 \text{ psf} \end{aligned}$$

$$\begin{aligned} 2) \quad l_u &= 100' \\ h_d &= 3' \\ h_c &= -0.83' \\ \text{drift max} &= 24 + 3(0.75)16.6 \\ &= 61.35 \text{ psf} \end{aligned}$$

### 3 WIND LOADS

This section provides an overview of the wind loads on SSM St. Clare Health Center. Representative hand calculations are followed with more thorough excel spreadsheet tables. Wind loads do not control for the site and structure.

#### 3.1 CALCULATIONS

Table 3: E-W Wind Loads

Location	z (ft)	Story Height (ft)	K <sub>h</sub>	K <sub>Z</sub>	K <sub>zt</sub>	q <sub>z</sub>	q <sub>h</sub>	C <sub>p</sub>	q <sub>z</sub> GC <sub>p</sub> (psf)	GC <sub>pi</sub>	q <sub>h</sub> GC <sub>pi</sub> (psf)	q <sub>z</sub> GC <sub>p</sub> -q <sub>h</sub> (+GC <sub>pi</sub> )	q <sub>z</sub> GC <sub>p</sub> -q <sub>h</sub> (-GC <sub>pi</sub> )	(ft <sup>2</sup> )	(kips/ft)
Windward	-16	16	0.96	0.57	1.00	16.54	27.60	0.8	10.63	0.18	4.97	5.66	15.59	2584.00	14.62
	0	16	0.96	0.57	1.00	16.54	27.60	0.8	10.63	0.18	4.97	5.66	15.59	5168.00	29.24
	16	14	0.96	0.59	1.00	16.85	27.60	0.8	10.82	0.18	4.97	5.86	15.79	4845.00	28.37
	30	14	0.96	0.70	1.00	20.16	27.60	0.8	12.95	0.18	4.97	7.98	17.92	4522.00	36.11
	44	14	0.96	0.78	1.00	22.49	27.60	0.8	14.45	0.18	4.97	9.48	19.42	4522.00	42.88
	58	14	0.96	0.85	1.00	24.34	27.60	0.8	15.64	0.18	4.97	10.67	20.60	4522.00	48.25
	72	18.75	0.96	0.90	1.00	25.89	27.60	0.8	16.63	0.18	4.97	11.67	21.60	5289.13	61.70
	90.75		0.96	0.96	1.00	27.66	27.60	0.8	17.77	0.18	4.97	12.80	22.74	3028.13	38.77
			0.00	0.00	1.00	0.00	0.00	0.8	0.00	0.18	0.00	0.00	0.00	0.00	0.00
			0.00	0.00	1.00	0.00	0.00	0.8	0.00	0.18	0.00	0.00	0.00	0.00	0.00
Leeward	90.75	90.75	0.96	0.96	1.00	27.66	27.60	-0.5	-11.11	0.18	4.97	-16.07	-6.14	29312.25	-471.15
Sides	90.75	90.75	0.96	0.96	1.00	27.66	27.60	-0.7	-15.55	0.18	4.97	-20.52	-10.58	29312.25	-601.37
Parapet WW	93	2.166	0.96	0.97	1.00	27.86	27.60	0	0.00	1.5	41.39	-41.39	41.39	699.62	-28.96
Parapet LW	93	2.166	0.96	0.97	1.00	27.86	27.60	0	0.00	-1	-27.60	27.60	-27.60	699.62	19.31
Roof (0 to h/2)	90.75	45	0.96	0.96	1.00	27.66	27.60	-0.9	-19.99	0.18	4.97	-24.96	-15.02	14535.00	-362.77
Roof (h/2 to h)	90.75	90	0.96	0.96	1.00	27.66	27.60	-0.9	-19.99	0.18	4.97	-24.96	-15.02	29070.00	-725.54
Roof (h to 2h)	90.75	180	0.96	0.96	1.00	27.66	27.60	-0.5	-11.11	0.18	4.97	-16.07	-6.14	58140.00	-934.51
Roof (>2h)	90.75	323	0.96	0.96	1.00	27.66	27.60	-0.3	-6.66	0.18	4.97	-11.63	-1.70	104329.00	-1213.45

Table 4: N-S Wind Loads

Location	z (ft)	Story Height (ft)	K <sub>h</sub>	K <sub>Z</sub>	K <sub>zt</sub>	q <sub>z</sub>	q <sub>h</sub>	C <sub>p</sub>	q <sub>z</sub> GC <sub>p</sub> (psf)	GC <sub>pi</sub>	q <sub>h</sub> GC <sub>pi</sub> (psf)	q <sub>z</sub> GC <sub>p</sub> -q <sub>h</sub> (+GC <sub>pi</sub> )	q <sub>z</sub> GC <sub>p</sub> -q <sub>h</sub> (-GC <sub>pi</sub> )	(ft <sup>2</sup> )	(kips/ft)
Windward	-16	16	0.96	0.57	1.00	16.54	27.60	0.8	11.37	0.18	4.97	6.40	16.34	616.00	3.94
	0	16	0.96	0.57	1.00	16.54	27.60	0.8	11.37	0.18	4.97	6.40	16.34	1232.00	7.89
	16	14	0.96	0.59	1.00	16.85	27.60	0.8	11.58	0.18	4.97	6.61	16.55	1155.00	7.64
	30	14	0.96	0.70	1.00	20.16	27.60	0.8	13.86	0.18	4.97	8.89	18.83	1078.00	9.58
	44	14	0.96	0.78	1.00	22.49	27.60	0.8	15.46	0.18	4.97	10.49	20.43	1078.00	11.31
	58	14	0.96	0.85	1.00	24.34	27.60	0.8	16.73	0.18	4.97	11.76	21.70	1078.00	12.68
	72	18.75	0.96	0.90	1.00	25.89	27.60	0.8	17.80	0.18	4.97	12.83	22.76	1260.88	16.18
	90.75		0.96	0.96	1.00	27.66	27.60	0.8	19.01	0.18	4.97	14.05	23.98	721.88	10.14
			0.00	0.00	1.00	0.00	0.00	0.8	0.00	0.18	0.00	0.00	0.00	0.00	0.00
			0.00	0.00	1.00	0.00	0.00	0.8	0.00	0.18	0.00	0.00	0.00	0.00	0.00
Leeward	90.75	90.75	0.96	0.96	1.00	27.66	27.60	-0.2	-4.75	0.18	4.97	-9.72	0.21	6987.75	-67.92
Sides	90.75	90.75	0.96	0.96	1.00	27.66	27.60	-0.7	-16.64	0.18	4.97	-21.60	-11.67	6987.75	-150.96
Parapet WW	93	2.166	0.96	0.97	1.00	27.86	27.60	0	0.00	1.5	41.39	-41.39	41.39	166.78	-6.90
Parapet LW	93	2.166	0.96	0.97	1.00	27.86	27.60	0	0.00	-1	-27.60	27.60	-27.60	166.78	4.60
Roof (0 to h/2)	90.75	45	0.96	0.96	1.00	27.66	27.60	-0.9	-21.39	0.18	4.97	-26.36	-16.42	3465.00	-91.33
Roof (h/2 to h)	90.75	90	0.96	0.96	1.00	27.66	27.60	-0.9	-21.39	0.18	4.97	-26.36	-16.42	6930.00	-182.65
Roof (h to 2h)	90.75	180	0.96	0.96	1.00	27.66	27.60	-0.5	-11.88	0.18	4.97	-16.85	-6.92	13860.00	-233.54
Roof (>2h)	90.75	323	0.96	0.96	1.00	27.66	27.60	-0.3	-7.13	0.18	4.97	-12.10	-2.16	24871.00	-300.86

Table 5: N-S Wind Loads on Projected Section

Location	z (ft)	Story Height (ft)	K <sub>h</sub>	K <sub>z</sub>	K <sub>zt</sub>	q <sub>z</sub>	q <sub>h</sub>	C <sub>p</sub>	q <sub>z</sub> GC <sub>p</sub> (psf)	GC <sub>pi</sub>	q <sub>h</sub> GC <sub>pi</sub> (psf)	q <sub>z</sub> GC <sub>p</sub> -q <sub>h</sub> (+GC <sub>pi</sub> )	q <sub>z</sub> GC <sub>p</sub> -q <sub>h</sub> (-GC <sub>pi</sub> )	(ft <sup>2</sup> )	(kips/ft)
Windward	-16	16	0.96	0.57	1.00	16.54	27.60	0.8	11.57	0.18	4.97	6.61	16.54	408.00	2.70
	0	16	0.96	0.57	1.00	16.54	27.60	0.8	11.57	0.18	4.97	6.61	16.54	816.00	5.39
	16	14	0.96	0.59	1.00	16.85	27.60	0.8	11.79	0.18	4.97	6.82	16.76	765.00	5.22
	30	14	0.96	0.70	1.00	20.16	27.60	0.8	14.11	0.18	4.97	9.14	19.08	714.00	6.53
	44	14	0.96	0.78	1.00	22.49	27.60	0.8	15.74	0.18	4.97	10.77	20.71	714.00	7.69
	58	14	0.96	0.85	1.00	24.34	27.60	0.8	17.03	0.18	4.97	12.07	22.00	714.00	8.62
	72	18.75	0.96	0.90	1.00	25.89	27.60	0.8	18.12	0.18	4.97	13.15	23.09	835.13	10.98
	90.75		0.96	0.96	1.00	27.66	27.60	0.8	19.36	0.18	4.97	14.39	24.32	478.13	6.88
			0.00	0.00	1.00	0.00	0.00	0.8	0.00	0.18	0.00	0.00	0.00	0.00	0.00
			0.00	0.00	1.00	0.00	0.00	0.8	0.00	0.18	0.00	0.00	0.00	0.00	0.00
Leeward	90.75	90.75	0.96	0.96	1.00	27.66	27.60	-0.3	-7.26	0.18	4.97	-12.23	-2.29	4628.25	-56.59
Sides	90.75	90.75	0.96	0.96	1.00	27.66	27.60	-0.7	-16.94	0.18	4.97	-21.90	-11.97	4628.25	-101.38
Parapet WW	93	2.166	0.96	0.97	1.00	27.86	27.60	0	0.00	1.5	41.39	-41.39	41.39	110.47	-4.57
Parapet LW	93	2.166	0.96	0.97	1.00	27.86	27.60	0	0.00	-1	-27.60	27.60	-27.60	110.47	3.05
Roof (0 to h/2)	90.75	45	0.96	0.96	1.00	27.66	27.60	-0.9	-21.78	0.18	4.97	-26.74	-16.81	2295.00	-61.38
Roof (h/2 to h)	90.75	90	0.96	0.96	1.00	27.66	27.60	-0.9	-21.78	0.18	4.97	-26.74	-16.81	4590.00	-122.76
Roof (h to 2h)	90.75	180	0.96	0.96	1.00	27.66	27.60	-0.5	-12.10	0.18	4.97	-17.07	-7.13	9180.00	-156.66
Roof (>2h)	90.75	323	0.96	0.96	1.00	27.66	27.60	-0.3	-7.26	0.18	4.97	-12.23	-2.29	16473.00	-201.40

# WIND LOADS

## WIND DESIGN CRITERIA

RISK CATEGORY : IV  
 BASIC WIND SPEED : 115 (originally 90 in ASCE 7-02)  
 EXPOSURE CATEGORY : B  
 IMPORTANCE FACTOR : 1.15

$$\begin{aligned} K_d &= 0.85 \\ K_{z+} &= 1.0 \\ G &= ? \end{aligned}$$

## APPROXIMATE NATURAL FREQUENCY:

$$L_{\text{eff}} = 393$$

$$\begin{aligned} ① \quad h &= 90 < 300 & \checkmark \\ ② \quad h &= 90 < 4(393) = 1572 & \checkmark \end{aligned}$$

USE EQUATION 26.9-4

$$\begin{aligned} n_a &= 75/h \\ &= 75/90 \\ &= 0.8333 \end{aligned}$$

CALCULATE G:

$$L_{\bar{z}} = 320 \left(\frac{54}{33}\right)^{0.333} = 377.09$$

$$Q = \sqrt{\frac{1}{1 + 0.63 \left(\frac{77.190}{377.09}\right)^{0.63}}} = 0.85214$$

$$V_{\bar{z}} = 0.45 \left(\frac{54}{33}\right)^{0.25} \left(\frac{88}{60}\right)(115) = 85.844$$

$$N_1 = \frac{0.833(377.09)}{85.844} = 3.66$$

$$R_n = \frac{7.47(3.66)}{(1 + 10.3(3.66))^{5/3}} = 0.0617$$

$$R_h = \frac{1}{4.02} - \frac{1}{2(4.02)^2} \left(1 - e^{-2(4.02)}\right) = 0.2179$$

$$R_B = = 0.2486$$

$$R_L = = 0.0554$$

NOTE: THE PENTHOUSE ROOF IS ASSUMED TO BE THE MEAN ROOF HEIGHT

$$R = \sqrt{\frac{1}{0.05} (0.0617)(0.2179)(0.2486)(0.53 + 0.47(0.0554))}$$

$$= 0.1928$$

$$g_r = \sqrt{2 \ln(3600(0.8333))} + \frac{0.577}{\sqrt{2 \ln(3600(0.8333))}}$$

$$= 4.1458$$

$$I_2 = 0.3 \left( \frac{33}{54} \right)^{1/6} = 0.2764$$

$$(E-W) \quad G_f = 0.925 \left( \frac{1 + 1.7(0.2764) \sqrt{3.4^2(0.852)^2 + (4.146)^2(0.1928)^2}}{1 + 1.7(3.4)(0.2764)} \right)$$

$$= 0.925 \left( \frac{2.412}{2.597} \right)$$

$$= 0.8591$$

## REPRESENTATIVE CALCULATION OF "P"

at  $z = 90'$


$$q_h = 0.00256 (0.96)(1.0)(0.85)(115)^2 \\ = 27.626$$

at  $z = 58'$


$$q_z = 0.00256 (0.85)(1.0)(0.85)(115)^2 \\ = 24.46$$

$$P = \frac{24.46(0.8)(0.85)}{21.78} - (-27.626(0.18))$$

NOTE THAT THIS RESULT ASSUMES A NEGATIVE PRESSURE ON THE INTERIOR OF THE BUILDING



PLAN




Assumptions:

- lower level dimensions have minimal effect on tower loads
- E-W winds on Bed Tower section 2 create only "side" loads.
- Building has negative internal pressure

## WIND LOAD DIAGRAM

ALL VALUES IN KIPS.



## WIND BASE SHEAR (E-W)

NOTE: ADD TOTAL E-W WIND, ASSUMING THE PROJECTED BUILDING SECTION IS NEGIGIBLE. INCLUDE THE PROJECTED SECTION IN THE N-S DIRECTION

$$14.62 + 29.24 + 28.37 + 36.11 + 42.88 + 48.25 + 61.70 + 38.77 + 471.15 \\ + 28.96 + 19.31 = \boxed{819.4 \text{ k}}$$

## WIND BASE SHEAR (N-S)

$$3.94 + 7.89 + 7.64 + 9.58 + 11.31 + 12.68 + 16.18 + 10.14 + 67.92 + 6.9 \\ + 4.60 = 158.78$$

$$2.7 + 5.39 + 5.22 + 6.53 + 7.69 + 8.62 + 10.98 + 6.88 + 56.59 \\ + 4.57 + 3.05 = 118.22$$

TOTAL: 277 k

## 4 SEISMIC LOADS

This section provides an overview of the seismic loads on SSM St. Clare Health Center. Table 4 provides a summary of the lateral force resisting elements used in the building. This analysis focuses on the bed tower, sections "A," "B," and the Penthouse. The main lateral force resisting elements in the structure are special moment frames, special reinforced concrete shear walls, and special concentrically braced frames.

<b>Seismic Design Criteria</b>	<b>Bed Tower</b>	<b>Interventional Care</b>	<b>Surgery</b>	<b>Penthouse</b>
Ie	1.5	1.5	1.5	1.5
SUG	III	III	III	III
Site Class	D	D	D	D
SLRS N-S	SMF	SCBF	SMF	OCBF
SLRS E-W	SCBF + SRCSW	SCBF	SMF	OCBF

## 4.1 CALCULATIONS

*Table 6: Seismic Loads and Story Forces*

## Seismic Loads

### DESIGN CRITERIA

$I_e = 1.5$   
 OC = III  
 Site Class = D  
 SDC = D

### LATERAL SYSTEMS

- Special moment frames
- Special concentric braced frames
- Specially reinforced concrete shear walls

$$\begin{aligned} R &= 6 \\ \Omega &= 2\frac{1}{2} \\ C_d &= 5 \end{aligned}$$

NOTE: THESE VALUES CORRESPOND TO SRCSW IN ASCE 7-10 Table 12.2-1

### FIND SEISMIC FORCES / BASE SHEAR

$$V = C_{SW}$$

$$\begin{aligned} S_g &= 0.414 \\ S_i &= 0.163 \end{aligned}$$

$$\frac{X_1 - 1.6}{0.414 - 0.25} = \frac{1.4 - 1.6}{0.5 - 0.25}$$

$$\begin{aligned} F_a &= 1.468 \\ F_v &= 2.148 \end{aligned}$$

$$X_1 = 1.468$$

$$\begin{aligned} S_{MS} &= S_g F_a \\ &= 0.414 (1.468) = 0.608 \\ S_{MI} &= S_i F_v \\ &= 0.163 (2.148) = 0.350 \end{aligned}$$

$$\frac{X_2 - 2.4}{0.163 - 0.1} = \frac{2.0 - 2.4}{0.2 - 0.1}$$

$$X_2 = 2.148$$

$$S_{DS} = S_{MS} \left(\frac{2}{3}\right) = 0.405$$

$$S_{DI} = S_{DS} \left(\frac{2}{3}\right) = 0.233$$

$$C_s = \frac{0.405}{\left(\frac{6}{1.5}\right)} = \boxed{0.1013}$$

### APPROXIMATE PERIOD

$$\begin{aligned} C_f &= 0.02 \\ X &= 0.75 \end{aligned}$$

(TABLE 12.8-2)

$$T_a = C_t h_n^x$$

$$= 0.02(90)^{0.75}$$

$$= 0.584$$

$$C_u = \frac{x - 1.5}{0.233 - 0.2} = \frac{1.4 - 1.5}{0.3 - 0.2}$$

$$= 1.467$$

$$T_L = 12$$

$$T \approx C_u T_a$$

$$= \frac{1.467(0.584)}{0.857}$$

$$T_L > T \therefore$$

$$C_s \leq \frac{0.233}{0.857 \left(\frac{6}{1.5}\right)} = 0.068$$

$$C_s \geq 0.044(0.405)(1.5) = 0.0267$$

$$S_i < 0.6g$$


CHECK  $C_s$

$$0.1013 > \underline{\underline{0.068}} > 0.0267 \checkmark$$

#### FIND STORY WEIGHTS

<u>LEVEL</u>	<u>FLOOR AREA</u>	<u>ASSEMBLY WT.</u>	<u>TOTAL</u>
1	$60(91)\frac{1}{2} + 135(91)\frac{1}{2} + 158(91)\frac{1}{2}$ $+ 287.47 = 44808.5$	76 psf	3406 kips
2	"	"	"
3	$77(323) + 114(51)(\frac{2}{3})$ $= 28747$	76 psf	2195 kips
4	"	"	"
5	"	"	"
6	"	"	"
7	$33(97) = 3201$	76 psf	243 kips

## SEISMIC LOAD DIAGRAM



### SEISMIC BASE SHEAR

$$\begin{aligned}
 V &= C_s W \\
 &= 0.068 \cdot (15795 \text{ k}) \\
 &= \boxed{1068.4 \text{ k}}
 \end{aligned}$$

## 5 CONCLUSION

---

The lateral system design of SSM St. Clare Health Center is governed by seismic forces as was expected. As analysis progresses, particular attention must be paid to mechanical and medical equipment point loads on floor diaphragms, especially for Technical Report III.

## 6 APPENDIX A: GRAVITY LOADS

---

### Design Criteria (Live Loads)

#### **Hospitals**

Operating rooms, labs	60 PSF *
Private rooms	40 PSF *
Wards	40 PSF *
Corridors (above 1 <sup>st</sup> floor)	80 PSF *

\* Design for uniform load indicated or 1000# concentrated load over 2.5 feet square, whichever produces the greater load effect.

#### **Offices**

Offices	50 PSF **
Lobbies & 1 <sup>st</sup> floor corridors	100 PSF **
Corridors (above 1 <sup>st</sup> floor)	80 PSF **

\*\* Design for uniform load indicated or 2000# concentrated load over 2.5 feet square whichever produces the greater load effect.

#### **Misc. Live Loads**

Corridors, except as otherwise indicated	100 PSF
Stairs and Exits	100 PSF ***
Dining Rooms and Restaurants	100 PSF
Retail Stores (first floor)	100 PSF
Mechanical rooms	125 PSF (Includes allowance for equipment pads)
Storage – Light	125 PSF

\*\*\* Design for uniform load indicated or 300# concentrated load over 4 inches square whichever produces the greater load effect

Partition loads (Offices & locations where partitions are subject to change)	20 PSF
---	--------

#### ***Design Floor Live Loads* (Typical unless noted otherwise in calculations)**

Typical floors: 80 PSF (60 PSF + 20 PSF Partitions) or (80 PSF Corridors)

First floor (typical): 100 PSF (60 PSF + 20 PSF Partitions) or (100 PSF Corridors)

First floor (equip): 120 PSF (60 PSF + 20 PSF Partitions + 40 PSF Equipment)

Mechanical Rooms: 125 PSF

Elevator Machine Rooms: 500 PSF

Interstitial Level: 25 PSF

Roof Top Mechanical Unit Support: 50 PSF (Live Load + Snow Load)

#### **Other Live Loads**

Handrails and guards	50 PLF or 200# concentrated load @ top rail
Components	50# over 1 foot square
Grab bars, shower seats, dressing rm. seats	250# load in any direction at any point

#### **Impact Loads**

Elevator loads shall be increased by 100 percent for impact  
Machinery weight shall be increased to allow for impact  
Elevator machinery: 100 percent  
Light machinery, shaft or motor driven: 20 percent  
Reciprocating machinery or power driven units: 50 percent  
Hangers for floors or balconies: 33 percent

### **Live Load Reduction**

Live loads to columns will be reduced in accordance with IBC Section 1607.9.1. Live loads that exceed 100 PSF and roof live loads will not be reduced.

### **Distribution of Floor Loads**

Uniform floor live loads shall be patterned to produce the greatest effect on continuous framing.

### **Roof Loads**

Uniform roof live loads shall be patterned to produce the greatest effect on continuous framing.

Minimum roof load will be less than snow load

See section 1607.11 for other roof loads (roof gardens, landscaped roofs, canopies)

### **Interior Walls and Partitions**

Interior Partitions                            5 PSF horizontal pressure

### **Medical Equipment**

MRI Equipment (four pt loads)                 $29000 \text{ lb}/4 = 7250 \text{ lb}$

MRI Equip minus equip allowance                 $7250 \text{ lb} - (40 \text{ PSF}) * (25 \text{ ft}^2) = 6250 \text{ lb}$

**Design Criteria (Dead Loads)**

Hospital Floor (Composite slab, 2 Hour)

3" Deck + 3 1/2" LW Conc	48 PSF
Beams/Girders/Columns	Self Wt (Assume = 9 PSF)
Ceiling/Mechanical/Misc	12 PSF
	60 PSF (Mass DL = 69 PSF + 10 PSF for Partition Mass)

Hospital Roof (Future Floor) (Composite slab, 2 Hour)

3" Deck + 3 1/2" LW Conc	48 PSF
Beams/Girders/Columns	Self Wt (Assume = 9 PSF)
Ceiling/Mechanical/Misc	12 PSF
Roofing/Insulation/Ballast	18 PSF
	78 PSF (Mass DL = 87 PSF)

Hospital Roof (No future floors) (Composite slab, 2 Hour)

3" Deck + 3 1/2" LW Conc	48 PSF
Beams/Girders/Columns	Self Wt (Assume 9 PSF)
Ceiling/Mechanical/Misc	12 PSF
Roofing/Insulation/Ballast	18 PSF
	78 PSF (Mass DL = 87 PSF)

Power Plant Roof (No future floors) (Composite slab, 2 Hour)

3" Deck + 3 1/2" LW Conc	48 PSF
Beams/Girders/Columns	Self Wt (Assume 9 PSF)
Ceiling/Misc	7 PSF
Mechanical Piping	60 PSF
Roofing/Insulation/Ballast	18 PSF
	133 PSF (Mass DL = 142 PSF)

Penthouse Floor (Composite slab, 2 Hour)

3" Deck + 3 1/2" LW Conc	48 PSF
Beams/Girders/Columns	Self Wt ( Assume = 9 PSF)
Mechanical/Misc	12 PSF
	60 PSF (Mass DL = 69 PSF + 10 PSF for Partition Mass)

Penthouse Roof (Steel Roof Deck)

Steel Deck	3 PSF
Beams/Girders/Columns	Self Wt ( Assume = 7 PSF)
Mechanical/Misc	7 PSF
Roofing/Insulation/Ballast	18 PSF
	28 PSF (Mass DL = 35 PSF)

Roof Top Mechanical Unit Support

Beams/Girders/Columns	Self Wt ( Assume = 7 PSF)
Mechanical Unit	60 PSF
Miscellaneous Pipes & Ducts	15 PSF

75 PSF (Mass DL = 82 PSF)

Hospital Floor – Piping Zone (Composite slab, 2 Hour)

3" Deck + 3 1/2" LW Conc	48 PSF
Beams/Girders/Columns	Self Wt (Assume = 9 PSF)
Mechanical Piping	60 PSF
Ceiling/Misc	7 PSF
	115PSF (Mass DL = 94 PSF + 10 PSF for Partition Mass)

Hospital Floor/Power Plant (Composite slab, 2 Hour)

3" Deck + 3 1/2" LW Conc	48 PSF
Beams/Girders/Columns	Self Wt (Assume = 9 PSF)
Mechanical Piping	60 PSF
Ceiling/Misc	7 PSF
	115PSF (Mass DL = 94 PSF + 10 PSF for Partition Mass)
Hospital Floor – MRI Zone (Composite slab, 2 Hour)	
3" Deck + 3 1/2" LW Conc	48 PSF
Beams/Girders/Columns	Self Wt (Assume = 9 PSF)
2" Concrete Topping	18 PSF
Mass for Permanent Equip	(15 PSF Mass DL)
Ceiling/Mechanical/Misc	12 PSF
	78 PSF (Mass DL = 102 PSF + 10 PSF for Partition Mass)
Hospital Floor – Piping Zone plus MRI Zone (Composite slab, 2 Hour)	
3" Deck + 3 1/2" LW Conc	48 PSF
Beams/Girders/Columns	Self Wt (Assume = 9 PSF)
2" Concrete Topping	18 PSF
Mass for Permanent Equip	(15 PSF Mass DL)
Mechanical	30 PSF
Ceiling/Misc	7 PSF
	103 PSF (Mass DL = 127 PSF + 10 PSF for Partition Mass)
MOB Floor (Non-Composite slab, 0 Hour)	
1 ½" Deck + 2" LW Conc	29 PSF
Beams/Girders/Columns	Self Wt (Assume 9 PSF)
Ceiling/Mechanical/Misc	7 PSF
	36 PSF (Mass DL = 45 PSF + 10 PSF for Partition M ass)

## 7 APPENDIX B: WIND LOADS

### WIND LOAD TABLES FOR AREAS A,B,F & G

Zone (Note 1)	Area (sq ft) (Note 2)	Design Wind Loads (psf)		Design Wind Loads (psf)							
		0' to 30' (Note 3)	30' to 40' (Note 3)	40' to 50' (Note 3)	50' to 60' (Note 3)	60' to 70' (Note 3)	70' to 80' (Note 3)	80' to 90' (Note 3)	90' to 100' (Note 3)	100' to 110' (Note 3)	110' to 120' (Note 3)
1 ROOF	10	-23.6	10	-25.3	10	-26.7	10	-27.8	10	-29.0	10.0
	20	-22.9	10	-24.5	10	-25.9	10	-27.0	10	-28.1	10.0
	50	-20.7	10	-22.2	10	-23.4	10	-24.4	10	-25.4	10.0
2 ROOF	100	-20.0	10	-21.4	10	-22.6	10	-23.5	10	-24.5	10.0
	10	-36.4	10	-39.2	10	-41.5	10	-43.3	10	-45.2	10.0
	20	-34.9	10	-37.6	10	-39.8	10	-41.6	10	-43.4	10.0
3 ROOF	50	-32.1	10	-34.5	10	-36.6	10	-38.2	10	-39.8	10.0
	100	-30.7	10	-33.0	10	-34.9	10	-36.5	10	-38.0	10.0
	10	-49.1	10	-53.0	10	-56.3	10	-58.9	10	-61.4	10.0
4 WALL	20	-47.0	10	-50.7	10	-53.8	10	-56.3	10	-58.7	10.0
	50	-44.2	10	-47.6	10	-50.5	10	-52.8	10	-55.1	10.0
	100	-42.0	10	-45.3	10	-48.1	10	-50.2	10	-52.4	10.0
5 WALL	10	-22.3	17.6	-22.3	18.5	-22.3	19.2	-22.3	20.0	-22.3	20.7
	20	-22.3	17.6	-22.3	18.5	-22.3	19.2	-22.3	20.0	-22.3	20.7
	50	-21.3	16.0	-21.3	16.9	-21.3	17.5	-21.3	18.2	-21.3	18.8
100	100	-20.3	15.3	-20.3	16.0	-20.3	16.6	-20.3	17.3	-20.3	17.9
	10	-40.9	17.6	-40.9	18.5	-40.9	19.2	-40.9	20.0	-40.9	20.7
	20	-40.9	17.6	-40.9	18.5	-40.9	19.2	-40.9	20.0	-40.9	20.7
WALL	50	-36.8	16.0	-36.8	16.9	-36.8	17.5	-36.8	18.2	-36.8	18.8
	100	-32.7	15.3	-32.7	16.0	-32.7	16.6	-32.7	17.3	-32.7	17.9

### WIND LOAD TABLES FOR AREAS A,B,F & G

Zone (Note 1)	Area (sq ft) (Note 2)	Design Wind Loads (psf)		Design Wind Loads (psf)							
		0' to 30' (Note 3)	30' to 40' (Note 3)	40' to 50' (Note 3)	50' to 60' (Note 3)	60' to 70' (Note 3)	70' to 80' (Note 3)	80' to 90' (Note 3)	90' to 100' (Note 3)	100' to 110' (Note 3)	110' to 120' (Note 3)
2 ROOF OVERHANG	10	-27.8	-29.9	-31.6	-33.0	-34.4	-35.8	-36.8	-37.8	-38.7	-39.6
	20	-27.4	-29.4	-31.1	-32.5	-33.8	-35.2	-36.2	-37.2	-38.1	-38.9
	50	-26.8	-28.8	-30.5	-31.8	-33.1	-34.4	-35.4	-36.4	-37.3	-38.1
3 ROOF OVERHANG	100	-26.4	-28.4	-30.0	-31.3	-32.6	-33.9	-34.9	-35.8	-36.6	-37.4
	10	-43.4	-46.9	-49.7	-52.0	-54.2	-56.5	-58.2	-59.9	-61.3	-62.7
	20	-34.9	-37.6	-39.8	-41.6	-43.4	-45.2	-46.5	-47.9	-49.0	-50.1
50	50	-23.6	-25.3	-26.7	-27.8	-29.0	-30.1	-31.0	-31.8	-32.5	-33.2
	100	-15.1	-16.0	-16.9	-17.5	-17.5	-18.2	-18.8	-19.3	-20.2	-20.6

## WIND LOAD TABLES FOR AREAS C & D

NOTES:

1. ZONES ARE PORTIONS OF THE WALLS OR ROOFS WHERE WIND LOADS ARE APPLIED, AS SHOWN ON THE "COMPONENT AND CLADDING LOAD DIAGRAM". THE WIDTH OF THE EDGE STRIPS " $a$ " SHALL BE 10 PERCENT OF THE LEAST HORIZONTAL DIMENSION OR 40 PERCENT OF THE EAVE HEIGHT " $h$ ", WHICHEVER IS LESS, BUT NOT LESS THAN EITHER 4 PERCENT OF THE LEAST HORIZONTAL DIMENSION OR 3 FEET.
2. AREA IS THE "EFFECTIVE WIND AREA" ON ELEMENTS OF THE COMPONENTS AND CLADDING, AND CLADDING FASTENERS, AS DEFINED IN IBC 1609.2.
3. BASIC WIND LOAD IS THE WIND LOAD ON COMPONENTS AND CLADDING FOR A BUILDING WITH A MEAN ROOF HEIGHT OF 30 FEET LOCATED IN EXPOSURE B, AS SHOWN IN THE IBC TABLE 1609.6.2.1(2).
4. BASIC WIND LOAD IS THE WIND LOAD ON ROOF OVERHANG COMPONENTS AND CLADDING FOR A BUILDING WITH A MEAN ROOF HEIGHT OF 30 FEET LOCATED IN EXPOSURE B, AS SHOWN IN IBC TABLE 1609.6.2.1(3).
5. DESIGN WIND LOADS ARE THE BASIC WIND LOADS, MULTIPLIED BY THE APPROPRIATE HEIGHT AND EXPOSURE COEFFICIENT FROM TABLE 1609.6.2.1(4) AND IMPORTANCE FACTOR FROM TABLE 1604.5.

Zone (Note 1)	Area (sq ft) (Note 2)	Design Wind Loads (psf)		Design Wind Loads (psf)		Design Wind Loads (psf)	
		0' to 30' (Note 3)	30' to 40' (Note 3)	40' to 50' (Note 3)	50' to 60' (Note 3)	Design Wind Loads (psf)	Design Wind Loads (psf)
1 ROOF	10	-22.8	10	-24.5	10	-25.9	10
	20	-22.1	10	-23.8	10	-25.1	10
	50	-20.0	10	-21.4	10	-22.7	10
2 ROOF	100	-19.3	10	-20.7	10	-21.8	10
	10	-35.6	10	-38.4	10	-40.7	10
	20	-34.2	10	-36.8	10	-39.1	10
3 ROOF	50	-31.3	10	-33.8	10	-35.8	10
	100	-29.9	10	-32.2	10	-34.1	10
	10	-48.4	10	-52.3	10	-55.5	10
3 ROOF	20	-46.2	10	-49.9	10	-53.0	10
	50	-43.4	10	-46.9	10	-49.7	10
	100	-41.3	10	-44.5	10	-47.3	10
4 WALL	10	15.7	-17.7	16.8	-17.7	17.7	-17.7
	20	15.7	-17.7	16.8	-17.7	17.7	-17.7
	50	14.3	-16.9	15.3	-16.9	16.1	-16.9
5 WALL	100	13.6	-16.1	14.5	-16.1	15.3	-16.1
	10	15.7	-32.5	16.8	-32.5	17.7	-32.5
	20	15.7	-32.5	16.8	-32.5	17.7	-32.5
5 WALL	50	14.3	-29.2	15.3	-29.2	16.1	-29.2
	100	13.6	-25.9	14.5	-25.9	15.3	-25.9

## WIND LOAD TABLES FOR AREAS C & D

Zone (Note 1)	Area (sq ft) (Note 2)	Design Wind Loads (psf)		Design Wind Loads (psf)		Design Wind Loads (psf)	
		0' to 30' (Note 3)	30' to 40' (Note 3)	40' to 50' (Note 3)	50' to 60' (Note 3)	Design Wind Loads (psf)	Design Wind Loads (psf)
2 ROOF OVERHANG	10	-35.6	-38.4	-40.7	-42.6	-42.6	-42.6
	20	-34.2	-36.8	-39.1	-40.9	-40.9	-40.9
3 ROOF OVERHANG	50	-31.3	-33.8	-35.8	-37.4	-37.4	-37.4
	100	-29.9	-32.2	-34.1	-35.7	-35.7	-35.7
3 ROOF OVERHANG	10	-48.4	-52.3	-55.5	-58.1	-58.1	-58.1
	20	-46.2	-49.9	-53.0	-55.5	-55.5	-55.5
3 ROOF OVERHANG	50	-43.4	-46.9	-49.7	-52.1	-52.1	-52.1
	100	-41.3	-44.5	-47.3	-49.5	-49.5	-49.5

## 8 APPENDIX C: SEISMIC LOADS

### USGS Design Maps Summary Report

#### User-Specified Input

**Building Code Reference Document** 2012 International Building Code  
 (which utilizes USGS hazard data available in 2008)

**Site Coordinates** 38.52197°N, 90.4727°W

**Site Soil Classification** Site Class D – "Stiff Soil"



**Risk Category** IV (e.g. essential facilities)



#### USGS-Provided Output

$$\begin{array}{lll} S_s = 0.414 \text{ g} & S_{ms} = 0.608 \text{ g} & S_{os} = 0.405 \text{ g} \\ S_1 = 0.163 \text{ g} & S_{m1} = 0.350 \text{ g} & S_{o1} = 0.233 \text{ g} \end{array}$$

For information on how the SS and S1 values above have been calculated from probabilistic (risk-targeted) and deterministic ground motions in the direction of maximum horizontal response, please return to the application and select the "2009 NEHRP" building code reference document.



Although this information is a product of the U.S. Geological Survey, we provide no warranty, expressed or implied, as to the accuracy of the data contained therein. This tool is not a substitute for technical subject-matter knowledge.

Note: In the calculations, Tb has been falsely entered as "999" so that the spreadsheet's formulas will not use the value. An actual Tb value has not been calculated at the date of this report's publication.

Design Parameters					
Categories	Parameter	Value	Units	Description	Reference
Site Code Factors	Occ. Category	IV		Occupant Category	Table 1-1
	Site Class	D		Site Class (A, B, C, D, E, or F)	Chapter 20
	SDC	D		Seismic Design Category	11.6-11.7
	I <sub>E</sub>	1.00		Seismic Importance Factor	Table 11.5-1
Seismic Response	S <sub>s</sub>	0.414		Short Period MCE Spectral Response Acceleration (%g)	Figure 22-1
	S <sub>1</sub>	0.163		One Second MCE Spectral Response Acceleration (%g)	Figure 22-1
	F <sub>a</sub>	1.468		Site Coefficient at Short Periods	Table 11.4-1
	F <sub>v</sub>	2.148		Site Coefficient at 1 Second Period	Table 11.4-2
Period	T <sub>L</sub>	12.00	s	Long-period Transition Period	Figure 22-15
	T <sub>b</sub>	999.00	s	Building Period determined from Modal Analysis	
	C <sub>t</sub>	0.02		Building Period Coefficient	12.8.1.1
	x	0.75		Building Period Coefficient	
	h <sub>n</sub>	90.75	ft	Height of building	
	C <sub>u</sub>	1.47			
	N	0.00	#	Number of Stories (leave blank unless approx Ta desired)	
SFRS Coefficients	R	6.00		Response Modification Coefficient	Table 12.2-1
	Ω	2.50		Overstrength Factor	Table 12.2-1
	C <sub>d</sub>	5.00		Deflection Amplification Factor	Table 12.2-1
Shear Wall Data	Concrete/masonry shear walls?	NO			
	Direction	X		X or Y?	
	A <sub>b</sub>	1200	sqft	Area of base of Structure	

Intermediate Calculations					
Categories	Calculated Values	Value	Units	Description	Reference
Seismic Response	S <sub>MS</sub>	0.608		Short Period MCE Spectral Response Acc., site adjusted	Eq. 11.4-1
	S <sub>M1</sub>	0.350		One Second MCE Spectral Response Acc., site adjusted	Eq. 11.4-2
	S <sub>DS</sub>	0.405		5% Damped Design Spectral Response Acc. at Short Periods	Eq. 11.4-3
	S <sub>D1</sub>	0.233		5% Damped Design Spectral Response Acc. at 1 Second Period	Eq. 11.4-4
	S <sub>a</sub>	3.764		Design Spectral Response Acceleration	11.4.5
Periods	T <sub>a</sub>	0.59	s	Approximate Fundamental Period	12.8.2
	T <sub>0</sub>	0.12	s		
	T <sub>s</sub>	0.58	s		
	T	0.86	s	Period of the Structure	
Coefficients	C <sub>w</sub>	0.00		Shear Wall Coefficient	12.8-10
	C <sub>s</sub>	0.05		T<=TL	
	C <sub>s</sub>	0.07		T>TL	
	C <sub>s</sub>	0.07		S1>0.6g	
	C <sub>s final</sub>	0.05		Seismic Response Coefficient	12.8.1.1
Base Shear	V	712.29		Base Shear	