

ELEMENTARY SCHOOL ONE TOWN, MARYLAND

Jonathan Cann

Mechanical Option

Advisor: Dr. Treado

BAE/MAE Integrated Program

Spring 2015

www.nps.gov/nr/

www.janneyschool.org



Presentation Outline

Project Background

Existing Conditions

Proposal

Mechanical Depth

Acoustical Breadth

Conclusion

Building Statistics

Existing Building: Built 1925
National Register of Historic Places

Gross Square Feet : 84,400
Overall Project Budget: \$25 Million
Completion Date: August 2011
3 stories above grade, 1 below
Function: Educational



maps.google.com

Presentation Outline

Project Background

Existing Conditions

Proposal

Mechanical Depth

Acoustical Breadth

Conclusion


Location and Weather

Town, Maryland

Relative Humidity – 50%

	Summer	Winter
Designed Dry Bulb (°F)	91	13
Designed Wet Bulb (°F)	77	-
Indoor Air Temperature (°F)	75	72

Weather data based on Baltimore, Maryland



www.ashrae.org

Presentation Outline

Project Background

Existing Conditions

Proposal

Mechanical Depth

Acoustical Breadth

Conclusion

Mechanical Layout


Blue: RTU-1 & 2 Cafeteria

Orange: RTU-3 & 4 (DOAS) and VRF

Purple: RTU- 5 (DOAS) and VRF

Green: RTU-6 & 7 Multipurpose

Red: AHU-1 Administrative Offices




First Floor


Basement



Second Floor



Third Floor



Presentation Outline

Project Background

Existing Conditions

Proposal

Mechanical Depth


Acoustical Breadth

Conclusion

Mechanical Schedule

Rooftop Unit Schedule			
Unit No.	Area Served	Supply CFM	Total Load (MBH)
RTU-1	Cafeteria	7500	227
RTU-2	Cafeteria	7500	227
RTU-3	Exist. Bldg.	8300	350
RTU-4	Exist. Bldg.	5600	236.9
RTU-5	Addition	10650	538
RTU-6	Multi-purpose	7500	235
RTU-7	Multi-purpose	7500	235

Air Cooled Condensing Units Schedules (VRF System)			
Unit No.	Cooling (MBH)	Heating (MBH)	Condenser CFM
CU-VRF-1	439	494	20100
CU-VRF-2	343	386	20100
CU-VRF-3	305	343	13400



www.daikin.com

Presentation Outline

Project Background

Existing Conditions


Proposal

Mechanical Depth


Acoustical Breadth

Conclusion


Mechanical Schematics



RTU- 1, 2, 6 & 7



RTU- 3, 4, & 5
DOAS



VRF System

Presentation Outline

Project Background

Existing Conditions

Proposal


Mechanical Depth

Acoustical Breadth

Conclusion

Energy Use & Emissions

Energy Consumption: Original Design



	% of Total Building Energy	Total Building Energy (kBtu/yr)
Heating	21.56%	894,258
Cooling	30.80%	1,277,511
Receptacles	0.51%	21,069
Lighting	47.13%	1,954,985
Total	100%	4,147,823

	CO2 (lbm/year)	SO2 (gm/year)	NOx (gm/year)
Building Emissions	1,626,597.0	14,638.5	2,801.8

Presentation Outline

Project Background

Existing Conditions

Proposal

Mechanical Depth

Acoustical Breadth

Conclusion



Depth: Implement a geothermal system to improve the buildings energy use.



Breadth: The impact of a geothermal system on the construction management of the project.



Breadth: Perform acoustical analysis to insure the comfort of the spaces



www.nps.gov/nr/

Presentation Outline

Project Background

Existing Conditions

Proposal

Mechanical Depth


Acoustical Breadth

Conclusion

Proposed System

Water-cooled VRF units coupled with closed loop ground coupled heat pump

- More efficient than air-cooled condensers
- Constant thermal properties
- Reduces noise pollution
- Minimal site area loss
- High initial cost (long term owners)
- Renewable energy source (earth)
- Low maintenance



Ball State University

Presentation Outline

Project Background

Existing Conditions


Proposal

Mechanical Depth

Acoustical Breadth


Conclusion

Site & Well Properties



Soil Properties	Wet dense sand
Dry Density	120 lb/ft ³
Conductivity (k)	1.63 Btu/h*ft*°F
Diffusivity (α)	0.91 ft ² /day

Annual Average Ground Temperature - 55°F



Geothermal Heat Pump Design Manual by McQuay Air Conditioning

Well Design Details		
Radius of bore	0.42	ft
SDR 11	1.00	in
R _{pipe}	0.10	ft*hr*°F/Btu
R _{grout}	0.05	ft*hr*°F/Btu
R _{bore}	0.15	ft*hr*°F/Btu

Presentation Outline

Geothermal Calculations

Project Background

Existing Conditions

Proposal

Mechanical Depth

Acoustical Breadth

Conclusion

Required Bore Length for Cooling (ft)

$$L_c = \frac{q_a R_{ga} + (q_{lc} - 3.41 W_c)(R_b + PLF_m R_{gm} + R_{gd} F_{sc})}{t_g - \frac{t_{wi} + t_{wo}}{2} - t_p}$$

Required Bore Length for Heating (ft)

$$L_h = \frac{q_a R_{ga} + (q_{lh} - 3.41 W_h)(R_b + PLF_m R_{gm} + R_{gd} F_{sc})}{t_g - \frac{t_{wi} + t_{wo}}{2} - t_p}$$

Equations from ASHRAE Handbook

	Symbol	Cooling	Heating	Units
Net annual average heat transfer to the ground	Qa	251,250	150,000	Btu/h
Building design cooling block load (or heating)	Qlc (or Qlh)	2,010,000	1,200,000	Btu/h
Power input at design cooling load (or heating)	Wc (or Wh)	130,000	130,000	W
Effective thermal resistance of ground annual pulse	Rga	0.2438	0.2438	ft*hr*°F/Btu
Effective thermal resistance of ground monthly pulse	Rgm	0.223	0.223	ft*hr*°F/Btu
Effective thermal resistance of ground daily pulse	Rgd	0.131	0.131	ft*hr*°F/Btu
Thermal resistance of bore	Rb	0.15	0.15	ft*hr*°F/Btu
Short circuit heat loss factor	Fsc	1.04	1.04	
Part load factor during design month	PLFm	1.00	1.00	
Undisturbed ground temperature	tg	55	55	°F
Liquid temperature at heat pump inlet	twi	74	44	°F
Liquid temperature at heat pump outlet	two	83	36	°F
Temperature penalty	tp	2.00	2.00	°F
	Length	33,689	32,454	ft
	# of wells	84.2	81.1	

Presentation Outline

Project Background

Existing Conditions

Proposal

Mechanical Depth

Acoustical Breadth

Conclusion



maps.google.com

Well Layout

85 wells


400 ft deep wells

15 ft well spacing

Area used 19,125 sq. ft.

Pump located in East Mechanical Room

Direct return piping



Presentation Outline

Project Background


Existing Conditions

Proposal

Mechanical Depth

Acoustical Breadth

Conclusion



Pipe & Flow Design

480 GPM


2.9 GPM/ton design

6" header pipe

2" row pipe

1" well U-tube

5" bore diameter



Presentation Outline

Project Background

Existing Conditions

Proposal

Mechanical Depth


Acoustical Breadth

Conclusion

Well Pump Selection


Table 22- Head Loss

Friction Loss	6.8 ft
Fixture Loss	109 ft
Velocity Loss	0.4 ft
Total head loss	116.2 ft



www.goulds.com

Size	Head	Flow Rate	RPM	HP	Manufacturer	Model
4x4x7	116.2 ft	480 gpm	3500	20	Goulds	AC-135.3F



www.goulds.com

Presentation Outline

Project Background

Existing Conditions

Proposal

Mechanical Depth

Acoustical Breadth

Conclusion

Water-Cooled VRF Unit Selection


Unified heat pump and heat recovery

Units in series to reach needed capacity

Self heat recovery between modules

	Daikin	VRV-WIII Series				
	Unit	21 ton	18 ton	12 ton	7 ton	6 ton
Cooling	Capacity (Btu/h)	252,000	216,000	144,000	84,000	72,000
	EER	15.0	15.3	15.3	15.0	15.3
Heating	Capacity (Btu/h)	283,500	243,000	162,000	94,000	81,000
	COP	4.7	5.3	5.3	4.7	5.3

	Units
CU-VRF-1	(3)x 21 ton + 12 ton
CU-VRF-2	(2)x 21 ton + 7 ton
CU-VRF-3	21 ton + 18 ton + 6 ton



www.daikin.com

Presentation Outline

Project Background

Existing Conditions

Proposal

Mechanical Depth

Acoustical Breadth

Conclusion

Heat Exchanger Details

Ground Temperature 55°F


Ground Coupled Side

- 20% glycol / 80% water

VRF Side

- R140a

	Water			Refrigerant			Indoor Units Air	
	Tin	Tout	GPM	Tin	Tout	GPM	Supply	Return
Cooling	74°F	83°F	480	76°F	50°F	280	53-55°F	78-80°F
Heating	44°F	36°F	480	105°F	89°F	280	78-81°F	68-70°F



www.dreamstime.com

EA Credit 6

Refrigerant	Q (tons)	Refrigerant Impact per ton	Credit (<100)
R-410a	324	95.7	Yes

Presentation Outline

Project Background

Existing Conditions

Proposal

Mechanical Depth

Acoustical Breadth

Conclusion

Alternative System Energy Use

Energy Consumption: Alternative Design




Table 25- Alternative Yearly Energy Consumption

	Building kWh	Building kBtu/yr	Source kBtu/yr
Heating	185,431	632,320	1,896,960
Cooling	192,269	656,215	1,968,843
Lighting	572,805	1,954,985	5,865,541
Receptacle	6,173	21,069	63,213
Total	956,678	3,264,589	9,794,557
Cost	\$131,064.90		

Presentation Outline

Project Background

Existing Conditions

Proposal

Mechanical Depth

Acoustical Breadth

Conclusion


Energy & Emissions Comparison

Table 26- Yearly Energy Breakdown				
	Building (kWh)	Building (kBtu/yr)	Source (kBtu/yr)	Cost
Original System	1,215,300	4,147,823	12,444,711	\$166,496.09
Alternative System	956,678	3,264,589	9,794,557	\$131,064.90
Yearly Savings	258,622	883,234	2,650,154	\$35,431.19

Emissions Comparison- 21.3% less

	CO2 (lbm/year)	SO2 (gm/year)	NOx (gm/year)
Original Design	1,626,597.0	14,638.5	2,801.8
Alternative Design	1,280,231.0	11,521.4	2,205.2

Monthly Energy Consumption



Presentation Outline

Project Background

Existing Conditions

Proposal

Mechanical Depth

Acoustical Breadth

Conclusion



Federal Tax Rebate

- 10 % of initial material and labor cost
- EER \geq 14.1
- COP \geq 3.3

Without rebate Payback Period = 19.53 years

Payback Period

Table 28- Payback Period

	Cost	
Original System	\$56,348.44	
Alternative System	\$692,071.26	
With 10% Rebate	\$622,564.13	
System Difference	\$566,215.69	
Yearly Energy Savings	\$35,431.19	
Payback Period	15.98	Years
	191.77	Months

Presentation Outline

Project Background

Existing Conditions

Proposal

Mechanical Depth

Acoustical Breadth

Conclusion



maps.google.com

Cost Comparison

	Mechanical Cost	Total Construction Cost
Original Design	\$3,461,864	\$20,969,617
Alternative Design	\$4,028,079	\$21,535,833
Percent Increase	16.4%	2.7%

Original Building cost is based on 2015 using inflation from 2010.

Original		
Material	Condensers	\$42,377.00
	Controls	\$823.00
Labor	Condensers	\$11,985.00
	Controls	\$1,163.00
Total Cost		\$56,348.00

Alternative		
Material	Pump	\$19,200
	Antifreeze	\$6,786
	Water	\$14
	Controls	\$1,475
	Investigation	\$915
	Loop	\$424,521
Sub-total		\$452,911
Labor	Pump	\$1,842
	Controls	\$2,952
	Investigation	\$3,993
	Loop	\$230,373
	Sub-total	\$239,160
Total Cost		\$692,071

Presentation Outline

Project Background


Existing Conditions

Proposal

Mechanical Depth

Acoustical Breadth

Conclusion



Multi-purpose Room Acoustical Treatment

Goal NC-45

Before: NC > 65 After: NC – 39

Added Treatment:



- 2" duct lining (60 ft each)
- One duct silencer each

Cost Breakdown

Duct lining = \$11,457

Duct Silencers = \$4,700

Total Cost = \$16,157



Presentation Outline

Project Background



Existing Conditions

Proposal

Mechanical Depth

Acoustical Breadth

Conclusion



Cafeteria Acoustical Treatment

Before: NC - 52 After: NC - 41

Added Treatment:

- One duct silencer each (36"x12"x50")



Cost Breakdown

Duct Silencers = \$4,000

Total Cost = \$4,000

Not recommended extra cost

Goal NC-45



Presentation Outline

Project Background

Existing Conditions

Proposal

Mechanical Depth

Acoustical Breadth

Conclusion



www.nps.gov/nr/

Conclusion

System Initial Cost - \$692,071.26

Monthly Savings - \$2952.60

Payback Period of System – 15.98
years

EUI Reduction – 21.3%



www.nbm.org



www.nps.gov/nr/

Acknowledgements

Penn State Faculty

JVP Engineers

Dr. Stephen Treado

All my peers that helped during the process

All my friends and family for their support



www.kumicm.com



www.nps.gov/nr/

Questions?



www.kumicm.com