AE 481W Tech Report 4A

Bucks County Justice Center

Joshua Lange Lighting/Electrical Dr. Richard Mistrick **Building Introduction**

Bucks County Justice Center Doylestown, PA

Size: 273,000 GSF

Levels: 7 levels above grade (with penthouse) 2 levels below grade

Dates of construction: July 2011-Early 2015

Overall Project Cost: approximately \$84 million


Bucks County Justice Center







Space Introduction ?



Space Introduction ?

(C) (****)

E

(8)

A\$115

H

J(J.3)

(K)

(G)


(F


Space 2 Circulation Space: • ---Main Lobby 1000 ---• Psychological Impression ---


(R)


P)

 \bigcirc









Main Plaza

Qualitative

Inviting

Way finding

Safety

Main Plaza

Quantitative ASHRAE 90.1

Daylight control

Building facade and landscaping shut off between midnight and 6:00 a.m.

Automatic reduction

Base	Plaza Areas	Main Entries	Building Facades (non tradable)	
600 W	0.14 W/SF	20 W/lin ft of door width	0.1 W/SF	

Main Plaza

Quantitative IES Handbook

Eh (lux)	Ev (lux)	Max:Avg	Avg:Min	
4	2	4:1	5:1	

IES & LDA MLO

Site lumen limit

Performance method requires bounding box to have:

- No more than 15% of site lumens
- An illuminance not greater than 3.0 lumens


Main Plaza

Quantitative Other Criteria


CCT: 3500K


CRI: ≥80


Life: very high due to the complexity of maintenance




Main Plaza









Final Considerations

Main Plaza


Equipment

















Main Lobby 1000

Qualitative

Spacious

Way finding

Safety

Main Lobby 1000

Quantitative ASHRAE 90.1

Local control

Automatic Daylight Responsive Controls for Sidelighting

Allocated LPD: 0.9 W/SF

Main Lobby 1000

Quantitative IES Handbook

Location	Eh (lux)	Elevation Eh	Ev (lux)	Elevation Ev	Avg:Min
Security screening	200	3'-0"	100	5'-0"	2:1
Lobbies near entries (day)	100	Floor	30	5'-0"	4:1

Main Lobby 1000


Quantitative Other Criteria


CCT: 3500K


CRI: ≥80


Life: very long


Efficacy/Efficiency: 20% reduction from ASHRAE 90.1












































41







Final Considerations

Main Lobby 1000



Equipment












Final Considerations


Main Lobby 1000

Emergency Power

Generator connected

Exit signs Egress illumination







Open Office 2520

Qualitative

Openness

Community

Views/Daylight

Open Office 2520

Quantitative ASHRAE 90.1


Local control

Bilevel Lighting Control

Scheduled Shutoff

Manual on

Allotted LPD: 0.98 W/SF



Open Office 2520

Quantitative IES Handbook

Illuminance values Eh: 300 lux @ 2'-6"

> Uniformity Avg: Min 1.5:1

Open Office 2520


Quantitative Other Criteria


CCT: 3500K

CRI: ≥80


Life: long


Efficacy/Efficiency: 20% reduction from ASHRAE 90.1













Final Considerations

Open Office 2520

Equipment







Emergency Power

Generator connected

Exit signs Basic egress lighting (~6 fixtures)







Ceremonial Courtroom 4100

Qualitative

Respect

Dignity

Virtuous

Flexible

Ceremonial Courtroom 4100

Quantitative ASHRAE 90.1

Local control

Scheduled Shutoff


Allocated LPD: 1.72 W/SF

Ceremonial Courtroom 4100

Automatic Daylight Responsive Controls for Sidelighting are required if either

1) The total of installed light in the sidelighted zone is ≥150 watts

or 2) The total of installed light in the primary and secondary sidelighted zone is ≥300 watts



Ceremonial Courtroom 4100


Quantitative Other Criteria

CCT: 3500K


CRI: ≥80

Life: long


Efficacy/Efficiency: 20% reduction from ASHRAE 90.1




Attorneys' Tables Eh = 500 Lux




Evidence Table Eh = 500 Lux




Bench and Clerks Eh = 500 Lux



Jury Box Eh = 300 Lux



Public Seating Eh = 300 Lux




Projection Screen Ev = 50 Lux


Ceremonial Courtroom 4100


Quantitative IES Handbook


Location	Eh (lux)	Height Eh	Ev (lux)	Height Ev	Max:Avg	Avg:Min	Notes
Attorneys' Tables	500	2'-6"	200	4'-0"		2:1	
AV Presentation, General	75	2'-0"	30	4'-0"		2:1	Note taking intended
AV Presentation Screen			50		2:1		Max value
Evidence Table	500	2'-6"	200	4'-0"		2:1	
Jury Box	300	2'-6"	150	4'-0"		2:1	
Public Seating	100	2'-6"	50	4'-0"		2:1	
Witness Stand	300	2'-6"	150	4'-0"		2:1	
Bench and Clerks	500	2'-6"	200	4'-0"		2:1	
Faces for Video Conferencing	300	4'-0"	400	3'-5'		1.5:1	E_v should be in the direction of the camera












































Final Considerations

Ceremonial Courtroom 4100













Final Considerations

Ceremonial Courtroom 4100

Emergency Power

Generator connected

All exit signs Exitways, corridors, stairways, etc. General room illumination

References

ASHRAE. (2013). Standard 90.1-2013 Energy Standard for Buildings Except Low-Rise Residential Buildings.

DiLaura, D. L., Mistrick, R. G., Houser, K. W., & Steffy, G. R. (2011). Illuminating Engineering Society The Lighting Handbook: Reference and Application Tenth Edition. New York, NY: Illuminating Engineering Society of North America.

IDA-IES. (2011). Model Lighting Ordinance. Illuminating Engineering Society and International Dark Sky Association.

AE 481W Tech Report 4A

Bucks County Justice Center

Joshua Lange Lighting/Electrical Dr. Richard Mistrick