



Submitted 18 Sept. 2014

Technical Report 1

Brault Building Renovation

Northern Virginia Community College

Annandale, VA



Michael Giuliani

MECHANICAL OPTION

ADVISOR PROFESSOR WILLIAM BAHNFLETH

Table of Contents

Executive Summary	2
Mechanical System Overview	3
ANSI/ASHRAE Standard 62.1 – 2013 Analysis	
Section 5 Systems and Equipment	4
Section 6 Ventilation Rate Calculation Procedure	7
Conclusion	8
ANSI/ASHRAE Standard 90.1 – 2013 Analysis	
Section 5 Building Envelope	9
Section 6 Heating, Ventilating, and Air Conditioning	10
Section 7 Service Water Heating	11
Section 8 Power	11
Section 9 Lighting	11
Section 10 Other Equipment	11
Conclusion	12
References	13
Appendix A	
Table 5.5.1 – Air Intake Minimum Separation Distance	14
Table A-1 - Standard 62.1 Outdoor Air Rates	14
Table A-2 – Outdoor Air Ventilation Rate Calculation	15
Appendix B	
Figure B-1 - ASHRAE Climate Zone Map	17
Table 5.5-4 –Building Envelope Requirements for Climate	18
Figure B-2 – Existing Wall Section	19
Figure B-3 – New Curtain Wall Section	19
Figure B-4 – Wall Section through Exterior Door	20
Table B-1 – Equipment Voltage Drop	20

Executive Summary

The Brault Building is an administrative office for the Northern Virginia Community College, located in Annandale, VA. This three story, 50,000 square foot building renovation will add additional office space which will allow more employees to occupy the building. This technical report will give a further understanding of the Brault Building's compliance with ANSI/ASHRAE Standard 62.1-2013: Ventilation for Acceptable Indoor Air Quality and ANSI/ASHRAE/IES Standard 90.1-2013: Energy Standard for Buildings Except Low-Rise Residential Buildings.

ANSI/ASHRAE Standard 62.1-2013: Ventilation for Acceptable Indoor Air Quality requires an analysis of a buildings system and equipment as well as the buildings ventilation rate. The Brault building follows Section 5 which has requirements on ventilation air distribution, exhaust duct location, ventilation system controls, airstream surfaces, outdoor air intakes, local capture of contaminants, combustion air, particle matter removal, dehumidification systems, drain pans, finned-tube coils and heat exchangers, humidifiers and water-spray systems, access for inspection, cleaning, and maintenance, building envelope and interior surfaces, buildings with attached parking garages, air classification and recirculation, and requirements for buildings containing ETS areas and ETS-Free areas. Section 6 requires a building to have a certain ventilation rate with a mandatory percentage of outdoor air mixed within. The Brault Building requires 44,550 CFM of ventilated air throughout the building, where 37% of that air must be outdoor air.

ANSI/ASHRAE/IES Standard 90.1-2013: Energy Standard for Buildings Except Low-Rise Residential Buildings requires a building to maintain a certain efficiency. As the Brault Building is try to reach LEED Silver rating, the building must meet stricter regulations than that in Standard 90.1. Standard 90.1 – 2013 requires an analysis of a buildings building envelope, heating, ventilating, and air conditioning, service water heating, power, lighting, and other equipment. These section require that the building must be properly insulated and sealed to prevent heat loss and infiltration, must have a properly sized and equipped HVAC system that will yield a high efficiency, and properly meeting the amount of domestic water, power density, efficient lighting, and ensure that all other equipment are regulated and will work safely.

The Brault Building successful complies with all of the regulations that are required by ANSI/ASHRAE Standard 62.1-2013: Ventilation for Acceptable Indoor Air Quality and ANSI/ASHRAE/IES Standard 90.1-2013: Energy Standard for Buildings Except Low-Rise Residential Buildings.

Mechanical System Overview

The Brault Building is located in Annandale, VA, which is considered to be in cool and humid climate. This requires that the building must be able to supply sufficient amount of cooling as well as heating to maintain occupant comfort.

The Brault Building renovation will incorporate five air handling units, three located on the roof and two in the mechanical room, with a capability of supplying 45,900 CFM. The building requires a minimum of 44,550 CFM to be able to properly ventilate the building according to ASHRAE Standard 62.1. The ventilation system supplies 37% of its overall airflow as fresh outdoor air. Areas that may need to be exhausted directly out of the building, including toilets, are done so properly.

The air temperature in the conditioned building is maintained by a hydronic water system. The building contains two 55 GPM gas powered boilers and a 210 GPM air cooled scroll or screw compressor chiller. The boilers are capable of heating water from 110 degrees Fahrenheit to 140 degrees Fahrenheit. The chiller is capable of cooling water from 59 degrees Fahrenheit to 44 degrees Fahrenheit at 95 degrees Fahrenheit outside ambient air temperature. The buildings cooling system uses a 210 GPM pump with 70 feet of head, and the heating system has a 55 GPM primary pump with 60 feet of head as well as have secondary pumps located at each of the air handling units. The Brault Building also makes use of fan-powered parallel flow terminals and variable air volume boxes. This allows the occupants to have more control of the building temperature to increase the occupancy comfort.

Passively, the Brault Building is capable of regulating loads and help increased mechanical system efficiency. The building utilizes a curtain wall system facing the south, which can help decrease the heating load needed for the building needed during the heating season. The building also has horizontal metal sun louvers which will help shade the building from solar heat gain during the cooling season to reduce the cooling load needed.

ANSI/ASHRAE Standard 62.1 – 2013

Section 5 Systems and Equipment

5.1 Ventilation Air Distribution

The Brault Building has been designed to supply the minimum amount of outdoor air needed to ventilate a building under maximum load conditions. This project uses direct connections from ventilation air ducts to terminal units. There is proper documentation of the ventilation air distribution calculations and assumptions approved by professional engineers.

5.2 Exhaust Duct Location

The Brault Building has proper air exhaust from restrooms throughout the building. In compliance with this standard, the exhaust ductwork does not circulate through any conditioned space where improper air contamination may occur. The exhaust ductwork runs directly from the buildings restrooms to the exterior of the building.

5.3 Ventilation System Controls

The Brault Building includes a Building Automation System (BAS) with CO₂ controls to modulate ventilation systems in response to occupancy are included in this system. This system included a direct digital control (DDC) to switch the system between occupied and und occupied situations. Also, the supply fan and outside air dampers have a hardwire interlock as well as the relief damper and return fan.

5.4 Airstream Surfaces

Galvanized sheet-metal with exterior fiberglass duct insulation is used for all ductwork within the Brault Building. This will ensure mold shall not grow and circulate throughout the ventilation system, as well as being composed of a material which will not erode.

5.5 Outdoor Air Intakes

With three air handling units on the roof of the building and one air handling unit in the mechanical room with direct ductwork to the building exterior, the air intakes of these units are properly located away from possible contaminants specified on Table 5.5.1, also located in Appendix A. And are protected from rain and snow with a bird screen to protect the air intake from bird nesting.

5.6 Local Capture of Contaminants

This section of the standard does not apply to the Brault Building.

5.7 Combustion Air

Combustion air intake and exhaust are directly ducted to the exterior of the building via 6 inch round ductwork. This section also complies with the requirements from Section 5.5: Outdoor Air Intakes.

5.8 Particulate Matter Removal

The Brault Building's filtration system complies with ASHRAE 52.2 with a MERV rating of 8. The disposable panel filter is 1 inch thick with interlaced glass fibers sprayed with nonflammable adhesive and antimicrobial agent.

5.9 Dehumidification Systems

This section of the standard does not apply to the Brault Building.

5.10 Drain Pans

Comprised of galvanized or Type 304 stainless steel sheet metal, the pan extends at minimum 12 inches past the coil. The pans are sloped at minimum in two planes to collect condensate

5.11 Finned-Tube Coils and Heat Exchangers

All cooling coil assemblies and condensate-producing heat exchangers are scheduled, with a drain pan with a minimum depth of 2 inches, in accordance with Section 5.10. There are no finned-tube coils in this building.

5.12 Humidifiers and Water-Spray Systems

This section of the standard does not apply to the Brault Building.

5.13 Access for Inspection, Cleaning, and Maintenance

The Brault Building currently maintains acceptable clearances for all mechanical equipment and appropriate ventilation equipment and air distribution system access.

5.14 Building Envelope and Interior Surfaces

The Brault Building is properly sealed with a moisture and vapor barrier as well as providing weep holes where water may accumulate. All doorways, joints, and windows are sealed to prevent moisture damage. The interior walls are made from Gypsum Shaftliner Board, Moisture- and Mold-Resistant Type X.

5.15 Buildings with Attached Parking Garages

This section of the standard does not apply to the Brault Building.

5.16 Air Classification and Recirculation

The air in the Brault Building is classified as Type 1 except for restrooms. Air from restrooms are pressurized and exhausted directly to the exterior of the building without contaminating other areas of the building.

5.17 Requirements for Buildings Containing ETS Areas and ETS-Free Areas

The Brault Building is being built to become a LEED Silver certified building. No smoking will be allowed in this building. This section of the standard does not apply to the Brault Building.

Section 6 Ventilation Rate Calculation Procedure

Section 6: Ventilation Rate Calculation Procedure of the ANSI/ASHRAE Standard 62.1-2013 explains how much air needs the system needs to intake in order to provide the proper amount of outdoor air based on space type, application, occupancy level, and floor zone. The first step in calculating the ventilation rate, the outdoor airflow required in the breathing zone must be acquired. The breathing zone outdoor airflow was calculated using the following equation:

$$V_{bz} = R_p * P_z + R_a * A_z$$

Where:

V_{bz} is the breathing zone outdoor airflow

R_p is the outdoor airflow rate required per person as determined from Table A-1

P_z is the zone population or the number of people in the ventilation zone during typical usage

R_a is the outdoor airflow rate required per unit area as determined from Table A-1

A_z is the zone floor area or the net occupiable floor area of the ventilation zone, ft² or m²

Once the required amount of outdoor air airflow is determined, the primary outdoor air fraction must be determined. The primary outdoor air fraction is calculated using the following equation:

$$Z_{pz} = V_{oz} / V_{pz}$$

Where:

Z_{pz} is the primary outdoor air fraction

V_{oz} is the zone outdoor airflow

V_{pz} is the primary airflow

The Brault Building has an estimated 406 occupants at full load, which requires 44,550 CFM to provide enough airflow for the occupancy load. To meet ASHRAE standards, 16,662 CFM, or 37% of the overall airflow, of outdoor air must be provided to the entire building. The Brault Building ventilation calculations can be found in Appendix A, Table A-2.

ANSI/ASHRAE Standard 62.1 – 2013

Conclusion

The Brault Building being a low rise non-residential building, must comply with ANSI/ASHRAE Standard 62.1 – 2013. After an in depth analysis of Standard 62.1 Section 5 and Section 6, it is determined that the Brault Building does comply with all the requirements that it must meet.

ANSI/ASHRAE Standard 62.1 – 2013 Section 5 requires an analysis of a buildings systems and equipment. There are some areas in this section that are inapplicable to the Brault Building, including Sections 5.6, 5.9 5.12, and 5.15, thus may be ignored in this analysis. The rest of Section 5 requirements are meet by the Brault Building design.

ANSI/ASHRAE Standard 62.1 – 2013 Section 6 requires an analysis of a buildings ventilation rates. The Brault Building design follows Section 6, and a table showing the calculations for each individual room and overall ventilation rate may be found in Appendix A as Table A-2.

ANSI/ASHRAE/IES Standard 90.1 – 2013

Section 5 Building Envelope

5.1 General

The Brault Building is located in Annandale, Virginia, which is considered to be in Climate Zone 4A. This zone is to be considered cool and humid. Please refer to Appendix B Figure B-1 for full map.

5.2 Compliance Paths

The Brault Building must comply with Section 5.1, Section 5.4, Section 5.7, and Section 5.8, as well as comply with either Section 5.5 or Section 5.6

5.3 Simplified Building

The section of the standard is not used for the Brault Building.

5.4 Mandatory Provisions

Being located in Climate Zone 4A, the Brault building must be properly sealed, especially at exterior doors and fenestrations. In Appendix B, Figures B-2, B-3, and B-4 illustrate that the buildings windows and doors are properly sealed for the outdoor environment. The building's exterior wall materials are also very important for to maintain proper insulation. The Brault Building meets these requirements of acceptable materials allowable in its climate zone. The main entrance of the Brault Building is separated from the interior of the building by a vestibule that will protect the conditioned space from the unconditioned outdoor environment.

5.5 Prescriptive Building Envelope Option

According to Table 5.5-4, also located in Appendix B, declares that vertical fenestration is limited to 40% of the wall and 3% of the roof for skylights. The Brault Buildings total exterior surface area is approximately 16,650 square feet with only approximately 6,250 square feet of vertical fenestration. This yields a 38% vertical fenestration limit, which is less than the maximum limit for the building. Since the Brault Building has no skylights, it meets the requirements for under 3% of the roof may be a skylight. Table 5.5-4 also requires that the walls, roof, and windows must meet a certain U-Value. Figures B-2 and B-3 in Appendix B illustrate the buildings compliance with Table 5.5-4. Have a large percentage of the building with vertical fenestration, solar heat gain must be regulated. As seen in Figures B-2 and B-3 in Appendix B, the Brault Building has horizontal metal sun louvers that is operable and may determine how much sunlight enters through the vertical fenestrations.

Section 6 Heating, Ventilating, and Air Conditioning

6.1 General

All mechanical equipment for the new addition of the Brault Building must comply with Section 6.2. All existing cooling systems serving previously unconditioned spaces must comply with Section 6.2.

6.2 Compliance Paths

The Brault Building must comply with Section 6.1, Section 6.7, and Section 6.8 as well as complying with either Section 6.3, Section 6.4, or Sections 6.4 and 6.6.

6.3 Simplified Approach Option

The Brault Building does not meet the qualifications to use Section 6.3.

6.4 Mandatory Provisions

This section requires that all equipment in Tables 6.8.1-1 through 6.8.1-13 will reach the minimum specified rating conditions for its performance.

6.5 Prescriptive Path

Being located in Climate Zone 4A, the Brault Building is not required have an economizer for its cooling system, but the building does take advantage of this energy efficient method. The control sensor for outside air will modulate the outdoor air damper when the outside air temperature falls below 69 degrees Fahrenheit. The building has reheating/recooling opportunities at each VAV box that may be individually controlled at each location by the use of a hydronic heat pump system. The Brault Building also complies with the fan power limitations and does not exceed the motor nameplate horsepower. All heating and cooling air flow and temperature is regulated using DDC Controllers and sensors that control the systems.

Section 7 Service Water Heating

The Brault Building utilizes boilers for hot water supply to the air handling units, the unit heaters, the variable air volume boxes, and the fan-powered parallel flow terminals. Each 55 gallon gas fueled condensing boiler is set to supply the water at 140 degrees Fahrenheit from 110 degrees Fahrenheit. A 100 gallon domestic water heater set at 140 degrees Fahrenheit is used to supply all the heated potable water in the building. All piping meets the minimum insulation requirements.

Section 8 Power

The Brault Building is required to have a maximum voltage drop of 2% of the design load for the feeders and a maximum of 3% of the design load at branch circuits. With the largest branch circuit voltage drop of 1.89%, the building is within the regulation of the standard. Table B-1 in Appendix B gives more detail for the voltage drop calculations.

Section 9 Lighting

The Brault Building lighting design uses many features to save energy. Having a curtain wall facing the south with operable sun louvers, the building is capable of maximizing its use of natural daylight while being able to regulate the amount of solar heat gain entering the building. The Brault Building also utilizes combination dual technology occupancy sensor and light switch, which will greatly reduce the energy used in a room when unoccupied. From the NEC Table 220-12, electrical loads for office buildings are required to be 3.5 VA/SqFt for lighting and 1 VA/SqFt for Power, which gives an overall power density of 4.5 VA/SqFt.

Section 10 Other Equipment

Under Section 230514 – Common Motor Requirements for HVAC Equipment in the Brault Building Project Manual, all electric motors are in conformance with National Electrical Manufacturers Association (NEMA) MG 1 standard, the Energy Independence and Security Act of 2007, and must comply with NFPA 70. The Brault Building complies with all of these regulations which makes the building compliant with ANSI/ASHRAE 90.1 – 2013 Section 10.

ANSI/ASHRAE/IES Standard 90.1 – 2013

Conclusion

The Brault Building being a low rise non-residential building, must comply with ANSI/ASHRAE/IES Standard 90.1 – 2013. As the design team has designed the building to reach LEED Silver rating, LEED requires that Section 90.1 needs to be met and surpassed. After an in depth analysis of Standard 90.1 Section 5, Section 6, Section 7, Section 8, Section 9, and Section 10, it is determined that the Brault Building does comply with all the requirements that it must meet.

ANSI/ASHRAE/IES Standard 90.1 – 2013 Section 5 requires an analysis of the building envelope. Being in Climate Zone 4A, the Brault Building must meet certain requirements for insulation and infiltration prevention. The Brault Building is properly insulated and sealed to meet and surpass ASHRAE standards.

ANSI/ASHRAE/IES Standard 90.1 – 2013 Section 6 requires an analysis of the heating, ventilation, and air conditioning systems. Being hydronically heated and cooled at both the air handling units as well as being able to be reheated or recooled at individual variable air volume boxes, the Brault Building is able to maintain proper temperature regulation within the conditioned area. The addition of being able to use an economizer in the building greatly increases the energy efficiency of the system.

ANSI/ASHRAE/IES Standard 90.1 – 2013 Section 7, Section 8, Section 9, and Section 10 require an analysis of the service water heating, power, lighting and other equipment. The domestic water is supplied from a single 100 gallon hot water heater at 140 degrees Fahrenheit, and the service water for heating systems is supplied from two 55 gallon boilers at 140 degrees Fahrenheit. The power for the building has a branch circuit voltage loss of only 1.89% and having a combined power and lighting density load of 4.5 VA/SqFt. The curtain wall system allows for optimal amount of daylighting in the building while having the capability of being shaded to prevent solar heat gain. All electric motors must fit regulations that have more complies and is stricter than the ASHRAE Standard.

References

ANSI/ASHRAE Standard 60.1-2013, Ventilation for Acceptable Indoor Air Quality. Atlanta, GA.
American Society of Heating Refrigeration and Air Conditioning Engineers, Inc.

ANSI/ASHRAE/IES Standard 90.1-2013, Ventilation for Acceptable Indoor Air Quality. Atlanta, GA.
American Society of Heating Refrigeration and Air Conditioning Engineers, Inc.

Cole & Denny Incorporated. "Architectural Construction Documents". Alexandria, VA.

Summer Consultants, Inc. "Electrical Construction Documents". McLean, VA.

Summer Consultants, Inc. "Mechanical Construction Documents". McLean, VA.

Appendix A

© ASHRAE (www.ashrae.org). For personal use only. Additional reproduction, distribution, or transmission in either print or digital form is not permitted without ASHRAE's prior written permission.

TABLE 5.5.1 Air Intake Minimum Separation Distance

Object	Minimum Distance, ft (m)
Class 2 air exhaust/relief outlet (Note 1)	10 (3)
Class 3 air exhaust/relief outlet (Note 1)	15 (5)
Class 4 air exhaust/relief outlet (Note 2)	30 (10)
Plumbing vents terminating less than 3 ft (1 m) above the level of the outdoor air intake	10 (3)
Plumbing vents terminating at least 3 ft (1 m) above the level of the outdoor air intake	3 (1)
Vents, chimneys, and flues from combustion appliances and equipment (Note 3)	15 (5)
Garage entry, automobile loading area, or drive-in queue (Note 4)	15 (5)
Truck loading area or dock, bus parking/idling area (Note 4)	25 (7.5)
Driveway, street, or parking place (Note 4)	5 (1.5)
Thoroughfare with high traffic volume	25 (7.5)
Roof, landscaped grade, or other surface directly below intake (Notes 5 and 6)	1 (0.30)
Garbage storage/pick-up area, dumpsters	15 (5)
Cooling tower intake or basin	15 (5)
Cooling tower exhaust	25 (7.5)

Note 1: This requirement applies to the distance from the outdoor air intakes for one ventilation system to the exhaust/relief outlets for any other ventilation system.
 Note 2: Minimum distance listed does not apply to laboratory fume hood exhaust air outlets. Separation criteria for fume hood exhaust shall be in compliance with NFPA 45⁵ and ANSI/AIHA Z9.5.⁶ Information on separation criteria for industrial environments can be found in the *ACGIH Industrial Ventilation Manual*⁷ and in *ASHRAE Handbook—HVAC Applications*.⁸
 Note 3: Shorter separation distances shall be permitted when determined in accordance with (a) ANSI Z223.1/NFPA 54⁹ for fuel gas burning appliances and equipment, (b) NFPA 31¹⁰ for oil burning appliances and equipment, or (c) NFPA 211¹¹ for other combustion appliances and equipment.
 Note 4: Distance measured to closest place that vehicle exhaust is likely to be located
 Note 5: Shorter separation distance shall be permitted where outdoor surfaces are sloped more than 45 degrees from horizontal or that are less than 1 in. (30 mm) wide.
 Note 6: Where snow accumulation is expected, the surface of the snow at the expected average snow depth constitutes the "other surface directly below intake."

Table A-1 - Standard 62.1 Outdoor Air Rates (Not Full List)

Occupancy Category	IP		SI		Default Occupant Density #/1000 ft ² (#/100 m ²)
	R _p (cfm/per)	R _a (cfm/ft ²)	R _p (L/s-per)	R _a (L/s-m ²)	
Conference/meeting	5	0.06	2.5	0.3	50
Corridors	0	0.06	0	0.3	0
Electrical equipment rooms	0	0.06	0	0.3	0
Elevator machine rooms	0	0.12	0	0.6	0
Office space	5	0.06	2.5	0.3	5
Storage rooms	0	0.12	0	0.6	0
Telephone closets	0	0	0	0	0
Telephone/data entry	5	0.06	2.5	0.3	60

Table A-2 - Outdoor Air Ventilation Rate Calculation

ASHRAE 62.1-2007														
System	Floor	Room	Usage	Floor Area	Load CFM	People / 1000 SqFt	People	CFM / Person	CFM / SqFt	Uncorrected OA Req(CFM)	Calc'd OA	30% more OA	OA % of Load	Minimum Exhaust (CFM)
AHU-1	1	100	Vestibule	60	50	0	0	0	0	0	17	22	0.44	
AHU-1	1	101,124,125,126,140	corridor	1847	300	0	0	0	0.06	111	102	132	0.44	
Vent	1	102	sprinkler	135		0	0	0	0	0				
AHU-1	1	103	office	131	150	5	1	5	0.06	11	51	66	0.44	
AHU-1	1	104	office	130	200	5	1	5	0.06	11	68	88	0.44	
AHU-1	1	105	office	130	200	5	1	5	0.06	11	68	88	0.44	
AHU-1	1	106	office	130	200	5	1	5	0.06	11	68	88	0.44	
AHU-1	1	107	office	124	125	5	1	5	0.06	11	42	55	0.44	
AHU-1	1	108	office	131	125	5	1	5	0.06	11	42	55	0.44	
AHU-1	1	109	office	124	125	5	1	5	0.06	11	42	55	0.44	
AHU-1	1	110	office	143	125	5	1	5	0.06	12	42	55	0.44	
vent	1	111	elec closet	130										
vent	1	112	elev. mach rm	60										
AHU-1	1	113	office	120	100	5	1	5	0.06	10	34	44	0.44	
AHU-1	1	114	office	126	125	5	1	5	0.06	11	42	55	0.44	
AHU-1	1	115	office	120	125	5	1	5	0.06	10	42	55	0.44	
AHU-1	1	116a	open office	440	150	5	2	5	0.06	37	51	66	0.44	
AHU-1	1	116b	office	152	250	5	1	5	0.06	13	85	110	0.44	
AHU-1	1	118	office	114	100	5	1	5	0.06	10	34	44	0.44	
AHU-1	1	119	office	134	200	5	1	5	0.06	11	68	88	0.44	
AHU-1	1	120	office	128	200	5	1	5	0.06	11	68	88	0.44	
AHU-1	1	121	office	110	100	5	1	5	0.06	9	34	44	0.44	
AHU-1	1	122	staff lounge	620	650	25	16	5	0.06	115	220	287	0.44	200
AHU-1	1	123	office	110	100	5	1	5	0.06	9	34	44	0.44	
AHU-1	1	126	125 office	180	150	5	1	5	0.06	15	51	66	0.44	
AHU-1	1	127	126 office	116	100	5	1	5	0.06	10	34	44	0.44	
AHU-1	1	128	127 office	110	100	5	1	5	0.06	9	34	44	0.44	
AHU-1	1	129	128 office	134	125	5	1	5	0.06	11	42	55	0.44	
AHU-1	1	130	129 office	135	125	5	1	5	0.06	11	42	55	0.44	
RTU-5	1	131	130 conference	475	450	50	24	5	0.06	147	78	101	0.23	
RTU-5	1	132	131 a/v room	470	125	0	0	0	0.12	56			0.00	
AHU-1	1	133	134 storage	150	75	0	0	0	0.06	9	25	33	0.44	
AHU-1	1	134	133 open office	300	275	5	2	5	0.06	26	93	121	0.44	
AHU-1	1	136	office	276	250	5	1	5	0.06	23	85	110	0.44	
split	1	137	lt server	182	300								0.00	
vent	1	138,139	toilet	305	50								0.00	
vent	1	143	elev mach rm	65										
vent	1	144	mech rm	2307										
AHU-1 TOTAL				10,654										
AHU-2	2	200	entry	216	225	0	0	0	0.06	13	74	96	0.43	
AHU-2	2	201	lobby	710	500	10	7	5	0.06	78	164	213	0.43	
AHU-2	2	207a	office	175	300	5	1	5	0.06	15	98	128	0.43	
AHU-2	2	207b	open office	350	300	5	2	0	0.12	42	98	128	0.43	
AHU-2	2	208	file room	175	50	0	0	5	0.06	11	16	21	0.43	
AHU-2	2	209	conference	242	600	50	12	5	0.12	90	196	255	0.43	
AHU-2	2	210	office	241	575	5	1	5	0.06	20	188	245	0.43	
AHU-2	2	211	office	120	225	5	1	5	0.06	10	74	96	0.43	
AHU-2	2	212	office	144	275	5	1	5	0.06	12	90	117	0.43	
AHU-2	2	213a	office	250	450	5	1	5	0.06	21	147	191	0.43	
AHU-2	2	213b	open office	375	325	5	2	5	0.06	32	106	138	0.43	
AHU-2	2	213c	corridor	480	75	0	0	2.5	0.06	29	25	32	0.43	
AHU-2	2	214	office	115	225	5	1	5	0.06	10	74	96	0.43	
AHU-2	2	215	office	122	125	5	1	5	0.06	10	41	53	0.43	
AHU-2	2	216a	office	430	650	5	2	5	0.06	37	213	276	0.43	
AHU-2	2	216b	office	612	1050	5	3	5	0.06	52	343	446	0.43	
AHU-2	2	216c	office	2,041	1700	5	10	5	0.06	173	556	723	0.43	
AHU-2	2	216d	office	250	225	5	1	5	0.06	21	74	96	0.43	
AHU-2	2	216e	office	855	800	5	4	5	0.06	73	262	340	0.43	
AHU-2	2	216f	office	550	700	5	3	5	0.06	47	229	298	0.43	
AHU-2	2	216g	office	511	525	5	3	5	0.06	43	172	223	0.43	
AHU-2	2	218	office	130	150	5	1	5	0.06	11	49	64	0.43	
AHU-2	2	219	office	113	100	5	1	5	0.06	10	33	43	0.43	
AHU-2	2	220	pantry	52	100	25	1	5	0.06	10	33	43	0.43	
AHU-2	2	221	storage	50	50	0	0	0	0.12	6	16	21	0.43	
AHU-2	2	224,225,242	corridor	720	100	0	0	0	0.06	43	33	43	0.43	
AHU-2	2	227	IT stack	85	50	0	0	0	0	0	16	21	0.43	
vent	2	228,229	TOILET	315	50	0	0	0	0	0	16	21	0.43	
AHU-2	2	231	office	1285	1250	5	6	5	0.06	109	409	532	0.43	
AHU-2	2	232	office	130	125	5	1	5	0.06	11	41	53	0.43	
AHU-2	2	233	office	152	125	5	1	5	0.06	13	41	53	0.43	
AHU-2	2	234	office	120	100	5	1	5	0.06	10	33	43	0.43	
AHU-2	2	235	office	120	150	5	1	5	0.06	10	49	64	0.43	
AHU-2	2	237	office	150	225	5	1	5	0.06	13	74	96	0.43	
AHU-2	2	238	office	380	350	5	2	5	0.06	32	114	149	0.43	
AHU-2	2	239	office	230	400	5	1	5	0.06	20	131	170	0.43	
AHU-2	2	241	office	110	100	5	1	5	0.06	9	33	43	0.43	
AHU-2	2	243	storage	70	50	0	0	0	0.12	8	16	21	0.43	
AHU-2	2	244	storage	70	50	0	0	0	0.12	8	16	21	0.43	
AHU-2	2	246	office	1,195	1150	5	6	5	0.06	102	376	489	0.43	
AHU-2	2	247	office	135	125	5	1	5	0.06	11	41	53	0.43	
AHU-2	2	248	office	135	125	5	1	5	0.06	11	41	53	0.43	
AHU-2	2	249	office	140	275	5	1	5	0.06	12	90	117	0.43	
AHU-2	2	250	office	130	225	5	1	5	0.06	11	74	96	0.43	
AHU-2	2	251	office	152	350	5	1	5	0.06	13	114	149	0.43	
AHU-2	2	252	office	185	400	5	1	5	0.06	16	131	170	0.43	
AHU-2 TOTAL				15,318										

Table A-2 - Outdoor Air Ventilation Rate Calculation Continued

ASHRAE 62.1-2007														
System	Floor	Room	Usage	Floor Area	Load CFM	People / 1000 SqFt	People	CFM / Person	CFM / SqFt	Uncorrected OA Req(CFM)	Calc'd OA	30% more OA	OA % of Load	Minimum Exhaust (CFM)
AHU-3	3	300	Lobby	200	75	0	0	0	0.06	12	23	30	0.41	
AHU-3	3	300a,320,331,339,340	corridor	1380	250	0	0	0	0.12	166	78	102	0.41	
AHU-3	3	301	open office	430	375	5	2	5	0.06	37	117	152	0.41	
AHU-3	3	302	file room	50	50	0	0	0	0.12	6	16	20	0.41	
AHU-3	3	303	conference	370	700	50	19	5	0.06	115	219	285	0.41	
AHU-3	3	304	office	115	175	5	1	5	0.06	10	55	71	0.41	
AHU-3	3	308	file room	120	50	0	0	0	0.12	14	16	20	0.41	
AHU-3	3	309	office	352	700	5	2	5	0.06	30	219	285	0.41	
AHU-3	3	310	bathroom	70	50	0	0	0	0	0	16	20	0.41	
AHU-3	3	311	office	125	225	5	1	5	0.06	11	70	91	0.41	
AHU-3	3	312	office	121	225	5	1	5	0.06	10	70	91	0.41	
AHU-3	3	313a	office	145	225	5	1	5	0.06	12	70	91	0.41	
AHU-3	3	313b	corridor	130	50	0	0	0	0.06	8	16	20	0.41	
AHU-3	3	314	conference	206	400	50	10	5	0.12	76	125	163	0.41	
AHU-3	3	315	office	123	225	5	1	5	0.06	10	70	91	0.41	
AHU-3	3	316	office	250	400	5	1	5	0.06	21	125	163	0.41	
AHU-3	3	317	bathroom	77	50								0.00	
AHU-3	3	318	office	190	175	5	1	5	0.06	16	55	71	0.41	
AHU-3	3	319	pantry	125	100	25	3	5	0.06	23	31	41	0.41	
AHU-3	3	325	office	208	350	5	1	5	0.06	18	109	142	0.41	
AHU-3	3	326	conference	246	300	50	12	5	0.06	76	94	122	0.41	
AHU-3	3	328	office	152	250	5	1	5	0.06	13	78	102	0.41	
AHU-3	3	329	office	470	600	5	2	5	0.06	40	188	244	0.41	
AHU-3	3	331	office	152	350	5	1	5	0.06	13	109	142	0.41	
AHU-3	3	333	office	320	500	5	2	5	0.06	27	156	203	0.41	
AHU-3	3	335	office	115	100	5	1	5	0.06	10	31	41	0.41	
AHU-3	3	336	office	125	225	5	1	5	0.06	11	70	91	0.41	
AHU-3	3	338	office	145	125	5	1	5	0.06	12	39	51	0.41	
AHU-3	3	339	office	125	175	5	1	5	0.06	11	55	71	0.41	
AHU-3	3	342	pantry	278	200	25	7	5	0.06	51	63	81	0.41	200
AHU-3	3	344,345	toilet	430	75	0	0	0	0	0	23	30	0.41	
AHU-3	3	347a	office	185	200	5	1	5	0.06	16	63	81	0.41	
AHU-3	3	347b	open office	340	350	5	2	5	0.06	29	109	142	0.41	
AHU-3	3	347c	corridor	120	50	0	0	0	0.06	7	16	20	0.41	
AHU-3	3	348	conference	242	275	50	12	5	0.06	75	86	112	0.41	
AHU-3	3	349	file room	127	50	0	0	0	0.06	8	16	20	0.41	
AHU-3	3	350	storage	45	50	0	0	0	0.12	5	16	20	0.41	
AHU-3	3	351	office	120	100	5	1	5	0.06	10	31	41	0.41	
AHU-3	3	352	office	130	200	5	1	5	0.06	11	63	81	0.41	
AHU-3	3	353	office	175	250	5	1	5	0.06	15	78	102	0.41	
AHU-3	3	354a	office	167	175	5	1	5	0.06	14	55	71	0.41	
AHU-3	3	354b	corridor	111	50	0	0	0	0.12	13	16	20	0.41	
AHU-3	3	355	office	135	150	5	1	5	0.06	11	47	61	0.41	
AHU-3	3	356	office	155	175	5	1	5	0.06	13	55	71	0.41	
AHU-3	3	357	office	125	150	5	1	5	0.06	11	47	61	0.41	
AHU-3	3	358	office	220	275	5	1	5	0.06	19	86	112	0.41	
AHU-3	3	359	storage	50	50	0	0	0	0.12	6	16	20	0.41	
AHU-3	3	360	pantry	50	100	25	1	5	0.06	9	31	41	0.41	150
AHU-3	3	361	file room	130	125	0	0	0	0.12	16	39	51	0.41	
AHU-3	3	362	pantry	65	100	25	2	5	0.06	12	31	41	0.41	150
AHU-3	3	363a	open office	403	500	5	2	5	0.06	34	156	203	0.41	
AHU-3	3	363b	corridor	190	50	0	0	0	0.06	11	16	20	0.41	
AHU-3	3	365	office	125	200	5	1	5	0.06	11	63	81	0.41	
AHU-3	3	366	office	125	200	5	1	5	0.06	11	63	81	0.41	
AHU-3	3	367	office	125	200	5	1	5	0.06	11	63	81	0.41	
AHU-3	3	368	office	128	200	5	1	5	0.06	11	63	81	0.41	
AHU-3	3	369	office	142	200	5	1	5	0.06	12	63	81	0.41	
AHU-3	3	370	office	142	200	5	1	5	0.06	12	63	81	0.41	
AHU-3	3	371	office	112	100	5	1	5	0.06	10	31	41	0.41	
AHU-3	3	372	office	125	225	5	1	5	0.06	11	70	91	0.41	
AHU-3	3	373	office	185	400	5	1	5	0.06	16	125	163	0.41	
AHU-3	3	374	office	112	225	5	1	5	0.06	10	70	91	0.41	
AHU-3	3	375	office	112	250	5	1	5	0.06	10	78	102	0.41	
AHU-3	3	376	open office	310	250	5	2	5	0.06	26	78	102	0.41	
AHU-3	3	377	open office	167	150	5	1	5	0.06	14	47	61	0.41	
AHU-3	3	379	conference	226	275	50	11	5	0.06	70	86	112	0.41	
AHU-3	3	380	office	110	100	5	1	5	0.06	9	31	41	0.41	
AHU-3	3	381	office	110	100	5	1	5	0.06	9	31	41	0.41	
AHU-3	3	382	office	110	100	5	1	5	0.06	9	31	41	0.41	
AHU-3	3	383	office	110	100	5	1	5	0.06	9	31	41	0.41	
AHU-3	3	385	office	125	125	5	1	5	0.06	11	39	51	0.41	
AHU-3	3	386	office	132	125	5	1	5	0.06	11	39	51	0.41	
AHU-3	3	387	IT stack	85	50	0	0	0	0	0	16	20	0.41	
AHU-3	3	388	storage	175	50	0	0	0	0.12	21	16	20	0.41	
AHU-3 TOTAL				13,723										
AHU-4	2	202	conference	850	975	50	43	5	0.06	264	292	379	0.39	
AHU-4	2	245	av room	240	100	0	0	0	0.12	29	30	39	0.39	
AHU-4	3	334	conference	430	500	50	22	5	0.06	133	150	194	0.39	
AHU-3	3	323	a/v room	180	200	0	0	0	0.12	22	60	78	0.39	
AHU-3	3	324	lounge	290	200	25	7	5	0.12	71	60	78	0.39	
AHU-4	3	322	conference	1515	1850	50	76	5	0.06	470	553	720	0.39	
AHU-4 TOTAL				3,505	3825								0.00	
Tot System					44550		406					16662	0.37	

*Calculation courtesy of Sumer Consultants, Inc.

Appendix B

Figure B-1 - ASHRAE Climate Zone Map




Figure B1-1 U.S. climate zone map (ASHRAE Transactions, Briggs et al., 2003).

Table 5.5-4 Building Envelope Requirements for Climate Zone 4 (A,B,C)*

Opaque Elements	Nonresidential			Residential			Semiheated		
	Assembly Maximum	Insulation Min. R-Value	Insulation Min. R-Value	Assembly Maximum	Insulation Min. R-Value	Insulation Min. R-Value	Assembly Maximum	Insulation Min. R-Value	Insulation Min. R-Value
<i>Roofs</i>									
Insulation Entirely above Deck	U-0.032	R-30 c.i.		U-0.032	R-30 c.i.		U-0.093	R-10 c.i.	
Metal Building ^a	U-0.037	R-19 + R-11 Ls or R-25 + R-8 Ls		U-0.037	R-19 + R-11 Ls or R-25 + R-8 Ls		U-0.082	R-19	
Attic and Other	U-0.021	R-49		U-0.021	R-49		U-0.034	R-30	
<i>Walls, above Grade</i>									
Mass	U-0.104	R-9.5 c.i.		U-0.090	R-11.4 c.i.		U-0.580	NR	
Metal Building	U-0.060	R-0 + R-15.8 c.i.		U-0.050	R-0 + R-19 c.i.		U-0.162	R-13	
Steel Framed	U-0.064	R-13 + R-7.5 c.i.		U-0.064	R-13 + R-7.5 c.i.		U-0.124	R-13	
Wood Framed and Other	U-0.064	R-13 + R-3.8 c.i. or R-20		U-0.064	R-13 + R-3.8 c.i. or R-20		U-0.089	R-13	
<i>Wall, below Grade</i>									
Below Grade Wall	C-0.119	R-7.5 c.i.		C-0.092	R-10 c.i.		C-1.140	NR	
<i>Floors</i>									
Mass	U-0.057	R-14.6 c.i.		U-0.051	R-16.7 c.i.		U-0.107	R-6.3 c.i.	
Steel Joist	U-0.038	R-30		U-0.038	R-30		U-0.052	R-19	
Wood Framed and Other	U-0.033	R-30		U-0.033	R-30		U-0.051	R-19	
<i>Slab-on-Grade Floors</i>									
Unheated	F-0.520	R-15 for 24 in.		F-0.520	R-15 for 24 in.		F-0.730	NR	
Heated	F-0.843	R-20 for 24 in.		F-0.688	R-20 for 48 in.		F-0.900	R-10 for 24 in.	
<i>Opaque Doors</i>									
Swinging	U-0.500			U-0.500			U-0.700		
Nonswinging	U-0.500			U-0.500			U-1.450		
Fenestration									
	Assembly Max. U	Assembly Max. SHGC	Assembly Min. VT/SHGC	Assembly Max. U	Assembly Max. SHGC	Assembly Min. VT/SHGC	Assembly Max. U	Assembly Max. SHGC	Assembly Min. VT/SHGC
<i>Vertical Fenestration, 0%–40% of Wall</i>									
	(for all frame types)			(for all frame types)			(for all frame types)		
Nonmetal framing, all	U-0.35			U-0.35			U-0.51		
Metal framing, fixed	U-0.42			U-0.42			U-0.73		
Metal framing, operable	U-0.50	SHGC-0.40	1.10	U-0.50	SHGC-0.40	1.10	U-0.81	NR	NR
Metal framing, entrance door	U-0.77			U-0.68			U-0.77		
<i>Skylight, 0%–3% of Roof</i>									
All types	U-0.50	SHGC-0.40	NR	U-0.50	SHGC-0.40	NR	U-1.15	NR	NR

* The following definitions apply: c.i. = continuous insulation (see Section 3.2), FC = filled cavity (see Section A2.3.2.5), Ls = liner system (see Section A2.3.2.4), NR = no (insulation) requirement.

a. When using the R-value compliance method for metal building roofs, a thermal spacer block is required (see Section A2.3.2).

Figure B-2 – Existing Wall Section




Figure B-3 – New Curtain Wall Section




Figure B-4 – Wall Section through Exterior Door




Table B-1 – Equipment Voltage Drop

Branch Circuit Voltage Drop (NEC Table 9)									
Circuit	Conductor Size	Resistance	Reactance	Power Factor	Effective Impedance	Cable Length (Ft)	Number of Sets	Voltage Drop (V)	Voltage Drop %
AHU-1	#10 THHN	1.2	0.063	90%	1.11	250	1	6.71	1.46%
AHU-2	#8 THHN	0.8	0.065	90%	0.73	500	1	5.31	1.15%
AHU-3	#8 THHN	0.8	0.065	90	0.73	200	1	6.82	1.48
AHU-4	#8 THHN	0.8	0.065	90%	0.73	200	1	5.31	1.15%
RF-1	#12 THHN	2.0	0.068	90%	1.83	200	1	2.15	0.47%
RF-2	#12 THHN	2.0	0.068	90%	1.83	250	1	8.70	1.89%
RF-3	#10 THHN	1.2	0.063	90%	1.11	200	1	5.36	1.17%
RF-4	#12 THHN	2	0.068	90%	1.83	200	1	4.81	1.05%
Pump 7.5 HP and Less	#12 THHN	2	0.068	90%	1.83	200	1	6.96	1.51%

*Calculation courtesy of Sumer Consultants, Inc.