


Northeastern Illinois University's El Centro Building

Chicago, Illinois

Michael Gramarossa, BAE/MAE
Mechanical Option


Advisor: Dr. James Freihaut





- Building Summary
- Thesis Objective
- Mechanical Depth
- Structural Breadth
- Electrical Breadth
- Evaluation and Conclusion





➤ Building Summary

➤ Overview

➤ Existing Mechanical System

- Cooling and Ventilation
- Heating

➤ Thesis Objective

➤ Mechanical Depth

➤ Structural Breadth

➤ Electrical Breadth


➤ Evaluation & Conclusion

Site and Location

- Chicago Illinois

- Summer: **91.9°F** (0.4%)
- Winter: **-4.0°F** (99.6%)





➤ Building Summary

➤ Overview

➤ Existing Mechanical System

- Cooling and Ventilation
- Heating

➤ Thesis Objective

➤ Mechanical Depth



➤ Structural Breadth


➤ Electrical Breadth

➤ Evaluation & Conclusion

Site and Location

- Chicago Illinois
 - Summer: **91.9°F** (0.4%)
 - Winter: **-4.0°F** (99.6%)
- Located along Kennedy Expressway







➤ Building Summary

- Overview
 - Existing Mechanical System
 - Cooling and Ventilation
 - Heating
- Thesis Objective
- Mechanical Depth
- Structural Breadth
- Electrical Breadth
- Evaluation & Conclusion

Site and Location

- Chicago Illinois
 - Summer: **91.9°F** (0.4%)
 - Winter: **-4.0°F** (99.6%)
- Located along Kennedy Expressway
- Passed by 400,000 vehicles each day






➤ Building Summary

- Overview
 - Existing Mechanical System
 - Cooling and Ventilation
 - Heating
- Thesis Objective
- Mechanical Depth
- Structural Breadth
- Electrical Breadth
- Evaluation & Conclusion

Architecture and Façade

- Recently completed in September 2014
- 3 stories (no basement)
- 55,000 ft²
- Classrooms, offices, labs, lounges, etc.





➤ Building Summary

➤ Overview

➤ Existing Mechanical System

- Cooling and Ventilation
- Heating

➤ Thesis Objective

➤ Mechanical Depth



➤ Structural Breadth


➤ Electrical Breadth

➤ Evaluation & Conclusion

Architecture and Façade

- Recently completed in September 2014
- 3 stories (no basement)
- 55,000 ft²
- Classrooms, offices, labs, lounges, etc.
- Curtain Wall Façade with solar fins
- Blue and Gold Fins






➤ Building Summary

- Overview
- **Existing Mechanical System**
 - **Cooling and Ventilation**
 - Heating
- Thesis Objective
- Mechanical Depth
- Structural Breadth
- Electrical Breadth
- Evaluation & Conclusion

Existing Mechanical System Cooling and Ventilation

- [2] 100 ton air handling roof top units (RTUs)
- The RTUs supply 55°F air year round






➤ Building Summary


- Overview
- **Existing Mechanical System**
 - **Cooling and Ventilation**
 - Heating
- Thesis Objective
- Mechanical Depth
- Structural Breadth
- Electrical Breadth
- Evaluation & Conclusion

Existing Mechanical System Cooling and Ventilation

- [2] 100 ton air handling roof top units (RTUs)
- The RTUs supply 55°F air year round
- RTU-1 & RTU-2
- Separate Air Cooled Condensing Units (CU-1 & CU-2)



Unit	Area Served (ft ²)	Supply Capacity (CFM)	Ventilation (CFM)	Cooling (Ton)	Heating (MBh)
RTU-1	24,000	38,000	12,000	100	1250
RTU-2	27,800	38,000	12,000	100	1250





- **Building Summary**
 - Overview
 - **Existing Mechanical System**
 - Cooling and Ventilation
 - **Heating**
- Thesis Objective
- Mechanical Depth
- Structural Breadth
- Electrical Breadth
- Evaluation & Conclusion

Existing Mechanical System Heating

- [2] 750 MBh Boilers
- Boilers serve 71 VAV reheat coils and hot water radiant finned tubes

Tag	Fuel Type	Rating (MBH)		Water Temperature (°F)		Flow Rate (GPM)	Min. Thermal Efficiency (%)
		Input	Output	Entering	Leaving		
B-1	NG	750	657	130	150	66	90
B-2	NG	750	657	130	150	66	90






- **Building Summary**
 - Overview
 - **Existing Mechanical System**
 - Cooling and Ventilation
 - Heating
- Thesis Objective
- Mechanical Depth
- Structural Breadth
- Electrical Breadth
- Evaluation & Conclusion


Existing Mechanical System Heating

- [2] 750 MBh Boilers
- Boilers serve 71 VAV reheat coils and hot water radiant finned tubes

Tag	Fuel Type	Rating (MBH)		Water Temperature (°F)		Flow Rate (GPM)	Min. Thermal Efficiency (%)
		Input	Output	Entering	Leaving		
B-1	NG	750	657	130	150	66	90
B-2	NG	750	657	130	150	66	90




Second Floor Plan Hot Water Schematic




- Building Summary
- **Thesis Objective**
- Mechanical Depth
- Structural Breadth
- Electrical Breadth
- Evaluation and Conclusion

Thesis Objective

- The Chicago Building Code (CBC) requires a certain amount of airflow be supplied to a space regardless of the load








- Building Summary
- **Thesis Objective**
- Mechanical Depth
- Structural Breadth
- Electrical Breadth
- Evaluation and Conclusion

Thesis Objective

- The Chicago Building Code (CBC) requires a certain amount of airflow be supplied to a space regardless of the load
- Redesign the current mechanical system according to the International Building Code (IBC)






- Building Summary
- **Thesis Objective**
- Mechanical Depth
- Structural Breadth
- Electrical Breadth
- Evaluation and Conclusion

Thesis Objective

- The Chicago Building Code (CBC) requires a certain amount of airflow be supplied to a space regardless of the load
- Redesign the current mechanical system according to the International Building Code (IBC)
- What are the greater implications if all mechanical systems for commercial buildings in Chicago were designed to the IBC rather than CBC.





- Building Summary
- Thesis Objective
- **Mechanical Depth**
 - **RTU Resize**
 - Energy Savings
 - Emission Savings
- Structural Breadth
- Electrical Breadth
- Evaluation and Conclusion


RTU Resize

Ventilation Requirements

System	CBC	IBC/IMC	% Saved
	Req'd OA (CFM)	Req'd OA (CFM)	
RTU-1 Total	9260	5761	37.79%
RTU-2 Total	10890	8292	23.86%
System Total	20150	14053	30.26%

Load Requirements

System	CBC		IBC/IMC	
	Cooling (Tons)	Supply Air (CFM)	Cooling (Tons)	Supply Air (CFM)
RTU-1	93	20,700	84	20,700
RTU-2	97	22,100	89	22,100
Total	190	42,800	173	42,800
		<i>% Saved</i>	-9.10%	0%



- Building Summary
- Thesis Objective
- **Mechanical Depth**
 - **RTU Resize**
 - Energy Savings
 - Emission Savings
- Structural Breadth
- Electrical Breadth
- Evaluation and Conclusion

RTU Resize


Ventilation Requirements


System	CBC	IBC/IMC	% Saved
	Req'd OA (CFM)	Req'd OA (CFM)	
RTU-1 Total	9260	5761	37.79%
RTU-2 Total	10890	8292	23.86%
System Total	20150	14053	30.26%

Load Requirements

System	CBC		IBC/IMC	
	Cooling (Tons)	Supply Air (CFM)	Cooling (Tons)	Supply Air (CFM)
RTU-1	93	20,700	84	20,700
RTU-2	97	22,100	89	22,100
Total	190	42,800	173	42,800
	% Saved		-9.10%	0%

Carrier model number chosen





- Building Summary
- Thesis Objective
- **Mechanical Depth**
 - **RTU Resize**
 - Energy Savings
 - Emission Savings
- Structural Breadth
- Electrical Breadth
- Evaluation and Conclusion

RTU Resize


Ventilation Requirements

System	IBC/IMC		% Saved
	CBC	Req'd OA (CFM)	
RTU-1 Total	9260	5761	37.79%
RTU-2 Total	10890	8292	23.86%
System Total	20150	14053	30.26%

Load Requirements

System	CBC		IBC/IMC	
	Cooling (Tons)	Supply Air (CFM)	Cooling (Tons)	Supply Air (CFM)
RTU-1	93	20,700	84	20,700
RTU-2	97	22,100	89	22,100
Total	190	42,800	173	42,800
		% Saved	-9.10%	0%

Carrier model number chosen




$$q \left(\frac{BTU}{hr} \right) = 1.10 * Q(CFM) * \Delta T(^{\circ}F)$$

where $\Delta T = T_s - T_{ma} = 0.3(-10^{\circ}F) + 0.7(70^{\circ}F) = 9^{\circ}F$

$$q = 1.10 * (34,000 CFM) * (9^{\circ}F) = 336,600 \frac{BTU}{hr}$$


$$q = 337 MBH \leq 527 MBH \checkmark$$




- Building Summary
- Thesis Objective
- **Mechanical Depth**
 - **RTU Resize**
 - Energy Savings
 - Emission Savings
- Structural Breadth
- Electrical Breadth
- Evaluation and Conclusion

RTU Resize

Fan Selection



or...







- Building Summary
- Thesis Objective
- **Mechanical Depth**
 - **RTU Resize**
 - Energy Savings
 - Emission Savings
- Structural Breadth
- Electrical Breadth
- Evaluation and Conclusion

RTU Resize


Fan Selection



or...




Fan Type	Total Supply (CFM)	Input Power (BHP)	Speed (rpm)
Housed FC	34,000	42.9	592
Housed AF	34,000	36.7	1432




- Building Summary
- Thesis Objective
- **Mechanical Depth**
 - **RTU Resize**
 - Energy Savings
 - Emission Savings
- Structural Breadth
- Electrical Breadth
- Evaluation and Conclusion

RTU Resize


RTU Schematic






- Building Summary
- Thesis Objective
- **Mechanical Depth**
 - **RTU Resize**
 - Energy Savings
 - Emission Savings
- Structural Breadth
- Electrical Breadth
- Evaluation and Conclusion

RTU Resize



Code	RTU Size	Cost (incl. O&P)	Location Factor	Adjusted Cost	Qty. of RTUs	Total Cost
CBC	105 tons	\$252,000	113.6%	\$286,272	2	\$572,544
IBC/IMC	90 tons	\$225,500	113.6%	\$256,168	2	\$512,336

Potential Savings
10.5%
\$60,000




- Building Summary
- Thesis Objective
- **Mechanical Depth**
 - RTU Resize
 - **Energy Savings**
 - Emission Savings
- Structural Breadth
- Electrical Breadth
- Evaluation and Conclusion

Annual Utility Usage

CBC			IBC/IMC		
Elec Used (kWh)	NG Used (therms)	Total Utility Cost	Elec Used (kWh)	NG Used (therms)	Total Utility Cost
727,000	9,600	\$65,500	723,000	7,400	\$63,700
<i>Savings</i>			<i>0.5%</i>	<i>29.5%</i>	<i>2.9%</i>

- Electricity Cost Savings: **0.5%**
- Natural Gas Cost Savings: **29.5%**
- Total Utility Cost Savings: **2.9%**
- Electric & NG Cost Savings: **\$1800**





- Building Summary
- Thesis Objective
- **Mechanical Depth**
 - RTU Resize
 - **Energy Savings**
 - Emission Savings
- Structural Breadth
- Electrical Breadth
- Evaluation and Conclusion

Annual Utility Usage

CBC			IBC/IMC		
Elec Used (kWh)	NG Used (therms)	Total Utility Cost	Elec Used (kWh)	NG Used (therms)	Total Utility Cost
727,000	9,600	\$65,500	723,000	7,400	\$63,700
<i>Savings</i>			<i>0.5%</i>	<i>29.5%</i>	<i>2.9%</i>

Why are there more energy savings in the heating system than the cooling system?






- Building Summary
- Thesis Objective
- **Mechanical Depth**
 - RTU Resize
 - **Energy Savings**
 - Emission Savings
- Structural Breadth
- Electrical Breadth
- Evaluation and Conclusion

Annual Utility Usage

CBC			IBC/IMC		
Elec Used (kWh)	NG Used (therms)	Total Utility Cost	Elec Used (kWh)	NG Used (therms)	Total Utility Cost
727,000	9,600	\$65,500	723,000	7,400	\$63,700
<i>Savings</i>			<i>0.5%</i>	<i>29.5%</i>	<i>2.9%</i>

Why are there more energy savings in the heating system than the cooling system?


Cooling Degree Days	842
Heating Degree Days	6311



$$\Delta T = |T_{RA} - T_{OA}|$$

$$\Delta T_{cooling} = |75^{\circ}\text{F} - 85^{\circ}\text{F}| = 10^{\circ}\text{F}$$




$$\Delta T_{heating} = |70^{\circ}\text{F} - 25^{\circ}\text{F}| = 45^{\circ}\text{F}$$




- Building Summary
- Thesis Objective
- **Mechanical Depth**
 - RTU Resize
 - **Energy Savings**
 - Emission Savings
- Structural Breadth
- Electrical Breadth
- Evaluation and Conclusion

Annual Utility Usage

CBC			IBC/IMC		
Elec Used (kWh)	NG Used (therms)	Total Utility Cost	Elec Used (kWh)	NG Used (therms)	Total Utility Cost
727,000	9,600	\$65,500	723,000	7,400	\$63,700
<i>Savings</i>			<i>0.5%</i>	<i>29.5%</i>	<i>2.9%</i>








- Building Summary
- Thesis Objective
- **Mechanical Depth**
 - RTU Resize
 - **Energy Savings**
 - Emission Savings
- Structural Breadth
- Electrical Breadth
- Evaluation and Conclusion

Annual Utility Usage

CBC			IBC/IMC		
Elec Used (kWh)	NG Used (therms)	Total Utility Cost	Elec Used (kWh)	NG Used (therms)	Total Utility Cost
727,000	9,600	\$65,500	723,000	7,400	\$63,700
<i>Savings</i>			<i>0.5%</i>	<i>29.5%</i>	<i>2.9%</i>






- Building Summary
- Thesis Objective
- **Mechanical Depth**
 - RTU Resize
 - Energy Savings
 - **Emission Savings**
- Structural Breadth
- Electrical Breadth
- Evaluation and Conclusion

Emission Savings

Code	Pollutant	Electricity		Natural Gas		Total (lbs pollutant/year)
		lb/kWh	lbs.	lb/MCF	lbs.	
CBC	CO _{2e}	1.74	1,273,668	123	118,080	1,391,748
	CO ₂	1.64	1,200,469	122	117,120	1,317,589
	NO _x	0.003	2,196	0.111	107	2,303
IBC	CO _{2e}	1.74	1,266,904	123	91,229	1,358,134
	CO ₂	1.64	1,194,094	122	90,487	1,284,581
	NO _x	0.003	2,184	0.111	82	2,267
		% Saved (CO _{2e})	0.53%		22.74%	2.42%


Emission Savings ~37,000 lbs. CO_{2e} per year



- Building Summary
- Thesis Objective
- Mechanical Depth
- **Structural Breadth**
 - RTU-2
 - RTU-1
 - Conclusion
- Electrical Breadth
- Evaluation & Conclusion


Structural Breadth

Will smaller RTU's designed according to the IBC lead to a reduction in structural steel?




- Building Summary
- Thesis Objective
- Mechanical Depth
- **Structural Breadth**
 - RTU-2
 - RTU-1
 - Conclusion
- Electrical Breadth
- Evaluation & Conclusion

Structural Breadth



Load Type	Material	Weight (psf)
Dead Load	PVC Roof	10
	1/2" Cover Board	2
	R-30 Insulation Board	2
	Galvanized Metal Deck	2
	Misc. (lights, duct, PV array, etc.)	10
Live Load or Snow Load	Live Load	20
	Snow Load	25
Total	Dead Load	26
	Snow Load	25


$$1.2(26 \text{ psf}) + 1.6(25 \text{ psf}) = 71 \text{ psf factored load}$$



- Building Summary
- Thesis Objective
- Mechanical Depth
- **Structural Breadth**
 - **RTU-2**
 - RTU-1
 - Conclusion
- Electrical Breadth
- Evaluation & Conclusion



RTU-2 Analysis






- Building Summary
- Thesis Objective
- Mechanical Depth
- **Structural Breadth**
 - **RTU-2**
 - RTU-1
 - Conclusion
- Electrical Breadth
- Evaluation & Conclusion



RTU-2 Analysis





- Building Summary
- Thesis Objective
- Mechanical Depth
- **Structural Breadth**
 - **RTU-2**
 - RTU-1
 - Conclusion
- Electrical Breadth
- Evaluation & Conclusion

RTU-2 Analysis




Mid Span Moment

$$M = \frac{wl^2}{8} = \frac{(2.8 \text{ klf})(25.5 \text{ ft})^2}{8} = 228 \text{ kip-ft}$$



Max Deflection

$$\Delta \leq \frac{L}{240} = \frac{25.5 \text{ ft} * 12 \frac{\text{in}}{\text{ft}}}{240} = 1.275 \text{ in.}$$



- Building Summary
- Thesis Objective
- Mechanical Depth
- **Structural Breadth**
 - **RTU-2**
 - RTU-1
 - Conclusion
- Electrical Breadth
- Evaluation & Conclusion

RTU-2 Analysis



Mid Span Moment


$$M = \frac{wl^2}{8} = \frac{(2.8 \text{ klf})(25.5 \text{ ft})^2}{8} = 228 \text{ kip-ft}$$

Max Deflection

$$\Delta \leq \frac{L}{240} = \frac{25.5 \text{ ft} * 12 \frac{\text{in}}{\text{ft}}}{240} = 1.275 \text{ in.}$$


W21x44 ($I_x = 843$)
 (Max M = 358 kip-ft) ✓

$$\Delta = \frac{5wl^4}{EI} = \frac{5 \left(233.3 \frac{\text{lb}}{\text{in}} \right) (306 \text{ in})^4}{384(30 * 10^6 \frac{\text{lb}}{\text{in}^2})(843 \text{ in}^4)} = 1.053 \text{ in.} \checkmark$$



- Building Summary
- Thesis Objective
- Mechanical Depth
- **Structural Breadth**
 - RTU-2
 - **RTU-1**
 - Conclusion
- Electrical Breadth
- Evaluation & Conclusion

RTU-1 Analysis



These beams are not reduced in size because the structural engineer did not use a smaller beam than W12x26.



- Building Summary
- Thesis Objective
- Mechanical Depth
- **Structural Breadth**
 - RTU-2
 - RTU-1
 - **Conclusion**
- Electrical Breadth
- Evaluation & Conclusion

Structural Breadth Conclusion

Beam Size	Existing Design	New Design	Cost (\$/LF)
	Length (ft)	Length (ft)	
C8x11.5	151	124	\$83.68
W21x44	0	51	\$84.21
W21x48	51	0	\$94.34
<i>Total Cost</i>	<i>\$17,447</i>	<i>\$14,671</i>	

New design leads to \$2,800 in savings




- Building Summary
- Thesis Objective
- Mechanical Depth
- **Structural Breadth**
 - RTU-2
 - RTU-1
 - **Conclusion**
- Electrical Breadth
- Evaluation & Conclusion

Structural Breadth Conclusion

Beam Size	Existing Design	New Design	Cost (\$/LF)
	Length (ft)	Length (ft)	
C8x11.5	151	124	\$83.68
W21x44	0	51	\$84.21
W21x48	51	0	\$94.34
<i>Total Cost</i>	<i>\$17,447</i>	<i>\$14,671</i>	

New design leads to \$2,800 in savings


- Structural steel savings are a result of a different design approach.
- There would be negligible structural steel savings associated with designing to the IBC rather than the CBC with regards to the mechanical system.



- Building Summary
- Thesis Objective
- Mechanical Depth
- Structural Breadth
- **Electrical Breadth**
- Evaluation & Conclusion



Electrical Breadth


Will smaller RTU's designed according to the IBC lead to a reduction in electrical wiring?



- Building Summary
- Thesis Objective
- Mechanical Depth
- Structural Breadth
- **Electrical Breadth**
- Evaluation & Conclusion

Electrical Breadth






- Building Summary
- Thesis Objective
- Mechanical Depth
- Structural Breadth
- **Electrical Breadth**
- Evaluation & Conclusion


Electrical Breadth

- The same as structural, using the IBC in lieu of the CBC will lead to minimal to no electrical cost savings
- The savings associated were a result of a different design strategy



New Design


Mechanical Option



- Building Summary
- Thesis Objective
- Mechanical Depth
- Structural Breadth
- Electrical Breadth
- **Evaluation & Conclusion**
 - **City of Chicago Study**
 - Overall Evaluation
 - Acknowledgements

City of Chicago Study





- Building Summary
- Thesis Objective
- Mechanical Depth
- Structural Breadth
- Electrical Breadth
- **Evaluation & Conclusion**
 - **City of Chicago Study**
 - Overall Evaluation
 - Acknowledgements


City of Chicago Study

CHICAGO CLIMATE ACTION PLAN

Reduce Chicago's greenhouse gas emissions by 80% below 1990 levels by 2050

- **Energy Efficient Buildings (30%)**
- Clean & Renewable Energy Sources (34%)
- Improved Transportation Options (23%)
- Reduction Waste & Industrial Pollution (13%)
- Adaptation






- Building Summary
- Thesis Objective
- Mechanical Depth
- Structural Breadth
- Electrical Breadth
- **Evaluation & Conclusion**
 - **City of Chicago Study**
 - Overall Evaluation
 - Acknowledgements

City of Chicago Study

**Chicago Building Energy
\$3 billion per year**

**Potential Savings 2.9%
\$87 million per year**





- Building Summary
- Thesis Objective
- Mechanical Depth
- Structural Breadth
- Electrical Breadth
- **Evaluation & Conclusion**
 - **City of Chicago Study**
 - Overall Evaluation
 - Acknowledgements

City of Chicago Study

**Chicago Building Energy
\$3 billion per year**

**Potential Savings 2.9%
\$87 million per year**

**Chicago Building Emissions
63 billion lbs. CO_{2e} per year**



**Potential Savings 2.42%
1.5 billion lbs. CO_{2e} per year**

**Equivalent to taking 184,000
cars off of the road**




- Building Summary
- Thesis Objective
- Mechanical Depth
- Structural Breadth
- Electrical Breadth
- **Evaluation & Conclusion**
 - City of Chicago Study
 - **Overall Evaluation**
 - Acknowledgements

Overall Evaluation





- Possible Mechanical First Cost Savings
- No Structural or Electrical Cost Savings
- Energy Cost Savings 2.9%
- Emission Savings 2.42%




- Building Summary
- Thesis Objective
- Mechanical Depth
- Structural Breadth
- Electrical Breadth
- **Evaluation & Conclusion**
 - City of Chicago Study
 - **Overall Evaluation**
 - Acknowledgements

Overall Evaluation




- Possible Mechanical First Cost Savings
- No Structural or Electrical Cost Savings
- Energy Cost Savings 2.9%
- Emission Savings 2.42%
- Minimal Impact on a small scale
- Big impact on a large scale




- Building Summary
- Thesis Objective
- Mechanical Depth
- Structural Breadth
- Electrical Breadth
- **Evaluation & Conclusion**
 - City of Chicago Study
 - Overall Evaluation
 - **Acknowledgements**

Acknowledgements

- Primera Engineers
- Professor Freihaut
- Penn State AE Faculty and Staff
- Friends and Family
- And of course,










- Building Summary
- Thesis Objective
- Mechanical Depth
- Structural Breadth
- Electrical Breadth
- **Evaluation & Conclusion**
 - City of Chicago Study
 - Overall Evaluation
 - **Acknowledgements**

Acknowledgements

- Primera Engineers
- Professor Freihaut
- Penn State AE Faculty and Staff
- Friends and Family
- And of course, President Obama



Questions?



Summary of Savings	Energy Savings		Annual Cost Savings		Emission Savings	
	%	kBtu/year	%	\$/year	%	lbs. CO _{2e} /yr
NEIU El Centro	6.70%	232,000	2.90%	\$1,850	2.42%	33,600
City of Chicago	6.70%	10.4 billion	2.90%	\$87 million	2.42%	1.5 billion

Electrical Appendix

System	Equipment	V/PH/Hz	FLA	MOCP	kVA	Wire (Copper) (THWN)	Ground (Copper)	Conduit (EMT)
Existing	RTU-1	460/3/60	149	150 A	124	(4) #2/0	#6	2"
	RTU-2	460/3/60	149	150 A	124	(4) #2/0	#6	2"
	CU-1	460/3/60	227	250 A	189	(4) 350 kcmil	#4	3 1/2"
	CU-2	460/3/60	227	250 A	189	(4) 350 kcmil	#4	3 1/2"
New	RTU-1	460/3/60	257	300 A	214	(4) 300 kcmil	#4	2 1/2"
	RTU-2	460/3/60	257	300 A	214	(4) 300 kcmil	#4	2 1/2"

Table 26 - Existing and New Branch Wire Sizing for RTUs

$$\begin{aligned}
 [300 \text{ kcmil}] & 0.4608 \text{ in}^2 * 4 = 1.8432 \text{ in}^2 \\
 [\#4] & 0.0824 \text{ in}^2 * 1 = 0.0824 \text{ in}^2 \\
 & 1.9256 \text{ in}^2 \therefore \text{use } \mathbf{2 \frac{1}{2}'' \text{ Conduit}}
 \end{aligned}$$

System	Panel Label	Equipment Served	Voltage	FLA	kVA	MOCP	Feeder Size (Copper, THWN, EMT)
Existing	DPM3-1	RTU-1 & RTU-2	480/277	298	248	600 A	(2) sets: 4-350 kcmil, #1/0 Grd, 3 1/2" C
New	DPM3-1	RTU-1 & RTU-2	480/277	514	428	800 A	(3) sets: 4-300 kcmil, #2 Grd, 2 1/2" C

Table 27 - Existing and New Feeder Sizing for RTUs

$$\begin{aligned}
 [300 \text{ kcmil}] & 0.4608 \text{ in}^2 * 4 = 1.8432 \text{ in}^2 \\
 [\#2] & 0.1158 \text{ in}^2 * 1 = 0.1158 \text{ in}^2 \\
 & 1.959 \text{ in}^2 \therefore \text{use } \mathbf{2 \frac{1}{2}'' \text{ Conduit}}
 \end{aligned}$$

City of Chicago Appendix

Total Amount Chicago Spends on Building Energy (\$)	Potential Savings (%)	Potential Savings (\$)
\$3 billion	2.90%	\$87 million

Total Amount of Energy Used by Chicago Buildings (kBtu/year)	Potential Savings (%)	Potential Savings (\$/year)
155 billion kBtu	6.70%	10.4 billion kBtu

Unit	Total Pollutants Produced by Chicago Buildings (CO _{2e} /year)	Potential Savings (%)	Potential Savings (CO _{2e} /year)
lbs. CO_{2e}/year	63 billion lbs.	2.42%	1.5 billion lbs.
tons CO_{2e}/year	31.6 million tons	2.42%	765,000 tons
Equivalent of Cars on the Road per year	7.6 million cars	2.42%	184,000 cars

Rank	City	Country	No. of Skyscrapers
1	Hong Kong	China	302
2	New York City	United States	235
3	Dubai	United Arab Emirates	148
4	Shanghai	China	126
5	Chicago	United States	115
6	Tokyo	Japan	112
7	Chongqing	China	94
8	Guangzhou	China	93
9	Shenzhen	China	83
10	Singapore	Singapore	79

Building Type	kBTU/ft ² /yr
Large Office	43
Medium Office	48
Small Office	51
Warehouse	24
Stand-alone Retail	81
Strip Mall	85
Primary School	65
Secondary School	76
Supermarket	195
Quick Service Restaurant	657
Hospital	148
Outpatient Facility	271
Small Hotel	80
Large Hotel	138
Mid-Rise Apartment	47
NEIU El Centro*	62