

April 8, 2015

# NEOMED RESEARCH AND GRADUATE EDUCATION + COMPARATIVE MEDICAL UNIT APPENDICES

PSUAE

MECHANICAL OPTION Advisor: Dr. James D. Freihaut

Appendices..... 2

Appendix A: Trane TRACE 700 Reports..... 2

Appendix B: Designer Elite CHVAC 7 Reports ..... 9

Appendix C: Utility Data and Trends ..... 12

Appendix D: Initial DOE CHP Screening ..... 20

Appendix E: CHP Configurations Screening ..... 22

Appendix F: Sensitivity Study ..... 47

Appendix G: Emissions Calculations ..... 49

Appendix H: Project Schedules ..... 59

## Appendices

### Appendix A: Trane TRACE 700 Reports

		<div style="border: 1px solid black; padding: 5px; text-align: center;"> <b>SYSTEM SUMMARY</b>  <b>DESIGN AIRFLOW QUANTITIES</b>                      By ACADEMIC                 </div>						
System Description	System Type	MAIN SYSTEM					Auxiliary System	Room
		Outside Airflow cfm	Cooling Airflow cfm	Heating Airflow cfm	Return Airflow cfm	Exhaust Airflow cfm	Supply Airflow cfm	Exhaust Airflow cfm
<b>Alternative 1</b>								
RGE AHU-1	Variable Volume Reheat (30% Min Flow Default)	68,749	98,914	29,914	98,914	68,749	0	96,704
RGE AHU-2	Variable Volume Reheat (30% Min Flow Default)	297,689	299,521	91,650	299,521	297,689	0	311,391
RGE AHU-3	Variable Volume Reheat (30% Min Flow Default)	3,245	26,354	8,001	26,354	3,245	0	10,572
RGE AHU-4	Bypass Multizone	450	18,956	18,956	18,956	450	0	18,753
<b>Totals</b>		<b>370,133</b>	<b>444,145</b>	<b>148,521</b>	<b>444,145</b>	<b>370,133</b>	<b>0</b>	<b>437,420</b>

**Note:** Airflows on this report are not additive because they are each taken at the time of their respective peaks. To view the balanced system design airflows, see the appropriate Checksums report (Airflows section).

*USE ONLY*

Project Name: Neomed Research and Graduate Education  
 Dataset Name: TECH 2.trc

TRACE® 700 v6.3 calculated at 03:46 AM on 10/06/2014  
 Design Airflow Quantities Report Page 1 of 1

**SYSTEM SUMMARY**  
**DESIGN COOLING CAPACITIES**  
 By ACADEMIC

**Alternative 1**

**Building Airside Systems and Plant Capacities**

Plant	System	Peak Plant Loads							Block Plant Loads									
		Main Coil	Aux Coil	Opt Vent	Misc Load	Stg 1 Desic Cond	Stg 2 Desic Cond	Base Utility	Peak Total	Time Of	Main Coil	Aux Coil	Opt Vent	Misc Load	Stg 1 Desic Cond	Stg 2 Desic Cond	Base Utility	Block Total
Cooling plant - 001		1,958.9	0.0	0.0	0.0	0.0	0.0	0.0	1,958.9	7/16	1,749.0	0.0	0.0	0.0	0.0	0.0	0.0	1,749.0
RGE AHU-1		386.6	0.0	0.0	0.0	0.0	0.0	0.0	386.6	7/16	353.8	0.0	0.0	0.0	0.0	0.0	0.0	353.8
RGE AHU-2		1,486.9	0.0	0.0	0.0	0.0	0.0	0.0	1,486.9	7/16	1,312.4	0.0	0.0	0.0	0.0	0.0	0.0	1,312.4
RGE AHU-3		54.5	0.0	0.0	0.0	0.0	0.0	0.0	54.5	7/16	53.1	0.0	0.0	0.0	0.0	0.0	0.0	53.1
RGE AHU-4		30.9	0.0	0.0	0.0	0.0	0.0	0.0	30.9	7/16	29.7	0.0	0.0	0.0	0.0	0.0	0.0	29.7
<b>Building totals</b>		<b>1,958.9</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>1,958.9</b>		<b>1,749.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>1,749.0</b>

Building peak load is 1,958.9 tons.

Building maximum block load of 1,749.0 tons occurs in July at hour 16 based on system simulation.

Project Name: Neomed Research and Graduate Education  
 Dataset Name: TECH 2.trc

TRACE® 700 v6.3 calculated at 03:46 AM on 10/06/2014  
 Design Capacity Quantities report Page 1 of 1

**SYSTEM SUMMARY**  
**DESIGN HEATING CAPACITIES**  
 By ACADEMIC

**Alternative 1**

**System Coil Capacities**

System Description	System Type	Main System Btu/h	Aux System Btu/h	Preheat Btu/h	Reheat Btu/h	Humid. Btu/h	Optional Vent Btu/h	Stg 1 Desic Regen Btu/h	Stg 2 Desic Regen Btu/h	Stg 1 Frost Prevention Btu/h	Stg 2 Frost Prevention Btu/h	Heating Totals Btu/h
RGE AHU-1	Variable Volume Reheat (30% Min Flow Default)	-3,279,402	0	-3,504,387	-576,530	0	0	0	0	0	0	-6,783,789
RGE AHU-2	Variable Volume Reheat (30% Min Flow Default)	-4,792,309	0	-14,572,320	-1,951,715	0	0	0	0	0	0	-19,364,628
RGE AHU-3	Variable Volume Reheat (30% Min Flow Default)	-1,271,535	0	-170,008	-141,833	0	0	0	0	0	0	-1,441,542
RGE AHU-4	Bypass Multizone	-66,281	0	0	0	0	0	0	0	0	0	-66,281
<b>Totals</b>		<b>-9,409,526</b>	<b>0</b>	<b>-18,246,715</b>	<b>-2,670,078</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>-27,656,240</b>

**Building Plant Capacities**

Plant	System	Peak Loads												
		Main Coil MBh	Preheat Coil MBh	Reheat Coil MBh	Humid. Coil MBh	Aux Coil MBh	Opt Vent Coil MBh	Misc Load MBh	Stg 1 Desic Regen MBh	Stg 2 Desic Regen MBh	Stg 1 Frost Prev. MBh	Stg 2 Frost Prev. MBh	Base Utility MBh	Absorption Load MBh
Heating plant - 002		9,410	18,247	0	0	0	0	0	0	0	0	0	0	0
	RGE AHU-1	3,279	3,504	0	0	0	0	0	0	0	0	0	0	0
	RGE AHU-2	4,792	14,572	0	0	0	0	0	0	0	0	0	0	0
	RGE AHU-3	1,272	170	0	0	0	0	0	0	0	0	0	0	0
	RGE AHU-4	66	0	0	0	0	0	0	0	0	0	0	0	0

Building peak load is 27,656.2 MBh.

Project Name: Neomed Research and Graduate Education  
 Dataset Name: TECH 2.trc

TRACE® 700 v6.3 calculated at 03:46 AM on 10/06/2014  
 Design Capacity Quantities report Page 1 of 1

**Economic Summary**


**Project Information**

Location	Rootstown, Ohio	Study Life:	20 years
Project Name	Neomed Research and Graduate Education	Cost of Capital:	10 %
User	Samuel T Bridwell	Alternative 1:	
Company	The Pennsylvania State University		
Comments			

**Economic Comparison of Alternatives**


Yearly Savings (\$)	First Cost Difference (\$)	Cumulative Cash Flow Difference (\$)	Simple Payback (yrs.)	Net Present Value (\$)	Life Cycle Payback (yrs.)	Internal Rate of Return (%)	Life Cycle Cost
---------------------	----------------------------	--------------------------------------	-----------------------	------------------------	---------------------------	-----------------------------	-----------------

**Annual Operating Costs**



Yearly Total Operating Cost (\$)	Yearly Utility Cost (\$)	Yearly Maintenance Cost (\$)	Plant kWh/ton-hr
----------------------------------	--------------------------	------------------------------	------------------

**Monthly Utility Costs**



Project Name: Neomed Research and Graduate Education  
 Dataset Name: TECH 2.trc

TRACE 700 6.3  
 calculated at 03:46 AM on 10/06/2014

**ENERGY CONSUMPTION SUMMARY**

By ACADEMIC

	Elect Cons. (kWh)	Gas Cons. (kBtu)	Water Cons. (1000 gals)	% of Total Building Energy	Total Building Energy (kBtu/yr)	Total Source Energy* (kBtu/yr)
<b>Alternative 1</b>						
<b>Primary heating</b>						
Primary heating		19,913,922		57.9 %	19,913,922	20,962,024
Other Htg Accessories	43,022			0.4 %	146,834	440,546
Heating Subtotal	43,022	19,913,922		58.3 %	20,060,756	21,402,570
<b>Primary cooling</b>						
Cooling Compressor	950,519			9.4 %	3,244,121	9,733,337
Tower/Cond Fans	272,359		7,413	2.7 %	929,562	2,786,966
Condenser Pump				0.0 %	0	0
Other Clg Accessories	10,814			0.1 %	36,908	110,736
Cooling Subtotal....	1,233,692		7,413	12.2 %	4,210,592	12,633,038
<b>Auxiliary</b>						
Supply Fans	1,512,810			15.0 %	5,163,221	15,491,213
Pumps	90,001			0.9 %	307,174	921,613
Stand-alone Base Utilities				0.0 %	0	0
Aux Subtotal....	1,602,811			15.9 %	5,470,395	16,412,826
<b>Lighting</b>						
Lighting	1,355,949			13.5 %	4,627,855	13,884,954
<b>Receptacle</b>						
Receptacles	6,078			0.1 %	20,743	62,235
<b>Cogeneration</b>						
Cogeneration				0.0 %	0	0
<b>Totals</b>						
Totals**	4,241,553	19,913,922	7,413	100.0 %	34,390,341	64,395,620

\* Note: Resource Utilization factors are included in the Total Source Energy value.  
 \*\* Note: This report can display a maximum of 7 utilities. If additional utilities are used, they will be included in the total.

**Energy Cost Budget / PRM Summary**

By ACADEMIC

Project Name: Neomed Research and Graduate Education	Date: October 06, 2014
City: Rootstown, Ohio	Weather Data: Akron, Ohio

Note: The percentage displayed for the "Proposed/ Base %" column of the base case is actually the percentage of the total energy consumption.

\* Denotes the base alternative for the ECB study.

		* Alt-1		
		Energy 10 <sup>6</sup> Btu/yr	Proposed / Base %	Peak kBtu/h
Lighting - Conditioned	Electricity	4,627.9	13	528
Space Heating	Electricity	146.8	0	36
	Gas	19,913.9	58	6,994
Space Cooling	Electricity	3,281.0	10	1,666
Pumps	Electricity	307.2	1	111
Heat Rejection	Electricity	929.6	3	224
Fans - Conditioned	Electricity	5,163.2	15	1,620
Receptacles - Conditioned	Electricity	20.7	0	2
<b>Total Building Consumption</b>		<b>34,390.3</b>		

		* Alt-1	
Total		Number of hours heating load not met	Number of hours cooling load not met
		0	0

		* Alt-1	
		Energy 10 <sup>6</sup> Btu/yr	Cost/yr \$/yr
Electricity		14,476.4	122,229
Gas		19,913.9	99,570
<b>Total</b>		<b>34,390</b>	<b>221,799</b>

Project Name: Neomed Research and Graduate Education  
Dataset Name: TECH 2.lrc

TRACE® 700 v6.3 calculated at 03:46 AM on 10/06/2014  
Energy Cost Budget Report Page 1 of 1



**MONTHLY ENERGY CONSUMPTION**

By ACADEMIC

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
<b>Alternative: 1</b>													
<b>Electric</b>													
On-Pk Cons. (kWh)	232,362	209,454	241,360	266,840	382,432	542,511	673,198	562,125	391,157	263,034	241,512	235,466	4,241,551
On-Pk Demand (kW)	384	392	431	558	968	1,134	1,148	1,094	958	510	452	398	1,148
Off-Pk Demand (kW)	350	392	412	474	735	1,018	1,103	988	818	466	423	395	1,103
Mid-Pk Demand (kW)	404	405	424	475	777	1,122	1,174	1,072	818	455	427	409	1,174
<b>Gas</b>													
On-Pk Cons. (therms)	41,507	40,987	31,096	11,945	1,924	486	118	581	1,294	13,422	18,570	37,209	199,139
On-Pk Demand (therms/hr)	65	70	57	37	9	3	1	3	5	40	45	60	70
<b>Water</b>													
Cons. (1000gal)	57	51	59	179	741	1,525	2,043	1,640	802	190	67	58	7,413
<b>Energy Consumption</b>				<b>Environmental Impact Analysis</b>									
Building Source	349,705 Btu/(ft <sup>2</sup> -year)			CO2			7,666,942 lbm/year						
	654,819 Btu/(ft <sup>2</sup> -year)			SO2			53,207 gm/year						
				NOX			13,296 gm/year						
Floor Area	98,341 ft <sup>2</sup>												

**ONLY**

Project Name: Neomed Research and Graduate Education  
 Dataset Name: TECH 2.3rc


TRACE® 700 v6.3 calculated at 03:46 AM on 10/06/2014  
 Alternative - 1 Monthly Energy Consumption report Page 1 of 1

Appendix B: Designer Elite CHVAC 7 Reports

Chvac - Full Commercial HVAC Loads Calculation Program SBM, Inc. Uniontown, OH 44685-8797				Elite Software Development, Inc. Neoucom RGE Offices Page 3			
<b>Building Summary Loads</b>							
Building peaks in August at 1pm.							
Bldg Load Descriptions	Area Quan	Sen Loss	%Tot Loss	Lat Gain	Sen Gain	Net Gain	%Net Gain
Roof	5,638	23,257	9.69	0	11,900	11,900	2.29
Wall	8,148	67,219	28.00	0	11,747	11,747	2.26
Glass	6,252	149,585	62.31	0	166,211	166,211	31.97
Floor Slab	0	0	0.00	0	0	0	0.00
<b>Skin Loads</b>		<b>240,061</b>	<b>100.00</b>	<b>0</b>	<b>189,858</b>	<b>189,858</b>	<b>36.52</b>
Lighting	20,043	0	0.00	0	75,229	75,229	14.47
Equipment	30,283	0	0.00	0	113,661	113,661	21.86
People	246	0	0.00	67,650	67,650	135,300	26.03
Partition	0	0	0.00	0	0	0	0.00
Cool. Pret.	0	0	0.00	0	0	0	0.00
Heat. Pret.	0	0	0.00	0	0	0	0.00
Cool. Vent.	0	0	0.00	0	0	0	0.00
Heat. Vent.	0	0	0.00	0	0	0	0.00
Cool. Infil.	0	0	0.00	0	0	0	0.00
Heat. Infil.	0	0	0.00	0	0	0	0.00
Draw-Thru Fan	0	0	0.00	0	5,793	5,793	1.11
Blow-Thru Fan	0	0	0.00	0	0	0	0.00
Reserve Cap.	0	0	0.00	0	0	0	0.00
Reheat Cap.	0	0	0.00	0	0	0	0.00
Supply Duct	0	0	0.00	0	0	0	0.00
Return Duct	0	0	0.00	0	0	0	0.00
Misc. Supply	0	0	0.00	0	0	0	0.00
Misc. Return	0	0	0.00	0	0	0	0.00
<b>Building Totals</b>		<b>240,061</b>	<b>100.00</b>	<b>67,650</b>	<b>452,191</b>	<b>519,841</b>	<b>100.00</b>
Building Summary	Sen Loss	%Tot Loss	Lat Gain	Sen Gain	Net Gain	%Net Gain	
Ventilation	0	0.00	0	0	0	0.00	
Infiltration	0	0.00	0	0	0	0.00	
Pretreated Air	0	0.00	0	0	0	0.00	
Zone Loads	240,061	100.00	67,650	446,398	514,048	98.89	
Plenum Loads	0	0.00	0	0	0	0.00	
Fan & Duct Loads	0	0.00	0	5,793	5,793	1.11	
<b>Building Totals</b>	<b>240,061</b>	<b>100.00</b>	<b>67,650</b>	<b>452,191</b>	<b>519,841</b>	<b>100.00</b>	
<b>Check Figures</b>							
Total Building Supply Air (based on a 17° TD):				25,265	CFM		
Total Building Vent. Air (0.00% of Supply):				0	CFM		
Total Conditioned Air Space:				20,043	Sq.ft		
Supply Air Per Unit Area:				1.2605	CFM/Sq.ft		
Area Per Cooling Capacity:				462.7	Sq.ft/Ton		
Cooling Capacity Per Area:				0.0022	Tons/Sq.ft		
Heating Capacity Per Area:				11.98	Btuh/Sq.ft		
Total Heating Required With Outside Air:				240,061	Btuh		
Total Cooling Required With Outside Air:				43.32	Tons		

Q:\09206\Design\HVAC\09206-cah-loadcalc-RGE Offices-08-29-11.CHV

Monday, February 06, 2012, 11:30 AM

Chvac - Full Commercial HVAC Loads Calculation Program SBM, Inc. Uniontown, OH 44685-8797					Elite Software Development, Inc. Neucom RGE Labs Page 3		
<b>Building Summary Loads</b>							
Building peaks in August at 3pm.							
Bldg Load Descriptions	Area Quan	Sen Loss	%Tot Loss	Lat Gain	Sen Gain	Net Gain	%Net Gain
Roof	0	0	0.00	0	0	0	0.00
Wall	9,558	75,269	36.29	0	14,191	14,191	1.06
Glass	5,787	132,161	63.71	0	121,290	121,290	9.05
Floor Slab	0	0	0.00	0	0	0	0.00
<b>Skin Loads</b>		<b>207,430</b>	<b>100.00</b>	<b>0</b>	<b>135,480</b>	<b>135,480</b>	<b>10.11</b>
Lighting	59,835	0	0.00	0	214,374	214,374	16.00
Equipment	212,480	0	0.00	0	761,262	761,262	56.80
People	411	0	0.00	107,888	107,888	215,775	16.10
Partition	0	0	0.00	0	0	0	0.00
Cool. Pret.	0	0	0.00	0	0	0	0.00
Heat. Pret.	0	0	0.00	0	0	0	0.00
Cool. Vent.	0	0	0.00	0	0	0	0.00
Heat. Vent.	0	0	0.00	0	0	0	0.00
Cool. Infil.	0	0	0.00	0	0	0	0.00
Heat. Infil.	0	0	0.00	0	0	0	0.00
Draw-Thru Fan	0	0	0.00	0	0	0	0.00
Blow-Thru Fan	0	0	0.00	0	13,275	13,275	0.99
Reserve Cap.	0	0	0.00	0	0	0	0.00
Reheat Cap.	0	0	0.00	0	0	0	0.00
Supply Duct	0	0	0.00	0	0	0	0.00
Return Duct	0	0	0.00	0	0	0	0.00
Misc. Supply	0	0	0.00	0	0	0	0.00
Misc. Return	0	0	0.00	0	0	0	0.00
<b>Building Totals</b>		<b>207,430</b>	<b>100.00</b>	<b>107,888</b>	<b>1,232,279</b>	<b>1,340,167</b>	<b>100.00</b>
Building Summary	Sen Loss	%Tot Loss	Lat Gain	Sen Gain	Net Gain	%Net Gain	
Ventilation	0	0.00	0	0	0	0.00	
Infiltration	0	0.00	0	0	0	0.00	
Pretreated Air	0	0.00	0	0	0	0.00	
Zone Loads	207,430	100.00	107,888	1,219,004	1,326,891	99.01	
Plenum Loads	0	0.00	0	0	0	0.00	
Fan & Duct Loads	0	0.00	0	13,275	13,275	0.99	
<b>Building Totals</b>		<b>207,430</b>	<b>100.00</b>	<b>107,888</b>	<b>1,232,279</b>	<b>1,340,166</b>	<b>100.00</b>
<b>Check Figures</b>							
Total Building Supply Air (based on a 20° TD):				57,892 CFM			
Total Building Vent. Air (0.00% of Supply):				0 CFM			
Total Conditioned Air Space:				33,050 Sq.ft			
Supply Air Per Unit Area:				1.7516 CFM/Sq.ft			
Area Per Cooling Capacity:				295.9 Sq.ft/Ton			
Cooling Capacity Per Area:				0.0034 Tons/Sq.ft			
Heating Capacity Per Area:				6.28 Btuh/Sq.ft			
Total Heating Required With Outside Air:				207,430 Btuh			
Total Cooling Required With Outside Air:				111.68 Tons			

Chvac - Full Commercial HVAC Loads Calculation Program				Elite Software Development, Inc.			
SBM, Inc. Uniontown, OH 44685-8797				NEOMED CMU Page 3			
<b>Building Summary Loads</b>							
Building peaks in June at 4pm.							
Bldg Load Descriptions	Area Quan	Sen Loss	%Tot Loss	Lat Gain	Sen Gain	Net Gain	%Net Gain
Roof	14,704	68,146	7.83	0	52,478	52,478	5.63
Wall	8,414	34,199	3.93	0	8,255	8,255	0.89
Glass	280	8,487	0.98	0	15,496	15,496	1.66
Floor Slab	0	0	0.00	0	0	0	0.00
<b>Skin Loads</b>		<b>110,832</b>	<b>12.73</b>	<b>0</b>	<b>76,229</b>	<b>76,229</b>	<b>8.17</b>
Lighting	22,056	0	0.00	0	82,784	82,784	8.88
Equipment	21,584	0	0.00	9,680	81,011	90,691	9.73
People	78	0	0.00	21,513	21,513	43,027	4.61
Partition	0	0	0.00	0	0	0	0.00
Cool. Pret.	0	0	0.00	0	0	0	0.00
Heat. Pret.	0	0	0.00	0	0	0	0.00
Cool. Vent.	14,781	0	0.00	372,252	264,166	636,418	68.25
Heat. Vent.	9,948	759,475	87.27	0	0	0	0.00
Cool. Infil.	0	0	0.00	0	0	0	0.00
Heat. Infil.	0	0	0.00	0	0	0	0.00
Draw-Thru Fan	0	0	0.00	0	3,389	3,389	0.36
Blow-Thru Fan	0	0	0.00	0	0	0	0.00
Reserve Cap.	0	0	0.00	0	0	0	0.00
Reheat Cap.	0	0	0.00	0	0	0	0.00
Supply Duct	0	0	0.00	0	0	0	0.00
Return Duct	0	0	0.00	0	0	0	0.00
Misc. Supply	0	0	0.00	0	0	0	0.00
Misc. Return	0	0	0.00	0	0	0	0.00
<b>Building Totals</b>		<b>870,307</b>	<b>100.00</b>	<b>403,445</b>	<b>529,093</b>	<b>932,538</b>	<b>100.00</b>
Building Summary		Sen Loss	%Tot Loss	Lat Gain	Sen Gain	Net Gain	%Net Gain
Ventilation		759,475	87.27	372,252	264,166	636,418	68.25
Infiltration		0	0.00	0	0	0	0.00
Pretreated Air		0	0.00	0	0	0	0.00
Zone Loads		110,832	12.73	31,193	261,537	292,730	31.39
Plenum Loads		0	0.00	0	0	0	0.00
Fan & Duct Loads		0	0.00	0	3,389	3,389	0.36
<b>Building Totals</b>		<b>870,307</b>	<b>100.00</b>	<b>403,445</b>	<b>529,093</b>	<b>932,538</b>	<b>100.00</b>
<b>Check Figures</b>							
Total Building Supply Air (based on a 17* TD):				14,781	CFM		
Total Building Vent. Air (100.00% of Supply):				14,781	CFM		
Total Conditioned Air Space:				14,704	Sq.ft		
Supply Air Per Unit Area:				1.0052	CFM/Sq.ft		
Area Per Cooling Capacity:				189.2	Sq.ft/Ton		
Cooling Capacity Per Area:				0.0053	Tons/Sq.ft		
Heating Capacity Per Area:				59.19	Btuh/Sq.ft		
Total Heating Required With Outside Air:				870,307	Btuh		
Total Cooling Required With Outside Air:				77.71	Tons		

Appendix C: Utility Data and Trends

		FY 03	FY 04	FY 05	FY 06	FY 07	FY 08	FY 09	FY 10	FY 11	FY 12	FY 13	FY 14	Monthly Average
July	Kilowatt Hrs	1,090,800	894,451	964,648	823,121	549,168	803,831	801,182	802,301	873,802	742,648	849,188	1,216,025	867,897
	Dollars	\$76,956.00	\$67,205.77	\$88,984.20	\$62,574.46	\$57,427.03	\$83,667.81	\$68,700.57	\$72,389.56	\$66,113.17	\$55,893.68	\$62,790.24	\$89,539.28	\$67,636.90
	\$/kwh	\$0.070	\$0.075	\$0.072	\$0.076	\$0.105	\$0.079	\$0.086	\$0.090	\$0.076	\$0.073	\$0.075	\$0.074	\$0.074
August	Temperature				74°	74°	69°	69°	68°	73°	70°	75°	70°	
	Kilowatt Hrs	1,039,200	970,422	928,187	918,745	620,852	886,110	808,037	790,258	881,642	869,299	932,194	1,171,771	901,393
	Dollars	\$73,246.12	\$67,155.69	\$88,692.77	\$67,713.83	\$59,254.89	\$70,286.08	\$72,098.86	\$72,350.75	\$65,413.83	\$67,165.08	\$70,420.88	\$86,584.41	\$70,031.08
September	Temperature				72°	72°	73°	71°	71°	72°	77°	76°	71°	
	Kilowatt Hrs	975,600	1,045,788	923,692	793,210	597,370	848,130	763,456	826,345	821,581	776,852	864,756	1,221,542	871,527
	Dollars	\$68,276.54	\$73,666.56	\$66,987.11	\$59,813.76	\$52,618.74	\$68,888.25	\$65,895.67	\$64,755.35	\$61,569.34	\$60,432.26	\$65,455.19	\$91,314.41	\$66,639.60
October	Temperature				68°	62°	67°	68°	64°	63°	70°	70°	70°	
	Kilowatt Hrs	942,000	867,898	830,910	758,171	522,133	895,846	793,020	749,675	707,548	733,208	775,208	1,070,569	803,849
	Dollars	\$64,867.04	\$65,309.91	\$62,178.27	\$56,046.41	\$49,896.64	\$68,339.73	\$64,477.73	\$59,299.41	\$54,968.49	\$55,617.58	\$59,044.17	\$73,620.25	\$61,138.80
November	Temperature				54°	50°	59°	60°	58°	52°	60°	56°	61°	
	Kilowatt Hrs	801,600	814,199	792,234	746,735	565,003	783,910	718,951	821,495	709,884	769,813	753,095	1,106,962	781,990
	Dollars	\$65,129.20	\$69,074.02	\$64,933.03	\$53,574.35	\$54,788.41	\$68,782.86	\$59,540.80	\$63,119.86	\$53,737.50	\$56,624.77	\$57,188.91	\$73,920.47	\$68,367.85
December	Temperature				44°	44°	41°	46°	45°	41°	51°	48°	49°	
	Kilowatt Hrs	789,600	792,906	822,665	753,764	764,435	771,334	694,931	737,906	732,248	755,099	754,084	1,032,840	783,484
	Dollars	\$62,255.12	\$64,452.99	\$64,942.47	\$60,201.89	\$64,248.00	\$66,852.25	\$64,703.88	\$66,977.70	\$65,440.83	\$65,424.54	\$67,593.06	\$88,031.99	\$66,760.39
January	Temperature				31°	38°	32°	31°	29°	24°	39°	40°	34°	
	Kilowatt Hrs	841,200	815,210	759,144	473,077	681,397	703,052	731,026	708,704	657,776	650,462	835,841	1,123,259	748,346
	Dollars	\$62,836.99	\$64,003.48	\$52,765.28	\$32,868.36	\$50,664.29	\$63,047.76	\$65,953.68	\$64,766.11	\$49,798.95	\$48,452.78	\$61,077.50	\$73,990.73	\$55,018.74
February	Temperature				27°	32°	30°	28°	24°	22°	34°	33°	28°	
	Kilowatt Hrs	790,800	810,055	754,786	676,228	777,793	734,842	731,884	680,824	675,017	700,753	763,616	1,084,702	763,608
	Dollars	\$63,627.92	\$63,763.63	\$62,550.45	\$60,749.17	\$63,126.01	\$64,161.90	\$65,201.99	\$62,770.13	\$50,632.89	\$60,760.05	\$67,600.58	\$71,054.58	\$65,349.98
March	Temperature				31°	20°	26°	20°	25°	23°	33°	27°	19°	
	Kilowatt Hrs	794,400	777,011	785,594	669,115	705,942	716,921	720,252	683,767	648,097	704,306	748,176	1,148,868	758,537
	Dollars	\$63,962.46	\$64,934.24	\$66,255.17	\$62,286.25	\$61,362.71	\$66,402.35	\$60,491.36	\$60,456.99	\$51,574.41	\$60,125.30	\$60,277.34	\$77,028.99	\$65,803.81
April	Temperature				34°	42°	34°	32°	41°	34°	35°	31°	26°	
	Kilowatt Hrs	896,400	837,648	757,345	677,027	702,451	752,149	682,739	779,435	682,739	828,228	824,821	1,108,614	804,047
	Dollars	\$63,962.46	\$64,934.24	\$66,255.17	\$62,286.25	\$61,362.71	\$66,402.35	\$60,491.36	\$60,456.99	\$51,574.41	\$60,125.30	\$60,277.34	\$77,028.99	\$65,803.81
May	Temperature				52°	47°	53°	42°	53°	42°	53°	39°	42°	
	Kilowatt Hrs	831,600	769,220	783,602	642,935	751,537	730,711	740,903	721,657	772,074	742,967	821,612	1,148,868	755,338
	Dollars	\$68,456.38	\$62,713.62	\$66,140.70	\$59,918.55	\$64,977.62	\$69,716.57	\$61,966.41	\$66,398.65	\$68,508.47	\$67,030.38	\$69,918.87	\$70,750.68	\$68,704.20
June	Temperature				59°	64°	56°	55°	60°	55°	55°	56°	55°	
	Kilowatt Hrs	963,396	928,351	838,655	625,872	769,400	785,900	779,017	762,090	740,270	873,359	946,424	1,148,868	819,303
	Dollars	\$65,435.81	\$67,224.67	\$65,200.60	\$57,881.83	\$62,101.49	\$67,897.80	\$66,399.81	\$69,368.47	\$63,985.30	\$61,788.08	\$70,750.68	\$83,440.41	\$63,440.41
Totals	Temperature				73°	70°	69°	63°	69°	68°	66°	65°	65°	
	Kilowatt Hrs	10,756,596	10,323,159	9,941,462	8,560,000	8,007,481	9,412,336	9,084,271	9,064,457	8,902,878	9,146,994	9,869,015	12,160,225	9,369,859
	Dollars	\$738,805.74	\$732,876.66	\$713,104.85	\$651,934.32	\$731,842.75	\$741,876.29	\$725,678.47	\$670,939.27	\$734,447.11	\$680,201.98	\$734,447.11	\$712,509.93	\$712,509.93
	\$/kwh	\$0.069	\$0.071	\$0.072	\$0.084	\$0.081	\$0.078	\$0.082	\$0.080	\$0.075	\$0.074	\$0.074	\$0.076	

Gas Usage and Cost Yearly Comparison		FY 03	FY 04	FY 05	FY 06	FY 07	FY 08	FY 09	FY 10	FY 11	FY 12	FY 13	FY 14	Average per month:
July	MCF's	2,656.30	2,657.61	2,647.05	2,139.01	2,002.50	1,957.90	2,013.40	2,339.90	2,207.60	1,964.50	2,373.90	4,102.00	2,409
	Dollars	\$13,929.47	\$18,895.61	\$18,820.53	\$16,962.35	\$17,101.35	\$15,584.88	\$28,811.75	\$20,331.39	\$18,005.19	\$13,008.92	\$13,664.17	\$19,488.10	\$17,881.98
	\$/M/M/BTU	\$5.56	\$7.11	\$7.11	\$7.93	\$8.54	\$7.96	\$14.31	\$8.69	\$8.16	\$6.62	\$5.76	\$4.75	\$7.71
August	Temperature													
	MCF's	3,333.58	2,649.85	3,057.88	1,854.00	2,314.00	1,812.60	2,339.70	2,399.70	2,522.00	1,677.10	2,075.30	3,791.50	2,469
	Dollars	\$17,634.65	\$18,841.14	\$21,741.53	\$13,293.18	\$19,892.14	\$13,458.56	\$23,435.66	\$19,534.16	\$20,980.52	\$12,393.77	\$13,292.30	\$16,481.66	\$17,564.94
September	Temperature													
	MCF's	2,568.12	2,910.18	2,984.29	2,075.10	2,079.60	2,251.80	2,471.40	2,894.50	2,819.00	1,983.20	2,251.40	3,466.80	2,563
	Dollars	\$13,585.34	\$20,891.38	\$21,218.30	\$20,460.49	\$17,562.22	\$16,348.07	\$26,023.84	\$24,730.61	\$23,083.25	\$15,355.92	\$15,185.69	\$16,363.29	\$19,218.20
October	Temperature													
	MCF's	2,959.20	4,231.89	3,735.98	2,862.80	3,334.90	2,054.20	3,481.60	4,143.20	3,251.10	2,506.60	3,452.70	3,862.20	3,323
	Dollars	\$15,654.17	\$30,088.74	\$26,562.82	\$26,967.58	\$24,881.69	\$15,433.20	\$36,686.06	\$33,133.17	\$28,687.71	\$20,183.14	\$23,837.44	\$16,893.88	\$25,084.97
November	Temperature													
	MCF's	6,267.30	4,959.15	4,450.92	3,935.50	4,861.00	4,598.70	6,067.60	4,418.80	4,453.50	4,234.80	4,007.90	5,754.50	4,834
	Dollars	\$33,154.02	\$35,259.56	\$31,646.04	\$44,538.11	\$45,780.90	\$38,822.23	\$68,624.56	\$39,716.17	\$39,230.88	\$34,293.41	\$31,013.13	\$26,539.76	\$39,051.56
December	Temperature													
	MCF's	6,834.50	5,873.66	6,253.44	7,094.50	4,928.40	6,196.80	6,537.20	6,503.90	7,764.80	5,282.60	5,051.20	8,572.00	6,408
	Dollars	\$36,154.51	\$41,761.72	\$44,461.96	\$80,948.25	\$51,546.14	\$42,671.16	\$75,439.29	\$49,858.80	\$51,402.98	\$39,397.63	\$37,111.17	\$34,348.00	\$48,758.48
January	Temperature													
	MCF's	6,946.90	8,047.26	1,559.48	4,777.80	5,106.30	7,574.20	8,909.10	7,521.10	7,956.30	6,293.50	6,452.60	9,545.50	6,572
	Dollars	\$36,743.81	\$57,216.02	\$11,087.90	\$38,365.73	\$35,943.25	\$44,433.93	\$100,940.10	\$55,204.87	\$52,511.58	\$42,745.45	\$43,851.87	\$37,332.45	\$46,364.75
February	Temperature													
	MCF's	9,194.60	8,696.89	6,791.38	6,731.50	8,629.70	9,120.30	7,686.50	8,181.20	5,673.20	5,673.20	9,070.60	9,392.70	7,980
	Dollars	\$52,448.23	\$61,834.89	\$48,286.71	\$44,851.98	\$61,857.69	\$73,692.02	\$79,716.69	\$60,393.62	\$45,826.80	\$39,326.62	\$60,909.08	\$45,592.17	\$56,228.04
March	Temperature													
	MCF's	6,042.80	5,915.89	6,144.96	5,604.00	1,723.60	6,958.10	6,201.00	6,120.40	4,994.70	4,501.10	7,630.70	7,630.70	5,622
	Dollars	\$31,966.41	\$42,061.98	\$43,690.67	\$54,599.77	\$14,492.03	\$68,759.94	\$66,747.56	\$47,310.69	\$37,135.59	\$32,353.91	\$61,900.24	\$61,900.24	\$45,547.16
April	Temperature													
	MCF's	4,865.21	5,000.45	4,192.98	4,334.00	8,560.10	4,264.30	3,865.80	3,865.80	3,592.40	3,815.30	5,735.80	4,812	
	Dollars	\$25,736.96	\$35,553.20	\$29,812.09	\$40,977.97	\$76,253.37	\$41,005.51	\$43,776.60	\$30,636.47	\$26,137.19	\$28,977.20	\$42,106.50	\$38,270.28	\$7.90
May	Temperature													
	MCF's	2,988.90	3,490.04	4,115.48	2,896.00	2,420.20	3,712.60	3,101.30	3,581.80	2,127.50	3,059.20	3,524.60	3,524.60	3,183
	Dollars	\$15,811.28	\$24,814.18	\$29,261.07	\$26,139.30	\$22,144.83	\$38,462.54	\$28,789.37	\$28,382.18	\$15,637.13	\$21,334.86	\$25,190.32	\$25,190.32	\$25,087.91
June	Temperature													
	MCF's	3,253.69	3,163.57	2,535.81	2,575.30	2,669.50	2,863.60	2,645.50	2,546.10	2,398.10	2,504.60	3,868.50	2,820	
	Dollars	\$17,212.02	\$22,492.98	\$18,029.61	\$21,233.35	\$24,563.43	\$32,364.41	\$25,481.46	\$20,088.73	\$16,949.77	\$14,431.51	\$25,829.97	\$21,699.75	\$7.75
Totals	Temperature													
	MCF's	\$7,759.10	\$7,596.54	\$8,469.65	\$6,879.51	\$6,629.80	\$51,545.10	\$6,027.40	\$4,456.40	\$50,786.60	\$43,495.70	\$55,495.20	\$51,922	
	Dollars	\$310,030.87	\$409,511.40	\$344,619.23	\$429,338.06	\$411,839.04	\$441,036.45	\$604,482.94	\$429,320.96	\$375,598.59	\$313,802.34	\$393,891.88	\$405,770.16	
Ave. Temp.	\$5.37	\$7.11	\$7.11	\$9.16	\$8.47	\$8.56	\$10.79	\$7.88	\$7.40	\$7.21	\$7.10	\$7.10	\$7.83	



## CHP Analysis

		<b>FY 03</b>	<b>FY 04</b>	<b>FY 05</b>	<b>FY 06</b>	<b>FY 07</b>	<b>FY 08</b>	<b>FY 09</b>
<b>July</b>	\$/kwh	\$0.070	\$0.075	\$0.072	\$0.076	\$0.105	\$0.079	\$0.086
	\$/MMBTU	\$5.56	\$7.11	\$7.11	\$7.93	\$8.54	\$7.96	\$14.31
	<b>Spark Gap</b>	<b>\$14.95</b>	<b>\$14.90</b>	<b>\$13.84</b>	<b>\$14.34</b>	<b>\$22.10</b>	<b>\$15.25</b>	<b>\$10.81</b>
	kW	1515	1242	1340	1143	763	1116	1113
	MBH	3480	3691	3676	2971	2781	2719	2796
	<b>ΔD</b>	<b>0.67</b>	<b>0.87</b>	<b>0.80</b>	<b>0.76</b>	<b>1.07</b>	<b>0.71</b>	<b>0.74</b>
	Temperature	0	0	0	74°	74°	69°	69°
<b>August</b>	\$/kwh	\$0.070	\$0.069	\$0.074	\$0.074	\$0.095	\$0.079	\$0.089
	\$/MMBTU	\$5.29	\$7.11	\$7.11	\$7.17	\$8.51	\$7.43	\$10.64
	<b>Spark Gap</b>	<b>\$15.36</b>	<b>\$13.17</b>	<b>\$14.57</b>	<b>\$14.42</b>	<b>\$19.45</b>	<b>\$15.82</b>	<b>\$15.50</b>
	kW	1443	1348	1289	1276	862	1231	1122
	MBH	4630	3680	4247	2575	3214	2518	3059
	<b>ΔD</b>	<b>0.94</b>	<b>0.80</b>	<b>0.97</b>	<b>0.59</b>	<b>1.09</b>	<b>0.60</b>	<b>0.80</b>
	Temperature	0	0	0	73°	72°	73°	71°
<b>September</b>	\$/kwh	\$0.070	\$0.070	\$0.073	\$0.075	\$0.088	\$0.081	\$0.086
	\$/MMBTU	\$5.29	\$7.11	\$7.11	\$9.86	\$8.44	\$7.26	\$10.53
	<b>Spark Gap</b>	<b>\$15.22</b>	<b>\$13.53</b>	<b>\$14.14</b>	<b>\$12.23</b>	<b>\$17.36</b>	<b>\$16.54</b>	<b>\$14.76</b>
	kW	1355	1452	1283	1102	830	1178	1060
	MBH	3567	4042	4145	2882	2888	3128	3433
	<b>ΔD</b>	<b>0.77</b>	<b>0.82</b>	<b>0.95</b>	<b>0.77</b>	<b>1.02</b>	<b>0.78</b>	<b>0.95</b>
	Temperature	0	0	0	68°	62°	67°	68°
<b>October</b>	\$/kwh	\$0.069	\$0.075	\$0.075	\$0.074	\$0.096	\$0.076	\$0.081
	\$/MMBTU	\$5.29	\$7.11	\$7.11	\$9.42	\$7.46	\$7.51	\$10.54
	<b>Spark Gap</b>	<b>\$14.89</b>	<b>\$14.94</b>	<b>\$14.82</b>	<b>\$12.24</b>	<b>\$20.54</b>	<b>\$14.84</b>	<b>\$13.28</b>
	kW	1308	1205	1154	1053	725	1244	1101
	MBH	4110	5878	5189	3976	4632	2853	4836
	<b>ΔD</b>	<b>0.92</b>	<b>1.43</b>	<b>1.32</b>	<b>1.11</b>	<b>1.87</b>	<b>0.67</b>	<b>1.29</b>
	Temperature	0	0	0	54°	50°	59°	60°
<b>November</b>	\$/kwh	\$0.069	\$0.073	\$0.069	\$0.072	\$0.097	\$0.075	\$0.083
	\$/MMBTU	\$5.29	\$7.11	\$7.11	\$11.32	\$9.42	\$8.44	\$11.31
	<b>Spark Gap</b>	<b>\$14.86</b>	<b>\$14.15</b>	<b>\$13.21</b>	<b>\$9.70</b>	<b>\$18.99</b>	<b>\$13.53</b>	<b>\$12.96</b>
	kW	1113	1131	1100	1037	785	1089	999
	MBH	8705	6888	6182	5466	6751	6387	8427
	<b>ΔD</b>	<b>2.29</b>	<b>1.78</b>	<b>1.65</b>	<b>1.54</b>	<b>2.52</b>	<b>1.72</b>	<b>2.47</b>
	Temperature	0	0	44°	44°	45°	41°	46°

## CHP Analysis

		<b>FY 03</b>	<b>FY 04</b>	<b>FY 05</b>	<b>FY 06</b>	<b>FY 07</b>	<b>FY 08</b>	<b>FY 09</b>
<b>December</b>	\$/kwh	\$0.066	\$0.069	\$0.067	\$0.080	\$0.071	\$0.074	\$0.079
	\$/MMBTU	\$5.29	\$7.11	\$7.11	\$11.41	\$10.46	\$6.89	\$11.54
	<b>Spark Gap</b>	<b>\$14.10</b>	<b>\$13.01</b>	<b>\$12.46</b>	<b>\$11.99</b>	<b>\$10.33</b>	<b>\$14.71</b>	<b>\$11.52</b>
	kW	1097	1101	1143	1047	1062	1071	965
	MBH	9492	8158	8685	9853	6845	8607	9079
	<b>ΔD</b>	<b>2.54</b>	<b>2.17</b>	<b>2.23</b>	<b>2.76</b>	<b>1.89</b>	<b>2.35</b>	<b>2.76</b>
	Temperature	0	0	31°	28°	38°	32°	31°
<b>January</b>	\$/kwh	\$0.063	\$0.066	\$0.070	\$0.112	\$0.074	\$0.075	\$0.077
	\$/MMBTU	\$5.29	\$7.11	\$7.11	\$8.03	\$7.04	\$7.72	\$11.33
	<b>Spark Gap</b>	<b>\$13.11</b>	<b>\$12.30</b>	<b>\$13.26</b>	<b>\$24.71</b>	<b>\$14.75</b>	<b>\$14.39</b>	<b>\$11.10</b>
	kW	1168	1132	1054	657	946	976	1015
	MBH	9647	11177	2166	6636	7092	7992	12374
	<b>ΔD</b>	<b>2.42</b>	<b>2.89</b>	<b>0.60</b>	<b>2.96</b>	<b>2.20</b>	<b>2.40</b>	<b>3.57</b>
	Temperature	0	0	27°	37°	32°	30°	28°
<b>February</b>	\$/kwh	\$0.068	\$0.066	\$0.070	\$0.090	\$0.068	\$0.074	\$0.075
	\$/MMBTU	\$5.70	\$7.11	\$7.11	\$6.66	\$7.17	\$8.08	\$10.37
	<b>Spark Gap</b>	<b>\$14.17</b>	<b>\$12.34</b>	<b>\$13.29</b>	<b>\$19.58</b>	<b>\$12.84</b>	<b>\$13.52</b>	<b>\$11.73</b>
	kW	1098	1125	1048	942	1080	1021	1017
	MBH	12770	12079	9432	9349	11986	12667	10676
	<b>ΔD</b>	<b>3.41</b>	<b>3.15</b>	<b>2.64</b>	<b>2.91</b>	<b>3.25</b>	<b>3.64</b>	<b>3.08</b>
	Temperature	0	0	31°	30°	20°	26°	20°
<b>March</b>	\$/kwh	\$0.068	\$0.069	\$0.068	\$0.093	\$0.073	\$0.075	\$0.078
	\$/MMBTU	\$5.29	\$7.11	\$7.11	\$9.74	\$8.41	\$9.88	\$10.76
	<b>Spark Gap</b>	<b>\$14.76</b>	<b>\$13.02</b>	<b>\$12.83</b>	<b>\$17.52</b>	<b>\$12.95</b>	<b>\$12.19</b>	<b>\$12.20</b>
	kW	1103	1079	1091	929	980	996	1000
	MBH	8393	8217	8535	7783	2394	9664	8613
	<b>ΔD</b>	<b>2.23</b>	<b>2.23</b>	<b>2.29</b>	<b>2.45</b>	<b>0.72</b>	<b>2.84</b>	<b>2.52</b>
	Temperature	0	0	34°	36°	42°	34°	32°
<b>April</b>	\$/kwh	\$0.071	\$0.066	\$0.074	\$0.092	\$0.073	\$0.075	\$0.075
	\$/MMBTU	\$5.29	\$7.11	\$7.11	\$9.46	\$8.91	\$9.62	\$9.29
	<b>Spark Gap</b>	<b>\$15.62</b>	<b>\$12.11</b>	<b>\$14.65</b>	<b>\$17.50</b>	<b>\$12.52</b>	<b>\$12.36</b>	<b>\$12.81</b>
	kW	1245	1163	1052	940	976	1045	1113
	MBH	6757	6945	5824	6019	11889	5923	6542
	<b>ΔD</b>	<b>1.59</b>	<b>1.75</b>	<b>1.62</b>	<b>1.88</b>	<b>3.57</b>	<b>1.66</b>	<b>1.72</b>
	Temperature	0	0	52°	53°	47°	53°	42°



## CHP Analysis

		<b>FY 03</b>	<b>FY 04</b>	<b>FY 05</b>	<b>FY 06</b>	<b>FY 07</b>	<b>FY 08</b>	<b>FY 09</b>
<b>May</b>	\$/kwh	\$0.070	\$0.082	\$0.072	\$0.093	\$0.073	\$0.082	\$0.084
	\$/MMBTU	\$5.29	\$7.11	\$7.11	\$9.03	\$9.15	\$10.36	\$9.28
	<b>Spark Gap</b>	<b>\$15.31</b>	<b>\$16.78</b>	<b>\$13.88</b>	<b>\$18.28</b>	<b>\$12.28</b>	<b>\$13.59</b>	<b>\$15.23</b>
	kW	1155	1068	1088	893	1044	1015	1029
	MBH	4151	4847	5716	4022	3361	5156	4307
	<b>ΔD</b>	<b>1.05</b>	<b>1.33</b>	<b>1.54</b>	<b>1.32</b>	<b>0.94</b>	<b>1.49</b>	<b>1.23</b>
	Temperature	0	0	57°	59°	64°	56°	55°
<b>June</b>	\$/kwh	\$0.068	\$0.072	\$0.078	\$0.092	\$0.081	\$0.086	\$0.085
	\$/MMBTU	\$5.29	\$7.11	\$7.11	\$8.25	\$9.21	\$11.30	\$9.63
	<b>Spark Gap</b>	<b>\$14.61</b>	<b>\$14.11</b>	<b>\$15.67</b>	<b>\$18.86</b>	<b>\$14.44</b>	<b>\$13.95</b>	<b>\$15.34</b>
	kW	1338	1289	1165	869	1069	1091	1082
	MBH	4519	4394	3522	3577	3708	3977	3674
	<b>ΔD</b>	<b>0.99</b>	<b>1.00</b>	<b>0.89</b>	<b>1.21</b>	<b>1.02</b>	<b>1.07</b>	<b>1.00</b>
	Temperature	0	0	73°	67°	70°	69°	63°
<b>Yearly Average</b>	\$/kwh	\$0.069	\$0.071	\$0.072	\$0.085	\$0.083	\$0.078	\$0.082
	\$/MMBTU	\$5.35	\$7.11	\$7.11	\$9.02	\$8.56	\$8.54	\$10.80
	<b>Spark Gap</b>	<b>\$14.75</b>	<b>\$13.70</b>	<b>\$13.89</b>	<b>\$15.95</b>	<b>\$15.71</b>	<b>\$14.22</b>	<b>\$13.10</b>
	kW	1245	1195	1151	991	927	1089	1051
	MBH	6685	6666	5610	5426	5628	5966	6485
	<b>ΔD</b>	<b>1.57</b>	<b>1.63</b>	<b>1.43</b>	<b>1.60</b>	<b>1.78</b>	<b>1.60</b>	<b>1.81</b>
	Temperature	0	0	0	52	51	51	49

## CHP Analysis

		FY 10	FY 11	FY 12	FY 13	FY 14	Monthly Average
<b>July</b>	\$/kwh	\$0.090	\$0.076	\$0.075	\$0.074	\$0.074	\$0.080
	\$/MMBTU	\$8.69	\$8.16	\$6.62	\$5.76	\$4.75	\$7.98
	<b>Spark Gap</b>	<b>\$17.75</b>	<b>\$14.01</b>	<b>\$15.43</b>	<b>\$15.91</b>	<b>\$16.83</b>	<b>\$15.39</b>
	kW	1114	1214	1031	1179	1689	1161
	MBH	3250	3066	2728	3297	5697	3132
	<b>ΔD</b>	<b>0.85</b>	<b>0.74</b>	<b>0.78</b>	<b>0.82</b>	<b>0.99</b>	<b>0.80</b>
	Temperature	68°	73°	70°	75	72	
<b>August</b>	\$/kwh	\$0.092	\$0.074	\$0.077	\$0.076	\$0.074	\$0.079
	\$/MMBTU	\$8.35	\$8.32	\$7.39	\$6.41	\$4.35	\$7.61
	<b>Spark Gap</b>	<b>\$18.48</b>	<b>\$13.42</b>	<b>\$15.25</b>	<b>\$15.73</b>	<b>\$17.30</b>	<b>\$15.56</b>
	kW	1098	1225	1207	1295	1627	1218
	MBH	3250	3503	2329	2882	5266	3262
	<b>ΔD</b>	<b>0.87</b>	<b>0.84</b>	<b>0.57</b>	<b>0.65</b>	<b>0.95</b>	<b>0.79</b>
	Temperature	71°	72°	77°	76	71	
<b>September</b>	\$/kwh	\$0.078	\$0.075	\$0.078	\$0.076	\$0.075	\$0.077
	\$/MMBTU	\$8.54	\$8.19	\$7.74	\$6.74	\$4.72	\$7.89
	<b>Spark Gap</b>	<b>\$14.42</b>	<b>\$13.77</b>	<b>\$15.05</b>	<b>\$15.43</b>	<b>\$17.18</b>	<b>\$14.77</b>
	kW	1148	1141	1079	1201	1697	1166
	MBH	4020	3915	2754	3127	4815	3446
	<b>ΔD</b>	<b>1.03</b>	<b>1.01</b>	<b>0.75</b>	<b>0.76</b>	<b>0.83</b>	<b>0.87</b>
	Temperature	64°	63°	70°	70	70	
<b>October</b>	\$/kwh	\$0.079	\$0.078	\$0.076	\$0.076	\$0.069	\$0.078
	\$/MMBTU	\$8.00	\$8.82	\$8.05	\$6.90	\$4.89	\$7.84
	<b>Spark Gap</b>	<b>\$15.18</b>	<b>\$13.94</b>	<b>\$14.17</b>	<b>\$15.41</b>	<b>\$15.26</b>	<b>\$14.93</b>
	kW	1041	983	1018	1077	1487	1083
	MBH	5754	4515	3481	4795	5364	4547
	<b>ΔD</b>	<b>1.62</b>	<b>1.35</b>	<b>1.00</b>	<b>1.30</b>	<b>1.06</b>	<b>1.26</b>
	Temperature	49°	52°	60°	56	61	
<b>November</b>	\$/kwh	\$0.077	\$0.076	\$0.074	\$0.076	\$0.067	\$0.076
	\$/MMBTU	\$8.99	\$8.81	\$8.10	\$7.74	\$4.61	\$8.51
	<b>Spark Gap</b>	<b>\$13.52</b>	<b>\$13.37</b>	<b>\$13.45</b>	<b>\$14.51</b>	<b>\$14.95</b>	<b>\$13.84</b>
	kW	1141	986	1069	1046	1537	1045
	MBH	6137	6185	5882	5567	7992	6598
	<b>ΔD</b>	<b>1.58</b>	<b>1.84</b>	<b>1.61</b>	<b>1.56</b>	<b>1.52</b>	<b>1.87</b>
	Temperature	45°	41°	51°	48	49	

### CHP Analysis

		<b>FY 10</b>	<b>FY 11</b>	<b>FY 12</b>	<b>FY 13</b>	<b>FY 14</b>	<b>Monthly Average</b>
<b>December</b>	\$/kwh	\$0.077	\$0.076	\$0.073	\$0.076	\$0.066	\$0.073
	\$/MMBTU	\$7.67	\$6.62	\$7.46	\$7.35	\$4.01	\$8.08
	<b>Spark Gap</b>	<b>\$14.96</b>	<b>\$15.56</b>	<b>\$14.05</b>	<b>\$15.03</b>	<b>\$15.29</b>	<b>\$13.43</b>
	kW	1025	1017	1049	1047	1435	1057
	MBH	9033	10784	7337	7016	11906	8626
	<b>AD</b>	<b>2.58</b>	<b>3.11</b>	<b>2.05</b>	<b>1.96</b>	<b>2.43</b>	<b>2.40</b>
	Temperature	29°	24°	39°	40	34	
<b>January</b>	\$/kwh	\$0.077	\$0.076	\$0.074	\$0.073	\$0.066	\$0.076
	\$/MMBTU	\$7.34	\$6.60	\$6.79	\$6.80	\$3.91	\$7.38
	<b>Spark Gap</b>	<b>\$15.30</b>	<b>\$15.58</b>	<b>\$15.03</b>	<b>\$14.61</b>	<b>\$15.39</b>	<b>\$14.92</b>
	kW	984	914	903	1161	1560	992
	MBH	10446	11050	8741	8962	13258	8753
	<b>AD</b>	<b>3.11</b>	<b>3.54</b>	<b>2.83</b>	<b>2.26</b>	<b>2.49</b>	<b>2.62</b>
	Temperature	24°	22°	34°	33	28	
<b>February</b>	\$/kwh	\$0.078	\$0.075	\$0.072	\$0.073	\$0.067	\$0.074
	\$/MMBTU	\$7.38	\$6.83	\$6.93	\$6.72	\$4.85	\$7.28
	<b>Spark Gap</b>	<b>\$15.33</b>	<b>\$15.15</b>	<b>\$14.29</b>	<b>\$14.70</b>	<b>\$14.70</b>	<b>\$14.27</b>
	kW	946	938	973	1061	1479	1023
	MBH	11363	9322	7879	12598	13045	10920
	<b>AD</b>	<b>3.52</b>	<b>2.91</b>	<b>2.37</b>	<b>3.48</b>	<b>2.58</b>	<b>3.12</b>
	Temperature	25°	23°	33°	27	19	
<b>March</b>	\$/kwh	\$0.078	\$0.076	\$0.072	\$0.072	\$0.067	\$0.075
	\$/MMBTU	\$7.73	\$7.43	\$7.19	\$8.11		\$8.07
	<b>Spark Gap</b>	<b>\$14.99</b>	<b>\$14.81</b>	<b>\$13.98</b>	<b>\$13.09</b>		<b>\$13.85</b>
	kW	950	900	978	1039	1596	1004
	MBH	8501	6937	6252	10598		7808
	<b>AD</b>	<b>2.62</b>	<b>2.26</b>	<b>1.87</b>	<b>2.99</b>		<b>2.28</b>
	Temperature	41°	34°	35°	31	26	
<b>April</b>	\$/kwh	\$0.078	\$0.076	\$0.073	\$0.073	\$0.066	\$0.075
	\$/MMBTU	\$7.93	\$7.30	\$7.59	\$7.34		\$7.90
	<b>Spark Gap</b>	<b>\$14.80</b>	<b>\$14.84</b>	<b>\$13.68</b>	<b>\$14.07</b>		<b>\$14.09</b>
	kW	1083	948	1150	1146	1540	1078
	MBH	5369	4976	5299	7966		6683
	<b>AD</b>	<b>1.45</b>	<b>1.54</b>	<b>1.35</b>	<b>2.04</b>		<b>1.83</b>
	Temperature	53°	42°	53°	39	42	

### CHP Analysis

		<b>FY 10</b>	<b>FY 11</b>	<b>FY 12</b>	<b>FY 13</b>	<b>FY 14</b>	<b>Monthly Average</b>
<b>May</b>	\$/kwh	\$0.078	\$0.076	\$0.077	\$0.073		\$0.078
	\$/MMBTU	\$7.92	\$7.35	\$6.97	\$7.15		\$7.88
	<b>Spark Gap</b>	<b>\$14.97</b>	<b>\$14.85</b>	<b>\$15.52</b>	<b>\$14.22</b>		<b>\$14.99</b>
	kW	1002	1072	1032	1141		1049
	MBH	4975	2955	4249	4895		4421
	<b>ΔD</b>	<b>1.45</b>	<b>0.81</b>	<b>1.21</b>	<b>1.26</b>		<b>1.24</b>
	Temperature	60°	55°	55°	56		
<b>June</b>	\$/kwh	\$0.078	\$0.073	\$0.071	\$0.075		\$0.078
	\$/MMBTU	\$7.89	\$7.07	\$5.76	\$6.68		\$7.75
	<b>Spark Gap</b>	<b>\$14.94</b>	<b>\$14.30</b>	<b>\$14.97</b>	<b>\$15.23</b>		<b>\$15.13</b>
	kW	1058	1028	1213	1314		1138
	MBH	3536	3331	3479	5373		3917
	<b>ΔD</b>	<b>0.98</b>	<b>0.95</b>	<b>0.84</b>	<b>1.20</b>		<b>1.01</b>
	Temperature	69°	68°	66°	65		
<b>Yearly Average</b>	\$/kwh	\$0.080	\$0.075	\$0.074	\$0.074	\$0.069	\$0.077
	\$/MMBTU	\$8.04	\$7.62	\$7.22	\$6.97	\$4.51	\$7.85
	<b>Spark Gap</b>	<b>\$15.39</b>	<b>\$14.47</b>	<b>\$14.57</b>	<b>\$14.83</b>	<b>\$15.69</b>	<b>\$14.60</b>
	kW	1049	1030	1059	1142	1565	1084
	MBH	6303	5878	5034	6423	8418	6010
	<b>ΔD</b>	<b>1.76</b>	<b>1.67</b>	<b>1.39</b>	<b>1.65</b>	<b>1.58</b>	<b>1.63</b>
	Temperature	50	47	54	51	0	

Appendix D: Initial DOE CHP Screening

Note: used 10-year average utility data for screening

DOE TAP CHP Qualification Screen				
<b>Gas Fueled CHP - Recip Engine, Microturbine, Fuel Cell or Gas Turbine Systems / natural gas, LFG, biogas</b>				
<i>Note: The results of this screening analysis use average values and assumptions and should not be utilized as an investment g</i>				
<b>Facility Information</b>				
Facility Name	NEOMED Campus			
Location (City, State)	Rootstown, Ohio			
Application	Laboratory/Higher Ed.			
<b>Loads</b>				
Annual Hours of Operation	8,760	Annual operating hours with loads conducive to CHP		
Average Power Demand, kW	1,084	Average power demand during operating hours		
Annual Electricity Consumption, kWh	9,495,840			
Average Thermal Demand, MMBtu/hr	6.01			
Annual Thermal Demand, MMBtu	52,648			
<b>Energy Costs</b>				
	<b>Base Case</b>	<b>CHP Case</b>		
Boiler/Thermal Fuel Costs, \$/MMBtu	\$7.85	\$7.85		
CHP Fuel Costs, \$MM/Btu		\$7.85		
Average Electricity Costs, \$/kWh	\$0.077		Annual electricity costs (demand :	
Percent Average per kWh Electric Cost Avoided		0%	Option 1 - Percent of average elec	
Standby Rate, \$/kW		\$0.05	Option 2 - Monthly \$/kW standby	
<b>Existing System</b>				
Displaced Thermal Efficiency, %	90.0%	Displaced onsite thermal (boiler, heater, etc) efficiency		
<b>CHP System</b>				
Net CHP Power, kW		1,084	CHP System Specs	C
CHP Electric Efficiency, % (HHV)		36.8%	CHP system specs	C
CHP Thermal Output, Btu/kWh		3,854	CHP system specs	C
CHP Thermal Output, MMBtu/hr		4.2	CHP system specs	C
CHP Power to Heat Ratio		0.89	Calculated based on CHP power o	
CHP Availability, %		98%	90 to 98%	
Incremental O&M Costs, \$/kWh		\$0.019	CHP system specs	C
Thermal Utilization, %		90%	Amount of available thermal capt	
Total Installed Costs, \$/kW		\$2,335	CHP system specs	C

DOE TAP CHP Qualification Screen		
Gas Fueled CHP - Recip Engine, Microturbine, Fuel Cell or Gas Turbine Systems / natural gas, LFG, biogas		
<i>Note: The results of this screening analysis use average values and assumptions and should not be utilized as an investment grade analysis.</i>		
<b>Facility Information</b>		
Facility Name	NEOMED Campus	
Location (City, State)	Rootstown, Ohio	
Application	Laboratory/Higher Ed.	
<b>Annual Energy Consumption</b>	<b>Base Case</b>	<b>CHP Case</b>
Purchased Electricity, kWh	9,495,840	189,917
Generated Electricity, kWh	0	9,305,923
On-site Boiler/Heater Thermal, MMBtu	52,648	20,372
CHP Thermal, MMBtu	0	32,276
Boiler/Heater Fuel, MMBtu	58,497	22,635
CHP Fuel, MMBtu	0	86,210
Total Fuel, MMBtu	58,497	108,845
<b>Annual Operating Costs</b>		
Purchased Electricity, \$	\$731,180	\$14,624
Standby Charges (Option 2), \$	\$0	\$650
On-site Boiler/Heater Fuel, \$	\$459,204	\$177,685
CHP Fuel, \$	\$0	\$676,749
Incremental O&M, \$	\$0	\$176,813
Total Operating Costs, \$	\$1,190,384	\$1,046,521
<b>Simple Payback</b>		
Annual Operating Savings		\$143,863
Total Installed Costs		\$2,531,140
Incentives		\$200,000
<b>Simple Payback, Years</b>		<b>16.2</b>
<b>Operating Costs to Generate</b>		
Fuel Costs, \$/kWh		\$0.073
Thermal Credit, \$/kWh		(\$0.030)
Incremental O&M, \$/kWh		\$0.019
<b>Total Operating Costs to Generate, \$/kWh</b>		<b>\$0.061</b>

Appendix E: CHP Configurations Screening

Option A: 1 GE Jenbacher J420 with process steam load

DOE TAP CHP Qualification Screen		
<b>Gas Fueled CHP - Recip Engine, Microturbine, Fuel Cell or Gas Turbine Systems / natural gas, LFG, biogas</b>		
<i>Note: The results of this screening analysis use average values and assumptions and should not be utilized as an</i>		
<b>Facility Information</b>		
Facility Name	NEOMED Campus	
Location (City, State)	Rootstown, Ohio	
Application	Laboratory/Higher Ed.	
<b>Loads</b>		
Annual Hours of Operation	8,760	Annual operating hours with
Average Power Demand, kW	1,565	Average power demand during
Annual Electricity Consumption, kWh	13,709,400	
Average Thermal Demand, MMBtu/hr	4.82	
Annual Thermal Demand, MMBtu	42,179	
<b>Energy Costs</b>		
	<b>Base Case</b>	<b>CHP Case</b>
Boiler/Thermal Fuel Costs, \$/MMBtu	\$4.51	\$4.51
CHP Fuel Costs, \$MM/Btu		\$4.51
Average Electricity Costs, \$/kWh	\$0.069	
Percent Average per kWh Electric Cost Avoided		0%
Standby Rate, \$/kW		\$0.05
<b>Existing System</b>		
Displaced Thermal Efficiency, %	85.0%	Displaced onsite thermal (kWh)
<b>CHP System</b>		
Net CHP Power, kW		1,426
CHP Electric Efficiency, % (HHV)		40.8%
CHP Thermal Output, Btu/kWh		3,852
CHP Thermal Output, MMBtu/hr		5.5
CHP Power to Heat Ratio		0.89
CHP Availability, %		98%
Incremental O&M Costs, \$/kWh		\$0.019
Thermal Utilization, %		90%
Total Installed Costs, \$/kW		\$2,335

DOE TAP CHP Qualification Screen		
<b>Gas Fueled CHP - Recip Engine, Microturbine, Fuel Cell or Gas Turbine Systems / natural gas, LFG, biogas</b>		
<i>Note: The results of this screening analysis use average values and assumptions and should not be utilized as an</i>		
<b>Facility Information</b>		
Facility Name	NEOMED Campus	
Location (City, State)	Rootstown, Ohio	
Application	Laboratory/Higher Ed.	
<b>Annual Energy Consumption</b>	<b>Base Case</b>	<b>CHP Case</b>
Purchased Electricity, kWh	13,709,400	1,467,475
Generated Electricity, kWh	0	12,241,925
On-site Boiler/Heater Thermal, MMBtu	42,179	0
CHP Thermal, MMBtu	0	42,441
Boiler/Heater Fuel, MMBtu	49,623	0
CHP Fuel, MMBtu	0	102,326
Total Fuel, MMBtu	49,623	102,326
<b>Annual Operating Costs</b>		
Purchased Electricity, \$	\$945,949	\$101,256
Standby Charges (Option 2), \$	\$0	\$856
On-site Boiler/Heater Fuel, \$	\$223,799	\$0
CHP Fuel, \$	\$0	\$461,490
Incremental O&M, \$	\$0	\$232,597
Total Operating Costs, \$	\$1,169,748	\$796,198
<b>Simple Payback</b>		
Annual Operating Savings		\$373,550
Total Installed Costs		\$3,329,710
Incentives		\$200,000
<b>Simple Payback, Years</b>		<b>8.4</b>
<b>Operating Costs to Generate</b>		
Fuel Costs, \$/kWh		\$0.038
Thermal Credit, \$/kWh		(\$0.018)
Incremental O&M, \$/kWh		\$0.019
<b>Total Operating Costs to Generate, \$/kWh</b>		<b>\$0.038</b>



Option B: 2 GE Jenbacher J316 with process steam load

DOE TAP CHP Qualification Screen			
<b>Gas Fueled CHP - Recip Engine, Microturbine, Fuel Cell or Gas Turbine Systems / natural gas, LFG, biogas</b>			
<i>Note: The results of this screening analysis use average values and assumptions and should not be utilized as an</i>			
<b>Facility Information</b>			
Facility Name	NEOMED Campus		
Location (City, State)	Rootstown, Ohio		
Application	Laboratory/Higher Ed.		
<b>Loads</b>			
Annual Hours of Operation	8,760		Annual operating hours with
Average Power Demand, kW	1,565		Average power demand during
Annual Electricity Consumption, kWh	13,709,400		
Average Thermal Demand, MMBtu/hr	4.82		
Annual Thermal Demand, MMBtu	42,179		
<b>Energy Costs</b>			
	<b>Base Case</b>		<b>CHP Case</b>
Boiler/Thermal Fuel Costs, \$/MMBtu	\$4.51		\$4.51
CHP Fuel Costs, \$MM/Btu			\$4.51
Average Electricity Costs, \$/kWh	\$0.069		
Percent Average per kWh Electric Cost Avoided			0%
Standby Rate, \$/kW			\$0.05
<b>Existing System</b>			
Displaced Thermal Efficiency, %	85.0%		Displaced onsite thermal (l
<b>CHP System</b>			
Net CHP Power, kW			1,696
CHP Electric Efficiency, % (HHV)			38.3%
CHP Thermal Output, Btu/kWh			4,382
CHP Thermal Output, MMBtu/hr			7.4
CHP Power to Heat Ratio			0.78
CHP Availability, %			98%
Incremental O&M Costs, \$/kWh			\$0.019
Thermal Utilization, %			90%
Total Installed Costs, \$/kW			\$2,335

DOE TAP CHP Qualification Screen		
<b>Gas Fueled CHP - Recip Engine, Microturbine, Fuel Cell or Gas Turbine Systems / natural gas, LFG, biogas</b>		
<i>Note: The results of this screening analysis use average values and assumptions and should not be utilized as an</i>		
<b>Annual Energy Consumption</b>	<b>Base Case</b>	<b>CHP Case</b>
Purchased Electricity, kWh	13,709,400	0
Generated Electricity, kWh	0	13,709,400
On-site Boiler/Heater Thermal, MMBtu	42,179	0
CHP Thermal, MMBtu	0	54,068
Boiler/Heater Fuel, MMBtu	49,623	0
CHP Fuel, MMBtu	0	122,228
Total Fuel, MMBtu	49,623	122,228
<b>Annual Operating Costs</b>		
Purchased Electricity, \$	\$945,949	\$0
Standby Charges (Option 2), \$	\$0	\$1,018
On-site Boiler/Heater Fuel, \$	\$223,799	\$0
CHP Fuel, \$	\$0	\$551,246
Incremental O&M, \$	\$0	\$260,479
Total Operating Costs, \$	\$1,169,748	\$812,742
<b>Simple Payback</b>		
Annual Operating Savings		\$357,005
Total Installed Costs		\$3,960,160
Incentives		\$200,000
<b>Simple Payback, Years</b>		<b>10.5</b>
<b>Operating Costs to Generate</b>		
Fuel Costs, \$/kWh		\$0.040
Thermal Credit, \$/kWh		(\$0.016)
Incremental O&M, \$/kWh		\$0.019
<b>Total Operating Costs to Generate, \$/kWh</b>		<b>\$0.043</b>

Option C: 3 GE Jenbacher J312 with process steam load

DOE TAP CHP Qualification Screen			
<b>Gas Fueled CHP - Recip Engine, Microturbine, Fuel Cell or Gas Turbine Systems / natural gas, LFG, biogas</b>			
<i>Note: The results of this screening analysis use average values and assumptions and should not be utilized as an</i>			
<b>Facility Information</b>			
Facility Name	NEOMED Campus		
Location (City, State)	Rootstown, Ohio		
Application	Laboratory/Higher Ed.		
<b>Loads</b>			
Annual Hours of Operation	8,760		Annual operating hours with
Average Power Demand, kW	1,565		Average power demand during
Annual Electricity Consumption, kWh	13,709,400		
Average Thermal Demand, MMBtu/hr	4.82		
Annual Thermal Demand, MMBtu	42,179		
<b>Energy Costs</b>		<b>Base Case</b>	<b>CHP Case</b>
Boiler/Thermal Fuel Costs, \$/MMBtu	\$4.51		\$4.51
CHP Fuel Costs, \$MM/Btu			\$4.51
Average Electricity Costs, \$/kWh	\$0.069		
Percent Average per kWh Electric Cost Avoided			0%
Standby Rate, \$/kW			\$0.05
<b>Existing System</b>			
Displaced Thermal Efficiency, %	85.0%		Displaced onsite thermal (l
<b>CHP System</b>			
Net CHP Power, kW			1,899
CHP Electric Efficiency, % (HHV)			38.1%
CHP Thermal Output, Btu/kWh			4,387
CHP Thermal Output, MMBtu/hr			8.3
CHP Power to Heat Ratio			0.78
CHP Availability, %			98%
Incremental O&M Costs, \$/kWh			\$0.021
Thermal Utilization, %			90%
Total Installed Costs, \$/kW			\$2,737

DOE TAP CHP Qualification Screen		
<b>Gas Fueled CHP - Recip Engine, Microturbine, Fuel Cell or Gas Turbine Systems / natural gas, LFG, biogas</b>		
<i>Note: The results of this screening analysis use average values and assumptions and should not be utilized as an</i>		
<b>Annual Energy Consumption</b>	<b>Base Case</b>	<b>CHP Case</b>
Purchased Electricity, kWh	13,709,400	-2,593,135
Generated Electricity, kWh	0	16,302,535
On-site Boiler/Heater Thermal, MMBtu	42,179	0
CHP Thermal, MMBtu	0	64,368
Boiler/Heater Fuel, MMBtu	49,623	0
CHP Fuel, MMBtu	0	145,957
Total Fuel, MMBtu	49,623	145,957
<b>Annual Operating Costs</b>		
Purchased Electricity, \$	\$945,949	-\$178,926
Standby Charges (Option 2), \$	\$0	\$1,139
On-site Boiler/Heater Fuel, \$	\$223,799	\$0
CHP Fuel, \$	\$0	\$658,267
Incremental O&M, \$	\$0	\$342,353
Total Operating Costs, \$	\$1,169,748	\$822,833
<b>Simple Payback</b>		
Annual Operating Savings		\$346,915
Total Installed Costs		\$5,197,563
Incentives		\$200,000
<b>Simple Payback, Years</b>		<b>14.4</b>
<b>Operating Costs to Generate</b>		
Fuel Costs, \$/kWh		\$0.040
Thermal Credit, \$/kWh		(\$0.014)
Incremental O&M, \$/kWh		\$0.021
<b>Total Operating Costs to Generate, \$/kWh</b>		<b>\$0.048</b>

Option B: 1 GE Jenbacher J420 with trigeneration, absorption cooling sized to thermal output

DOE TAP CHP Qualification Screen			
<b>Gas Fueled CHP - Recip Engine, Microturbine, Fuel Cell or Gas Turbine Systems / natural gas, LFG, biogas with Heating</b>			
<i>Note: The results of this screening analysis use average values and assumptions and should not be utilized as an investment decision.</i>			
<b>Facility Information</b>			
Facility Name	NEOMED Campus		
Location (City, State)	Rootstown, Ohio		
Application	Laboratory/Higher Ed.		
<b>Loads</b>			
Annual Hours of Operation	8,760		
Average Power Demand, kW	1,565	Average power demand	
Annual Hours of Cooling Demand	2,520	input	
Annual Hours of Heating Demand	6,240	determined by annual	
Annual Electricity Consumption, kWh	13,709,400		
Average Heating Demand, MMBtu/hr	8.42	CHP system sized to heat	
Annual Heating Demand, MMBtu	52,541		
Average Cooling Demand, Tons	394	2014 cooling	
Average Power Demand without Cooling, kW	1,329	CHP system sized not to	
Average Thermal Requirements for Cooling, MMBtu/hr	6.75	Thermal requirements for	
Average Thermal Requirements for Cooling, MMBtu/hr	#REF!	Thermal requirements for	
Annual Cooling Demand, Tons	992,880		
<b>Energy Costs</b>		<b>Base Case</b>	<b>CHP Case</b>
Boiler/Thermal Fuel Costs, \$/MMBtu	\$4.51		\$4.51
CHP Fuel Costs, \$MM/Btu			\$4.51
Average Electricity Costs, \$/kWh	0.069		
Cooling Electricity Costs, \$/kWh	\$0.069		
Percent Average per kWh Electric Cost Avoided			0%
Standby Rate, \$/kW			\$0.05
<b>Existing System</b>			
Displaced Thermal Efficiency, %	90.0%		
Existing Chiller Power Requirements, kWh/Ton	0.60		

DOE TAP CHP Qualification Screen			
<b>Gas Fueled CHP - Recip Engine, Microturbine, Fuel Cell or Gas Turbine Systems / natural gas, LFG, biogas with Heating</b>			
<i>Note: The results of this screening analysis use average values and assumptions and should not be utilized as an investment decision.</i>			
<b>Facility Information</b>			
Facility Name	NEOMED Campus		
Location (City, State)	Rootstown, Ohio		
Application	Laboratory/Higher Ed.		
<b>CHP System</b>		<b>CHP Cooling Single Effect</b>	
Net CHP Power, kW			1,426
CHP Electric Efficiency, % (HHV)			40.8%
CHP Thermal Output, Btu/kWh (Available Heating)			3,852
CHP Thermal Output, MMBtu/hr (Available Heating)			5.49
CHP Thermal Output, Btu/kWh (Available Cooling)			3,274
CHP Thermal Output, MMBtu/hr (Available Cooling)			4.67
CHP Power to Heat Ratio			0.89
CHP Availability, %			98%
Incremental O&M Costs for CHP, \$/kWh			\$0.019
Incremental O&M Costs for chiller, \$/Ton-Year			\$30.00
CHP Installed Costs, \$/kW (without chillers)			\$2,335
Thermal Utilization, %			90%
<b>CHP Cooling</b>			
Absorption Chiller COP			0.7
Absorption Chiller Capacity, Tons			245
Absorption Installed Costs, \$/Ton			\$1,720

DOE TAP CHP Qualification Screen		
<b>Gas Fueled CHP - Recip Engine, Microturbine, Fuel Cell or Gas Turbine Systems / natural gas, LFG, biogas with Heating</b>		
<i>Note: The results of this screening analysis use average values and assumptions and should not be utilized as an investment</i>		
<b>Annual Energy Consumption</b>	<b>Base Case</b>	<b>CHP Cooling Single Effect</b>
Purchased Electricity, kWh	13,709,400	1,104,259
Generated Electricity, kWh	0	12,241,925
Annual Cooling Demand, Tons	992,880	992,880
Electric Cooling, Tons	992,880	387,519
Cooling Electricity, kWh	595,728	232,511
CHP Cooling, Tons	0	605,361
On-site Boiler/Heater Thermal Demand, MMBtu	52,541	22,309
Boiler/Heater Fuel, MMBtu	58,379	24,788
CHP Heating, MMBtu	0	30,232
CHP Fuel, MMBtu	0	102,326
Total Fuel, MMBtu	58,379	127,114
<b>Annual Operating Costs</b>		
Purchased Electricity, \$	\$945,949	\$76,194
Standby Charges (Option 2), \$	\$0	\$856
On-site Boiler/Heater Fuel, \$	\$263,288	\$111,793
CHP Fuel, \$	\$0	\$461,490
Incremental O&M, \$	\$0	\$239,950
Total Operating Costs, \$	\$1,209,236	\$890,283
<b>Simple Payback</b>		
Annual Operating Savings, \$		\$318,953
Chiller Installed Costs, \$/kW		\$296
Total CHP System Costs, \$/kW (including chiller)		\$2,631
Total Installed Costs		\$3,751,325
Incentives		\$200,000
<b>Simple Payback, Years</b>		<b>11.1</b>
<b>Operating Costs to Generate, \$/kWh</b>		
Fuel Costs, \$/kWh		\$0.038
Cooling Credit, \$/kWh		\$0.000
Heating Credit, \$/kWh		(\$0.012)
Incremental O&M, \$/kWh		\$0.020
<b>Total Operating Costs to Generate, \$/kWh</b>		<b>\$0.045</b>

Option E: 2 GE Jenbacher J316 with trigeneration, absorption cooling sized to thermal output

DOE TAP CHP Qualification Screen			
<b>Gas Fueled CHP - Recip Engine, Microturbine, Fuel Cell or Gas Turbine Systems / natural gas, LFG, biogas with Heating</b>			
<i>Note: The results of this screening analysis use average values and assumptions and should not be utilized as an investment decision.</i>			
<b>Facility Information</b>			
Facility Name	NEOMED Campus		
Location (City, State)	Rootstown, Ohio		
Application	Laboratory/Higher Ed.		
<b>Loads</b>			
Annual Hours of Operation	8,760		
Average Power Demand, kW	1,565	Average power demand	
Annual Hours of Cooling Demand	2,520	input	
Annual Hours of Heating Demand	6,240	determined by annual	
Annual Electricity Consumption, kWh	13,709,400		
Average Heating Demand, MMBtu/hr	8.42	CHP system sized to heat	
Annual Heating Demand, MMBtu	52,541		
Average Cooling Demand, Tons	394		
Average Power Demand without Cooling, kW	1,329	CHP system sized not to	
Average Thermal Requirements for Cooling, MMBtu/hr	6.75	Thermal requirements for	
Average Thermal Requirements for Cooling, MMBtu/hr	#REF!	Thermal requirements for	
Annual Cooling Demand, Tons	992,880		
<b>Energy Costs</b>		<b>Base Case</b>	<b>CHP Case</b>
Boiler/Thermal Fuel Costs, \$/MMBtu	\$4.51		\$4.51
CHP Fuel Costs, \$MM/Btu			\$4.51
Average Electricity Costs, \$/kWh	0.069		
Cooling Electricity Costs, \$/kWh	\$0.069		
Percent Average per kWh Electric Cost Avoided			0%
Standby Rate, \$/kW			\$0.05
<b>Existing System</b>			
Displaced Thermal Efficiency, %	90.0%		
Existing Chiller Power Requirements, kWh/Ton	0.60		



DOE TAP CHP Qualification Screen			
<b>Gas Fueled CHP - Recip Engine, Microturbine, Fuel Cell or Gas Turbine Systems / natural gas, LFG, biogas with Heating</b>			
<i>Note: The results of this screening analysis use average values and assumptions and should not be utilized as an investment decision.</i>			
<b>Facility Information</b>			
Facility Name	NEOMED Campus		
Location (City, State)	Rootstown, Ohio		
Application	Laboratory/Higher Ed.		
<b>CHP System</b>		<b>CHP Cooling Single Effect</b>	
Net CHP Power, kW			1,696
CHP Electric Efficiency, % (HHV)			38.3%
CHP Thermal Output, Btu/kWh (Available Heating)			4,382
CHP Thermal Output, MMBtu/hr (Available Heating)			7.43
CHP Thermal Output, Btu/kWh (Available Cooling)			3,725
CHP Thermal Output, MMBtu/hr (Available Cooling)			6.32
CHP Power to Heat Ratio			0.78
CHP Availability, %			98%
Incremental O&M Costs for CHP, \$/kWh			\$0.019
Incremental O&M Costs for chiller, \$/Ton-Year			\$30.00
CHP Installed Costs, \$/kW (without chillers)			\$2,335
Thermal Utilization, %			90%
<b>CHP Cooling</b>			
Absorption Chiller COP			0.7
Absorption Chiller Capacity, Tons			332
Absorption Installed Costs, \$/Ton			\$1,350

DOE TAP CHP Qualification Screen		
<b>Gas Fueled CHP - Recip Engine, Microturbine, Fuel Cell or Gas Turbine Systems / natural gas, LFG, biogas with Heating</b>		
<i>Note: The results of this screening analysis use average values and assumptions and should not be utilized as an investment</i>		
<b>Annual Energy Consumption</b>	<b>Base Case</b>	<b>CHP Cooling Single Effect</b>
Purchased Electricity, kWh	13,709,400	-1,341,851
Generated Electricity, kWh	0	14,559,821
Annual Cooling Demand, Tons	992,880	992,880
Electric Cooling, Tons	992,880	173,830
Cooling Electricity, kWh	595,728	104,298
CHP Cooling, Tons	0	819,050
On-site Boiler/Heater Thermal Demand, MMBtu	52,541	11,637
Boiler/Heater Fuel, MMBtu	58,379	12,931
CHP Heating, MMBtu	0	40,903
CHP Fuel, MMBtu	0	129,810
Total Fuel, MMBtu	58,379	142,740
<b>Annual Operating Costs</b>		
Purchased Electricity, \$	\$945,949	-\$92,588
Standby Charges (Option 2), \$	\$0	\$1,018
On-site Boiler/Heater Fuel, \$	\$263,288	\$58,317
CHP Fuel, \$	\$0	\$585,441
Incremental O&M, \$	\$0	\$286,586
Total Operating Costs, \$	\$1,209,236	\$838,774
<b>Simple Payback</b>		
Annual Operating Savings, \$		\$370,463
Chiller Installed Costs, \$/kW		\$264
Total CHP System Costs, \$/kW (including chiller)		\$2,599
Total Installed Costs		\$4,407,892
Incentives		\$200,000
<b>Simple Payback, Years</b>		<b>11.4</b>
<b>Operating Costs to Generate, \$/kWh</b>		
Fuel Costs, \$/kWh		\$0.040
Cooling Credit, \$/kWh		\$0.000
Heating Credit, \$/kWh		(\$0.014)
Incremental O&M, \$/kWh		\$0.020
<b>Total Operating Costs to Generate, \$/kWh</b>		<b>\$0.046</b>

Option F: 3 GE Jenbacher J312 with trigeneration, absorption cooling sized to thermal output

DOE TAP CHP Qualification Screen			
<b>Gas Fueled CHP - Recip Engine, Microturbine, Fuel Cell or Gas Turbine Systems / natural gas, LFG, biogas with Heating</b>			
<i>Note: The results of this screening analysis use average values and assumptions and should not be utilized as an investment</i>			
<b>Facility Information</b>			
Facility Name	NEOMED Campus		
Location (City, State)	Rootstown, Ohio		
Application	Laboratory/Higher Ed.		
<b>Loads</b>			
Annual Hours of Operation	8,760		
Average Power Demand, kW	1,565	Average power demand	
Annual Hours of Cooling Demand	2,520	input	
Annual Hours of Heating Demand	6,240	determined by annual	
Annual Electricity Consumption, kWh	13,709,400		
Average Heating Demand, MMBtu/hr	8.42	CHP system sized to heat	
Annual Heating Demand, MMBtu	52,541		
Average Cooling Demand, Tons	394		
Average Power Demand without Cooling, kW	1,329	CHP system sized not to	
Average Thermal Requirements for Cooling, MMBtu/hr	6.75	Thermal requirements for	
Average Thermal Requirements for Cooling, MMBtu/hr	#REF!	Thermal requirements for	
Annual Cooling Demand, Tons	992,880		
<b>Energy Costs</b>		<b>Base Case</b>	<b>CHP Case</b>
Boiler/Thermal Fuel Costs, \$/MMBtu	\$4.51		\$4.51
CHP Fuel Costs, \$MM/Btu			\$4.51
Average Electricity Costs, \$/kWh	0.069		
Cooling Electricity Costs, \$/kWh	\$0.069		
Percent Average per kWh Electric Cost Avoided			0%
Standby Rate, \$/kW			\$0.05
<b>Existing System</b>			
Displaced Thermal Efficiency, %	90.0%		
Existing Chiller Power Requirements, kWh/Ton	0.60		

DOE TAP CHP Qualification Screen			
<b>Gas Fueled CHP - Recip Engine, Microturbine, Fuel Cell or Gas Turbine Systems / natural gas, LFG, biogas with Heating</b>			
<i>Note: The results of this screening analysis use average values and assumptions and should not be utilized as an investment decision.</i>			
<b>Facility Information</b>			
Facility Name	NEOMED Campus		
Location (City, State)	Rootstown, Ohio		
Application	Laboratory/Higher Ed.		
<b>CHP System</b>		<b>CHP Cooling Single Effect</b>	
Net CHP Power, kW			1,899
CHP Electric Efficiency, % (HHV)			38.1%
CHP Thermal Output, Btu/kWh (Available Heating)			4,387
CHP Thermal Output, MMBtu/hr (Available Heating)			8.33
CHP Thermal Output, Btu/kWh (Available Cooling)			3,729
CHP Thermal Output, MMBtu/hr (Available Cooling)			7.08
CHP Power to Heat Ratio			0.78
CHP Availability, %			98%
Incremental O&M Costs for CHP, \$/kWh			\$0.021
Incremental O&M Costs for chiller, \$/Ton-Year			\$30.00
CHP Installed Costs, \$/kW (without chillers)			\$2,737
Thermal Utilization, %			90%
<b>CHP Cooling</b>			
Absorption Chiller COP			0.7
Absorption Chiller Capacity, Tons			372
Absorption Installed Costs, \$/Ton			\$1,350

DOE TAP CHP Qualification Screen		
<b>Gas Fueled CHP - Recip Engine, Microturbine, Fuel Cell or Gas Turbine Systems / natural gas, LFG, biogas with Heating</b>		
<i>Note: The results of this screening analysis use average values and assumptions and should not be utilized as an investment</i>		
<b>Annual Energy Consumption</b>	<b>Base Case</b>	<b>CHP Cooling Single Effect</b>
Purchased Electricity, kWh	13,709,400	-3,144,010
Generated Electricity, kWh	0	16,302,535
Annual Cooling Demand, Tons	992,880	992,880
Electric Cooling, Tons	992,880	74,755
Cooling Electricity, kWh	595,728	44,853
CHP Cooling, Tons	0	918,125
On-site Boiler/Heater Thermal Demand, MMBtu	52,541	6,690
Boiler/Heater Fuel, MMBtu	58,379	7,433
CHP Heating, MMBtu	0	45,851
CHP Fuel, MMBtu	0	145,957
Total Fuel, MMBtu	58,379	153,390
<b>Annual Operating Costs</b>		
Purchased Electricity, \$	\$945,949	-\$216,937
Standby Charges (Option 2), \$	\$0	\$1,139
On-site Boiler/Heater Fuel, \$	\$263,288	\$33,523
CHP Fuel, \$	\$0	\$658,267
Incremental O&M, \$	\$0	\$353,506
Total Operating Costs, \$	\$1,209,236	\$829,498
<b>Simple Payback</b>		
Annual Operating Savings, \$		\$379,738
Chiller Installed Costs, \$/kW		\$264
Total CHP System Costs, \$/kW (including chiller)		\$3,001
Total Installed Costs		\$5,699,454
Incentives		\$200,000
<b>Simple Payback, Years</b>		<b>14.5</b>
<b>Operating Costs to Generate, \$/kWh</b>		
Fuel Costs, \$/kWh		\$0.040
Cooling Credit, \$/kWh		\$0.000
Heating Credit, \$/kWh		(\$0.014)
Incremental O&M, \$/kWh		\$0.022
<b>Total Operating Costs to Generate, \$/kWh</b>		<b>\$0.048</b>

Option G: 1 GE Jenbacher J420 with trigeneration, full load absorption cooling with boiler makeup

DOE TAP CHP Qualification Screen			
<b>Gas Fueled CHP - Recip Engine, Microturbine, Fuel Cell or Gas Turbine Systems / natural gas, LFG, biogas with Heating</b>			
<i>Note: The results of this screening analysis use average values and assumptions and should not be utilized as an investment decision.</i>			
<b>Facility Information</b>			
Facility Name	NEOMED Campus		
Location (City, State)	Rootstown, Ohio		
Application	Laboratory/Higher Ed.		
<b>Loads</b>			
Annual Hours of Operation	8,760		
Average Power Demand, kW	1,565	Average power demand	
Annual Hours of Cooling Demand	2,520	input	
Annual Hours of Heating Demand	6,240	determined by annual	
Annual Electricity Consumption, kWh	13,709,400		
Average Heating Demand, MMBtu/hr	8.42	CHP system sized to heat	
Annual Heating Demand, MMBtu	52,541		
Average Cooling Demand, Tons	394	2014 cooling	
Average Power Demand without Cooling, kW	1,329	CHP system sized not to	
Average Thermal Requirements for Cooling, MMBtu/hr	6.75	Thermal requirements for	
Average Thermal Requirements for Cooling, MMBtu/hr	#REF!	Thermal requirements for	
Annual Cooling Demand, Tons	992,880		
<b>Energy Costs</b>		<b>Base Case</b>	<b>CHP Case</b>
Boiler/Thermal Fuel Costs, \$/MMBtu	\$4.51		\$4.51
CHP Fuel Costs, \$MM/Btu			\$4.51
Average Electricity Costs, \$/kWh	0.069		
Cooling Electricity Costs, \$/kWh	\$0.069		
Percent Average per kWh Electric Cost Avoided			0%
Standby Rate, \$/kW			\$0.05
<b>Existing System</b>			
Displaced Thermal Efficiency, %	90.0%		
Existing Chiller Power Requirements, kWh/Ton	0.60		

DOE TAP CHP Qualification Screen			
<b>Gas Fueled CHP - Recip Engine, Microturbine, Fuel Cell or Gas Turbine Systems / natural gas, LFG, biogas with Heating</b>			
<i>Note: The results of this screening analysis use average values and assumptions and should not be utilized as an investment</i>			
<b>Facility Information</b>			
Facility Name	NEOMED Campus		
Location (City, State)	Rootstown, Ohio		
Application	Laboratory/Higher Ed.		
<b>CHP System</b>		<b>CHP Cooling Single Effect</b>	
Net CHP Power, kW			1,426
CHP Electric Efficiency, % (HHV)			40.8%
CHP Thermal Output, Btu/kWh (Available Heating)			3,852
CHP Thermal Output, MMBtu/hr (Available Heating)			5.49
CHP Thermal Output, Btu/kWh (Available Cooling)			3,274
CHP Thermal Output, MMBtu/hr (Available Cooling)			4.67
CHP Power to Heat Ratio			0.89
CHP Availability, %			98%
Incremental O&M Costs for CHP, \$/kWh			\$0.019
Incremental O&M Costs for chiller, \$/Ton-Year			\$30.00
CHP Installed Costs, \$/kW (without chillers)			\$2,335
Thermal Utilization, %			90%
<b>CHP Cooling</b>			
Absorption Chiller COP			0.7
Absorption Chiller Capacity, Tons			245
Absorption Installed Costs, \$/Ton			\$1,720
tons made up by boiler			154
MMBTU/hr			1.85

DOE TAP CHP Qualification Screen		
<b>Gas Fueled CHP - Recip Engine, Microturbine, Fuel Cell or Gas Turbine Systems / natural gas, LFG, biogas with Heating</b>		
<i>Note: The results of this screening analysis use average values and assumptions and should not be utilized as an investment</i>		
<b>Annual Energy Consumption</b>	<b>Base Case</b>	<b>CHP Cooling Single Effect</b>
Purchased Electricity, kWh	13,709,400	871,747
Generated Electricity, kWh	0	12,241,925
Annual Cooling Demand, Tons	992,880	992,880
Electric Cooling, Tons	992,880	0
Cooling Electricity, kWh	595,728	0
CHP Cooling, Tons	0	992,880
On-site Boiler/Heater Thermal Demand, MMBtu	52,541	26,959
Boiler/Heater Fuel, MMBtu	58,379	29,955
CHP Heating, MMBtu	0	30,232
CHP Fuel, MMBtu	0	102,326
Total Fuel, MMBtu	58,379	132,281
<b>Annual Operating Costs</b>		
Purchased Electricity, \$	\$945,949	\$60,151
Standby Charges (Option 2), \$	\$0	\$856
On-site Boiler/Heater Fuel, \$	\$263,288	\$135,096
CHP Fuel, \$	\$0	\$461,490
Incremental O&M, \$	\$0	\$239,950
Total Operating Costs, \$	\$1,209,236	\$897,543
<b>Simple Payback</b>		
Annual Operating Savings, \$		\$311,694
Chiller Installed Costs, \$/kW		\$296
Total CHP System Costs, \$/kW (including chiller)		\$2,631
Total Installed Costs		\$3,751,325
Incentives		\$200,000
<b>Simple Payback, Years</b>		<b>11.4</b>
<b>Operating Costs to Generate, \$/kWh</b>		
Fuel Costs, \$/kWh		\$0.038
Cooling Credit, \$/kWh		\$0.000
Heating Credit, \$/kWh		(\$0.010)
Incremental O&M, \$/kWh		\$0.020
<b>Total Operating Costs to Generate, \$/kWh</b>		<b>\$0.047</b>



Option H: 2 GE Jenbacher J316 with trigeneration, full load absorption cooling with boiler makeup

DOE TAP CHP Qualification Screen			
<b>Gas Fueled CHP - Recip Engine, Microturbine, Fuel Cell or Gas Turbine Systems / natural gas, LFG, biogas with Heating</b>			
<i>Note: The results of this screening analysis use average values and assumptions and should not be utilized as an investment decision.</i>			
<b>Facility Information</b>			
Facility Name	NEOMED Campus		
Location (City, State)	Rootstown, Ohio		
Application	Laboratory/Higher Ed.		
<b>Loads</b>			
Annual Hours of Operation	8,760		
Average Power Demand, kW	1,565	Average power demand	
Annual Hours of Cooling Demand	2,520	input	
Annual Hours of Heating Demand	6,240	determined by annual	
Annual Electricity Consumption, kWh	13,709,400		
Average Heating Demand, MMBtu/hr	8.42	CHP system sized to heat	
Annual Heating Demand, MMBtu	52,541		
Average Cooling Demand, Tons	394		
Average Power Demand without Cooling, kW	1,329	CHP system sized not to	
Average Thermal Requirements for Cooling, MMBtu/hr	6.75	Thermal requirements for	
Average Thermal Requirements for Cooling, MMBtu/hr	#REF!	Thermal requirements for	
Annual Cooling Demand, Tons	992,880		
<b>Energy Costs</b>		<b>Base Case</b>	<b>CHP Case</b>
Boiler/Thermal Fuel Costs, \$/MMBtu	\$4.51		\$4.51
CHP Fuel Costs, \$MM/Btu			\$4.51
Average Electricity Costs, \$/kWh	0.069		
Cooling Electricity Costs, \$/kWh	\$0.069		
Percent Average per kWh Electric Cost Avoided			0%
Standby Rate, \$/kW			\$0.05
<b>Existing System</b>			
Displaced Thermal Efficiency, %	90.0%		
Existing Chiller Power Requirements, kWh/Ton	0.60		

DOE TAP CHP Qualification Screen			
<b>Gas Fueled CHP - Recip Engine, Microturbine, Fuel Cell or Gas Turbine Systems / natural gas, LFG, biogas with Heating</b>			
<i>Note: The results of this screening analysis use average values and assumptions and should not be utilized as an investment</i>			
<b>Facility Information</b>			
Facility Name	NEOMED Campus		
Location (City, State)	Rootstown, Ohio		
Application	Laboratory/Higher Ed.		
<b>CHP System</b>		<b>CHP Cooling Single Effect</b>	
Net CHP Power, kW			1,696
CHP Electric Efficiency, % (HHV)			38.3%
CHP Thermal Output, Btu/kWh (Available Heating)			4,382
CHP Thermal Output, MMBtu/hr (Available Heating)			7.43
CHP Thermal Output, Btu/kWh (Available Cooling)			3,725
CHP Thermal Output, MMBtu/hr (Available Cooling)			6.32
CHP Power to Heat Ratio			0.78
CHP Availability, %			98%
Incremental O&M Costs for CHP, \$/kWh			\$0.019
Incremental O&M Costs for chiller, \$/Ton-Year			\$30.00
CHP Installed Costs, \$/kW (without chillers)			\$2,335
Thermal Utilization, %			90%
<b>CHP Cooling</b>			
Absorption Chiller COP			0.7
Absorption Chiller Capacity, Tons			332
Absorption Installed Costs, \$/Ton			\$1,350
tons made up by boiler			69
MMBTU/hr			0.83

DOE TAP CHP Qualification Screen		
<b>Gas Fueled CHP - Recip Engine, Microturbine, Fuel Cell or Gas Turbine Systems / natural gas, LFG, biogas with Heating</b>		
<i>Note: The results of this screening analysis use average values and assumptions and should not be utilized as an investment</i>		
<b>Annual Energy Consumption</b>	<b>Base Case</b>	<b>CHP Cooling Single Effect</b>
Purchased Electricity, kWh	13,709,400	-1,446,149
Generated Electricity, kWh	0	14,559,821
Annual Cooling Demand, Tons	992,880	992,880
Electric Cooling, Tons	992,880	0
Cooling Electricity, kWh	595,728	0
CHP Cooling, Tons	0	992,880
On-site Boiler/Heater Thermal Demand, MMBtu	52,541	13,723
Boiler/Heater Fuel, MMBtu	58,379	15,248
CHP Heating, MMBtu	0	40,903
CHP Fuel, MMBtu	0	129,810
Total Fuel, MMBtu	58,379	145,058
<b>Annual Operating Costs</b>		
Purchased Electricity, \$	\$945,949	-\$99,784
Standby Charges (Option 2), \$	\$0	\$1,018
On-site Boiler/Heater Fuel, \$	\$263,288	\$68,770
CHP Fuel, \$	\$0	\$585,441
Incremental O&M, \$	\$0	\$286,586
Total Operating Costs, \$	\$1,209,236	\$842,030
<b>Simple Payback</b>		
Annual Operating Savings, \$		\$367,206
Chiller Installed Costs, \$/kW		\$264
Total CHP System Costs, \$/kW (including chiller)		\$2,599
Total Installed Costs		\$4,407,892
Incentives		\$200,000
<b>Simple Payback, Years</b>		<b>11.5</b>
<b>Operating Costs to Generate, \$/kWh</b>		
Fuel Costs, \$/kWh		\$0.040
Cooling Credit, \$/kWh		\$0.000
Heating Credit, \$/kWh		(\$0.013)
Incremental O&M, \$/kWh		\$0.020
<b>Total Operating Costs to Generate, \$/kWh</b>		<b>\$0.047</b>

Option I: 3 GE Jenbacher J312 with trigeneration, full load absorption cooling with boiler makeup

DOE TAP CHP Qualification Screen			
<b>Gas Fueled CHP - Recip Engine, Microturbine, Fuel Cell or Gas Turbine Systems / natural gas, LFG, biogas with Heating</b>			
<i>Note: The results of this screening analysis use average values and assumptions and should not be utilized as an investment decision.</i>			
<b>Facility Information</b>			
Facility Name	NEOMED Campus		
Location (City, State)	Rootstown, Ohio		
Application	Laboratory/Higher Ed.		
<b>Loads</b>			
Annual Hours of Operation	8,760		
Average Power Demand, kW	1,565	Average power demand	
Annual Hours of Cooling Demand	2,520	input	
Annual Hours of Heating Demand	6,240	determined by annual	
Annual Electricity Consumption, kWh	13,709,400		
Average Heating Demand, MMBtu/hr	8.42	CHP system sized to heat	
Annual Heating Demand, MMBtu	52,541		
Average Cooling Demand, Tons	394		
Average Power Demand without Cooling, kW	1,329	CHP system sized not to	
Average Thermal Requirements for Cooling, MMBtu/hr	6.75	Thermal requirements for	
Average Thermal Requirements for Cooling, MMBtu/hr	#REF!	Thermal requirements for	
Annual Cooling Demand, Tons	992,880		
<b>Energy Costs</b>		<b>Base Case</b>	<b>CHP Case</b>
Boiler/Thermal Fuel Costs, \$/MMBtu	\$4.51		\$4.51
CHP Fuel Costs, \$MM/Btu			\$4.51
Average Electricity Costs, \$/kWh	0.069		
Cooling Electricity Costs, \$/kWh	\$0.069		
Percent Average per kWh Electric Cost Avoided			0%
Standby Rate, \$/kW			\$0.05
<b>Existing System</b>			
Displaced Thermal Efficiency, %	90.0%		
Existing Chiller Power Requirements, kWh/Ton	0.60		

DOE TAP CHP Qualification Screen			
<b>Gas Fueled CHP - Recip Engine, Microturbine, Fuel Cell or Gas Turbine Systems / natural gas, LFG, biogas with Heating</b>			
<i>Note: The results of this screening analysis use average values and assumptions and should not be utilized as an investment decision.</i>			
<b>Facility Information</b>			
Facility Name	NEOMED Campus		
Location (City, State)	Rootstown, Ohio		
Application	Laboratory/Higher Ed.		
<b>CHP System</b>		<b>CHP Cooling Single Effect</b>	
Net CHP Power, kW			1,899
CHP Electric Efficiency, % (HHV)			38.1%
CHP Thermal Output, Btu/kWh (Available Heating)			4,387
CHP Thermal Output, MMBtu/hr (Available Heating)			8.33
CHP Thermal Output, Btu/kWh (Available Cooling)			3,729
CHP Thermal Output, MMBtu/hr (Available Cooling)			7.08
CHP Power to Heat Ratio			0.78
CHP Availability, %			98%
Incremental O&M Costs for CHP, \$/kWh			\$0.021
Incremental O&M Costs for chiller, \$/Ton-Year			\$30.00
CHP Installed Costs, \$/kW (without chillers)			\$2,737
Thermal Utilization, %			90%
<b>CHP Cooling</b>			
Absorption Chiller COP			0.7
Absorption Chiller Capacity, Tons			372
Absorption Installed Costs, \$/Ton			\$1,350
tons made up by boiler			30
MMBTU/hr			0.36

DOE TAP CHP Qualification Screen		
<b>Gas Fueled CHP - Recip Engine, Microturbine, Fuel Cell or Gas Turbine Systems / natural gas, LFG, biogas with Heating</b>		
<i>Note: The results of this screening analysis use average values and assumptions and should not be utilized as an investment</i>		
<b>Annual Energy Consumption</b>	<b>Base Case</b>	<b>CHP Cooling Single Effect</b>
Purchased Electricity, kWh	13,709,400	-3,188,863
Generated Electricity, kWh	0	16,302,535
Annual Cooling Demand, Tons	992,880	992,880
Electric Cooling, Tons	992,880	0
Cooling Electricity, kWh	595,728	0
CHP Cooling, Tons	0	992,880
On-site Boiler/Heater Thermal Demand, MMBtu	52,541	7,587
Boiler/Heater Fuel, MMBtu	58,379	8,430
CHP Heating, MMBtu	0	45,851
CHP Fuel, MMBtu	0	145,957
Total Fuel, MMBtu	58,379	154,387
<b>Annual Operating Costs</b>		
Purchased Electricity, \$	\$945,949	-\$220,032
Standby Charges (Option 2), \$	\$0	\$1,139
On-site Boiler/Heater Fuel, \$	\$263,288	\$38,018
CHP Fuel, \$	\$0	\$658,267
Incremental O&M, \$	\$0	\$353,506
Total Operating Costs, \$	\$1,209,236	\$830,899
<b>Simple Payback</b>		
Annual Operating Savings, \$		\$378,338
Chiller Installed Costs, \$/kW		\$264
Total CHP System Costs, \$/kW (including chiller)		\$3,001
Total Installed Costs		\$5,699,454
Incentives		\$200,000
<b>Simple Payback, Years</b>		<b>14.5</b>
<b>Operating Costs to Generate, \$/kWh</b>		
Fuel Costs, \$/kWh		\$0.040
Cooling Credit, \$/kWh		\$0.000
Heating Credit, \$/kWh		(\$0.014)
Incremental O&M, \$/kWh		\$0.022
<b>Total Operating Costs to Generate, \$/kWh</b>		<b>\$0.048</b>



Appendix F: Sensitivity Study




<b>Option A</b>		<b>Electric Price</b>	<b>Payback Period</b>
		Current .069\$/kWH	8.4
		\$0.074	7.3
		\$0.077	6.6
		\$0.081	6.1
		\$0.084	5.6
		\$0.088	5.2
		\$0.091	4.9
		\$0.095	4.6
		\$0.098	4.3
		<b>Gas Price</b>	<b>Payback Period</b>
		Current \$4.51/MMBtu	8.4
		\$4.28	8.1
		\$4.05	7.9
		\$3.83	7.6
		\$3.60	7.4
		\$3.38	7.2
		\$3.15	7.0
		\$2.93	6.9
		\$2.70	6.7
<b>electric increase/gas decrease</b>	<b>Electric Price</b>	<b>Gas Price</b>	<b>Payback Period</b>
0	Current .069\$/kWH	Current \$4.51/MMBtu	8.4
5%	\$0.074	\$4.28	7.0
10%	\$0.077	\$4.05	6.3
15%	\$0.081	\$3.83	5.6
20%	\$0.084	\$3.60	5.2
25%	\$0.088	\$3.38	4.7
30%	\$0.091	\$3.15	4.4
35%	\$0.095	\$2.93	4.0
40%	\$0.098	\$2.70	3.8




<b>Option B</b>		<b>Electric Price</b>	<b>Payback Period</b>
		Current .069\$/kWH	10.5
		\$0.074	8.6
		\$0.077	7.8
		\$0.081	7.0
		\$0.084	6.4
		\$0.088	5.9
		\$0.091	5.5
		\$0.095	5.1
		\$0.098	4.8
		<b>Gas Price</b>	<b>Payback Period</b>
		Current \$4.51/MMBtu	10.5
		\$4.28	9.8
		\$4.05	9.3
		\$3.83	9.0
		\$3.60	8.6
		\$3.38	8.2
		\$3.15	7.9
		\$2.93	7.6
		\$2.70	7.4
<b>electric increase/gas decrease</b>	<b>Electric Price</b>	<b>Gas Price</b>	<b>Payback Period</b>
0	Current .069\$/kWH	Current \$4.51/MMBtu	10.5
5%	\$0.074	\$4.28	8.2
10%	\$0.077	\$4.05	7.2
15%	\$0.081	\$3.83	6.3
20%	\$0.084	\$3.60	5.7
25%	\$0.088	\$3.38	5.1
30%	\$0.091	\$3.15	4.7
35%	\$0.095	\$2.93	4.3
40%	\$0.098	\$2.70	4.0

Appendix G: Emissions Calculations

Option A



Documentation

**1. CHP: Type of System**

Recip Engine - Lean Burn

**2. CHP: Electricity Generating Capacity (per unit)**

Normal size range for this technology is 500 to 5,000 kW

1,426 kW

**3. CHP: How Many Identical Units (i.e., engines) Does This System Have?**

1

**4. CHP: How Many Hours per Year Does the CHP System Operate?**

7 days per week, 24 hours per day, 8,760 hours

As a number of hours per year

OR As a percentage

**5. CHP: Does the System Provide Heating or Cooling or Both?**

Heating Only

If Heating and Cooling: How many of the 8,760 hours are in cooling mode?

As a number of hours per year

as a percentage of the 8,760 hours?

If Heating and Cooling: Does the System Provide Simultaneous Heating and Cooling?

No

**6. CHP: Fuel**

Fuel Type

View Biomass and Coal Fuel Characteristics

**7. CHP: If Diesel, Distillate, Coal or Other: What is the Sulfur Content?**

If WHP, what is the sulfur content of the stack?

I will enter a value in one of the following blocks

or

High sulfur oil: 0.15% or 1,500

Low sulfur oil: 0.05% or 500

Ultra low sulfur diesel: 15 ppm

Enter Sulfur Content of Fuel as a percent

OR ppm  ppm

**8. CHP: What is the CO<sub>2</sub> Emission Rate for this Fuel? (default completed for fuel in Item 6)**

Enter alternative value:  lb CO<sub>2</sub>/MMBtu

**9. CHP: What is the Heat Content of this Fuel? (Enter a value in only ONE of the boxes)** Submit

	1,028	Btu/cubic foot (HHV)
OR	-	Btu/gallon (HHV)
OR	-	Btu/lb (HHV)

**10. CHP: Boiler Steam To Process (Steam Turbine CHP Only)**

Boiler Steam to Process as lb Steam/hr	0	Submit
Boiler Steam to Process as MMBtu Steam/hr	0	

**11. CHP: Steam Turbine System Boiler Efficiency (Steam Turbine CHP Only)**

I will enter an efficiency
Use default for this technology

Enter Boiler Efficiency as %  Submit

**12. CHP: Electric Efficiency**

I will enter an efficiency in **one** of the following blocks
Use default for this technology

Enter Generating Efficiency as %  (HHV) Submit

OR Enter Generating Efficiency as Btu/kWh HHV  Btu/kWh (HHV)

OR Enter Generating Efficiency as Btu/kWh LHV  Btu/kWh (LHV)

**13. CHP: Base Power to Heat Ratio**

The Power to Heat Ratio should reflect ONLY the thermal production of the generating unit (i.e., combustion turbine). Thermal Output of the duct burners (if equipped) should not be included.

I will enter a Power to Heat
Use default for this technology

Power to Heat Ratio  Submit

If WHP: Useful Thermal Output (MMBtu/hr)

**14. CHP: NOx Emission Rate**

I will enter a NOx rate in **one** of the following blocks

Use default emissions for this technology.  
 Note: Default emissions are without aftertreatment. Some areas may require add-on controls and you will need to enter an emission rate based on your local requirements. SCR can reduce emissions by up to 90%

	Enter a NOx Rate as ppm (15% O <sub>2</sub> )	-	ppm
OR	Enter a NOx Rate as gm/hp-hr	1.100	gm/hp-hr
OR	Enter a NOx Rate as lb/MMBtu	-	lb NOx/MMBtu
OR	Enter a NOx Rate as lb/MWh	-	lb NOx/MWh

Submit

**15. Duct Burners: Does the System Incorporate Duct Burners?** Submit  
 ▼

---

**16. Duct Burners: What is the Total Fuel Input Capacity of the Burners for Each CHP Unit?** Submit  
 For reference, the Recip Engine - Lean Burn has a heat input of 11.9 MMBtu/hr  
 MMBtu/hr

---

**17. Duct Burners: The CHP system operates 8,760 hours per year. How much do the duct burners operate?** Submit  
 As a number of hours per year   
 As a percentage of the 8,760 hours?

---

**18. Duct Burners: NOx Emission Rate for the Duct Burners** Submit

lb/MMBtu  
 OR  ppm NOx at 15% O2

---

**19. Cooling: Does the CHP Provide Cooling?** No Submit  
 You indicated No Cooling in Item 5

---

**20. Cooling: Type of Absorption Chiller Used?** Submit  
 ▼  
 Coefficient of Performance (COP)

---

**21. Cooling: What is the Cooling Capacity of the System?** Submit  
 Based on your other entries, the maximum cooling capacity is . tons or . MMBtu/hr of cooling

(Enter a value in only ONE of the boxes)  Cooling Tons  
 OR MMBtu per Hour of Cooling

---

**22. Displaced Cooling: What is the Efficiency of the Cooling System that is Being Displaced?** Submit  
 ▼

(Enter a value in only ONE of the boxes)  
 Electricity Demand (kW per ton)   
 OR Coefficient of Performance (COP)

**23. Displaced Thermal: Type of System:** Existing Gas Boiler

**24. Displaced Thermal: If not a Natural Gas System: What is the Sulfur Content?**

I will enter a  or

Enter Sulfur Content as a percent   ppm  ppm

**25. Displaced Thermal: What is the CO2 Emission Rate for this Fuel? (default completed for fuel in Item 23)**

Enter alternative value:  lb CO2/MMBtu

**26. Displaced Thermal: What is the Heat Content of this Fuel? (Enter a value in only ONE of the boxes)**

Btu/cubic foot (HHV)

OR  Btu/gallon (HHV)

OR  Btu/lb (HHV)

**27. Displaced Thermal: Efficiency (usually a boiler)**

I will enter an efficiency

Enter Generating Efficiency as %

**28. Displaced Thermal Production: NOx Emission Rate**

I will enter the NOx rate

NOx Rate  lb NOx/MMBtu

**29. Displaced Electricity: Generation Profile**

eGRID Fossil Fuel (2010 data)

[Link to EPA's Fuel and CO2 Emissions Savings Calculation Methodology for CHP](#)


**30. Displaced Electricity: Select U.S. Average, eGRID Subregion, NERC region, or State**

RFCW West

**31. Displaced Electricity: Select Electric Grid Region for Transmission and Distribution (T&D) Losses**

Eastern Interconnect

**CHP Results**



The results generated by the CHP Emissions Calculator are intended for educational and outreach purposes only; it is not designed for use in developing emission inventories or preparing air permit applications.

**The results of this analysis have not been reviewed or endorsed by the EPA CHP Partnership.**

**Table 1**

**Annual Emissions Analysis**

	CHP System	Displaced Electricity Production	Displaced Thermal Production	Emissions/Fuel Reduction	Percent Reduction
NO <sub>x</sub> (tons/year)	20.30	10.82	2.82	(6.66)	-49%
SO <sub>2</sub> (tons/year)	0.03	30.93	0.02	30.92	100%
CO <sub>2</sub> (tons/year)	6,105	14,337	3,293	11,525	65%
CH <sub>4</sub> (tons/year)	0.12	0.163	0.06	0.110	49%
N <sub>2</sub> O (tons/year)	0.01	0.231	0.01	0.225	95%
Total GHGs (CO <sub>2</sub> e tons/year)	6,111	14,412	3,296	11,597	65%
Fuel Consumption (MMBtu/year)	104,445	139,368	56,341	91,264	47%
Equal to the annual GHG emissions from this many passenger vehicles:				2,201	
Equal to the annual GHG emissions from the generation of electricity for this many homes:				1,439	

**This CHP project will avoid yearly emissions of greenhouse gases by 11,597 tons of carbon dioxide equivalent.**

**Equal to the annual greenhouse gas emissions from 2,201 passenger vehicles.**



**Equal to the annual greenhouse gas emissions from the generation of electricity used by 1,439 homes.**



Option B

Documentation

**1. CHP: Type of System**

Recip Engine - Lean Burn

**2. CHP: Electricity Generating Capacity (per unit)**

Normal size range for this technology is 500 to 5,000 kW

848 kW

**3. CHP: How Many Identical Units (i.e., engines) Does This System Have?**

2

**4. CHP: How Many Hours per Year Does the CHP System Operate?**

7 days per week, 24 hours per day, 8,760 hours

As a number of hours per year

OR As a percentage

**5. CHP: Does the System Provide Heating or Cooling or Both?**

Heating Only

If Heating and Cooling: How many of the 8,760 hours are in cooling mode?

As a number of hours per year

as a percentage of the 8,760 hours?

If Heating and Cooling: Does the System Provide Simultaneous Heating and Cooling?

No

**6. CHP: Fuel**

Fuel Type: Natural Gas

**7. CHP: If Diesel, Distillate, Coal or Other: What is the Sulfur Content?**

If WHP, what is the sulfur content of the stack?

I will enter a value in one of the following blocks

or

High sulfur oil: 0.15% or 1,500

Low sulfur oil: 0.05% or 500

Ultra low sulfur diesel: 15 ppm

Enter Sulfur Content of Fuel as a percent

OR ppm  ppm

**8. CHP: What is the CO<sub>2</sub> Emission Rate for this Fuel? (default completed for fuel in Item 6)**

Enter alternative value:  lb CO<sub>2</sub>/MMBtu

**9. CHP: What is the Heat Content of this Fuel? (Enter a value in only ONE of the boxes)**

	<input type="text" value="1,028"/>	Btu/cubic foot (HHV)
OR	<input type="text" value="-"/>	Btu/gallon (HHV)
OR	<input type="text" value="-"/>	Btu/lb (HHV)

Submit

**10. CHP: Boiler Steam To Process (Steam Turbine CHP Only)**

Boiler Steam to Process as lb Steam/hr	<input type="text" value="0"/>
Boiler Steam to Process as MMBtu Steam/hr	<input type="text" value="0"/>

Submit

**11. CHP: Steam Turbine System Boiler Efficiency (Steam Turbine CHP Only)**

Enter Boiler Efficiency as %

Submit

**12. CHP: Electric Efficiency**

Enter Generating Efficiency as %  (HHV)

OR Enter Generating Efficiency as Btu/kWh HHV  Btu/kWh (HHV)

OR Enter Generating Efficiency as Btu/kWh LHV  Btu/kWh (LHV)

Submit

**13. CHP: Base Power to Heat Ratio**

The Power to Heat Ratio should reflect ONLY the thermal production of the generating unit (i.e., combustion turbine). Thermal Output of the duct burners (if equipped) should not be included.

Power to Heat Ratio

If WHP: Useful Thermal Output (MMBtu/hr)

Submit

**14. CHP: NOx Emission Rate**

Note: Default emissions are without aftertreatment. Some areas may require add-on controls and you will need to enter an emission rate based on your local requirements. SCR can reduce emissions by up to 90%

Enter a NOx Rate as ppm (15% O<sub>2</sub>)  ppm

OR Enter a NOx Rate as gm/hp-hr  gm/hp-hr

OR Enter a NOx Rate as lb/MMBtu  lb NOx/MMBtu

OR Enter a NOx Rate as lb/MWh  lb NOx/MWh

Submit



**15. Duct Burners: Does the System Incorporate Duct Burners?** Submit

No

---

**16. Duct Burners: What is the Total Fuel Input Capacity of the Burners for Each CHP Unit?** Submit

For reference, the Recip Engine - Lean Burn has a heat input of 7.6 MMBtu/hr

MMBtu/hr

---

**17. Duct Burners: The CHP system operates 8,760 hours per year. How much do the duct burners operate?** Submit

As a number of hours per year

As a percentage of the 8,760 hours?  0%

---

**18. Duct Burners: NOx Emission Rate for the Duct Burners**

I will enter a NOx rate in **one** of the following blocks

Use default for this technology

Submit

OR  lb/MMBtu

OR  ppm NOx at 15% O2

---

**19. Cooling: Does the CHP Provide Cooling?** **No** Submit

You indicated No Cooling in Item 5

---

**20. Cooling: Type of Absorption Chiller Used?** Submit

Coefficient of Performance (COP)

---

**21. Cooling: What is the Cooling Capacity of the System?** Submit

Based on your other entries, the maximum cooling capacity is . tons or . MMBtu/hr of cooling

**(Enter a value in only ONE of the boxes)**

Cooling Tons

OR  MMBtu per Hour of Cooling

---

**22. Displaced Cooling: What is the Efficiency of the Cooling System that is Being Displaced?** Submit

**(Enter a value in only ONE of the boxes)**

Electricity Demand (kW per ton)

OR Coefficient of Performance (COP)

**23. Displaced Thermal: Type of System:** Existing Gas Boiler

**24. Displaced Thermal: If not a Natural Gas System: What is the Sulfur Content?**

I will enter a  or

Enter Sulfur Content as a percent  OR ppm  ppm

**25. Displaced Thermal: What is the CO2 Emission Rate for this Fuel? (default completed for fuel in Item 23)**

Enter alternative value:  lb CO2/MMBtu

**26. Displaced Thermal: What is the Heat Content of this Fuel? (Enter a value in only ONE of the boxes)**

OR  Btu/cubic foot (HHV)  
OR  Btu/gallon (HHV)  
OR  Btu/lb (HHV)

**27. Displaced Thermal: Efficiency (usually a boiler)**

I will enter an efficiency

Enter Generating Efficiency as %

**28. Displaced Thermal Production: NOx Emission Rate**

I will enter the NOx rate

NOx Rate  lb NOx/MMBtu

**29. Displaced Electricity: Generation Profile**

[Link to EPA's Fuel and CO2 Emissions Savings Calculation Methodology for CHP](#)

**30. Displaced Electricity: Select U.S. Average, eGRID Subregion, NERC region, or State**

[Link to eGRID Subregion Map](#)

**31. Displaced Electricity: Select Electric Grid Region for Transmission and Distribution (T&D) Losses**

[Link to NERC Interconnections Map](#)

**CHP Results**



The results generated by the CHP Emissions Calculator are intended for educational and outreach purposes only; it is not designed for use in developing emission inventories or preparing air permit applications.

**The results of this analysis have not been reviewed or endorsed by the EPA CHP Partnership.**

**Table 1**

Annual Emissions Analysis					
	CHP System	Displaced Electricity Production	Displaced Thermal Production	Emissions/Fuel Reduction	Percent Reduction
NO <sub>x</sub> (tons/year)	24.14	12.87	3.82	(7.45)	-45%
SO <sub>2</sub> (tons/year)	0.04	36.79	0.02	36.77	100%
CO <sub>2</sub> (tons/year)	7,744	17,051	4,469	13,776	64%
CH <sub>4</sub> (tons/year)	0.15	0.194	0.08	0.132	48%
N <sub>2</sub> O (tons/year)	0.01	0.274	0.01	0.268	95%
Total GHGs (CO <sub>2</sub> e tons/year)	7,752	17,141	4,473	13,862	64%
Fuel Consumption (MMBtu/year)	132,498	165,756	76,458	109,717	45%
Equal to the annual GHG emissions from this many passenger vehicles:				2,630	
Equal to the annual GHG emissions from the generation of electricity for this many homes:				1,720	

**This CHP project will avoid yearly emissions of greenhouse gases by 13,862 tons of carbon dioxide equivalent.**


Equal to the annual greenhouse gas emissions from 2,630 passenger vehicles.



Equal to the annual greenhouse gas emissions from the generation of electricity used by 1,720 homes.



Appendix H: Project Schedules  
Original Schedule



Start Date: 23MAY11  
Print Date: 03SEP12  
Run Date: 20DEC11 14:42

© Primavera Systems, Inc.


Legend:  
█ Early Bar  
█ Progress Bar  
█ Critical Activity

Sheet 1 of 9

The Ruhlman Company  
 NEOMED - Roodroom, CMU  
 Campus Renovation/Partial Project Schedule  
 [Layout LT-01, All Activities]


The Ruhlman Company  
 Since 1915













Activity ID	Activity Description	Orig Dur	Risk %	Early Start	Early Finish
CR-120	CONCR - FRIP Int Concrete Footers (Barrt) [RGE]	5	5	0 21MAY12	25MAY12
CR-140	CONCR - Cure Time Concrete Wall (Basement) [RGE]	5	5	0 24MAY12	31MAY12
CR-145	CONCR - Cure Time Concrete Int Foot (Barrt) [RGE]	5	5	0 29MAY12	04JUN12
CR-150	STEEL - Erect/Detail Steel Deck (Basement)[RGE]	10	10	0 01JUN12	14JUN12
CR-160	PLUMB - Install U/G Plumbing (Basement) [RGE]	10	10	0 15JUN12	28JUN12
CR-180	STEEL - Erect/Detail Steel & Deck (2&3F) [RGE]	10	10	0 15JUN12	28JUN12
CR-190	ELECT - Install U/G Electrical (Basement) [RGE]	5	5	0 29JUN12	06JUL12
CR-250	STEEL - Erect/Detail Steel & Deck (4F&5F) [RGE]	10	10	0 29JUN12	13JUL12
CR-299	MEP - Install MEP Box-outs in FloorDeck (2) [RGE]	5	5	0 29JUN12	06JUL12
CR-300	CONCR - FRIP Concrete SOG (Basement) [RGE]	10	10	0 06JUL12	20JUL12
CR-301	MEP - Install MEP Box-outs in FloorDeck (3) [RGE]	5	5	0 06JUL12	13JUL12
CR-303	MEP - Install MEP Box-outs in FloorDeck (4) [RGE]	5	5	0 16JUL12	20JUL12
CR-270	PLUMB - Install U/G Plumbing (1) [RGE]	10	10	0 16JUL12	27JUL12
CR-254	STEEL - Erect/Detail S/S ScreenWall(Floor) [RGE]	5	5	0 18JUL12	20JUL12
CR-210	CONCR - FRIP Concrete SOG (Over Basement) [RGE]	5	5	0 23JUL12	27JUL12
CR-305	MEP - Install MEP Box-outs in FloorDeck (R) [RGE]	5	5	0 23JUL12	27JUL12
CR-300	CONCR - FRIP Concrete SOG (2nd Floor) [RGE]	5	5	0 30JUL12	09AUG12
CR-510	MASON - Install Interior CMU Walls (B-4) [RGE]	60	60	0 30JUL12	22OCT12
CR-272	ELECT - Install U/G Electrical (1) [RGE]	5	5	0 30JUL12	09AUG12
CR-360	HVAC - Install HVAC Duct & Pipe R-4 (B) [RGE]	40	40	0 30JUL12	24SEP12
CR-212	WATERP - Install Waterproof & Drain Tile [RGE]	5	5	0 30JUL12	09AUG12
CR-302	CONCR - FRIP Concrete SOG (3rd Floor) [RGE]	5	5	0 06AUG12	10AUG12
CR-274	CONCR - FRIP Concrete SOG (1) [RGE]	5	5	0 06AUG12	10AUG12
CR-214	CONCR - Backfill Basement Walls [RGE]	5	5	0 06AUG12	10AUG12
CR-304	CONCR - FRIP Concrete SOG (4th Floor) [RGE]	5	5	0 13AUG12	17AUG12
CR-370	HVAC - Install HVAC Duct & Pipe R-4 (1-4) [RGE]	80	80	0 13AUG12	05DEC12
CR-362	PLUMB - Install Plumbing R-4 (B) [RGE]	40	40	0 13AUG12	09OCT12
CR-330	STEEL - Install Steel Stairs [RGE]	20	20	0 13AUG12	10SEP12
CR-710	GT - Install Exterior Metal Studs [RGE]	50	50	0 20AUG12	29OCT12
CR-306	CONCR - FRIP Concrete SOG (Roof) [RGE]	5	5	0 20AUG12	24AUG12
CR-372	PLUMB - Install Plumbing R-4 (1-4) [RGE]	75	75	0 27AUG12	12DEC12
CR-364	ELECT - Install Electrical R-4 (B) [RGE]	75	75	0 27AUG12	12DEC12
CR-306	HVAC - FRIP Concrete AHU Maint Pads (Roof)[RGE]	5	5	0 04SEP12	10SEP12
CR-720	GT - Install Ext Insulat/Moisture Barrier [RGE]	50	50	0 04SEP12	12NOV12
CR-310	HVAC - Lit, Set & Install AHUs (Roof) [RGE]	10	10	0 11SEP12	24SEP12
CR-374	ELECT - Install Electrical R-4 (1-4) [RGE]	50	50	0 11SEP12	19NOV12
CR-335	CONCR - Pour Concrete Stair Pans [RGE]	10	10	0 11SEP12	24SEP12
CR-620	GT - Install Metal Stud Walls (B-4) [RGE]	50	50	0 25SEP12	05DEC12
CR-336	HVAC - Lit & Set Exhaust Stacks (Roof) [RGE]	10	10	0 25SEP12	09OCT12
CR-4750	MASON - Install Ext Masonry Walls & Brick [RGE]	80	80	0 25SEP12	22JAN13
CR-740	MASON - Install Ext Brick Linels [RGE]	60	60	0 25SEP12	19DEC12
CR-376	SPRINK - Install Sprinkler R-4 (1-4) [RGE]	30	30	0 25SEP12	09NOV12
CR-366	SPRINK - Install Sprinkler R-4 (B) [RGE]	10	10	0 25SEP12	09OCT12
CR-790	GT - Install Ext Plywood & Roof Wood Block [RGE]	20	20	0 09OCT12	09NOV12
CR-540	PLUMB - Install In-Wall Plumbing R-4 (B-4) [RGE]	50	50	0 09OCT12	19DEC12
CR-500	ELECT - Install In-Wall Electric R-4 (1-4) [RGE]	50	50	0 09OCT12	19DEC12









Activity ID	Activity Description	Orig Dur	Rem %	Early Start	Early Finish
CC-EI-130	PLUMB - Install UG Plumbing R-I [CMU-BS]	4	0	23JAN13	28JAN13
CC-EI-140	ELECT - Install UG Electrical R-I [CMU-BS]	3	0	25JAN13	29JAN13
CC-EI-150	GT - FRIP Concrete Slab on Grade [CMU-BS]	5	0	30JAN13	09FEB13
CC-EI-160	HVAC - Install HVAC R-I (OH) [CMU-BS]	3	0	06FEB13	09FEB13
CC-EI-170	PLUMB - Install Plumbing R-I (OH) [CMU-BS]	3	0	08FEB13	12FEB13
CC-EI-180	ELECT - Install Electrical R-I (OH) [CMU-BS]	3	0	11FEB13	13FEB13
CC-EI-190	SPRINK - Install Sprinkler R-I (OH) [CMU-BS]	1	0	12FEB13	12FEB13
CC-EI-200	GT - Install Interior Metal Wall Studs [CMU-BS]	5	0	14FEB13	20FEB13
CC-EI-210	PLUMB - Install Plumbing R-I (In-Wall) [CMU-BS]	5	0	21FEB13	27FEB13
CC-EI-220	ELECT - Install Electric R-I (In-Wall) [CMU-BS]	5	0	21FEB13	27FEB13
CC-EI-230	GT - Hang & Finish Drywall Walls [CMU-BS]	5	0	28FEB13	06MAR13
CC-EI-240	PAINT - Paint Walls (Primer Coat) [CMU-BS]	5	0	07MAR13	13MAR13
CC-EI-250	GT - Install Acoustical Ceiling Grid [CMU-BS]	5	0	14MAR13	20MAR13
CC-EI-260	ELECT - Install Light Fixtures [CMU-AA]	2	0	21MAR13	22MAR13
CC-EI-270	HVAC - Install HVAC Diffusers [CMU-AA]	2	0	25MAR13	26MAR13
CC-EI-280	SPRINK - Install Sprinkler Heads [CMU-AA]	1	0	27MAR13	27MAR13
CC-EI-290	GT - Install Acoustical Ceiling Tiles [CMU-BS]	5	0	28MAR13	03APR13
CC-EI-300	PAINT - Paint Walls, Etc. (Final Coat) [CMU-BS]	5	0	04APR13	10APR13
CC-EI-310	FLOOR - Install Flooring [CMU-BS]	5	0	11APR13	17APR13
CC-EI-320	GT - Install Casework [CMU-BS]	5	0	18APR13	24APR13
CC-EI-330	GT - Install Doors & Hardware [CMU-BS]	5	0	18APR13	24APR13
CC-EI-340	PLUMB - Install Plumbing Fixtures [CMU-BS]	2	0	25APR13	26APR13
CC-EI-350	ELECT - Install Electrical Devices [CMU-BS]	2	0	25APR13	26APR13
CC-EI-360	ALL - Substantial Completion [CMU-BS]	0	0	0	26APR13
CC-EI-370	ALL - Start-up Systems & Training [CMU-BS]	5	0	29APR13	03MAY13
CC-EI-380	ALL - Complete Punchlist Items [CMU-BS]	5	0	05MAY13	10MAY13
CC-EI-390	HVAC - Balance & Commission HVAC System [CMU-BS]	5	0	13MAY13	17MAY13
CC-EI-400	ALL - Construction Complete [CMU-BS]	0	0	0	17MAY13
CC-EI-410	OWNER - Move-In [CMU-BS]	5	0	20MAY13	24MAY13
<b>Existing CMU - Inter Work (Electrical Upgrades)</b>					
CC-EI-710	ELECT - Install Electric Feeders & Panels [CMU-EU]	15	15	30JAN13	18FEB13
CC-EI-720	ELECT - Rerouted Existing Electric Panels [CMU-EU]	15	15	20FEB13	12MAR13
<b>New CMU Mechanical Building</b>					
CC-NE-900	ALL - Construct New CMU Mechanical Building	40	40	22JUN12	17AUG12
<b>Existing CMU MEP &amp; Boiler House Upgrades</b>					
CU-BH-900	PLUMB - Install Existing CMU Boiler House Upgrades	40	40	22JUN12	17AUG12
<b>Central Mechanical Room</b>					
CU-MR-300	ALL - Construct Central Mechanical Room	40	40	22JUN12	17AUG12
<b>Existing Building D Renovation</b>					
CD-010	SAO & NEOMED - Authorization of Funds Building D	0	0	0	04APR12
CD-020	NEOMED - Move Staff to New RGE Building	10	10	05JUN13	14JUN13
CD-100	ALL - Renovate Existing Building D [D]	55	55	17JUN13	03SEP13
<b>Alternate Bridge (RGE Building to CMU Building)</b>					
CB-100	ALL - Construct Alternate Bridge [BRIDGE]	100	100	06OCT12	05MAR13



















RS07-8 FOR RUHLIN / OWNER / OFCC REVIEW		NEOMED		Revised Baseline for July 15, 2013 Owner Move-In		RS07-8 Printed 27-May-13 09:08											
Activity ID	Task Description	Orig Dur	Rem Dur	Start	Finish	Total Float	May	June	July	August	September	October	Nov	Dec			
<b>Alternate Bridge (RGE Building to CMU Building)</b>																	
CB-190	CONC - Pour Edge Foundation (All Bridge)	5	5	02-Jun-13	02-Sep-13	-5											
CB-191	CONC - Pour Bridge Foundation (All Bridge)	5	5	02-Jun-13	02-Sep-13	-5											
CB-192	STEEL - Install Structural Steel (All Bridge)	5	5	02-Jun-13	07-Jun-13	-5											
CB-200	CONC - Install Concrete Slab on Deck (All Bridge)	5	5	16-Jun-13	14-Jun-13	-5											
CB-193	GLASS - Install Window Framing & Glazing	17	17	24-Jun-13	21-Jun-13	-5											
CB-110	GLASS - Exterior Metal Studs (All Bridge)	5	5	16-Jul-13	24-Jul-13	-5											
CB-115	GLASS - Install Exterior Metal Studs (All Bridge)	12	12	16-Jul-13	02-Aug-13	-2											
CB-118	WLSGLG - Install Metal Studs (All Bridge)	3	3	25-Jul-13	26-Jul-13	-3											
CB-120	ROOF - Install Rubber Roofing (All Bridge)	5	5	25-Jul-13	31-Jul-13	-3											
CB-108	ELEC - Electrical Rough-In, ALL (All Bridge)	5	5	26-Jul-13	05-Aug-13	-3											
CB-106	WELP - HVAC Rough-In, ALL (All Bridge)	5	5	26-Jul-13	05-Aug-13	-3											
CB-105	WELP - HVAC Rough-In, ALL (All Bridge)	5	5	07-Aug-13	07-Aug-13	-5											
CB-140	WLSGLG - Hang / Finish Drywall (All Bridge)	8	8	08-Aug-13	19-Aug-13	-5											
CB-111	WLSGLG - Hanging / Finish Drywall (All Bridge)	2	2	20-Aug-13	21-Aug-13	-5											
CB-119	WLSGLG - Install Ceiling Grid (All Bridge)	4	4	22-Aug-13	27-Aug-13	-5											
CB-115	ELEC - Install Light Fixtures (All Bridge)	5	5	22-Aug-13	04-Sep-13	-5											
CB-128	FLOOR - Install Rubber Flooring Mem	3	3	05-Sep-13	05-Sep-13	-5											
CB-129	WLSGLG - Install Ceiling Grid (All Bridge)	3	3	05-Sep-13	05-Sep-13	-5											
<b>Site Electrical Loop - East</b>																	
LOOP-100	"1 DELAY" ELEC - Electric Loop Relocation, East Campus	99	9	14-Jan-13 A	31-May-13	64											
LOOP-101	"1 DELAY" ELEC - Electric Loop Relocation, East Campus	99	9	14-Jan-13 A	31-May-13	64											
LOOP-102	ELEC - Excavate / Install Conduit 18x11 to road	2	2	20-May-13	20-May-13	-16											
LOOP-103	ELEC - Pull Wire New 20x7 to 18x7, Call	2	2	20-May-13	21-May-13	-21											
LOOP-104	ELEC - Pull Wire New 20x7 to 18x7, Call	2	2	20-May-13	21-May-13	-21											
LOOP-105	ELEC - Pull Wire 18x4 to 18x4	2	2	20-May-13	21-May-13	-24											
LOOP-106	ELEC - Pull Wire 18x4 to 18x4	2	2	20-May-13	21-May-13	-24											
LOOP-107	ELEC - Pull Wire 18x2 to 18x2, S&A	1	1	24-May-13	24-May-13	-26											
LOOP-108	ELEC - New Wire at 20x7, S&A	1	1	24-May-13	24-May-13	-26											
LOOP-109	ELEC - Excavate / Install Conduit New, Mainroom	5	5	24-May-13	31-May-13	-26											
LOOP-110	ELEC - Excavate / Install Conduit New, Mainroom	5	5	24-May-13	31-May-13	-26											
LOOP-111	ELEC - Terminate 20x7, S&A, E&R&E&E	1	1	28-May-13	24-May-13	-27											
LOOP-112	ELEC - Terminate 20x7, S&A, E&R&E&E	1	1	28-May-13	24-May-13	-27											
<b>Cooling Tower Replacement</b>																	
CTWR-100	BP22 - Cooling Tower Replacement Work	99	24	14-Jan-13 A	21-Jan-13	-15											
CTWR-101	BP22 - Start-Up New Tower #2 [CTWR]	99	24	14-Jan-13 A	21-Jan-13	-15											
CTWR-102	BP22 - Start-Up New Tower #1 [CTWR]	5	4	28-May-13 A	23-May-13	0											
CTWR-103	BP22 - Punch List / Close-Out [CTWR]	5	5	24-May-13	31-May-13	0											

Actual Work Remaining Work Milestone

Page 8 of 8 TASK filters: NEO Not Complete, NEO Omit

© Primavera Systems, Inc.