



Image © <www.neomed.edu>

NEOMED Research and Graduate Education Building + Comparative Medical Unit Expansion

the Northeast Ohio Medical University Campus
Rootstown, Ohio



Image © <www.crystaldiagnosics.com>

Sam Bridwell, BAE Mechanical Option Advisor: Dr. Freihaut

Table of Contents

- Introduction
- Project Overview
- Existing Systems
- Proposal
- Depth: Cogeneration Plant Implementation
- Breadth 1: Power Interconnect and Black Start Capability
- Breadth 2: Alternate Project Delivery System
- Final Recommendations
- Conclusion/Acknowledgements




Table of Contents

- Introduction
- **Project Overview**
- Existing Systems
- Proposal
- Depth: Cogeneration Plant Implementation
- Breadth 1: Power Interconnect and Black Start Capability
- Breadth 2: Alternate Project Delivery System
- Final Recommendations
- Conclusion/Acknowledgements



Project Location




Image © <http://upload.wikimedia.org/wikipedia/commons/thumb/b/b2/Utica_Shale_assessment_-_01.jpg/220px-Utica_Shale_assessment_-_01.jpg>

Utica Shale Region





Figure B1-1 U.S. climate zone map (ASHRAE Transactions, Briggs et al., 2003).

Image © ASHRAE Std. 90.1.5.1.4 Figure B1-1

5A Cool and Moist

Table of Contents

- Introduction
- **Project Overview**
- Existing Systems
- Proposal
- Depth: Cogeneration Plant Implementation
- Breadth 1: Power Interconnect and Black Start Capability
- Breadth 2: Alternate Project Delivery System
- Final Recommendations
- Conclusion/Acknowledgements



Campus Map

Table of Contents

- Introduction
- **Project Overview**
- Existing Systems
- Proposal
- Depth: Cogeneration Plant Implementation
- Breadth 1: Power Interconnect and Black Start Capability
- Breadth 2: Alternate Project Delivery System
- Final Recommendations
- Conclusion/Acknowledgements




Image © <<http://www.neomed.edu/about/pdfs/neomed-campus-map.pdf>>

Phase 1

Research and Graduate Education Building



Image © <<http://www.ruhlin.com/highered-neomedrgccmu>>





Table of Contents

- Introduction
- **Project Overview**
- Existing Systems
- Proposal
- Depth: Cogeneration Plant Implementation
- Breadth 1: Power Interconnect and Black Start Capability
- Breadth 2: Alternate Project Delivery System
- Final Recommendations
- Conclusion/Acknowledgements




Image © <<http://www.neomed.edu/about/pdfs/neomed-campus-map.pdf>>

Phase 1

Comparative Medical Unit Expansion




Image © Scheeser Buckley Mayfield LLC




Image © Scheeser Buckley Mayfield LLC

REDI-Zone

Table of Contents

- Introduction
- **Project Overview**
- Existing Systems
- Proposal
- Depth: Cogeneration Plant Implementation
- Breadth 1: Power Interconnect and Black Start Capability
- Breadth 2: Alternate Project Delivery System
- Final Recommendations
- Conclusion/Acknowledgements



The Village



Table of Contents

- Introduction
- **Project Overview**
- Existing Systems
- Proposal
- Depth: Cogeneration Plant Implementation
- Breadth 1: Power Interconnect and Black Start Capability
- Breadth 2: Alternate Project Delivery System
- Final Recommendations
- Conclusion/Acknowledgements




Image © <<http://www.neomed.edu/about/pdfs/neomed-campus-map.pdf>>

Phase 2



Image © <<http://www.ruhlin.com/highered-neomedhwmc>>





Image © <<http://www.ruhlin.com/highered-neomedhwmc>>

NEOMED Education and Wellness Center

Table of Contents

- Introduction
- Project Overview
- Existing Systems
 - Existing Infrastructure
 - Water-side HVAC
 - Air-side HVAC
 - Design Conditions
 - Design Objectives
- Proposal
- Depth: Cogeneration Plant Implementation
- Breadth 1: Power Interconnect and Black Start Capability
- Breadth 2: Alternate Project Delivery System
- Final Recommendations
- Conclusion/Acknowledgements




Existing Infrastructure

Main HW/CW Plant

High-Pressure Steam Plant

Table of Contents

- Introduction
- Project Overview
- Existing Systems
 - Existing Infrastructure
 - **Water-side HVAC**
 - Air-side HVAC
 - Design Conditions
 - Design Objectives
- Proposal
- Depth: Cogeneration Plant Implementation
- Breadth 1: Power Interconnect and Black Start Capability
- Breadth 2: Alternate Project Delivery System
- Final Recommendations
- Conclusion/Acknowledgements



RGE Standalone Utilities



Image © Scheeser Buckley Mayfield LLC



Image © Scheeser Buckley Mayfield LLC

Table of Contents

- Introduction
- Project Overview
- **Existing Systems**
 - Existing Infrastructure
 - **Water-side HVAC**
 - Air-side HVAC
 - Design Conditions
 - Design Objectives
- Proposal
- Depth: Cogeneration Plant Implementation
- Breadth 1: Power Interconnect and Black Start Capability
- Breadth 2: Alternate Project Delivery System
- Final Recommendations
- Conclusion/Acknowledgements




Image © Scheeser Buckley Mayfield LLC



Image © Scheeser Buckley Mayfield LLC


RGE Standalone Utilities

Table of Contents

- Introduction
- Project Overview
- **Existing Systems**
 - Existing Infrastructure
 - Water-side HVAC
 - **Air-side HVAC**
 - Design Conditions
 - Design Objectives
- Proposal
- Depth: Cogeneration Plant Implementation
- Breadth 1: Power Interconnect and Black Start Capability
- Breadth 2: Alternate Project Delivery System
- Final Recommendations
- Conclusion/Acknowledgements

Custom RTU's

AHU-1 and AHU-2
50,000 CFM
100% OA



AHU-3
28,000 CFM

AHU-4
8,400 CFM




Table of Contents

- Introduction
- Project Overview
- **Existing Systems**
 - Existing Infrastructure
 - Water-side HVAC
 - **Air-side HVAC**
 - Design Conditions
 - Design Objectives
- Proposal
- Depth: Cogeneration Plant Implementation
- Breadth 1: Power Interconnect and Black Start Capability
- Breadth 2: Alternate Project Delivery System
- Final Recommendations
- Conclusion/Acknowledgements

Custom RTU's



Image © Scheeser Buckley Mayfield LLC

AHU-5
85,000 CFM
100% OA




Table of Contents

- Introduction
- Project Overview
- Existing Systems
 - Existing Infrastructure
 - Water-side HVAC
 - Air-side HVAC
 - Design Conditions
 - Design Objectives
- Proposal
- Depth: Cogeneration Plant Implementation
- Breadth 1: Power Interconnect and Black Start Capability
- Breadth 2: Alternate Project Delivery System
- Final Recommendations
- Conclusion/Acknowledgements

Design Conditions

- Filtration Levels**
 - Supply air tunnel to have MERV-9 pre-filter and MERV-14 after filter within AHU (serving new and existing Vivarium).
 - Room side replaceable "Filter Grilles" to be utilized for holding room exhaust.
 - Heat pipe energy recovery (within exhaust) to have MERV-9 pre-filters.
- Chilled Water Design: 42°F EWT, 58°F LWT
- Hot Water Design: 160°F EWT, 120° LWT
- Steam System Design: 60 psig – process (Autoclaves + Cagewasher)
15 psig – (Humidification) reduced by new PRV

Image © BR+A Consulting Engineers

	Winter °F	Summer °F (±2°F)
<u>Exterior Design Temp.</u>	0	89°db /73°wb
<u>Interior Design Temp.</u>		
Laboratories / support spaces	72	72
Mechanical/Electrical Rooms	65	Vent Only
Animal Holding Rooms	68-85	68-85 (Selectable range)
Rabbits Holding Room	65	65
<u>Supply Air Temperature</u> (at discharge of chilled water coil)	48°F db	48°F db /47.5° wb Vivarium
<u>Humidity</u>		
Lab / Support spaces	35%±5	50% (±5%)
Vivarium	30-40%±5	50% (±5%)

Image © BR+A Consulting Engineers

a. The HVAC systems and equipment shall be designed in accordance with the following Ventilation / Pressurization / Cooling criteria:

- Laboratories and support spaces
 - Exhaust: 100% Exhaust.
 - Air Circulation: As required by air conditioning load or equipment ventilation load. Min. 6 ACH/HR.
 - Pressure: Negative in relation to corridors and office spaces
 - Electrical Loads: 10 w/sf power, 2 w/sf lighting
- Toilets/Janitors Closets
 - Exhaust: 100% Exhaust
 - Air Circulation: 10 ACH exhaust (min.), constant volume
 - Pressure: Negative to adjacent spaces
 - Electrical Loads: 1.5 w/sf lighting, convenience outlets
- Animal Holding
 - Exhaust: MERV-9
 - Air Circulation: Minimum 15 ACH, constant volume
 - Pressure: Negative to adjacent spaces
 - Electrical Loads: 10 w/sf power, 1.5 w/sf lighting
- Procedure Room
 - Exhaust: 100% Exhaust
 - Air Circulation: 15 ACH minimum, as required for equipment makeup ventilation Load, constant volume
 - Pressure: Negative to adjacent spaces
 - Electrical Loads: 15 w/sf power, 2 w/sf lighting
- Operating Rooms
 - Exhaust: 100% Exhaust
 - Air Circulation: 15 ACH minimum, as required for cooling
 - Pressure: Positive
 - Electrical Load: 15 w/sf power; 2 w/sf lighting
- Airlocks
 - Exhaust: 100% Exhaust
 - Air Circulation: 10 ACH minimum, constant volume
 - Pressure: Negative to adjacent spaces
 - Electrical Loads: 1.5 w/sf lighting
- Corridors
 - Exhaust: 100% Exhaust
 - Air Circulation: Minimum 6 ACH or requirement for make-up due to labs being at negative pressure.
 - Pressure: Positive to Laboratories
 - Electrical Loads: 1.5 w/sf lighting
- Environmental Rooms
 - Exhaust: 100% Exhaust
 - Air Circulation: 20 CFM ventilation only
 - Pressure: Neutral

Image © BR+A Consulting Engineers

Table of Contents

- Introduction
- Project Overview
- **Existing Systems**
 - Existing Infrastructure
 - Water-side HVAC
 - Air-side HVAC
 - Design Conditions
 - **Design Objectives**
- Proposal
- Depth: Cogeneration Plant Implementation
- Breadth 1: Power Interconnect and Black Start Capability
- Breadth 2: Alternate Project Delivery System
- Final Recommendations
- Conclusion/Acknowledgements



Image © <<http://microinnova.com>>



Image © <<http://www.laborcosting.com>>

Design Objectives

Top-Notch Quality of Facility

24/7 Availability for Staff and Researchers

Independence and Reliability of Building Systems

Flexibility for Future Changes and Campus Expansion



Image © <<http://www.transactbookkeeping.co.uk/images/reliability.jpg>>




Image © <<http://davegreenwald.com>>

Table of Contents

- Introduction
- Project Overview
- Existing Systems
- **Proposal**
 - Decision Factors
 - Proposal Components
- Depth: Cogeneration Plant Implementation
- Breadth 1: Power Interconnect and Black Start Capability
- Breadth 2: Alternate Project Delivery System
- Final Recommendations
- Conclusion/Acknowledgements

Considerations Made

High Air Turnover, Need for Energy Recovery

Multi-Phase, Multiple Bids

Complex Controls and Metering

Distance to Existing Utilities

Strict Technical Requirements

Environmental Impact

Ease of Maintenance

Goal of Long-Term Growth and Development

Strict Project Delivery Timeline

Cost Impact

Efficiency

Atypical Building Systems

Built to Benefit not only Students and Researchers but Entire Regional Community

Table of Contents

- Introduction
- Project Overview
- Existing Systems
- **Proposal**
 - Decision Factors
 - **Proposal Components**
- Depth: Cogeneration Plant Implementation
- Breadth 1: Power Interconnect and Black Start Capability
- Breadth 2: Alternate Project Delivery System
- Final Recommendations
- Conclusion/Acknowledgements

Proposed Alternatives

Breadth 1: Power Interconnect & Black Start Capability



Image © <<http://www-tc.pbs.org>>

Depth: Cogeneration Plant Implementation





Image © <<http://www.epa.gov>>

Breadth 2: Alternate Project Delivery System




Image © <<http://www.fhwa.dot.gov>>

Table of Contents

- Introduction
- Project Overview
- Existing Systems
- Proposal
- **Depth: Cogeneration Plant Implementation**
 - **Utility Data Analysis**
 - Screening
 - Configuration Analyses
 - System Operation
 - Further Expansion
- Breadth 1: Power Interconnect and Black Start Capability
- Breadth 2: Alternate Project Delivery System
- Final Recommendations
- Conclusion/Acknowledgements


Campus Utility Data

		Year
Month	Kilowatt Hrs	823,121
	Dollars	\$62,575.46
	\$/kwh	\$0.076
	Temperature	74°


		Year
Month	MCF's	2,139.01
	Dollars	\$16,962.35
	\$/MMBTU	\$7.93
	Temperature	74°

Yearly Average	\$/kwh	\$0.077
	\$/MMBTU	\$7.85
	Spark Gap	\$14.60
	kW	1084
	MBH	6010
	ΔD	1.63
	Temperature	


Thermal/Electric Demand Ratio By Month




Electric Demand by Month



Thermal Demand by Month



Electric Price by Year



Gas Price by Year




Table of Contents

- Introduction
- Project Overview
- Existing Systems
- Proposal
- **Depth: Cogeneration Plant Implementation**
 - Utility Data Analysis
 - **Screening**
 - Configuration Analyses
 - System Operation
 - Further Expansion
- Breadth 1: Power Interconnect and Black Start Capability
- Breadth 2: Alternate Project Delivery System
- Final Recommendations
- Conclusion/Acknowledgements

System Selection

Site Data Collection

1. How many hours per year does the facility operate? (hours) Or, ask about operating schedule - day/week, hours/day	8,760	
2. What is your average power demand during operation? (kW), or	1,084	
3. How much electricity do you use in a year, kWh?	9,369,859	
4. What is your facility's primary thermal load (i.e., DHW, steam/HW space heating, process steam, cooling, etc.)	Space Heating	
5. What is your average thermal demand? (MMBtu/hr), or	6.01	
6. How much fuel (gas/oil/etc) do you use in a year? (MMBtu/yr, Therms/yr, etc.)	51,922	
7. What is your current fuel price? (\$/MMBtu)	\$7.850	
8. How much do you pay for fuel annually? (Dollars/yr)	\$405,770	
9. What are the CHP Fuel Costs? (\$/MMBtu)	\$7.850	
10. What is your average electricity price? (\$/kWh)	\$0.077	
11. How much do you pay for electricity annually? (Dollars/yr)	\$712,509	
12. What is the efficiency of your existing boiler(s)/thermal equipment? (decimal)	0.90	RGE HW Boiler
13. What is the efficiency of your existing chillers? (kWh/ton)	0.60	RGE Chiller

CHP System

Net CHP Power, kW	1,084	CHP System Specs	C
CHP Electric Efficiency, % (HHV)	36.8%	CHP system specs	C
CHP Thermal Output, Btu/kWh	3,854	CHP system specs	C
CHP Thermal Output, MMBtu/hr	4.2	CHP system specs	C
CHP Power to Heat Ratio	0.89	Calculated based on CHP power output and thermal output	
CHP Availability, %	98%	90 to 98%	
Incremental O&M Costs, \$/kWh	\$0.019	CHP system specs	C
Thermal Utilization, %	90%	Amount of available thermal captured and used - typically 80 to 100%	
Total Installed Costs, \$/kW	\$2,335	CHP system specs	C

	Based on Recip Engines				Based on Gas Turbines			
Thermal Output, MMBtu/hr	0.34	2.64	3.85	10.67	24.47	52.62	76.42	141.33
Net Capacity, kW	50	600	1,000	3,300	5,000	10,000	20,000	45,000
System	A	B	C	D	E	F	G	H
Heat Rate, Btu/kWh	12,637	9,896	9,264	8,454	11,807	12,482	10,265	9,488
Net Electrical Efficiency, %	27.0%	34.5%	36.8%	40.4%	28.9%	27.3%	33.2%	36.0%
Thermal Output, Btu/kWh	6,700	4,392	3,854	3,233	4,893	5,262	3,821	3,141
Thermal Output, MMBtu/hr	0.34	2.64	3.85	10.67	24.47	52.62	76.42	141.33
Thermal Output for Cooling (single effect)	80%	85%	85%	85%	100%	100%	100%	100%
Thermal Output for Cooling (double effect)	50%	50%	50%	50%	90%	90%	90%	90%
Total Efficiency, %	80%		78%	79%	70%	69%	70%	69%
Incremental O&M, \$/kWh	\$0.0240	\$0.0210	\$0.0190	\$0.0126	\$0.0123	\$0.0120	\$0.0093	\$0.0092
Total Installed Costs, \$/kW	\$2,900	\$2,737	\$2,335	\$1,917	\$2,080	\$1,976	\$1,518	\$1,248

GE Jenbacher Reciprocating Engine






Image © <http://site.ge-energy.com/prod_serv/products/recip_engines/en/type3.htm>

Table of Contents

- Introduction
- Project Overview
- Existing Systems
- Proposal
- **Depth: Cogeneration Plant Implementation**
 - Utility Data Analysis
 - Screening
 - **Configuration Analyses**
 - System Operation
 - Further Expansion
- Breadth 1: Power Interconnect and Black Start Capability
- Breadth 2: Alternate Project Delivery System
- Final Recommendations
- Conclusion/Acknowledgements

System Sizing

		FY 14
Yearly Average	\$/kwh	\$0.069
	\$/MMBTU	\$4.51
	Spark Gap	\$15.69
	kW	1565
	MBH	8418
	ΔD	1.58
	Temperature	0



		Cooling Months					
		June	July	August	September		
2014	total kW		1,689	1,627	1,697	avg. (non-cooling) kW	1,435
	cooling power (kW)		254	193	262	avg. (cooling) kW	236
	cooling load (MBH)		5087	3858	5240	Avg. Cooling MBH	4,728
	cooling load (Ton)		424	322	437	Avg. Cooling Tons	394

Table of Contents

- Introduction
- Project Overview
- Existing Systems
- Proposal
- **Depth: Cogeneration Plant Implementation**
 - Utility Data Analysis
 - Screening
 - **Configuration Analyses**
 - System Operation
 - Further Expansion
- Breadth 1: Power Interconnect and Black Start Capability
- Breadth 2: Alternate Project Delivery System
- Final Recommendations
- Conclusion/Acknowledgements

Configurations







Table of Contents

- Introduction
- Project Overview
- Existing Systems
- Proposal
- **Depth: Cogeneration Plant Implementation**
 - Utility Data Analysis
 - Screening
 - **Configuration Analyses**
 - System Operation
 - Further Expansion
- Breadth 1: Power Interconnect and Black Start Capability
- Breadth 2: Alternate Project Delivery System
- Final Recommendations
- Conclusion/Acknowledgements

Configuration Analysis

Plant Configuration Results

Configuration	Equipment Setup	Payback Period	Emissions	
			Vehicles	Houses
A	1 GE Jenbacher J420 with process steam load	8.4	2,201	1,439
B	2 GE Jenbacher J316 with process steam load	10.5	2,630	1,720
C	3 GE Jenbacher J312 with process steam load	14.4	2,945	1,926
D	1 GE Jenbacher J420 with trigeneration, absorption cooling sized to thermal output	11.1	2,076	1,358
E	2 GE Jenbacher J316 with trigeneration, absorption cooling sized to thermal output	11.4	2,461	1,610
F	3 GE Jenbacher J312 with trigeneration, absorption cooling sized to thermal output	14.5	2,756	1,802
G	1 GE Jenbacher J420 with trigeneration, full load absorption cooling with boiler makeup	11.4	2,076	1,358
H	2 GE Jenbacher J316 with trigeneration, full load absorption cooling with boiler makeup	11.5	2,461	1,610
I	3 GE Jenbacher J312 with trigeneration, full load absorption cooling with boiler makeup	14.5	2,756	1,802






Table of Contents

- Introduction
- Project Overview
- Existing Systems
- Proposal
- **Depth: Cogeneration Plant Implementation**
 - Utility Data Analysis
 - Screening
 - Configuration Analyses
 - **System Operation**
 - Further Expansion
- Breadth 1: Power Interconnect and Black Start Capability
- Breadth 2: Alternate Project Delivery System
- Final Recommendations
- Conclusion/Acknowledgements

Cogeneration System Schematic



High-Temperature Water Steam System




Image © <http://inproheat.com/sites/files/imagecache/product_nodeview/products/pic-onceThrough-zz_0.jpg>




Image © <<http://www.davegreenwald.com>>

Once-Trough Steam Generator

Table of Contents

- Introduction
- Project Overview
- Existing Systems
- Proposal
- **Depth: Cogeneration Plant Implementation**
 - Utility Data Analysis
 - Screening
 - Configuration Analyses
 - System Operation
 - **Further Expansion**
- Breadth 1: Power Interconnect and Black Start Capability
- Breadth 2: Alternate Project Delivery System
- Final Recommendations
- Conclusion/Acknowledgements




Image © <<http://www.neomed.edu/about/pdfs/neomed-campus-map.pdf>>

Further Expansion

- **Generator Sizing Accommodates Expansion**
 - Fit out of 4th Floor
 - AHU Humidifiers

- **Locate Additional Plant Capacity in NEW Building**
 - Lap Pool
 - Hydrotherapy Pool

Table of Contents

- Introduction
- Project Overview
- Existing Systems
- Proposal
- Depth: Cogeneration Plant Implementation
- **Breadth 1: Power Interconnect and Black Start Capability**
 - Interconnect Laws and Standards
 - Utility Interconnect Design
 - Black Start Capability
- Breadth 2: Alternate Project Delivery System
- Final Recommendations
- Conclusion/Acknowledgements

State Interconnect Laws and Standards


Ohio has very “DG-Friendly” Policies

Disconnect Switch at discretion of Utility

No Generation System Size Limit for Interconnection

Net Metering mandated for all IOU’s; No Generation System Size Limit

Figure 5.4.1: States with DG Interconnection Standards



Legend:
 ■ States with interconnection rules
 ■ States with proposed interconnection rules


- Notes:
- New Jersey also has interconnection standards for net metered renewable DG ≤ 2 MW.
 - New Hampshire has interconnection standards for net metered renewable DG ≤ 25 kW.

Maximum System Size for a State Interconnection Standard

State	Standard	State	Standard
CA	None	NH	25 kW
CT	25 MW	NJ	2 MW
DE	1 MW	NM	10 kW
HI	None	OH	None
MA	None	NY	2 MW
MI	None	TX	10 MW
MN	10 MW	WI	15 MW
NC*	100 kW		

* System size is limited to 20 kW for residential customers.
 Source: Navigant 2005.
 Image © EPA Clean Energy-Environment Guide to Action

Figure 5.4.2: States with Net Metering Rules



Net Metering System Size Limit (kW)

(in some cases limits are different for residential and commercial as shown)

State	Residential	Commercial	State	Residential	Commercial
AR	25/100		MN	40	
AZ	10		MT	50	
CA	1,000		ND	100	
CO	Under development		NH	25	
CT	100		NJ	2,000	
DC	100/25		NM	10	
DE	Varies		NV	30	
FL	Varies		NY	10/400	
GA	10/100		OH	No limit	
HI	50		OK	100	
IA	Varies		OR	25	
ID	25/100		PA	Varies	
IL	40		RI	25	
IN	10		TX	50	
KY	15		UT	25	
LA	25/100		VA	10/500	
MA	60		VT	15/150	
MD	80		WA	25	
ME	100		WI	20	
MI	Varies		WY	25	

Source: IREC 2005.
 Image © EPA Clean Energy-Environment Guide to Action

Table of Contents

- Introduction
- Project Overview
- Existing Systems
- Proposal
- Depth: Cogeneration Plant Implementation
- **Breadth 1: Power Interconnect and Black Start Capability**
 - Interconnect Laws and Standards
 - **Utility Interconnect Design**
 - Black Start Capability
- Breadth 2: Alternate Project Delivery System
- Final Recommendations
- Conclusion/Acknowledgements

Generation and Utility Parallel Operation Schematic




Table of Contents

- Introduction
- Project Overview
- Existing Systems
- Proposal
- Depth: Cogeneration Plant Implementation
- Breadth 1: Power Interconnect and Black Start Capability
- **Breadth 2: Alternate Project Delivery System**
 - Background
 - Research
 - Potential Benefits
- Final Recommendations
- Conclusion/Acknowledgements

Project Delivery Methods




Table of Contents

- Introduction
- Project Overview
- Existing Systems
- Proposal
- Depth: Cogeneration Plant Implementation
- Breadth 1: Power Interconnect and Black Start Capability
- **Breadth 2: Alternate Project Delivery System**
 - Background
 - Research
 - Potential Benefits
- Final Recommendations
- Conclusion/Acknowledgements

Project Delivery Methods





Table of Contents

- Introduction
- Project Overview
- Existing Systems
- Proposal
- Depth: Cogeneration Plant Implementation
- Breadth 1: Power Interconnect and Black Start Capability
- **Breadth 2: Alternate Project Delivery System**
 - Background
 - **Research**
 - Potential Benefits
- Final Recommendations
- Conclusion/Acknowledgements

Research Results



Facility Type \ Metric	Unit Cost	Cost Growth	Schedule Growth	Construction Speed	Delivery Speed	Intensity	Turnover Quality	System Quality	Equipment Quality
Light industrial	DB, CMR < DBB	○	CMR < DB, DBB	DB, CMR > DBB	DB, CMR > DBB	○	○	DB > DBB	○
Multi-story dwelling	○	○	○	○	○	DB > DBB	○	○	○
Simple office	○	○	CMR < DBB	○	CMR > DBB	DB > CMR, DBB	CMR > DB, DBB	○	○
Complex office	○	○	DB < DBB	○	○	DB > DBB	DB > CMR, DBB	○	DB > CMR
Heavy manufacturing	○	○	○	○	○	○	○	○	○
High technology	○	DB < DBB	○	○	○	DB > CMR	DB, CMR > DBB	DB > DBB	○

Legend	
Significant differences called out	< or >
No significant differences between systems	○
Significant differences	●

FIG. 2. Matrix of Significance by Facility Type and Owner Type Unadjusted for Other Explanatory Variables

Image © Journal of Construction Engineering and Management Nov/Dec 1998

Univariate Results

- 50% CMR and DB delivered on-time or early
- 50% DBB more than 4% late
- CMR, DB Quality > DBB Quality

Multivariate Results


- DB < CMR DBB
- Delivery Method significant influence on construction speed, some influence on total delivery speed
- Delivery Method single biggest influence on schedule growth
- Project Delivery Method biggest influence on every metric overall, matched only by Facility Type

Table of Contents

- Introduction
- Project Overview
- Existing Systems
- Proposal
- Depth: Cogeneration Plant Implementation
- Breadth 1: Power Interconnect and Black Start Capability
- Breadth 2: Alternate Project Delivery System
 - Background
 - Research
 - Potential Benefits
- Final Recommendations
- Conclusion/Acknowledgements

Project Benefits

Schedule Slippage



	Bid Schedule	Actual Substantial Completion	Days Delayed
CMU	5/13/2013	7/31/2013	79
RGE	5/31/2013	7/31/2013	61




Table of Contents

- Introduction
- Project Overview
- Existing Systems
- Proposal
- Depth: Cogeneration Plant Implementation
- Breadth 1: Power Interconnect and Black Start Capability
- **Breadth 2: Alternate Project Delivery System**
 - Background
 - Research
 - **Potential Benefits**
- Final Recommendations
- Conclusion/Acknowledgements


Project Benefits

Disputes



Date	Actual Man-hours Expenditures					Base Contract Labor Dollars Earned			Man-hour per percent
	Cumulative Electrician Payroll hours	Less Field Supervision hours	Temporary Power & Clean up	Less Approved & Pending Change Orders	Net Cumulative Actual Man-hours	Period Earned Labor Dollars	Cumulative Earned Labor Dollars	Cumulative Percent Complete	
10/28/12	751	258	28	10	455	\$32,825	\$32,825	2.8%	164
02/24/13	11,726	945	492	284	10,015	\$579,399	\$612,224	51.6%	194
03/31/13	18,167	1,168	528	835	15,636	\$209,106	\$821,330	69.2%	226
04/28/13	22,449	1,318	566	1,024	19,541	\$155,832	\$977,162	82.4%	237
05/26/13	25,319	1,479	604	1,121	22,115	\$74,353	\$1,051,515	88.6%	250
06/30/13	27,995	1,680	650	1,147	24,519	\$92,896	\$1,144,412	96.4%	254
07/28/13	29,801	1,861	688	1,273	25,980	\$21,086	\$1,165,498	98.2%	264
08/31/13	30,382	2,066	737	1,429	26,151	\$21,087	\$1,186,585	100.0%	262
Total									

Loss of Productivity Calculation			
	Measured Mile	Impact Period	Total
	Start to 2/24/13	2/25/13 to 8/31/13	
Man-hours Expended	10,015	16,136	26,151
Base Contract Dollars Earned	\$612,224	\$574,361	\$1,186,585
Earned Percent Complete	51.6%	48.4%	100.0%
Man-hours/ 1% Earned	194	333	
Less Measured Mile		(194)	
Net Impact per 1% Complete		139	
Portion of Project Impacted		48.4%	
Added Impact Hours		6,728	6,728



Added Labor Cost	\$384,580.00
Premium Time	\$17,770.00
Supervision	\$91,735.00
General Conditions	\$33,501.00
Home Office Support	\$69,615.00
Less: 2nd Shift Premium in Bid	(\$23,740.00)
Total	\$573,461.00

Original Contract Amount	\$3,486,140.00
Executed Change Orders	\$301,699.53
Agreed Upon Adjusted Contract	\$3,787,839.53
Amount Paid to Date as of May 21, 2014	\$3,508,163.70
Agreed Upon Contract Balance	\$279,675.83
Pending Change Orders	\$7,975.59
Total Contract Balance and Disputed Direct Costs	\$287,651.42

Table of Contents



- Introduction
- Project Overview
- Existing Systems
- Proposal
- Depth: Cogeneration Plant Implementation
- Breadth 1: Power Interconnect and Black Start Capability
- Breadth 2: Alternate Project Delivery System
- **Final Recommendations**
- Conclusion/Acknowledgements

Breadth 1: Power Interconnect & Black Start Capability



Final Recommendations Based On Analyses

Depth: Cogeneration Plant Implementation



Breadth 2: Alternate Project Delivery System





Table of Contents

- Introduction
- Project Overview
- Existing Systems
- Proposal
- Depth: Cogeneration Plant Implementation
- Breadth 1: Power Interconnect and Black Start Capability
- Breadth 2: Alternate Project Delivery System
- Final Recommendations
- **Conclusion/Acknowledgements**



Chris Schoonover
Brian Ault
Blaine Wyckoff
Jim Rankin
Jim Freihaut
Rob Leicht
Tim Warren
Tom Leary
Ari Tinkoff
Scott Walthour
Chris Elgin
Diet Mt. Dew
Steam

Acknowledgements

Principal - Scheeser Buckley Mayfield, LLC
Mechanical Engineer - Scheeser Buckley Mayfield, LLC
Director of Campus Operations- Northeast Ohio Medical University
Asst. Dir. of Campus Operations- Northeast Ohio Medical University
Professor of Architectural Engineering – Penn State
Asst. Professor of Architectural Engineering – Penn State
President - JDB Engineering, Inc.
Executive VP/DOP - JDB Engineering, Inc.
Managing Director/Principal - BR+A Consulting Engineers
Managing Principal – Arium AE
Structural Engineer - GPD Group
Carbonated Soft Drink – PepsiCo Inc.
Internet-based gaming platform – Valve Corporation

