

Air System Sizing Summary for AHU01 Sys

Project Name: jxf_lab_mech2b_ACH
Prepared by: psuae

Appendix C - HAP Output

10/29/2003
07:17AM

Air System Information

Air System Name **AHU01 Sys**
Equipment Class **PKG ROOF**
Air System Type **SZCAV**

Number of zones **1**
Floor Area **1008.2** ft²

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM **Sum of space airflow rates**
Space CFM **Individual peak space loads**

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Central Cooling Coil Sizing Data

Total coil load **21.4** Tons
Total coil load **257.4** MBH
Sensible coil load **215.5** MBH
Coil CFM at Jul 1400 **6138** CFM
Max block CFM **6138** CFM
Sum of peak zone CFM **6077** CFM
Sensible heat ratio **0.837**
ft²/Ton **47.0**
BTU/(hr-ft²) **255.3**
Water flow @ 10.0 °F rise **N/A**

Load occurs at **Jul 1400**
OA DB / WB **91.5 / 74.9** °F
Entering DB / WB **79.7 / 61.7** °F
Leaving DB / WB **47.2 / 45.7** °F
Coil ADP **43.6** °F
Bypass Factor **0.100**
Resulting RH **42** %
Design supply temp. **47.0** °F
Zone T-stat Check **1 of 1** OK
Max zone temperature deviation **0.0** °F

Central Heating Coil Sizing Data

Max coil load **13.3** MBH
Coil CFM at Des Htg **6138** CFM
Max coil CFM **6138** CFM
Water flow @ 20.0 °F drop **N/A**

Load occurs at **Des Htg**
BTU/(hr-ft²) **13.2**
Ent. DB / Lvg DB **66.4 / 68.4** °F

Supply Fan Sizing Data

Actual max CFM **6138** CFM
Standard CFM **6131** CFM
Actual max CFM/ft² **6.09** CFM/ft²

Fan motor BHP **20.00** BHP
Fan motor kW **14.91** kW

Outdoor Ventilation Air Data

Design airflow CFM **1000** CFM
CFM/ft² **0.99** CFM/ft²

CFM/person **200.00** CFM/person

Air System Sizing Summary for AHU02 Sys

Project Name: jxf_lab_mech2b_ACH
Prepared by: psuae

Appendix C - HAP Output

10/29/2003
07:17AM

Air System Information

Air System Name **AHU02 Sys**
Equipment Class **PKG ROOF**
Air System Type **SZCAV**

Number of zones **1**
Floor Area **2888.2** ft²

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM **Sum of space airflow rates**
Space CFM **Individual peak space loads**

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Central Cooling Coil Sizing Data

Total coil load **85.6** Tons
Total coil load **1027.1** MBH
Sensible coil load **569.5** MBH
Coil CFM at Jul 1600 **12313** CFM
Max block CFM **12313** CFM
Sum of peak zone CFM **12190** CFM
Sensible heat ratio **0.554**
ft²/Ton **33.7**
BTU/(hr-ft²) **355.6**
Water flow @ 10.0 °F rise **N/A**

Load occurs at **Jul 1600**
OA DB / WB **91.5 / 74.9** °F
Entering DB / WB **91.3 / 74.7** °F
Leaving DB / WB **48.4 / 47.7** °F
Coil ADP **43.6** °F
Bypass Factor **0.100**
Resulting RH **44** %
Design supply temp. **48.3** °F
Zone T-stat Check **1 of 1** OK
Max zone temperature deviation **0.0** °F

Central Heating Coil Sizing Data

Max coil load **708.8** MBH
Coil CFM at Des Htg **12313** CFM
Max coil CFM **12313** CFM
Water flow @ 20.0 °F drop **N/A**

Load occurs at **Des Htg**
BTU/(hr-ft²) **245.4**
Ent. DB / Lvg DB **11.6 / 64.9** °F

Supply Fan Sizing Data

Actual max CFM **12313** CFM
Standard CFM **12300** CFM
Actual max CFM/ft² **4.26** CFM/ft²

Fan motor BHP **20.00** BHP
Fan motor kW **14.91** kW

Outdoor Ventilation Air Data

Design airflow CFM **12190** CFM
CFM/ft² **4.22** CFM/ft²

CFM/person **641.58** CFM/person

Air System Sizing Summary for AHU03 Sys

Project Name: jxf_lab_mech2b_ACH
Prepared by: psuae

Appendix C - HAP Output

10/29/2003
07:17AM

Air System Information

Air System Name **AHU03 Sys**
Equipment Class **PKG ROOF**
Air System Type **SZCAV**

Number of zones **1**
Floor Area **1177.0** ft²

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM **Sum of space airflow rates**
Space CFM **Individual peak space loads**

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Central Cooling Coil Sizing Data

Total coil load **31.7** Tons
Total coil load **380.1** MBH
Sensible coil load **224.6** MBH
Coil CFM at Aug 1500 **5796** CFM
Max block CFM **5796** CFM
Sum of peak zone CFM **5738** CFM
Sensible heat ratio **0.591**
ft²/Ton **37.2**
BTU/(hr-ft²) **322.9**
Water flow @ 10.0 °F rise **N/A**

Load occurs at **Aug 1500**
OA DB / WB **92.0 / 75.0** °F
Entering DB / WB **88.5 / 72.6** °F
Leaving DB / WB **52.6 / 51.6** °F
Coil ADP **48.6** °F
Bypass Factor **0.100**
Resulting RH **46** %
Design supply temp. **46.9** °F
Zone T-stat Check **1 of 1** OK
Max zone temperature deviation **0.0** °F

Central Heating Coil Sizing Data

Max coil load **275.8** MBH
Coil CFM at Des Htg **5796** CFM
Max coil CFM **5796** CFM
Water flow @ 20.0 °F drop **N/A**

Load occurs at **Des Htg**
BTU/(hr-ft²) **234.3**
Ent. DB / Lvg DB **22.1 / 66.2** °F

Supply Fan Sizing Data

Actual max CFM **5796** CFM
Standard CFM **5790** CFM
Actual max CFM/ft² **4.92** CFM/ft²

Fan motor BHP **15.00** BHP
Fan motor kW **11.19** kW

Outdoor Ventilation Air Data

Design airflow CFM **4740** CFM
CFM/ft² **4.03** CFM/ft²

CFM/person **592.50** CFM/person

Air System Sizing Summary for AHU04 Sys

Project Name: jxf_lab_mech2b_ACH
Prepared by: psuae

Appendix C - HAP Output

10/29/2003
07:17AM

Air System Information

Air System Name **AHU04 Sys**
Equipment Class **PKG ROOF**
Air System Type **SZCAV**

Number of zones **1**
Floor Area **1135.3** ft²

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM **Sum of space airflow rates**
Space CFM **Individual peak space loads**

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Central Cooling Coil Sizing Data

Total coil load **31.1** Tons
Total coil load **372.6** MBH
Sensible coil load **221.9** MBH
Coil CFM at Jul 1600 **5589** CFM
Max block CFM **5589** CFM
Sum of peak zone CFM **5533** CFM
Sensible heat ratio **0.595**
ft²/Ton **36.6**
BTU/(hr-ft²) **328.2**
Water flow @ 10.0 °F rise **N/A**

Load occurs at **Jul 1600**
OA DB / WB **91.5 / 74.9** °F
Entering DB / WB **86.8 / 71.3** °F
Leaving DB / WB **50.0 / 49.1** °F
Coil ADP **45.9** °F
Bypass Factor **0.100**
Resulting RH **42** %
Design supply temp. **47.2** °F
Zone T-stat Check **1 of 1** OK
Max zone temperature deviation **0.0** °F

Central Heating Coil Sizing Data

Max coil load **237.8** MBH
Coil CFM at Des Htg **5589** CFM
Max coil CFM **5589** CFM
Water flow @ 20.0 °F drop **N/A**

Load occurs at **Des Htg**
BTU/(hr-ft²) **209.5**
Ent. DB / Lvg DB **26.4 / 65.9** °F

Supply Fan Sizing Data

Actual max CFM **5589** CFM
Standard CFM **5583** CFM
Actual max CFM/ft² **4.92** CFM/ft²

Fan motor BHP **15.00** BHP
Fan motor kW **11.19** kW

Outdoor Ventilation Air Data

Design airflow CFM **4170** CFM
CFM/ft² **3.67** CFM/ft²

CFM/person **521.25** CFM/person

Air System Sizing Summary for AHU05 Sys

Project Name: jxf_lab_mech2b_ACH
Prepared by: psuae

Appendix C - HAP Output

10/29/2003
07:17AM

Air System Information

Air System Name **AHU05 Sys**
Equipment Class **PKG ROOF**
Air System Type **SZCAV**

Number of zones **1**
Floor Area **869.2** ft²

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM **Sum of space airflow rates**
Space CFM **Individual peak space loads**

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Central Cooling Coil Sizing Data

Total coil load **13.1** Tons
Total coil load **157.6** MBH
Sensible coil load **98.8** MBH
Coil CFM at Jul 1500 **2633** CFM
Max block CFM **2633** CFM
Sum of peak zone CFM **2607** CFM
Sensible heat ratio **0.627**
ft²/Ton **66.2**
BTU/(hr-ft²) **181.3**
Water flow @ 10.0 °F rise **N/A**

Load occurs at **Jul 1500**
OA DB / WB **92.0 / 75.0** °F
Entering DB / WB **84.7 / 69.3** °F
Leaving DB / WB **50.0 / 48.9** °F
Coil ADP **46.1** °F
Bypass Factor **0.100**
Resulting RH **41** %
Design supply temp. **47.3** °F
Zone T-stat Check **1 of 1** OK
Max zone temperature deviation **0.0** °F

Central Heating Coil Sizing Data

Max coil load **87.9** MBH
Coil CFM at Des Htg **2633** CFM
Max coil CFM **2633** CFM
Water flow @ 20.0 °F drop **N/A**

Load occurs at **Des Htg**
BTU/(hr-ft²) **101.1**
Ent. DB / Lvg DB **34.8 / 65.7** °F

Supply Fan Sizing Data

Actual max CFM **2633** CFM
Standard CFM **2630** CFM
Actual max CFM/ft² **3.03** CFM/ft²

Fan motor BHP **7.50** BHP
Fan motor kW **5.59** kW

Outdoor Ventilation Air Data

Design airflow CFM **1600** CFM
CFM/ft² **1.84** CFM/ft²

CFM/person **228.57** CFM/person

Air System Sizing Summary for AHU06 Sys

Project Name: jxf_lab_mech2b_ACH
Prepared by: psuae

Appendix C - HAP Output

10/29/2003
07:17AM

Air System Information

Air System Name **AHU06 Sys**
Equipment Class **PKG ROOF**
Air System Type **SZCAV**

Number of zones **1**
Floor Area **807.9** ft²

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM **Sum of space airflow rates**
Space CFM **Individual peak space loads**

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Central Cooling Coil Sizing Data

Total coil load **17.9** Tons
Total coil load **214.9** MBH
Sensible coil load **118.4** MBH
Coil CFM at Aug 1600 **2424** CFM
Max block CFM **2424** CFM
Sum of peak zone CFM **2399** CFM
Sensible heat ratio **0.551**
ft²/Ton **45.1**
BTU/(hr-ft²) **266.0**
Water flow @ 10.0 °F rise **N/A**

Load occurs at **Aug 1600**
OA DB / WB **91.5 / 74.9** °F
Entering DB / WB **91.5 / 74.9** °F
Leaving DB / WB **46.2 / 45.7** °F
Coil ADP **41.2** °F
Bypass Factor **0.100**
Resulting RH **41** %
Design supply temp. **47.4** °F
Zone T-stat Check **1 of 1** OK
Max zone temperature deviation **0.0** °F

Central Heating Coil Sizing Data

Max coil load **133.3** MBH
Coil CFM at Des Htg **2424** CFM
Max coil CFM **2424** CFM
Water flow @ 20.0 °F drop **N/A**

Load occurs at **Des Htg**
BTU/(hr-ft²) **164.9**
Ent. DB / Lvg DB **11.0 / 62.0** °F

Supply Fan Sizing Data

Actual max CFM **2424** CFM
Standard CFM **2421** CFM
Actual max CFM/ft² **3.00** CFM/ft²

Fan motor BHP **7.50** BHP
Fan motor kW **5.59** kW

Outdoor Ventilation Air Data

Design airflow CFM **2424** CFM
CFM/ft² **3.00** CFM/ft²

CFM/person **346.24** CFM/person

Air System Sizing Summary for AHU07 Sys

Project Name: jxf_lab_mech2b_ACH
Prepared by: psuae

Appendix C - HAP Output

10/29/2003
07:17AM

Air System Information

Air System Name **AHU07 Sys**
Equipment Class **PKG ROOF**
Air System Type **SZCAV**

Number of zones **1**
Floor Area **2004.4** ft²

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM **Sum of space airflow rates**
Space CFM **Individual peak space loads**

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Central Cooling Coil Sizing Data

Total coil load **61.3** Tons
Total coil load **735.8** MBH
Sensible coil load **430.1** MBH
Coil CFM at Jul 1400 **11616** CFM
Max block CFM **11616** CFM
Sum of peak zone CFM **11500** CFM
Sensible heat ratio **0.585**
ft²/Ton **32.7**
BTU/(hr-ft²) **367.1**
Water flow @ 10.0 °F rise **N/A**

Load occurs at **Jul 1400**
OA DB / WB **91.5 / 74.9** °F
Entering DB / WB **91.2 / 74.7** °F
Leaving DB / WB **56.8 / 55.7** °F
Coil ADP **53.0** °F
Bypass Factor **0.100**
Resulting RH **56** %
Design supply temp. **49.0** °F
Zone T-stat Check **1 of 1** OK
Max zone temperature deviation **0.0** °F

Central Heating Coil Sizing Data

Max coil load **692.1** MBH
Coil CFM at Des Htg **11616** CFM
Max coil CFM **11616** CFM
Water flow @ 20.0 °F drop **N/A**

Load occurs at **Des Htg**
BTU/(hr-ft²) **345.3**
Ent. DB / Lvg DB **11.6 / 66.8** °F

Supply Fan Sizing Data

Actual max CFM **11616** CFM
Standard CFM **11604** CFM
Actual max CFM/ft² **5.80** CFM/ft²

Fan motor BHP **20.00** BHP
Fan motor kW **14.91** kW

Outdoor Ventilation Air Data

Design airflow CFM **11500** CFM
CFM/ft² **5.74** CFM/ft²

CFM/person **605.26** CFM/person

Air System Sizing Summary for AHU08 Sys

Project Name: jxf_lab_mech2b_ACH
Prepared by: psuae

Appendix C - HAP Output

10/29/2003
07:17AM

Air System Information

Air System Name **AHU08 Sys**
Equipment Class **PKG ROOF**
Air System Type **SZCAV**

Number of zones **1**
Floor Area **2296.3** ft²

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM **Sum of space airflow rates**
Space CFM **Individual peak space loads**

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Central Cooling Coil Sizing Data

Total coil load **30.0** Tons
Total coil load **360.4** MBH
Sensible coil load **227.3** MBH
Coil CFM at Jul 1400 **6964** CFM
Max block CFM **6964** CFM
Sum of peak zone CFM **6894** CFM
Sensible heat ratio **0.631**
ft²/Ton **76.5**
BTU/(hr-ft²) **157.0**
Water flow @ 10.0 °F rise **N/A**

Load occurs at **Jul 1400**
OA DB / WB **91.5 / 74.9** °F
Entering DB / WB **82.7 / 68.8** °F
Leaving DB / WB **52.4 / 51.4** °F
Coil ADP **49.1** °F
Bypass Factor **0.100**
Resulting RH **49** %
Design supply temp. **47.1** °F
Zone T-stat Check **1 of 1** OK
Max zone temperature deviation **0.0** °F

Central Heating Coil Sizing Data

Max coil load **219.9** MBH
Coil CFM at Des Htg **6964** CFM
Max coil CFM **6964** CFM
Water flow @ 20.0 °F drop **N/A**

Load occurs at **Des Htg**
BTU/(hr-ft²) **95.8**
Ent. DB / Lvg DB **35.7 / 65.0** °F

Supply Fan Sizing Data

Actual max CFM **6964** CFM
Standard CFM **6956** CFM
Actual max CFM/ft² **3.03** CFM/ft²

Fan motor BHP **20.00** BHP
Fan motor kW **14.91** kW

Outdoor Ventilation Air Data

Design airflow CFM **4000** CFM
CFM/ft² **1.74** CFM/ft²

CFM/person **285.71** CFM/person

Air System Sizing Summary for AHU09 Sys

Project Name: jxf_lab_mech2b_ACH
Prepared by: psuae

Appendix C - HAP Output

10/29/2003
07:17AM

Air System Information

Air System Name **AHU09 Sys**
Equipment Class **PKG ROOF**
Air System Type **SZCAV**

Number of zones **1**
Floor Area **2228.2** ft²

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM **Sum of space airflow rates**
Space CFM **Individual peak space loads**

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Central Cooling Coil Sizing Data

Total coil load **14.5** Tons
Total coil load **174.4** MBH
Sensible coil load **128.0** MBH
Coil CFM at Jul 1600 **6752** CFM
Max block CFM **6752** CFM
Sum of peak zone CFM **6685** CFM
Sensible heat ratio **0.734**
ft²/Ton **153.3**
BTU/(hr-ft²) **78.3**
Water flow @ 10.0 °F rise **N/A**

Load occurs at **Jul 1600**
OA DB / WB **91.5 / 74.9** °F
Entering DB / WB **76.7 / 66.5** °F
Leaving DB / WB **59.1 / 58.2** °F
Coil ADP **57.2** °F
Bypass Factor **0.100**
Resulting RH **64** %
Design supply temp. **47.2** °F
Zone T-stat Check **1 of 1** OK
Max zone temperature deviation **0.0** °F

Central Heating Coil Sizing Data

Max coil load **94.5** MBH
Coil CFM at Des Htg **6752** CFM
Max coil CFM **6752** CFM
Water flow @ 20.0 °F drop **N/A**

Load occurs at **Des Htg**
BTU/(hr-ft²) **42.4**
Ent. DB / Lvg DB **52.3 / 65.3** °F

Supply Fan Sizing Data

Actual max CFM **6752** CFM
Standard CFM **6745** CFM
Actual max CFM/ft² **3.03** CFM/ft²

Fan motor BHP **15.00** BHP
Fan motor kW **11.19** kW

Outdoor Ventilation Air Data

Design airflow CFM **2000** CFM
CFM/ft² **0.90** CFM/ft²

CFM/person **133.33** CFM/person

Air System Sizing Summary for AHU10 Sys

Project Name: jxf_lab_mech2b_ACH
Prepared by: psuae

Appendix C - HAP Output

10/29/2003
07:17AM

Air System Information

Air System Name **AHU10 Sys**
Equipment Class **PKG ROOF**
Air System Type **VAV**

Number of zones **14**
Floor Area **12246.6** ft²

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM **Peak zone sensible load**
Space CFM **Individual peak space loads**

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Central Cooling Coil Sizing Data

Total coil load **64.1** Tons
Total coil load **769.4** MBH
Sensible coil load **578.7** MBH
Coil CFM at Jul 1600 **16212** CFM
Max block CFM at Jul 1600 **17743** CFM
Sum of peak zone CFM **16877** CFM
Sensible heat ratio **0.752**
ft²/Ton **191.0**
BTU/(hr-ft²) **62.8**
Water flow @ 10.0 °F rise **N/A**

Load occurs at **Jul 1600**
OA DB / WB **91.5 / 74.9** °F
Entering DB / WB **82.6 / 65.2** °F
Leaving DB / WB **49.5 / 48.1** °F
Coil ADP **45.8** °F
Bypass Factor **0.100**
Resulting RH **37** %
Design supply temp. **54.0** °F
Zone T-stat Check **14 of 14** OK
Max zone temperature deviation **0.0** °F

Supply Fan Sizing Data

Actual max CFM at Jul 1600 **17743** CFM
Standard CFM **17724** CFM
Actual max CFM/ft² **1.45** CFM/ft²

Fan motor BHP **40.00** BHP
Fan motor kW **29.83** kW

Outdoor Ventilation Air Data

Design airflow CFM **4680** CFM
CFM/ft² **0.38** CFM/ft²

CFM/person **25.57** CFM/person

Air System Sizing Summary for AHU11 Sys

Project Name: jxf_lab_mech2b_ACH
Prepared by: psuae

Appendix C - HAP Output

10/29/2003
07:17AM

Air System Information

Air System Name **AHU11 Sys**
Equipment Class **PKG ROOF**
Air System Type **SZCAV**

Number of zones **1**
Floor Area **1619.6** ft²

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM **Sum of space airflow rates**
Space CFM **Individual peak space loads**

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Central Cooling Coil Sizing Data

Total coil load **31.1** Tons
Total coil load **373.7** MBH
Sensible coil load **216.3** MBH
Coil CFM at Aug 1500 **5622** CFM
Max block CFM **5622** CFM
Sum of peak zone CFM **5060** CFM
Sensible heat ratio **0.579**
ft²/Ton **52.0**
BTU/(hr-ft²) **230.7**
Water flow @ 10.0 °F rise **N/A**

Load occurs at **Aug 1500**
OA DB / WB **92.0 / 75.0** °F
Entering DB / WB **89.4 / 73.5** °F
Leaving DB / WB **53.7 / 52.7** °F
Coil ADP **49.7** °F
Bypass Factor **0.100**
Resulting RH **47** %
Design supply temp. **51.0** °F
Zone T-stat Check **1 of 1** OK
Max zone temperature deviation **0.0** °F

Central Heating Coil Sizing Data

Max coil load **307.4** MBH
Coil CFM at Des Htg **5622** CFM
Max coil CFM **5622** CFM
Water flow @ 20.0 °F drop **N/A**

Load occurs at **Des Htg**
BTU/(hr-ft²) **189.8**
Ent. DB / Lvg DB **17.0 / 67.7** °F

Supply Fan Sizing Data

Actual max CFM **5622** CFM
Standard CFM **5616** CFM
Actual max CFM/ft² **3.47** CFM/ft²

Fan motor BHP **10.00** BHP
Fan motor kW **7.46** kW

Outdoor Ventilation Air Data

Design airflow CFM **5060** CFM
CFM/ft² **3.12** CFM/ft²

CFM/person **506.00** CFM/person

Air System Sizing Summary for AHU12 Sys

Project Name: jxf_lab_mech2b_ACH
Prepared by: psuae

Appendix C - HAP Output

10/29/2003
07:17AM

Air System Information

Air System Name **AHU12 Sys**
Equipment Class **PKG ROOF**
Air System Type **SZCAV**

Number of zones **1**
Floor Area **8044.3** ft²

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM **Sum of space airflow rates**
Space CFM **Individual peak space loads**

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Central Cooling Coil Sizing Data

Total coil load **80.3** Tons
Total coil load **963.3** MBH
Sensible coil load **611.3** MBH
Coil CFM at Jul 1500 **14865** CFM
Max block CFM **14865** CFM
Sum of peak zone CFM **14122** CFM
Sensible heat ratio **0.635**
ft²/Ton **100.2**
BTU/(hr-ft²) **119.7**
Water flow @ 10.0 °F rise **N/A**

Load occurs at **Jul 1500**
OA DB / WB **92.0 / 75.0** °F
Entering DB / WB **82.9 / 67.5** °F
Leaving DB / WB **44.8 / 43.9** °F
Coil ADP **40.5** °F
Bypass Factor **0.100**
Resulting RH **35** %
Design supply temp. **50.8** °F
Zone T-stat Check **1 of 1** OK
Max zone temperature deviation **0.0** °F

Central Heating Coil Sizing Data

Max coil load **447.4** MBH
Coil CFM at Des Htg **14865** CFM
Max coil CFM **14865** CFM
Water flow @ 20.0 °F drop **N/A**

Load occurs at **Des Htg**
BTU/(hr-ft²) **55.6**
Ent. DB / Lvg DB **37.7 / 65.6** °F

Supply Fan Sizing Data

Actual max CFM **14865** CFM
Standard CFM **14849** CFM
Actual max CFM/ft² **1.85** CFM/ft²

Fan motor BHP **40.00** BHP
Fan motor kW **29.83** kW

Outdoor Ventilation Air Data

Design airflow CFM **8250** CFM
CFM/ft² **1.03** CFM/ft²

CFM/person **222.97** CFM/person

Air System Sizing Summary for AHU13 Sys

Project Name: jxf_lab_mech2b_ACH
Prepared by: psuae

Appendix C - HAP Output

10/29/2003
07:17AM

Air System Information

Air System Name **AHU13 Sys**
Equipment Class **PKG ROOF**
Air System Type **SZCAV**

Number of zones **1**
Floor Area **6541.9** ft²

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM **Sum of space airflow rates**
Space CFM **Individual peak space loads**

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Central Cooling Coil Sizing Data

Total coil load **58.7** Tons
Total coil load **704.9** MBH
Sensible coil load **454.5** MBH
Coil CFM at Jul 1600 **11613** CFM
Max block CFM **11613** CFM
Sum of peak zone CFM **11032** CFM
Sensible heat ratio **0.645**
ft²/Ton **111.4**
BTU/(hr-ft²) **107.8**
Water flow @ 10.0 °F rise **N/A**

Load occurs at **Jul 1600**
OA DB / WB **91.5 / 74.9** °F
Entering DB / WB **81.8 / 66.8** °F
Leaving DB / WB **45.6 / 44.7** °F
Coil ADP **41.5** °F
Bypass Factor **0.100**
Resulting RH **36** %
Design supply temp. **51.0** °F
Zone T-stat Check **1 of 1** OK
Max zone temperature deviation **0.0** °F

Central Heating Coil Sizing Data

Max coil load **327.5** MBH
Coil CFM at Des Htg **11613** CFM
Max coil CFM **11613** CFM
Water flow @ 20.0 °F drop **N/A**

Load occurs at **Des Htg**
BTU/(hr-ft²) **50.1**
Ent. DB / Lvg DB **40.1 / 66.2** °F

Supply Fan Sizing Data

Actual max CFM **11613** CFM
Standard CFM **11600** CFM
Actual max CFM/ft² **1.78** CFM/ft²

Fan motor BHP **30.00** BHP
Fan motor kW **22.37** kW

Outdoor Ventilation Air Data

Design airflow CFM **5960** CFM
CFM/ft² **0.91** CFM/ft²

CFM/person **192.26** CFM/person

Air System Sizing Summary for AHU14 Sys

Project Name: jxf_lab_mech2b_ACH
Prepared by: psuae

Appendix C - HAP Output

10/29/2003
07:17AM

Air System Information

Air System Name **AHU14 Sys**
Equipment Class **PKG ROOF**
Air System Type **SZCAV**

Number of zones **1**
Floor Area **1035.4** ft²

Sizing Calculation Information

Zone and Space Sizing Method:

Zone CFM **Sum of space airflow rates**
Space CFM **Individual peak space loads**

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Central Cooling Coil Sizing Data

Total coil load **23.3** Tons
Total coil load **280.0** MBH
Sensible coil load **160.5** MBH
Coil CFM at Jul 1400 **4095** CFM
Max block CFM **4095** CFM
Sum of peak zone CFM **3890** CFM
Sensible heat ratio **0.573**
ft²/Ton **44.4**
BTU/(hr-ft²) **270.5**
Water flow @ 10.0 °F rise **N/A**

Load occurs at **Jul 1400**
OA DB / WB **91.5 / 74.9** °F
Entering DB / WB **90.3 / 74.2** °F
Leaving DB / WB **54.0 / 53.0** °F
Coil ADP **49.9** °F
Bypass Factor **0.100**
Resulting RH **57** %
Design supply temp. **53.0** °F
Zone T-stat Check **1 of 1** OK
Max zone temperature deviation **0.0** °F

Central Heating Coil Sizing Data

Max coil load **229.8** MBH
Coil CFM at Des Htg **4095** CFM
Max coil CFM **4095** CFM
Water flow @ 20.0 °F drop **N/A**

Load occurs at **Des Htg**
BTU/(hr-ft²) **221.9**
Ent. DB / Lvg DB **13.8 / 65.9** °F

Supply Fan Sizing Data

Actual max CFM **4095** CFM
Standard CFM **4090** CFM
Actual max CFM/ft² **3.95** CFM/ft²

Fan motor BHP **5.00** BHP
Fan motor kW **3.73** kW

Outdoor Ventilation Air Data

Design airflow CFM **3890** CFM
CFM/ft² **3.76** CFM/ft²

CFM/person **648.33** CFM/person