



space	Sensible Cooling (BTU/hr)	Latent Cooling (BTU/hr)	Heating (BTU/hr)	Latent Removal CFM	Sensible Removal CFM	Latent Removal CFM	Minimum OA (Vbz) CFM	Resultant Sensible Removal (BTU/hr)	Remaining Sensible (BTU/hr)	Min SA (l/s)	SA via Beam (l/s)	SA w/o Beam l/s	Oversupply Test	Length of Beam (mm)	Beam Qty	Beam Cooling (W)/unit	Beam DeltaTw (K)	Beam Water Flow (l/h)/unit	Heating (W)	Heating Test	Beam Heating (W)/unit	Beam DeltaTw (K)	Beam Water Flow (l/h)/unit	Balance of Qs (overcooling) (W)
B086	786		457	0	35	0	14	420	366	6.8	12.5		Oversupply	900	1	144	1.1	110	134					(14)
B088	1,616	410	802	35	72	26	11	764	852	12.4	12.4			900	2	125	1	110	235					(0)
B075	905	410		35	40	26	10	764	141	12.4	15.0								0					(6)
B077	905	410		35	40	26	10	764	141	12.4	15.0								0					(6)
B012				0	0	0	0	0	0	0.0	0.0								0					0
B010				0	0	0	0	0	0	0.0	0.0								0					0
B079				0	0	0	0	0	0	0.0	0.0								0					0
B081				0	0	0	0	0	0	0.0	0.0								0					0
B083				0	0	0	0	0	0	0.0	0.0								0					0
B008	369			0	16	0	5	144	225	2.3	6.0								0					(0)
B085	1,191	820		71	53	52	6	1,529	338	24.7	24.7			900	1				0		100	2	50	1
B000	23,290	8,520	2,418	737	1,037	545	332	15,885	7,405	257.1	180.0	121.0	Oversupply	1800	4	344	2.7	110	709					(0)
B087A	905	410		35	40	26	17	764	141	12.4	15.0								0					(6)
B087	1,025	410		35	46	26	13	764	261	12.4	17.0		Oversupply						0					(7)
B089				0	0	0	3	99	99	1.6	12.0		Oversupply	900	1				0		200	3.5	62	(17)
B087B	320			0	14	0	17	483	163	7.8	12.0		Oversupply	900	1				0		130	2.5	50	7
B101	699			0	31	0	9	274	425	4.4	12.0		Oversupply	900	1				0					Unit added for cooling capacity (12)
B103	1,605	820		71	71	52	16	1,529	76	24.7	26.0			900	1				0					Unit added for cooling capacity (0)
B150				0	0	0	28	815	815	13.2	13.2			900	1				0					1
B153	2,420	1,080	468	93	108	69	37	2,014	406	32.6	12.0	20.6		900	1	125	1	110	137		240	2	110	(6)
B148	1,605	820		71	71	52	16	1,529	76	24.7	26.0			900	1				0					Unit added for cooling capacity (0)
B151				0	0	0	5	144	144	2.3	12.0		Oversupply	900	1				0		220	2	110	3
B149	1,143	615	266	53	51	39	11	1,147	4	18.6	18.6			900	1				78		75	1.5	54	74
B147	1,143	615	266	53	51	39	11	1,147	4	18.6	18.6			900	1				78		75	1.5	54	74
B145	1,143	615	266	53	51	39	11	1,147	4	18.6	18.6			900	1				78		75	1.5	54	74
B143	1,143	615	266	53	51	39	11	1,147	4	18.6	18.6			900	1				78		75	1.5	54	74
B141	614		295	0	27	0	17	483	131	7.8	10.0			900	1				86		75	1.5	54	74
B109	1,139	615		53	51	39	11	1,147	8	18.6	18.6			900	1				0					(2)
B107	1,139	615		53	51	39	11	1,147	8	18.6	18.6			900	1				0					(2)
B105	1,139	615		53	51	39	11	1,147	8	18.6	18.6			900	1				0					(2)
B110	10,639	1,640	4,995	142	474	105	81	3,058	7,581	49.5	108.0		Oversupply	900	6	193	1.5	110	1,464					5
B111	1,094	615		53	49	39	10	1,147	53	18.6	23.0		Oversupply	900	1				0		100	2	50	4
B106	1,094	615		53	49	39	10	1,147	53	18.6	23.0		Oversupply	900	1				0		100	2	50	4
B108	1,650	1,230		106	73	79	10	2,293	643	37.1	12.0	25.1		900	1				0		200	3.5	50	12
B113	307			0	14	0	8	241	66	3.9	5.0			900	1				0					Unit added for cooling capacity (1)
B135	4,015	3,280		284	179	210	54	6,115	2,100	99.0	36.0	62.0		900	3				0		200	3.5	50	2
B137	231			0	10	0	6	181	50	2.9	4.0			900	1				0					(5)
B118	10,591	1,640	4,995	142	471	105	81	3,058	7,533	49.5	108.0		Oversupply	900	6	193	1.5	110	1,464					(10)
B115				0	0	0	0	0	0	0.0	0.0								0					0
B134				0	0	0	0	0	0	0.0	0.0								0					0
B117				0	0	0	0	0	0	0.0	0.0								0					0
B119				0	0	0	0	0	0	0.0	0.0								0					0
B132	1,891	615		53	84	39	26	1,147	744	18.6	12.0	8.0		900	1	193	1.5	110	0					(1)
MES BB	303			0	13	0	8	238	65	3.9	12.0		Oversupply	900	1				0		130	2.5	56	2
B123	142			0	6	0	4	112	30	1.8	2.5			900	1				0					(4)
B30				0	0	0	0	0	0	0.0	0.0								0					0
B127	3,833	1,680	618	145	171	107	86	3,132	701	50.7	27.0	24.0		900	1	193	1.5	110	181					7
B126A	1,424	205	1,180	18	63	13	9	382	1,042	6.2	15.0		Oversupply	900	2	144	1.1	110	346					second unit added for htg capabil #VALUE!
B126	1,861	410	1,048	35	83	26	13	764	1,097	12.4	18.0	3.0	Oversupply	900	1	159	1.2	110	307	AddHtg	heating capable			#VALUE!
B124	630	205	197	18	28	13	9	382	248	6.2	10.0			900	1				58		heating capable			#VALUE!
B122	2,912	410	995	35	130	26	11	764	2,148	12.4	31.0		Oversupply	900	2	144	1.1	110	292					4
B120	3,731	410	2,016	35	166	26	11	764	2,967	12.4	40.0		Oversupply	900	3	125	1	110	591					(6)
CB-9.7	1,525			0	68	0	31	899	626	14.6	25.0		Oversupply	900	2				0					(6)
CB-10	1,584		597	0	71	0	32	933	651	15.1	26.0		Oversupply	900	2				175		heating capable			#VALUE!
CB-14	1,584			0	71	0	29	834	750	13.5	26.0		Oversupply						0					(7)
CB-15	540			0	24	0	11	318	222	5.1	9.0								0					(5)
CB-13	768			0	34	0	16	452	316	7.3	13.0		Oversupply						0					(10)
CB-11	279			0	12	0	6	164	115	2.7	5.0								0					(9)
	98,872	31,370	22,145	2,714	4,401	2,006	1,205	58,488	40,384	SA SUl	5,848	Beam Sum	900 mm	82	cold water	(l/h)	4,400	8,360	hot water	(l/h)	1,908			
		130,242			7,115					cfm	1		1800 mm	4	Clg Cap	(BTU/hr)	25,361	SUM of Heating			8			

space	DOAS application					Trolox Active Chilled/Heated Beam Estimator																		
	Sensible Cooling (BTU/hr)	Latent Cooling (BTU/hr)	Heating (BTU/hr)	Latent Removal CFM	Sensible Removal CFM	Latent Removal CFM	Minimum OA (Vbz) CFM	Resultant Sensible Removal (BTU/hr)	Remaining Sensible (BTU/hr)	Min SA (l/s)	SA via Beam (l/s)	SA w/o Beam l/s	Oversupply Test	Length of Beam (mm)	Beam Qty	Beam Cooling (W)/unit	Beam DeltaTw (K)	Beam Water Flow (l/h)/unit	Heating (W)	Heating Test	Beam Heating (W)/unit	Beam DeltaTw (K)	Beam Water Flow (l/h)/unit	Balance of Qs (overcooling) (W)
1058	3,008	410	1,095	35	134	26	14	764	2,244	12.4	33.0		Oversupply	900	2	144	1.1	110	321					(4)
1057	5,999	410	1,960	35	267	26	17	764	5,235	12.4	68.0		Oversupply	900	3	172	1.3	110	574					11
1055	4,266	410	1,296	35	190	26	17	764	3,502	12.4	36.0	12	Oversupply	900	3	125	1	110	380					6
1053	4,266	410	1,296	35	190	26	17	764	3,502	12.4	36.0	12	Oversupply	900	3	125	1	110	380					6
1051	6,225	410	2,964	35	277	26	17	764	5,461	12.4	54.0	18	Oversupply	900	3	172	1.3	110	869	Add Htg	htg capable			#VALUE!
1056	1,158	1,025		89	52	66	11	1,911	753	30.9	30.9			900	1				0		220	2	110	(1)
1060	1,217	615	83	53	54	39	11	1,147	70	18.6	20.0			900	1				24	Units added because of exterior wall				#VALUE!
1062	1,090	615		53	49	39	10	1,147	57	18.6	18.6			900	1				0	Units added because of exterior wall				(17)
1064	1,090	615		53	49	39	10	1,147	57	18.6	18.6			900	1				0	Units added because of exterior wall				(17)
1066				0	0	0	0	0	0	0.0	0.0			900	1				0	Units added because of exterior wall				0
1068				0	0	0	0	0	0	0.0	0.0			900	1				0	Units added because of exterior wall				0
1070	1,090	615		53	49	39	10	1,147	57	18.6	18.6			900	1				0	Units added because of exterior wall				(17)
1072	1,090	615		53	49	39	10	1,147	57	18.6	18.6			900	1				0	Units added because of exterior wall				(17)
1074	1,090	615		53	49	39	10	1,147	57	18.6	18.6			900	1				0	Units added because of exterior wall				(17)
1076	1,090	615		53	49	39	10	1,147	57	18.6	18.6			900	1				0	Units added because of exterior wall				(17)
1078	1,090	615		53	49	39	10	1,147	57	18.6	18.6			900	1				0	Units added because of exterior wall				(17)
1080	1,090	615		53	49	39	10	1,147	57	18.6	18.6			900	1				0	Units added because of exterior wall				(17)
1082	1,090	615		53	49	39	28	1,147	57	18.6	18.6			900	1				0	Units added because of exterior wall				(17)
1084	267			0	12	0	7	210	57	3.4	4.0			900	1				0	Units added because of exterior wall				6
1086	1,562	410	990	35	70	26	8	764	798	12.4	15.0	2	Oversupply	900	1	144	1.1	110	290	Add Htg	htg capable			#VALUE!
1061	1,117	615		53	50	39	11	1,147	30	18.6	18.6			900	1				0					(9)
1054	1,223	615		53	54	39	13	1,147	76	18.6	20.0			900	1				0					(4)
1042	1,170	615		53	52	39	12	1,147	23	18.6	18.6			900	1				0					7
1040	1,068	615		53	48	39	10	1,147	79	18.6	18.6			900	1				0					(23)
1031	1,094	615		53	49	39	10	1,147	53	18.6	18.6			900	1				0					(15)
1035	2,862	1,440		125	127	92	37	2,685	177	43.5	46.0			900	2				0	Units added to increase cooling capacity				6
1035A	507			0	23	0	14	399	108	6.5	6.5			900	1				0					32
1063	1,090	615		53	49	39	10	1,147	57	18.6	18.6			900	1				0					(17)
1037	1,117	615		53	50	39	11	1,147	30	18.6	18.6			900	1				0					(9)
1041	11,366	1,920	4,232	166	506	123	65	3,580	7,786	57.9	127.0		Oversupply	900	6	172	1.3	110	1,240					(0)
1019	1,427	720		62	64	46	18	1,342	85	21.7	23.0			900	1				0					2
1019A	3,374	615	1,268	53	150	39	9	1,147	2,227	18.6	37.0		Oversupply	900	2	159	1.2	110	372					1
1017	3,387	615	1,213	53	151	39	10	1,147	2,240	18.6	37.0		Oversupply	900	2	159	1.2	110	355					5
1015	3,420	615	1,228	53	152	39	10	1,147	2,273	18.6	38.0		Oversupply	900	2	159	1.2	110	360					(4)
1013	3,444	615	1,228	53	153	39	11	1,147	2,297	18.6	38.0		Oversupply	900	2	159	1.2	110	360					3
1011	11,017	2,400	3,352	208	490	153	23	4,475	6,542	72.4	128.0		Oversupply	900	5	183	1.4	110	982					(4)
1029	2,196	820	190	71	98	52	24	1,529	667	24.7	18.0	9		900	1	159	1.2	110	56					(4)
1034	1,134	615		53	50	39	11	1,147	13	18.6	18.6			900	1				0					(4)
1032	1,108	615		53	49	39	10	1,147	39	18.6	18.6			900	1				0					(11)
MES A1	307			0	14	0	8	241	66	3.9	3.9			900	1				0	Units added to increase cooling capacity				19
1027	334			0	15	0	9	262	72	4.2	4.2			900	1				0					21
1025	503			0	22	0	14	394	109	6.4	8.0			900	1				0					3
1023	360			0	16	0	10	284	76	4.6	6.0			900	1				0					(3)
1028	1,117	615		53	50	39	11	1,147	30	18.6	18.6			900	1				0					(9)
1026	1,072	615		53	48	39	10	1,147	75	18.6	18.6			900	1				0					(22)
1024	1,072	615		53	48	39	10	1,147	75	18.6	18.6			900	1				0					(22)
1014	1,072	615		53	48	39	10	1,147	75	18.6	18.6			900	1				0					(22)
1075	5,150	1,230	399	106	229	79	246	7,173	2,023	116.1	117.0			900	2			117		308	5.3	50		7
1012				0	0	0	0	0	0	0.0	0.0			900	1				0					0
1010				0	0	0	0	0	0	0.0	0.0			900	1				0					0
1081				0	0	0	0	0	0	0.0	0.0			900	1				0					0
1083				0	0	0	0	0	0	0.0	0.0			900	1				0					0
CRI-002	776	410		35	35	26	8	764	12	12.4	12.4			900	1				0	Units added to increase cooling capacity				3
1009	962	410		35	43	26	11	764	198	12.4	16.0			900	1				0	Units added to increase cooling capacity				(8)
1091	2,034	1,640		142	91	105	27	3,058	1,024	49.5	50.0			900	1				0		308	5.3	50	(1)
1093	1,414	615	133	53	63	39	13	1,147	267	18.6	23.0		Oversupply	900	1				39	Units added to increase cooling capacity				(2)
1095	262			66	0	12	0	3	99	1.6	5.0			900	1				19	Units added to increase cooling capacity				(14)
1093A	534		133	0	24	0	18	537	3	8.7	12.0			900	1				39		75	1.5	54	14
1098	1,352	615	334	53	60	39	13	1,147	205	18.6	22.0			900	1				98		htg capable			#VALUE!
1001	570			0	25	0	8	224	346	3.6	50.0		Oversupply	1800	1				0		726	12.5	50	(12)
1000	45,819	12,000	10,024	1,038	2,040	767	298	22,373	23,446	362.1	500.0	42	Oversupply	1800	10	361	2.8	110	2,938	Add Htg	htg capable			#VALUE!
C1-5	3,544		1,117	0	158	0	26	751	2,793	12.1	58.0		Oversupply	900	1				327	Add Htg	339	5.8	63	328
C1-6	4,203		1,341	0	187	0	63	1,843	2,360	29.8	68.0		Oversupply	900	1				393	Add Htg	387	6.7	63	388
C1-3	934		86	0	42	0	17	486	448	7.9	15.0		Oversupply	900	1				25	Add Htg	htg capable			#VALUE!

C1-4	566	182	0	25	0	10	284	282	4.6	9.0	Oversupply	900	1	53	htg capable	#VALUE!
C1-2	534		0	24	0	11	315	219	5.1	9.0				0		(6)
C1-1	1,163		0	52	0	24	686	477	11.1	19.0	Oversupply			0		(3)
C1-10	350		0	16	0	7	206	144	3.3	6.0				0		(6)
A-1	0		0	0	0	0	0	0	0.0	0.0				0		0
B-1	0		0	0	0	0	0	0	0.0	0.0				0		0
	166,903	44,310	36,210	3,833	7,430	2,833	1,428	82,614	84,289							48,914
		211,213			11,263	13,505	0	393,796	393,796							0

space	Sensible Cooling (BTU/hr)	Latent Cooling (BTU/hr)	Heating (BTU/hr)	Latent Removal CFM	Sensible Removal CFM	Latent Removal CFM	Minimum OA (Vbz) CFM	Resultant Sensible Removal (BTU/hr)	Remaining Sensible (BTU/hr)	Min SA (l/s)	SA via Beam (l/s)	SA w/o Beam (l/s)	Oversupply Test	Length of Beam (mm)	Beam Qty	Beam Cooling (W/unit)	Beam DeltaTw (K)	Beam Water Flow (l/h/unit)	Heating (W)	Heating Test	Beam Heating (W/unit)	Beam DeltaTw (K)	Beam Water Flow (l/h/unit)	Balance of Qs (overcooling) (W)	
1097	1,157	615		53	52	39	11	1,147	10	18.6	18.6			900	1				0	Unit added to increase cooling capacity				3	
1100	1,769	615	1,072	53	79	39	9	1,147	622	18.6	12.0	10		900	1	125	1	110	314	Add Htg				(5)	
1102	7,359	2,160	2,929	187	328	138	118	4,027	3,332	65.2	72.0	12	Oversupply	900	4	159	1.2	110	858					(0)	
1114	3,237	615	1,209	53	144	39	11	1,147	2,090	18.6	36.0		Oversupply	900	2	144	1.1	110	354					9	
1116	1,219	615	269	53	54	39	11	1,147	72	18.6	20.0			900	1				79	unit added because of exterior wall				(5)	
1118	1,967	615	1,263	53	88	39	11	1,147	820	18.6	22.0			900	1	172	1.3	110	370	Add Htg				6	
1161	1,037	615		53	46	39	9	1,147	110	18.6	18.6								0					(32)	
1159	1,090	615		53	49	39	10	1,147	57	18.6	18.6								0					(17)	
1157	1,117	615		53	50	39	11	1,147	30	18.6	18.6								0					(9)	
1155	3,576	615	1,199	53	159	39	14	1,147	2,429	18.6	40.0		Oversupply	900	2	159	1.2	110	351					6	
1153	3,404	615	1,199	53	152	39	10	1,147	2,257	18.6	36.0		Oversupply	900	3	125	1	110	351					(29)	
1151	2,666	615	886	53	119	39	10	1,147	1,519	18.6	29.0		Oversupply	900	2	125	1	110	260					6	
1149	2,672	615	901	53	119	39	10	1,147	1,525	18.6	29.0		Oversupply	900	2	125	1	110	264					8	
1147	2,672	615	901	53	119	39	10	1,147	1,525	18.6	29.0		Oversupply	900	2	125	1	110	264					8	
1145	2,672	615	901	53	119	39	10	1,147	1,525	18.6	29.0		Oversupply	900	2	125	1	110	264					8	
1144	1,094	615		53	49	39	129	3,774	2,680	61.1	62.0			900	3				0		269	4.6	50	5	
1143	2,672	615	901	53	119	39	10	1,147	1,525	18.6	29.0		Oversupply	900	2	125	1	110	264					8	
1141	2,672	615	901	53	119	39	10	1,147	1,525	18.6	29.0		Oversupply	900	2	125	1	110	264					8	
1101	1,709	820	151	71	76	52	15	1,529	180	24.7	28.0			900	1				44	Unit added to increase cooling capacity				(6)	
1158	427			0	19	0	12	336	91	5.4	5.4								0					27	
1103	1,775			0	79	0	48	1,396	379	22.6	22.6			900	1	125	1	110	0					(14)	
1105	727	410		35	32	26	-69	764	37	12.4	12.4								0					(11)	
1148	1,094	615		53	49	39	10	1,147	53	18.6	18.6								0					(15)	
1146	1,094	615		53	49	39	10	1,147	53	18.6	18.6								0					(15)	
1133	1,094	615		53	49	39	10	1,147	53	18.6	18.6								0					(15)	
1135	587			0	26	0	160	4,672	4,085	75.6	60.0	24	Oversupply	900	5				0		269	4.6	50	(4)	
1138				0	0	0	0	0	0	0.0	0.0								0					0	
1139	402		69	0	18	0	0	0	402	0.0	7.0		Oversupply						20	Add Htg				(9)	
1136				0	0	0	0	0	0	0.0	0.0								0					0	
1113				0	0	0	0	0	0	0.0	0.0								0					0	
1115				0	0	0	0	0	0	0.0	0.0								0					0	
1134	1,502	820		71	67	52	14	1,529	27	24.7	24.7			900	2				0	Units added to increase cooling capacity				(8)	
1123	601			0	27	0	8	236	365	3.8	10.0		Oversupply						0					(5)	
1120	4,527	615	2,441	53	202	39	8	1,147	3,380	18.6	49.0		Oversupply	900	3	144	1.1	110	715					8	
1122	1,030	615	203	53	46	39	8	1,147	117	18.6	18.6			900	1				59					(34)	
1124	1,808	615	901	53	80	39	10	1,147	661	18.6	12.0	10		900	1	125	1	110	264					7	
1126	1,838	615	913	53	82	39	11	1,147	691	18.6	12.0	11	Oversupply	900	1	125	1	110	268					(3)	
1128	4,017	615	2,327	53	179	39	15	1,147	2,870	18.6	36.0	8	Oversupply	900	3	125	1	110	682					6	
1129	8,728	1,920	3,193	166	389	123	21	3,580	5,148	57.9	90.0	7	Oversupply	900	5	159	1.2	110	936					7	
1130				0	0	0	0	0	0	0.0	0.0								0					0	
1150	2,146	1,640		142	96	105	46	3,058	912	49.5	12.0	38		900	1				0		269	4.6	50	(7)	
C1-8	5,470		2,289	0	244	0	36	1,059	4,411	17.1	89.0		Oversupply	900	4				671	Units added to increase heating capacity				(8)	
C1-12	991			0	44	0	20	583	408	9.4	16.0		Oversupply						0					1	
C1-11	1,795			0	80	0	36	1,059	736	17.1	29.0		Oversupply						0					1	
C1-15	608		72	0	27	0	10	303	305	4.9	10.0		Oversupply						21	Add Htg				(3)	
C1-9	605			0	27	0	12	356	249	5.8	10.0		Oversupply						0					(4)	
C1-13	627		87	0	28	0	10	303	324	4.9	10.0		Oversupply						25	Add Htg				3	
C-1				0	0	0	0	0	0	0.0	0.0													0	
	89,254	23,145	27,177	2,002	3,973	1,480	877	43,153	46,101																
		112,399			5,975																				
										SA SUM	7,635	Beam Sum	900 mm	122	cold water	(l/h)	9,240	18,577	hot water	(l/h)	940				
										cfm	11	1800 mm	11				41	SUM of			4				
																Clg Cap	(BTU/hr)	49,791	Heating						17,374

space	DOAS application				Trolox Active Chilled/Heated Beam Estimator														Balance of Qs (overcooling) (W)					
	Latent Cooling	Heating	Latent Removal	Sensible Removal	Latent Removal	Minimum OA (Vbz)	Resultant Sensible Removal	Remaining Sensible	Min SA	SA via Beam	SA w/o Beam	Oversupply Test	Length of Beam	Beam Qty	Beam Cooling	Beam DeltaTw	Beam Water Flow	Heating		Heating Test	Beam Heating	Beam DeltaTw	Beam Water Flow	
	(BTU/hr)	(BTU/hr)	(CFM)	(CFM)	CFM	CFM	(BTU/hr)	(BTU/hr)	(l/s)	(l/s)	l/s		(mm)		(W)/unit	(K)	(l/h)/unit	(W)			(W)/unit	(K)	(l/h)/unit	
2055	820	2,536	71	91	52	15	1,529	526	24.7	63.0		5 Oversupply	900	3	172	1.3	110	743					(1,145)	
2053	410	1,268	35	91	26	10	764	1,289	12.4	36.0		7 Oversupply	900	3	125	1	110	372					(552)	
2051	410	2,399	35	91	26	9	764	1,287	12.4	54.0		7 Oversupply	900	3	159	1.2	110	703					(980)	
2056	410	1,519	35	92	26	14	764	1,292	12.4	36.0		4 Oversupply	900	3	125	1	110	445					(497)	
2063	410	589	35	92	26	10	764	1,299	12.4	26.0		Oversupply	900	1	183	1.4	110	173					(49)	
2061	410		35	92	26	10	764	1,297	12.4	14.0							0						351	
2062	410	1,213	35	92	26	10	764	1,298	12.4	21.0		Oversupply	900	1	172	1.3	110	355 Add Htg	htg capable				#VALUE!	
2060	410	1,213	35	92	26	10	764	1,296	12.4	21.0		Oversupply	900	1	172	1.2	110	355 Add Htg	htg capable				#VALUE!	
2065	410	729	35	92	26	11	764	1,301	12.4	27.0		Oversupply	900	1	193	1.5	110	214					(77)	
2064	410	1,005	35	92	26	11	764	1,300	12.4	19.0		Oversupply	900	1	159	1.2	110	295 Add Htg	htg capable				#VALUE!	
2054	410		35	91	26	8	764	1,290	12.4	12.4							0						378	
2044	410		35	91	26	8	764	1,280	12.4	12.4			900	1			0	Units added to increase cooling capacity					375	
2033	410		35	91	26	7	764	1,269	12.4	12.4							0						372	
2042	410		35	91	26	8	764	1,278	12.4	12.4			900	1			0	Units added to increase cooling capacity					374	
2032	410		35	90	26	10	764	1,268	12.4	14.0							0						342	
2030	410		35	90	26	10	764	1,266	12.4	14.0							0						341	
2067	410		35	92	26	7	764	1,303	12.4	12.4							0						382	
2071	410		35	92	26	7	764	1,307	12.4	12.4							0						383	
2075	410	1,096	35	92	26	10	764	1,311	12.4	36.0		Oversupply	900	3	125	1	110	321					(419)	
2073	410	1,068	35	92	26	10	764	1,309	12.4	36.0		Oversupply	900	3	125	1	110	313					(419)	
2074	410	1,096	35	92	26	10	764	1,310	12.4	20.0		Oversupply	900	1	159	1.2	110	321 Add Htg	htg capable				#VALUE!	
2072	410	1,068	35	92	26	10	764	1,308	12.4	20.0		Oversupply	900	1	159	1.2	110	313 Add Htg	htg capable				#VALUE!	
2077	410	1,018	35	92	26	11	764	1,313	12.4	36.0		Oversupply	900	2	159	1.2	110	298					(361)	
2076	410	990	35	92	26	11	764	1,312	12.4	19.0		Oversupply	900	1	159	1.2	110	290 Add Htg	htg capable				#VALUE!	
MES A2			0 #VALUE!		0	8	231	#VALUE!	3.7	3.7			900	1			0	Unit added because of electrical equipmer					#VALUE!	
2022	615		53	90	39	11	1,147	875	18.6	18.6							0						257	
2018	3,360		291	90	215	134	6,265	4,247	101.4	101.4			900	2	172	1.3	110	0					(1,589)	
2026	410		35	90	26	12	764	1,262	12.4	16.0							0						304	
2023	410	1,240	35	90	26	9	764	1,259	12.4	30.0		6 Oversupply	900	2	144	1.1	110	363					(347)	
2021	410	1,240	35	90	26	9	764	1,257	12.4	30.0		6 Oversupply	900	2	144	1.1	110	363					(348)	
2019	820	2,314	71	90	52	12	1,529	490	24.7	60.0		7 Oversupply	900	4	144	1.1	110	678					(1,197)	
2017	410	1,240	35	90	26	9	764	1,253	12.4	30.0		6 Oversupply	900	2	144	1.1	110	363					(349)	
2015	410	1,435	35	90	26	10	764	1,251	12.4	36.0		Oversupply	900	2	159	1.2	110	421					(379)	
2125	615		53	95	39	9	1,147	978	18.6	18.6			900	1			0	Unit added because of exterior wall					287	
2127	615	1,848	53	95	39	12	1,147	980	18.6	33.0		Oversupply	900	2	144	1.1	110	542 Add Htg	htg capable				#VALUE!	
C2-2			0 #VALUE!		0	6	177	#VALUE!	2.9	2.9							0						#VALUE!	
C2-6			0 #VALUE!		0	9	254	#VALUE!	4.1	7.0			900	1			0	Unit added because of exterior wall					#VALUE!	
C2-7		1,290	0 #VALUE!		0	38	1,094	#VALUE!	17.7	45.0		Oversupply	900	4			378		387	6.8	63		#VALUE!	
C2-4		1,324	0 #VALUE!		0	8	240	#VALUE!	3.9	47.0		Oversupply	900	1			388 Add Htg	387	6.8	63			#VALUE!	
C2-5			0 #VALUE!		0	6	183	#VALUE!	3.0	4.0			900	1			0	Unit added because of exterior wall					#VALUE!	
C2-8			0 #VALUE!		0	8	231	#VALUE!	3.7	6.0							0						#VALUE!	
	18,325	30,738	1,585	0	1,172	543	34,166	34,166																
	18,325			1,585	1,172	0	34,166	34,166																

space	DOAS application				Trolox Active Chilled/Heated Beam Estimator														Balance of Qs (overcooling) (W)				
	Latent Cooling	Heating	Latent Removal	Sensible Removal	Latent Removal	Minimum OA (Vbz)	Resultant Sensible Removal	Remaining Sensible	Min SA	SA via Beam	SA w/o Beam	Oversupply Test	Length of Beam	Beam Qty	Beam Cooling	Beam DeltaTw	Beam Water Flow	Heating		Heating Test	Beam Heating	Beam DeltaTw	Beam Water Flow
	(BTU/hr)	(BTU/hr)	(CFM)	(CFM)	CFM	CFM	(BTU/hr)	(BTU/hr)	(l/s)	(l/s)	l/s		(mm)		(W)/unit	(K)	(l/h)/unit	(W)			(W)/unit	(K)	(l/h)/unit
2041	1,230	3,851	106	91	79	14	2,293	252	37.1	105.0		1 Oversupply	900	5	172	1.3	110	1,129					(2,181)
2027	410	1,200	35	90	26	8	764	1,263	12.4	30.0		5 Oversupply	900	2	144	1.1	110	352					(328)
2025	410	1,200	35	90	26	8	764	1,261	12.4	30.0		5 Oversupply	900	2	144	1.1	110	352					(328)
2079			0	93	0	0	0	2,079	0.0	0.0								0					609
2013			0	90	0	0	0	2,013	0.0	0.0								0					590
2085	1,230	1,905	106	93	79	17	2,293	208	37.1	72.0		1 Oversupply	900	4	159	1.2	110	558					(1,347)
2083	820	1,096	71	93	52	12	1,529	554	24.7	42.0		4 Oversupply	900	2	172	1.3	110	321					(566)
2086			0	93	0	9	252	1,834	4.1	4.1							0						538
2088	2,460	1,262	213	93	157	32	4,587	2,499	74.2	77.0			900	4			370	Units added to increase cooling capacity					(782)

2082			0	93	0	11	325	1,757	5.3	5.3						0	515	
2002	5,400	3,208	467	89	345	195	10,068	8,066	163.0	162.0	5 Oversupply	900	6	193	1.5	110	940	(3,595)
2012	410		35	90	26	10	764	1,248	12.4	14.0						0	336	
2081			0	93	0	19	558	1,523	9.0	12.0						0	393	
2011	4,100	3,074	355	90	262	55	7,644	5,633	123.7	108.0	22 Oversupply	900	4	193	1.5	110	901	(2,536)
2095	410	1,554	35	93	26	10	764	1,331	12.4	36.0	5 Oversupply	900	2	159	1.2	110	455	(446)
2093	410	1,043	35	93	26	7	764	1,329	12.4	36.0	2 Oversupply	900	2	159	1.2	110	306	(393)
2091	615	1,123	53	93	39	11	1,147	944	18.6	42.0	1 Oversupply	900	2	172	1.3	110	329	(510)
2089	2,870		248	93	184	64	5,351	3,262	86.6	24.0	63	900	2				0	(418)
2057	1,230		106	92	79	21	2,293	236	37.1	37.1		900	3				0	(69)
1094	615	1,549	53	49	39	12	1,147	53	18.6	24.0	Oversupply	900	2	125	1	110	454	(364)
2096	2,050	2,193	177	93	131	20	3,822	1,726	61.9	24.0	39	900	2	125	1	110	643 Add Htg	(776)
2153	615	1,227	53	96	39	10	1,147	1,006	18.6	36.0	2 Oversupply	900	2	159	1.2	110	360	(375)
2151	615	1,215	53	96	39	9	1,147	1,004	18.6	36.0	1 Oversupply	900	2	159	1.2	110	356	(358)
2149	615	1,200	53	96	39	9	1,147	1,002	18.6	36.0	1 Oversupply	900	2	159	1.2	110	352	(358)
2147	615	1,200	53	96	39	9	1,147	1,000	18.6	36.0	1 Oversupply	900	2	159	1.2	110	352	(359)
2145	820	2,238	71	95	52	12	1,529	616	24.7	63.0	7 Oversupply	900	3	172	1.3	110	656	(1,155)
2143	615	1,200	53	95	39	9	1,147	996	18.6	36.0	1 Oversupply	900	2	159	1.2	110	352	(360)
2141	615	1,254	53	95	39	11	1,147	994	18.6	36.0	2 Oversupply	900	2	159	1.2	110	368	(379)
2158	1,230		106	96	79	23	2,293	135	37.1	37.1		900	3				0	(40)
2158A	205		18	#VALUE!	13	15	434	#VALUE!	7.0	16.0	Oversupply						0	#VALUE!
2148	820		71	96	52	15	1,529	619	24.7	24.7							0	181
2109	615		53	94	39	11	1,147	962	18.6	18.6							0	282
2146	615		53	96	39	11	1,147	999	18.6	18.6							0	293
2144	615		53	95	39	11	1,147	997	18.6	18.6							0	292
2157	615	3,047	53	96	39	21	1,147	1,010	18.6	84.0	9 Oversupply	900	4	172	1.3	110	893	(1,740)
2134			0	95	0	0	0	2,134	0.0	0.0							0	625
2132			0	95	0	0	0	2,132	0.0	0.0							0	625
2030			0	90	0	0	0	2,030	0.0	0.0							0	595
2107	615	1,500	53	94	39	10	1,147	960	18.6	36.0	5 Oversupply	900	3	125	1	110	440	(500)
2105	615	1,069	53	94	39	9	1,147	958	18.6	36.0	3 Oversupply	900	3	125	1	110	313	(464)
2103	615	1,084	53	94	39	11	1,147	956	18.6	42.0	Oversupply	900	2	172	1.3	110	318	(488)
2106	615	1,488	53	94	39	10	1,147	959	18.6	24.0	1 Oversupply	900	1	183	1.4	110	436 Add Htg	(18)
2102	1,230	2,193	106	94	79	20	2,293	191	37.1	42.0	4 Oversupply	900	2	172	1.3	110	643 Add Htg	(561)
2115	615	1,500	53	94	39	10	1,147	968	18.6	42.0	1 Oversupply	900	2	172	1.3	110	440	(503)
2114	615	1,488	53	94	39	10	1,147	967	18.6	21.0	5 Oversupply	900	1	172	1.3	110	436 Add Htg	(23)
2113	615	1,069	53	94	39	9	1,147	966	18.6	36.0	3 Oversupply	900	3	125	1	110	313	(462)
2111	615	1,084	53	94	39	11	1,147	964	18.6	36.0	5 Oversupply	900	3	125	1	110	318	(499)
2112	615		53	94	39	11	1,147	965	18.6	18.6							0	283
MES B2			0	#VALUE!	0	8	223	#VALUE!	3.6	5.0		900	1				0	#VALUE!
2118			0	94	0	5	134	1,984	2.2	2.2							0	581
2120	2,050	4,120	177	94	131	22	3,822	1,702	61.9	84.0	8 Oversupply	900	4	172	1.3	110	1,207 Add Htg	(1,732)
2122			0	94	0	9	252	1,870	4.1	5.0		900	1				0	531
2124	615	1,215	53	95	39	11	1,147	977	18.6	24.0	1 Oversupply	900	1	183	1.4	110	356 Add Htg	(13)
2126	615	2,948	53	95	39	11	1,147	979	18.6	54.0	5 Oversupply	900	3	159	1.2	110	864 Add Htg	(922)
C2-19			0	#VALUE!	0	5	157	#VALUE!	2.5	19.0	Oversupply						0	#VALUE!
C2-18			0	#VALUE!	0	24	691	#VALUE!	11.2	12.0	3	900	1				0	#VALUE!
C2-2			0	#VALUE!	0	15	432	#VALUE!	7.0	7.0							0	#VALUE!
C2-3			0	#VALUE!	0	7	203	#VALUE!	3.3								0	#VALUE!
C2-1/2010	960		83	#VALUE!	61	53	1,790	#VALUE!	29.0	30.0	4 Oversupply	900	2	144	1.1	110	0	#VALUE!
C2-9A			0	#VALUE!	0	7	218	#VALUE!	3.5	6.0							0	#VALUE!
2000	1,230		106	89	79	82	2,380	380	38.5	45.0	3 Oversupply	900	3	144	1.1	110	0	(715)
C2-11		861	0	#VALUE!	0	39	1,133	#VALUE!	18.3	37.0	Oversupply						252 Add Htg	#VALUE!
C2-12			0	#VALUE!	0	8	219	#VALUE!	3.5	6.0							0	#VALUE!
C2-13			0	#VALUE!	0	7	197	#VALUE!	3.2	5.0							0	#VALUE!
C2-14			0	#VALUE!	0	7	197	#VALUE!	3.2	5.0							0	#VALUE!
C2-15		1,065	0	#VALUE!	0	2	66	#VALUE!	1.1	41.0	Oversupply						312 Add Htg	#VALUE!
C2-16			0	#VALUE!	0	10	283	#VALUE!	4.6	8.0							0	#VALUE!
C2-17			0	#VALUE!	0	2	57	#VALUE!	0.9	2.0							0	#VALUE!
C2-9B			0	#VALUE!	0	8	231	#VALUE!	3.7	6.0							0	#VALUE!
A-2			0	#VALUE!	0	0	0	#VALUE!	0.0	0.0							0	#VALUE!
	46,130	59,523	3,990	0	2,949	1,165	86,007	86,007	SA SUM 7,354	Beam Sum 900 mm 157	cold water (l/h)	14,410	26,453	hot water (l/h)	585			
	46,130			3,990					63	SUM of	gpm	69,775	Heating	Htg Cap (BTU/hr)	3			
											Clg Cap (BTU/hr)				9,120			



space	Sensible Cooling	Latent Cooling	Heating	Latent Removal	Sensible Removal	Latent Removal	Minumum OA (Vbz)	Resultant Sensible Removal	Remaining Sensible	Min SA	SA via Beam	SA w/o Beam	Oversupply Test	Length of Beam	Beam Qty	Beam Cooling	Beam DeltaTw	Beam Water Flow	Heating	Heating Test	Beam Heating	Beam DeltaTw	Beam Water Flow	Balance of Qs (overcooling)
	BTU/hr	BTU/hr	BTU/hr	(CFM)	(CFM)	CFM	CFM	(BTU/hr)	(BTU/hr)	(l/s)	(l/s)	l/s		(mm)		(W)/unit	(K)	(l/h)/unit	(W)		(W)/unit	(K)	(l/h)/unit	(W)
3057	1,139	615	143	53	51	39	8	1,147	-8	18.6	18.6			900	1				42		75	1.5	54	73
3053	1,415	615		53	63	39	9	1,147	268	18.6	18.6			900	1	80	1	80	0					(1)
3051	1,415	615		53	63	39	17	1,147	268	18.6	18.6			900	1	80	1	80	0					(1)
3146	865		212	0	39	0	16	461	404	7.5	7.5			900	1	125	1	110	62					(7)
3144	1,415	615	211	53	63	39	11	1,147	268	18.6	18.6			900	1	80	1	80	62					(1)
3107	3,891	615	1,590	53	173	39	10	1,147	2,744	18.6	36.0	6 Oversupply		900	3	125	1	110	466					5
3105	3,832	615	1,243	53	171	39	9	1,147	2,685	18.6	36.0	5 Oversupply		900	3	125	1	110	364					6
3103	3,934	615	1,287	53	175	39	11	1,147	2,787	18.6	36.0	7 Oversupply		900	3	125	1	110	377					(1)
3106	2,583	615	1,772	53	115	39	12	1,147	1,436	18.6	24.0	4 Oversupply		900	2	125	1	110	519					0
3102	4,500	1,230	2,552	106	200	79	20	2,293	2,207	37.1	48.0	5 Oversupply		900	2	183	1.4	110	748 Add Htg	htg capable				#VALUE!
3091	3,289	2,050	352	177	146	131	68	3,822	-533	61.9	68.0	Oversupply		900	1			103		269	4.6	50		2
3094	2,535	615	1,652	53	113	39	12	1,147	1,388	18.6	24.0	3 Oversupply		900	2	125	1	110	484					4
3096	5,619	2,460	2,579	213	250	157	74	4,587	1,032	74.2	74.2	3		900	2	125	1	110	756 Add Htg	htg capable				#VALUE!
3097A	1,198	615	158	53	53	39	8	1,147	51	18.6	19.0			900	1			46		htg capable				#VALUE!
3150	2,534	1,230	349	106	113	79	18	2,293	241	37.1	41.0			900	1			102		htg capable				#VALUE!
3101	1,421	615	212	53	63	39	11	1,147	274	18.6	23.0	Oversupply		900	1			62		htg capable				#VALUE!
3148	1,336	615	191	53	59	39	48	1,405	-69	22.7	22.7			900	1			56		htg capable				#VALUE!
3089	3,522	2,460	318	213	157	157	61	4,587	-1,065	74.2	74.2			900	1			93		308	5.3	50		(4)
3095	4,278	615	1,752	53	190	39	10	1,147	3,131	18.6	45.0	4 Oversupply		900	3	125	1	110	513					(8)
3093	7,331	820	2,519	71	326	52	19	1,529	5,802	24.7	75.0	4 Oversupply		900	5	144	1.1	110	738					(2)
3055	1,139	615	143	53	51	39	8	1,147	-8	18.6	18.6			900	1			42		htg capable				#VALUE!
3026	1,460	615	222	53	65	39	12	1,147	313	18.6	24.0	Oversupply		900	1			65		htg capable				#VALUE!
3079				0	0	0	0	0	0	0.0	0.0							0						0
3013				0	0	0	0	0	0	0.0	0.0							0						0
3000	6,225	1,920	844	166	277	123	58	3,580	2,645	57.9	60.0	6 Oversupply		900	5	125	1	110	247					4
3149	3,436	615	1,357	53	153	39	9	1,147	2,289	18.6	36.0	2 Oversupply		900	2	159	1.2	110	398					1
3147	3,412	615	1,349	53	152	39	8	1,147	2,265	18.6	36.0	2 Oversupply		900	2	159	1.2	110	395					(6)
3145	3,412	615	1,349	53	152	39	8	1,147	2,265	18.6	36.0	2 Oversupply		900	2	159	1.2	110	395					(6)
3143	3,436	615	1,357	53	153	39	9	1,147	2,289	18.6	36.0	2 Oversupply		900	2	159	1.2	110	398					1
3141	3,412	615	1,349	53	152	39	8	1,147	2,265	18.6	36.0	2 Oversupply		900	2	159	1.2	110	395					(6)
3115	3,952	615	1,687	53	176	39	10	1,147	2,805	18.6	42.0	3 Oversupply		900	2	172	1.3	110	494					(1)
3113	3,832	615	1,243	53	171	39	9	1,147	2,685	18.6	42.0	1 Oversupply		900	2	172	1.3	110	364					0
3111	3,934	615	1,287	53	175	39	11	1,147	2,787	18.6	42.0	3 Oversupply		900	2	172	1.3	110	377					(6)
3114	2,808	615	1,892	53	125	39	14	1,147	1,661	18.6	30.0	Oversupply		900	2	144	1.1	110	554 Add Htg	htg capable				#VALUE!
3120	8,878	1,640	4,733	142	395	105	31	3,058	5,820	49.5	96.0	7 Oversupply		900	4	183	1.4	110	1,387 Add Htg	htg capable				#VALUE!
MES B3	419		103	0	19	0	8	223	196	3.6	7.0			900	1			30		htg capable				#VALUE!
3118				0	0	0	0	0	0	0.0	0.0							0						0
3134				0	0	0	0	0	0	0.0	0.0							0						0
3132				0	0	0	0	0	0	0.0	0.0							0						0
3130				0	0	0	0	0	0	0.0	0.0							0						0
3124	2,716	820	1,485	71	121	52	12	1,529	1,187	24.7	24.7	5 Oversupply		900	2	125	1	110	435					7
3125	12,310	2,050	6,720	177	548	131	107	3,822	8,488	61.9	135.0	11 Oversupply		900	5	193	1.5	110	1,969 Add Htg	htg capable				#VALUE!
C3-10	548		174	0	24	0	6	188	360	3.0	9.0	Oversupply		900	1			51		htg capable				#VALUE!
C3-12	634		201	0	28	0	8	219	415	3.5	10.0	Oversupply		900	1			59		htg capable				#VALUE!
C3-1	1,749		555	0	78	0	21	604	1,145	9.8	28.0	Oversupply		900	1			163		htg capable				#VALUE!
C3-15	7,439		3,408	0	331	0	33	971	6,468	15.7	75.0	6 Oversupply		900	5	144	1.1	110	999					(6)
C3-20/30	2,053	480	333	42	91	31	12	895	1,158	14.5	21.0	3 Oversupply		900	1	172	1.3	110	98					(5)
C3-19	1,876		595	0	84	0	22	647	1,229	10.5	21.0	Oversupply		900	1	172	1.3	110	174					(2)
C3-18	406		129	0	18	0	5	140	266	2.3	7.0	Oversupply						38 Add Htg						(8)
C3-17	629		199	0	28	0	7	217	412	3.5	10.0	Oversupply						58 Add Htg						3
C3-14	700		222	0	31	0	8	241	459	3.9	11.0	Oversupply						65 Add Htg						6
C3-16	193		61	0	9	0	2	66	127	1.1	3.0							18 Add Htg						2
C3-13	700		222	0	31	0	8	241	459	3.9	11.0	Oversupply						65 Add Htg						6
3009	3,171	840	479	73	141	54	62	1,820	1,351	29.5	30.0	5 Oversupply		900	2	144	1.1	110	140					8
A-3				0	0	0	0	0	0	0.0	0.0							0						0
				0	0	0	0	0	0	0.0	0.0							0						0
	142,931	32,760	52,790	2,834	6,363	2,095	972			SA SUM	8,270	Beam Sum	900 mm	186	cold water	(l/h)	17,180	34,035	hot water	(l/h)	962			
		175,691			9,197						cfm	Λ				gpm	76	SUM of			gpm	4		
																Clg Cap (BTU/hr)	80,970	Heating			Htg Cap (BTU/hr)	6,677		