


Indianapolis International Airport –
Midfield Terminal
Indianapolis, IN



Electrical Depth

Introduction

The electrical redesign for the Indianapolis International Airport is performed to only three of the interior spaces. Exterior electrical study is not included in this report. While most of my spaces are tremendously large, electrical system analysis is narrowed down to, and tightly joint with only the redesign of its lighting system. This report is a result of changes occurred to the electrical systems due to the modification of the existing lighting system and hence, readjustment is needed. Since the emergency power system and the uninterruptible power system should be left unaltered, mechanical and receptacle loads are also left unchanged to leave the overall picture the way it was. My primary focus is on the resizing of the distribution and lighting panels based on a primary voltage of 480/277V. Feeders will be resized and a voltage drop study will be performed to ensure the new distribution system is a efficient addition. LED luminaires are installed into the Passenger Concourse area, which as a result, requires a step down transformer to accommodate its low voltage needs. A cost analysis of the additional electrical equipments is included in my Construction Management Breadth Study.

Problem Statement

It is necessary to provide adequate power to additional lighting, following the NEC recommended practice. After the redesign of a new panelboard layout, with spares for future expansion and development, electrical equipments are specified according to the system demand.


Design Criteria

All electrical resizing was completed using requirements and tables from the 2002 National Electrical Code.

Design Goals

Upon completing technical assignment 2, it was evident that there are not many options, nor is it feasible for redesigning of the existing electrical system in this scale. Hence, I have only focused on the lighting distribution panelboard as part of my electrical depth requirement. I will re-design panelboard layout specifically to the addition of new lighting system, size feeders according to load demand, perform voltage drop study, as well as specifying new required electrical equipment such as panelboards and step down transformers. To illustrate the wiring layout, a switching and circuiting diagram for each analyzed space will be included. The retrofitted sytem should then to be included in the construction management breadth analysis of cost.

Indianapolis International Airport –
Midfield Terminal
Indianapolis, IN



Concourse Electrical Details

Circuit, Control and Wiring Layout

Please see attached Concourse Control Layout

Panelboard Layout

Please see attached Concourse panelboard layout

Equipment Specification:

Eaton Cutler-Hammer PRL-1a Distribution + Lighting Panel (see attached specification sheet)

Price: USD \$7,280.00

Designation: HA/L

Eaton Cutler-Hammer PRL-2a Distribution + Lighting Panel (see attached specification sheet)

Price: USD \$7,280.00

Designation: LA/L

Eaton 45 KVA K-factor Dry Type Transformer (see attached specification sheet)

480 Δ - 208Y/120V

Price: USD \$6,460.00

Catalog Number: H48M28F45CU

Load calculation for feeders leaving panel board HA/L:

Total Load: 179.8 KVA

Load Current: $179.8 \text{ KVA} / \sqrt{3} * 0.48 \text{ KV} * 1000 = 216.3 \text{ A}$

Feeder Size: 1 set of (3) #300 1" copper conductor rated at 75 degree Celsius

Voltage Drop

Length: 600 feet

Power Factor: 90%

Ampere-feet = $216.3 \text{ A} * 600 \text{ ft} = 129780 \text{ Amp-ft} = 130 * 1000 \text{ Amp-ft}$


Voltage Drop (line to neutral) = $130 \text{ Amp-ft} * 0.055 \text{ V/Amp-ft} = 7.15 \text{ V}$

Voltage Drop (line to line) = $7.15 * 1.73 = 12.3 \text{ V}$

% Voltage Drop = $12.3 \text{ V} / 480 \text{ V} * 100 = 2.5 \% \text{ (within 5\%)}$

Load calculation for feeders leaving panel board LA/L:

Indianapolis International Airport –
Midfield Terminal
Indianapolis, IN



Total Load: 33.8 KVA

Load Current: $33.8 \text{ KVA} / \sqrt{3} * 0.208 \text{ KV} * 1000 = 93.8 \text{ A}$

Feeder Size: 1 sets of (3) #2/0 1" copper conductor rated at 75 degree Celsius

Voltage Drop

Length: 600 feet

Power Factor: 80%

Ampere-feet = $93.8 \text{ A} * 600 \text{ ft} = 56280 \text{ Amp-ft} = 56.2 * 1000 \text{ Amp-ft}$

Voltage Drop (line to neutral) = $56.2 \text{ Amp-ft} * 0.104 \text{ V/Amp-ft} = 5.6 \text{ V}$

Voltage Drop (line to line) = $5.6 \text{ V} * 1.73 = 9.7 \text{ V}$

% Voltage Drop = $9.7 \text{ V} / 208 \text{ V} * 100 = 4.6 \% \text{ (within 5\%)}$

Civic Plaza & Ticket Hall Electrical Details

Circuit, Control and Wiring Layout

Please see attached Civic Plaza and Ticket Hall Control Layout

Panelboard Layout

Please see attached panelboard layout

Equipment Specification:

Eaton Cutler-Hammer PRL-1a Distribution + Lighting Panel (see attached specification sheet)

Price: USD \$7,280.00

Designation: HB/L

Eaton Cutler-Hammer PRL-2a Distribution + Lighting Panel (see attached specification sheet)

Price: USD \$7,280.00

Designation: LB/L

Eaton 45 KVA K-factor Dry Type Transformer (see attached specification sheet)

480 □ - 208Y/120V


Price: USD \$6,460.00

Catalog Number: H48M28F45CU

Load calculation for feeders leaving panel board HB/L:

Total Load: 69.95 KVA

Indianapolis International Airport –
Midfield Terminal
Indianapolis, IN



Load Current: $69.95 \text{ KVA} / \sqrt{3} * 0.48 \text{ KV} * 1000 = 84.1 \text{ A}$

Feeder Size: 1 sets of (3) #1 1" copper conductor rated at 75 degree Celsius

Voltage Drop

Length: 230 ft

Power Factor: 90%

Ampere-feet = $216.3 \text{ A} * 230 \text{ ft} = 49749 \text{ Amp-ft} = 50 * 1000 \text{ Amp-ft}$

Voltage Drop (line to neutral) = $50 \text{ Amp-ft} * .156 \text{ V/Amp-ft} = 7.8 \text{ V}$

Voltage Drop (line to line) = $7.8 \text{ V} * 1.73 = 13.5 \text{ V}$

% Voltage Drop = $13.5 \text{ V} / 480 \text{ V} * 100 = 2.8\%$ (within 5%)

Load calculation for feeders leaving panel board LB/L:

Total Load: 47 KVA

Load Current: $47 \text{ KVA} / \sqrt{3} * 0.208 \text{ KV} * 1000 = 130.7 \text{ A}$

Feeder Size: 1 sets of (3) #2/0 1" copper conductor rated at 75 degree Celsius

Voltage Drop

Length: 230 feet

Power Factor: 80%


Ampere-feet = $130.7 \text{ A} * 230 \text{ ft} = 30061 \text{ Amp-ft} = 30 * 1000 \text{ Amp-ft}$

Voltage Drop (line to neutral) = $30 \text{ Amp-ft} * 0.104 \text{ V/Amp-ft} = 3.12 \text{ V}$

Voltage Drop (line to line) = $3.12 \text{ V} * 1.73 = 5.4 \text{ V}$

% Voltage Drop = $5.4 \text{ V} / 208 \text{ V} * 100 = 26 \%$ (within 5%)

Indianapolis International Airport –
Midfield Terminal
Indianapolis, IN




Conclusion

The redesign of the electrical distribution system has presented potential problems such the length of the concourse can cause a very high value of voltage drop. However, this problem can be easily overcome with sizing a larger wire size to achieve a reasonable voltage drop value (within 5%). All panel boards, feeders, breakers, and transformers were resized based on this new system. The main adjustment of this system is the addition of several step down transformers to low voltage panels for LED lighting loads. Additional Lighting system resulted from the redesign had very little impact on the distribution system. Changes were made accordingly for the new lighting loads.


The redesign of my Civic Plaza lighting system has been effective. It yields a significantly lower lighting load which allows the consolidation of distribution panels with the Ticket Hall panelboard. A dedicated circuit is connected to each level of spotlights for flexible controls, accommodating the Civic Plaza's the multiple-purpose usage. For cost analysis, please refer to Construction Management Breadth Study.

Indianapolis International Airport –
Midfield Terminal
Indianapolis, IN




Concourse Lighting Panelboard																	
Panel HA / L		Eaton Culter-Hammer PRL-2a															
Voltage		480/277V 3P, 4W															
Breaker		250															
Bus		400															
Location Concourse																	
Ckt	Equipment	Demand	kVA	Amp	Bkr	Pole	A	B	C	Pole	Bkr	Ckt					
1	MH Lighting Zone 1-1	1.25	4.25	15.34	20	1	8.5				1	20	15.34	4.25	1.25	Fluor. Lighting Zone 1-1	
3	Fluor. Lighting Zone 2-1	1.25	4.25	15.34	20	1		8.5			1	20	15.34	4.25	1.25	Fluor. Lighting Zone 2-1	
5	Fluor. Lighting Zone 2-1	1.25	4.25	15.34	20	1			8.5		1	20	15.34	4.25	1.25	Fluor. Lighting Zone 2-1	
7	MH Lighting Zone 3-1	1.25	3.75	13.53	20	1	7.5				1	20	13.53	3.75	1.25	MH Lighting Zone 3-1	
9	Fluor. Lighting Zone 1-2	1.25	3.75	13.53	20	1			7.5		1	20	13.53	3.75	1.25	MH Lighting Zone 3-1	
11	Fluor. Lighting Zone 2-2	1.25	4.25	15.34	20	1			8.5		1	20	15.34	4.25	1.25	Fluor. Lighting Zone 1-2	
13	Fluor. Lighting Zone 2-2	1.25	4.25	15.34	20	1	8.5				1	20	15.34	4.25	1.25	Fluor. Lighting Zone 2-2	
15	MH Lighting Zone 3-2	1.25	4.25	15.34	20	1			8.5		1	20	15.34	4.25	1.25	Fluor. Lighting Zone 2-2	
17	Fluor. Lighting Zone 1-3	1.25	3.75	13.53	20	1			7.5		1	20	13.53	3.75	1.25	MH Lighting Zone 3-2	
19	Fluor. Lighting Zone 2-3	1.25	3.75	13.53	20	1	7.5				1	20	13.53	3.75	1.25	MH Lighting Zone 3-2	
21	Fluor. Lighting Zone 2-3	1.25	4.25	15.34	20	1			8.5		1	20	15.34	4.25	1.25	Fluor. Lighting Zone 1-3	
23	MH Lighting Zone 3-3	1.25	4.25	15.34	20	1			8.5		1	20	15.34	4.25	1.25	Fluor. Lighting Zone 1-3	
25	Fluor. Lighting Zone 1-4	1.25	4.25	15.34	20	1	8.5				1	20	15.34	4.25	1.25	Fluor. Lighting Zone 2-3	
27	Fluor. Lighting Zone 2-4	1.25	3.75	13.53	20	1			7.5		1	20	13.53	3.75	1.25	MH Lighting Zone 3-3	
29	Fluor. Lighting Zone 2-4	1.25	3.75	13.53	20	1			7.5		1	20	13.53	3.75	1.25	MH Lighting Zone 3-3	
31	MH Lighting Zone 3-4	1.25	4.25	15.34	20	1	8.5				1	20	15.34	4.25	1.25	Fluor. Lighting Zone 1-4	
33	SPARE	1	0	0	-	-			4.25		1	20	15.34	4.25	1.25	Fluor. Lighting Zone 2-4	
35	SPARE	1	0	0	-	-			4.25		1	20	15.34	4.25	1.25	Fluor. Lighting Zone 2-4	
37	LA / L	1	33.8	40.66	50	3	37.55				1	20	13.53	3.75	1.25	MH Lighting Zone 3-4	
39	LA / L	1							3.75		1	20	13.53	3.75	1.25	MH Lighting Zone 3-4	
41	LA / L	1							0		-	-	-	0	1	SPARE	
Total Load per phase						86.55		48.5								44.75	
Total Load						179.8		KVA									
Total Amps						216.3		A									

Indianapolis International Airport –
Midfield Terminal
Indianapolis, IN




Concourse Lighting Panelboard																	
Panel LA / L		Eaton Cutler-Hammer PRL-1a															
Voltage Breaker Bus		208/120V 3P, 4W 40 100															
Location Concourse																	
Ckt	Equipment	Demand	kVA	Amp	Bkr	Pole	A	B	C	Pole	Bkr	Demand	kVA	Amp	Demand	Equipment	Ckt
1	LED 1-1	1.25	2.113	17.59	20	1	4.225				1	20	17.59	2.11	1.25	LED 2-1	2
3	LED 3-1	1.25	2.113	17.59	20	1	4.225	4.225			1	20	17.59	2.11	1.25	LED 4-1	4
5	LED 1-2	1.25	2.113	17.59	20	1			4.225		1	20	17.59	2.11	1.25	LED 2-2	6
7	LED 3-2	1.25	2.113	17.59	20	1	4.225				1	20	17.59	2.11	1.25	LED 4-2	8
9	LED 1-3	1.25	2.113	17.59	20	1		4.225			1	20	17.59	2.11	1.25	LED 2-3	10
11	LED 3-3	1.25	2.113	17.59	20	1			4.225		1	20	17.59	2.11	1.25	LED 4-3	12
13	LED 1-4	1.25	2.113	17.59	20	1	4.225				1	20	17.59	2.11	1.25	LED 2-4	14
15	LED 3-4	1.25	2.113	17.59	20	1		4.225			1	20	17.59	2.11	1.25	LED 4-4	16
17	SPARE	1	0	0	20	1			0		1	20	0	0	1	SPARE	18
19	SPARE	1	0	0	20	1	0				1	20	0	0	1	SPARE	20
21	SPARE	1	0	0	-	1		0			1	-	0	0	1	SPARE	22
23	SPARE	1	0	0	-	1			0		1	-	0	0	1	SPARE	24
25	SPARE	1	0	0	-	1	0				1	-	0	0	1	SPARE	26
27	SPARE	1	0	0	-	1		0			1	-	0	0	1	SPARE	28
29	SPARE	1	0	0	-	1			0		1	-	0	0	1	SPARE	30
31	SPARE	1	0	0	-	1	0				1	-	0	0	1	SPARE	32
33	SPARE	1	0	0	-	1		0			1	-	0	0	1	SPARE	34
35	SPARE	1	0	0	-	1			0		1	-	0	0	1	SPARE	36
37	SPARE	1	0	0	-	1	0				1	-	0	0	1	SPARE	38
39	SPARE	1	0	0	-	1		0			1	-	0	0	1	SPARE	40
41	SPARE	1	0	0	-	1			0		1	-	0	0	1	SPARE	42
		Total Load per phase		12.68		12.68		8.45									
		Total Load		33.8		KVA											
		Total Amps		93.8		A											

Indianapolis International Airport –
Midfield Terminal
Indianapolis, IN




Civic Plaza & Ticket Hall Lighting Panelboard																	
Panel	HB / L	Voltage	480/277V 3P, 4W	Eaton Cutler-Hammer PRL-2a													
Location	Civic Plaza + Ticket Hall	Breaker	250														
		Bus	400														
Ckt	Equipment	Demand	kVA	Amp	Bkr	Pole	A	B	C	Pole	Bkr	Equipment	Demand	kVA	Amp	Bkr	Pole
1	MH Lighting Zone 1-1	1.25	3	10.83	20	1	4.5				1	MH Lighting Zone 1-1	1.25	1.5	5.413	20	2
3	MH Lighting Zone 2-1	1.25	3	10.83	20	1		6			1	MH Lighting Zone 2-1	1.25	3	10.83	20	4
5	MH Lighting Zone 3-1	1.25	3	10.83	20	1			6		1	MH Lighting Zone 3-1	1.25	3	10.83	20	6
7	Fluor. Lighting Zone 1-1,2	1.25	1.75	6.315	20	1	3.5				1	Fluor. Lighting Zone 1-2,4	1.25	1.75	6.315	20	8
9	Fluor. Lighting Zone 2-1,2	1.25	1.75	6.315	20	1		3.5			1	Fluor. Lighting Zone 2-3,4	1.25	1.75	6.315	20	10
11	MH Lighting Zone 3-1	1.25	5.25	18.94	20	1			10.5		1	MH Lighting Zone 3-3	1.25	5.25	18.94	20	12
13	MH Lighting Zone 3-1	1.25	5.25	18.94	20	1	10.5				1	MH Lighting Zone 3-3	1.25	5.25	18.94	20	14
15	MH Lighting Zone 3-2	1.25	5.25	18.94	20	1		10.5			1	MH Lighting Zone 3-4	1.25	5.25	18.94	20	16
17	MH Lighting Zone 3-2	1.25	5.25	18.94	20	1			10.5		1	MH Lighting Zone 3-4	1.25	5.25	18.94	20	18
19	SPARE	1	0	0	-	-	4.375				1	MH Lighting Zone 4-1	1.25	4.38	15.79	20	20
21	SPARE	1	0	0	-	-		4.375			1	MH Lighting Zone 4-2	1.25	4.38	15.79	20	22
23	SPARE	1	0	0	-	-			0		-	SPARE	1	0	0	-	24
25	SPARE	1	0	0	-	-	0				-	SPARE	1	0	0	-	26
27	SPARE	1	0	0	-	-		0			-	SPARE	1	0	0	-	28
29	SPARE	1	0	0	-	-			0		-	SPARE	1	0	0	-	30
31	SPARE	1	0	0	-	-	0				-	SPARE	1	0	0	-	32
33	SPARE	1	0	0	-	-		0			-	SPARE	1	0	0	-	34
35	SPARE	1	0	0	-	-			0		-	SPARE	1	0	0	-	36
37	LB / L	1	47.08	56.62	50	3	47.075				-	SPARE	1	0	0	-	38
39	LB / L	1						0			-	SPARE	1	0	0	-	40
41	LB / L	1							0		-	SPARE	1	0	0	-	42
													Total Load per phase		69.95	24-375	27
													Total Load		69.95	KVA	
													Total Amps		84.1	A	
Civic Plaza																	

Indianapolis International Airport –
Midfield Terminal
Indianapolis, IN




Civic Plaza & Ticket Hall Lighting Panelboard

Panel	LB / L	Voltage	208/120V 3P, 4W	Eaton Cutler-Hammer PRL-1a	A		B		C		Demand Equipment		Pole Bkr		Amp		kVA		Demand Equipment		Ckt	
Location	Civic Plaza + Ticket Hall	Breaker	40	100																		
Ckt	Equipment	Demand	kVA	Amp	Bkr	Pole																
1	LED Zone 4 (78ft)	1.25	2.288	19.05	20	1	4.575					1.25	2.29	19.05	20	1	19.05	2.29	1.25	LED Zone 4 (78ft)	2	
3	LED Zone 4 (78ft)	1.25	2.288	19.05	20	1		4.575				1.25	2.29	19.05	20	1	19.05	2.29	1.25	LED Zone 4 (78ft)	4	
5	LED Zone 4 (78ft)	1.25	2.288	19.05	20	1			4.575			1.25	2.29	19.05	20	1	19.05	2.29	1.25	LED Zone 4 (78ft)	6	
7	LED Zone 4 (78ft)	1.25	2.288	19.05	20	1	4.575					1.25	2.29	19.05	20	1	19.05	2.29	1.25	LED Zone 4 (78ft)	8	
9	LED Zone 4 (78ft)	1.25	2.288	19.05	20	1		4.575				1.25	2.29	19.05	20	1	19.05	2.29	1.25	LED Zone 4 (78ft)	10	
11	LED Zone 4 (78ft)	1.25	2.288	19.05	20	1	4.575					1.25	2.29	19.05	20	1	19.05	2.29	1.25	LED Zone 4 (78ft)	12	
13	LED Zone 4 (78ft)	1.25	2.288	19.05	20	1		4.575				1.25	2.29	19.05	20	1	19.05	2.29	1.25	LED Zone 4 (78ft)	14	
15	LED Zone 4 (78ft)	1.25	2.288	19.05	20	1	4.575					1.25	2.29	19.05	20	1	19.05	2.29	1.25	LED Zone 4 (78ft)	16	
17	LED Zone 4 (78ft)	1.25	2.288	19.05	20	1		4.575				1.25	2.29	19.05	20	1	19.05	2.29	1.25	LED Zone 4 (78ft)	18	
19	LED Zone 4 (78ft)	1.25	2.288	19.05	20	1	4.575					1.25	2.29	19.05	20	1	19.05	2.29	1.25	LED Zone 4 (78ft)	20	
21	SPARE	1	0	0	-	1		1.325				1.25	1.33	4.781	20	1	4.781	1.33	1.25	LED Zone 5 (Ticket Hall)	22	
23	SPARE	1	0	0	-	1			0			1.25	0	-	0	1	-	0	1	SPARE	24	
25	SPARE	1	0	0	-	1	0					1.25	0	-	0	1	-	0	1	SPARE	26	
27	SPARE	1	0	0	-	1		0				1.25	0	-	0	1	-	0	1	SPARE	28	
29	SPARE	1	0	0	-	1			0			1.25	0	-	0	1	-	0	1	SPARE	30	
31	SPARE	1	0	0	-	1	0					1.25	0	-	0	1	-	0	1	SPARE	32	
33	SPARE	1	0	0	-	1		0				1.25	0	-	0	1	-	0	1	SPARE	34	
35	SPARE	1	0	0	-	1			0			1.25	0	-	0	1	-	0	1	SPARE	36	
37	SPARE	1	0	0	-	1	0					1.25	0	-	0	1	-	0	1	SPARE	38	
39	SPARE	1	0	0	-	1		0				1.25	0	-	0	1	-	0	1	SPARE	40	
41	SPARE	1	0	0	-	1			0			1.25	0	-	0	1	-	0	1	SPARE	42	
					Total Load per phase		18.3	15.05	13.725													
					Total Load		47.075	KVA														
					Total Amps		130.7	A														
Civic Plaza																						




1

Departure Canopy Switching Enlarged




Scale: 1"=32'




1

Departure Canopy + Ticket Counter Hall Switching



Scale: 1" = 32'






Civic Plaza Control + Switching

Scale: 1"=32'





1

Concourse Control Zone



Scale: 1"=16'