

Philip Mackey  
L/E  
Dr. Mistrick

Holy Cross Hospital – North Addition  
Silver Spring, MD  
1/17/06

## Lutron Presentation Critiques

### Sandra

Throughout – a little key plan that helps figure out where you are in the space  
Some sketches were nice, some...needed work  
Birds flying in the multipurpose room (pendants?)  
Lost in the transition from some slides to other slides – blue on black  
Liked how you thought out light on surfaces, vertical surfaces particularly  
Flag wasn't lit  
Overall – nice presentation, little more on the exterior  
    Good concept, just needs to be developed more  
    Good systematic report, good walkthrough space to space  
    Just need to improve some graphical spaces

### Luke

Key plan would be very helpful  
Like the idea of the inspirational shot, but set up for disappointment  
    Didn't institute recovery space  
    Brightness of the surrounding, sketches indicated but verbage did not  
Reception desk – flood lights, cove, column...if we do the cove and the column cover,  
    how will that affect each other...choose one damn it  
Commented on Kelvin temperature...but you need to evaluate client, can be hard to  
    maintain, careful not to set yourself up for an inconsistency that will not last,  
Looking for hand sketch at the end of the presentation  
Registration area, doesn't think enough light is being provided for task  
Multipurpose room, think about it as three separate rooms, not just the single room when  
    the divider is open.  
Drop a screen, and backlight from inside the atrium, what happens on the outside?  
    Change screen to translucent material that is light from behind and thus glows  
    outwards.  
  
“if it could be wrong through maintenance, make sure everyone will know its wrong  
    when it's done wrong”