



# A p p e n d i x V



## Design Calculations

Project	Prepared by	Date
Subject/Title	Reviewed by	Date
ERV calculations	Calculation Number	Sheet 1 of 2

### Exhaust (total)

Tx-A → (5) @ 180 cfm  
 Tx-B → (5) @ 360 cfm  
 Tx-D → (1) @ 180 cfm  
2880 cfm

### RS-Means

↳ 320 cfm = \$400

$$\Rightarrow \text{Exhaust cost} = 2880 \times \frac{400}{320} = \$3600$$

### ERV costs

$$\$3200 \times 2 = \$6400$$

$$\begin{array}{r} \$6400 \\ - \$3600 \\ \hline \$2800 \leftarrow \text{Need to make up} \end{array}$$

### Sensible heat

$$\Delta T = (90^\circ - 70^\circ) = 20^\circ$$

$$q_s = 1.08 \text{ cfm } \Delta T$$

$$= (1.08)(2880)(20^\circ) = 62,208 \text{ BTu/hr}$$

\* ERV is 50% more efficient

$$\Rightarrow 31,104 \text{ BTu/hr saving @ } 1 \text{ Kw/ton}$$

$$\Rightarrow \frac{31,104}{12,000} = 2.59 \text{ Ton} \times 1 \text{ Kw/ton} = 2.59 \text{ Kw}$$

cost is 10¢/kw

$$\Rightarrow 25.9 \text{ ¢ saved per hour}$$

## Design Calculations

Project	Prepared by	Date
Subject/Title	Reviewed by	Date
	Calculation Number	Sheet 2 of 2

$$\frac{\$2800}{\$0.259/\text{hr}} = 10,810 \text{ hrs}$$

→ IP running 8 hrs per day @ 90°

$$10810 \text{ hr} \times \frac{1 \text{ day}}{8 \text{ hr}} = 1351 \text{ days}$$

→ assume 150 days a year where its at least 90°

$$1351/150 = 9 \text{ years}$$

