


APPENDIX C

Structural Calculations:

STRUCTURAL CALCULATIONS: ADDING COOLING TOWER



$$M = \frac{wL^2}{8}$$

$$\begin{aligned} W &= 1.2 \times (40) + 1.6(20) \\ &= 80 \text{ PSF (10,22)} \\ &= 818 \text{ PLF} \end{aligned}$$

$$M = \frac{818(28)^2}{8}$$

$$M_U = 80.14 \text{ Ft-K}$$

BEAM


DEAD LOAD:

40 PSF [FROM UNITED STEEL DECK]

LIVE LOAD:

20 PSF [ASCE 705]

NEW COOLING TOWER



$$\begin{aligned} M &= R_1 \left(a + \frac{R_1}{2W} \right) \\ &= 3,648 \left(10 + \frac{3,648}{2(924)} \right) \end{aligned}$$

$$M_U = 36.15$$

DEAD

$$12160/2 = 6080/7.896'$$

$$= 770 \text{ PLF}$$

$$W_U = 1.2(770)$$

$$= 924 \text{ PLF}$$

$$R_1 = \frac{924(7.896)}{2}$$

$$R_1 = 3648 \text{ P}$$

BEAM + COOLING TOWER

$$M_{U \text{ TOTAL}} = 80.14 + 36.5 = \underline{\underline{116.63 \text{ Ft-K}}}$$

CHECK HSS 10 x 6 x 3/8

$$\lambda = b/t = 14.2$$

$$\lambda = h/t = 25.7$$

SECTION 16.2.4

$$\lambda_p = 3.76 \sqrt{E/F_y} = \frac{29000 \text{ KSI}}{46 \text{ KSI}} = 94.4$$

$$\lambda_r = 5.7 \sqrt{E/F_y} = 5.7 \times 25.1 = 143.07$$

CARBON A500 GR. B, $F_y = 46$ $F_u = 58$

FOLLOWING EQN FROM LRFD PG 16.2.7

DESIGN SPEC FOR STEEL TOWER STRUCTURE

$$M = F_y Z = 48 \times 33.8 \text{ IN}^3 = 1622.4 \text{ K}\cdot\text{IN} = 135.2 \text{ K}\cdot\text{FT}$$

$$135.2 \text{ K}\cdot\text{FT} > 116.63 \text{ K}\cdot\text{FT}$$

SO BEAM OK FOR NEW COOLING TOWERS