

Comments from Lutron.

- Be more confident in my design and go with it without hesitation.
- Top of flagpole fixture may cause glare and the wind blows so it probably won't work too well.
- Lighting of the anchor is an issue; one suggestion was to add in a light pole closer to it.
- Being a Naval base they didn't like the random order of the fixtures in the lobby or bollards along the sidewalk.
- Sconces compete with the pendants in the lobby
- Just adding in light to get my renderings showed some interesting light patterns for the lobby, something I can look at.
- What I did with the auditorium some liked and others thought it was too decorative for the navy.
- Liked the idea of the daylight in the office area but thought that the skylights were spaced too far apart.
- Unsure of how the controls would work for the up and downlight components of the cubicle fixtures.
- Glare issues from the cubicle fixtures for someone leaning over one cubicle to talk to a person in the next.