

Lighting Designer Comments

From Lutron Headquarters, Coopersburg, PA



The Pennsylvania Academy of Music
Lancaster, PA

David Smith
Lighting/Electrical Option

December 15, 2006

Faculty Advisor: Dr. Mistrick
Electrical Advisor: Ted Dannerth

Sandra Stashik

Is the building LEED rated?

Good hierarchy of light

Hand sketch of exterior should be a bit stronger and have more contrast

Wanted a more clear explanation of inspection table

Luke Tique

Outside of façade could have been darker

Didn't address the desk area in the library

Roof terrace picture was good but needed to explain the design better – Non-uniform?

Kari Nystrom

Didn't like the HID lighting, thought it reminded her of prison yard

Roof terrace is more like an indoor space, and should treat it that way

Renderings seemed flat, too uniform compared to computer models