



# 1050 K STREET

## Mechanical Systems Redesign

Malory J. Faust • Mechanical Option • Senior Thesis 2007



1050 K Street

# Topics of Discussion

- Building Introduction
- Chilled Beam Analysis
- Solar Shading Analysis
- Daylighting Analysis
- Conclusions



1050 K Street

Building Introduction

Chilled Beam Analysis

Solar Shading Analysis

Daylighting Analysis

Conclusions

# Project Team

- Owners: The Lenkin Company  
The Tower Companies
- Contractor: The Lenkin Company
- Architect: Hickok Cole Architects
- Structural Engineer: Tadjer Cohen  
Edelson Associates
- MEP Engineer: Vanderweil Engineers
- Civil Engineer: Timmons Group
- Curtain Wall Consultant: CDC



1050 K Street

# Building Site

- Located on the corner of 11<sup>th</sup> & K Streets
- Streets on the North & West facades
- Alleys on East & South facades

Building Introduction

Chilled Beam Analysis

Solar Shading Analysis

Daylighting Analysis

Conclusions





1050 K Street

Building Introduction

Chilled Beam Analysis


Solar Shading Analysis

Daylighting Analysis

Conclusions

# Architectural Background

- 11 story office building
- 4 levels below ground for parking
- Retail on the first level
- Curtain Wall – North & West facades
- Green Roof





1050 K Street

Building Introduction

Chilled Beam Analysis

Solar Shading Analysis

Daylighting Analysis

Conclusions

# System Summary

- Energy Recovery Unit (ERU)
  - 30,000 CFM Enthalpy Wheel
  - Cooling Coil
- AHU with cooling on each level
- VAV System with terminal reheat
- Chiller Plant
  - (3) 115 ton rotary screw chillers
  - (2) Cell, Induced draft open cell cooling tower
  - Waterside free cooling HX
- All heating done by enthalpy wheel and electric reheat



1050 K Street

# System Summary

- Energy Consumption

Building Introduction


Chilled Beam Analysis

Solar Shading Analysis

Daylighting Analysis

Conclusions

Energy Simulation Summaries	
Enduse	KWh
Space Cooling	124400
Heat Rejection	7000
Space Heating	154200
Hot Water	44500
Vent Fans	242700
Pumps & Auxillary	243200
Misc Equipment	277700
Lighting	482700
Total	1576400





1050 K Street

Building Introduction

Chilled Beam Analysis

Solar Shading Analysis

Daylighting Analysis

Conclusions

# System Summary

- Initial Cost

VAV System Initial Cost Data				
Component Description	Materials Cost	Unit	Total Units	Cost
VAV Box 300-600 CFM W/RH	\$ 358.00	Ea	80	\$ 28,640.00
VAV Box 500-1000 CFM W/RH	\$ 368.00	Ea	11	\$ 4,048.00
VAV Box 800-1600 CFM W/RH	\$ 383.00	Ea	1	\$ 383.00
VAV Box 500-1000 CFM W/o RH	\$ 345.00	Ea	22	\$ 7,590.00
Air Handling Unit 8000 CFM	\$ 13,353.00	Ea	1	\$ 13,353.00
Air Handling Unit 12500 CFM	\$ 18,470.00	Ea	1	\$ 18,470.00
Air Handling Unit 13500	\$ 19,850.00	Ea	9	\$ 178,650.00
				\$ 251,134.00





1050 K Street

Building Introduction

Chilled Beam Analysis

Solar Shading Analysis

Daylighting Analysis

Conclusions

# Alternate Mechanical System

- Design Goals
  - Lessen annual energy consumption
  - Flexible system layouts & capacities
  - Aesthetically responsive



1050 K Street

Building Introduction

Chilled Beam Analysis

Solar Shading Analysis

Daylighting Analysis

Conclusions

# Chilled Beam Background

- Air Conditioning system providing cooling & heating
- Uses principles of induction and free convection
- Can significantly reduce energy costs
- Aesthetic benefits





1050 K Street

Building Introduction

Chilled Beam Analysis



Solar Shading Analysis

Daylighting Analysis

Conclusions

# Chilled Beam Background

- Active
  - Integrated with outdoor air supply
  - Utilizes air flow to induce room air
  - Can provide heating when requirements are low
- Passive
  - Typically used parallel to another system
  - Do not supply outdoor air
  - Rely on natural convection for cooling
  - May be provided in addition to active beams in high cooling spaces





1050 K Street

Building Introduction

Chilled Beam Analysis


Solar Shading Analysis

Daylighting Analysis

Conclusions

# Calculation Procedure

- eQuest
  - Core & Shell design did not require room by room analysis
  - Zoning
    - 4 perimeter zones (15')
    - 1 core zone





1050 K Street

Building Introduction

Chilled Beam Analysis

Solar Shading Analysis

Daylighting Analysis

Conclusions

# Calculation Procedure

- eQuest
  - Modeled as one large chilled beam per zone
  - Each beam modeled as a fan coil unit, removing the fan
  - Utilized “OA-From-System” command to provide ventilation to units
  - Attached all latent load to ERU dummy zone to decouple the space cooling loads



1050 K Street

Building Introduction

Chilled Beam Analysis

Solar Shading Analysis


Daylighting Analysis

Conclusions

# Simulation Results

- Energy Consumption

Energy Simulation Summaries	
Enduse	KWh
Space Cooling	166400
Heat Rejection	7500
Space Heating	84600
Hot Water	44500
Vent Fans	39400
Pumps & Auxillary	316400
Misc Equipment	277700
Lighting	482700
Total	1419200



- 10 % reduction in energy consumption
- Overall savings of 157200 KWh/year



1050 K Street

Building Introduction

Chilled Beam Analysis

Solar Shading Analysis

Daylighting Analysis

Conclusions

# System Design Summary

- Chilled Beam Sizing
  - Used Halton Hit Design Program
  - Maintained ventilation requirements
  - Uphold aesthetic appeal of office spaces



1050 K Street

Building Introduction

Chilled Beam Analysis

Solar Shading Analysis

Daylighting Analysis

Conclusions

# System Design Summary

Halton HIT Design - Unit selection design data

**DESIGN DATA**

Total air flow rate:  l/s

AQ opening:

Nozzle airflow rate:  l/s

AQ diffuser airflow rate:  l/s

Supply air temperature:  °C

Inlet water temperature:  °C

Outlet water temperature:

Water mass flow rate:  kg/s

**SPACE RESULTS**

Air flow:	180	l/s
Room temperature:	22.0	°C
Supply air temperature:	18.0	°C
Inlet water temperature:	14.0	°C
Heat gain:	0	W
Primary air capacity:	866	W
Coil capacity:	6786	W
Total capacity:	7652	W
Water mass flow rate:	1.080	kg/s

**UNIT PERFORMANCE**

Air flow:	6	l/s
Primary air capacity:	29	W
Coil capacity:	226	W
Total capacity:	255	W
Total pressure drop:	111	Pa
Water pressure drop:	0.6	kPa
Water mass flow rate:	0.036	kg/s
Sound pressure level:	14	LpA

**LOCATION**

Installation height:  m    Columns:

Location:     Rows:

**VELOCITY CONTROL**

Side:     Middle:

**VIEW**

3D     Side    vlim:  m/s

**DESIGN STATUS**

\*OK\*





1050 K Street

Building Introduction

Chilled Beam Analysis

Solar Shading Analysis

Daylighting Analysis

Conclusions

# System Design Summary

- Chilled Beam Layout
  - Perimeter zones
    - East & West – (2) rows of 15
    - South & North – (2) rows of 9
    - All additional cooling by passive
  - Internal
    - 11 rows to line up with perimeter active beams



1050 K Street

Building Introduction

Chilled Beam Analysis

Solar Shading Analysis

Daylighting Analysis

Conclusions

# System Design Summary

- Chilled Beam System Cost
  - Cost of Beams: \$200/ LF
  - 1985 Beams total
  - 735 MBH Electric Boiler

Chilled Beam Initial Cost				
Component Description	Materials Cost	Unit	Total Units	Cost
Chilled Beam	\$ 200.00	LF	7940	\$ 1,588,000.00
Boiler	\$ 10,300.00	Ea	1	\$ 10,300.00
				\$ 1,598,300.00



1050 K Street

Building Introduction

Chilled Beam Analysis

Solar Shading Analysis

Daylighting Analysis

Conclusions

# Solar Shading Background

- Blocks 75% of incoming radiation
- Absorbs up to 15 % of incoming radiation
- Prevents 25% of internal heat from escaping in heating conditions
- Transparent
- Reduces glare





1050 K Street

Building Introduction

Chilled Beam Analysis

Solar Shading Analysis

Daylighting Analysis

Conclusions

# Design Summary

- Apply shades to 100% of curtain wall
- North and West facades
- 8'–9" floor to ceiling height
- 235 LF of shades
- (517) 5x8.75 shades

Chilled Beam Initial Cost

Component Description	Materials Cost	Unit	Total Units	Cost
Chilled Beam	\$ 200.00	LF	7160	\$ 1,432,000.00
Solar Shades	\$164	43.75 SF	514.8	\$ 84,427.20
Boiler	\$ 10,300.00	Ea	1	\$ 10,300.00
				\$ 1,526,727.20



1050 K Street

Building Introduction

Chilled Beam Analysis

Solar Shading Analysis


Daylighting Analysis

Conclusions

# Design Summary

- Energy Consumption

Energy Simulation Summaries	
Enduse	KWh
Space Cooling	157400
Heat Rejection	7100
Space Heating	89800
Hot Water	44500
Vent Fans	39300
Pumps & Auxillary	294800
Misc Equipment	277700
Lighting	482700
<b>Total</b>	<b>1393300</b>



- 6% reduction in cooling energy
- 7% reduction in pump energy



1050 K Street

Building Introduction

Chilled Beam Analysis

Solar Shading Analysis

Daylighting Analysis

Conclusions

# Daylighting Background

- Daylight sensors installed in perimeter zones
- Utilize sunlight when sufficient
- Decrease lighting energy consumption
- Sophisticated, dynamic controls
- Require calibration



1050 K Street

Building Introduction

Chilled Beam Analysis

Solar Shading Analysis


Daylighting Analysis

Conclusions

# Design Summary

- Energy Consumption

Energy Simulation Summaries		
Enduse	VAV	Daylighting
Space Cooling	124400	116100
Heat Rejection	7000	6500
Space Heating	154200	155900
Hot Water	44500	44500
Vent Fans	242700	230500
Pumps & Auxillary	243200	236200
Misc Equipment	277700	277700
Lighting	482700	364200
Total	1576400	1431600



- 25% reduction in lighting energy consumption



1050 K Street

Building Introduction

Chilled Beam Analysis

Solar Shading Analysis

Daylighting Analysis

Conclusions

# Conclusions

Simple Payback Summary				
	VAV	Chilled Beam	Shading	Daylighting
Initial Cost	\$ 251,134.00	\$ 1,598,300.00	\$ 1,526,727.00	n/a
Annual Energy Cost	\$ 189,010.36	\$ 170,174.07	\$ 167,056.67	\$ 171,648.84
Annual Savings	\$ -	\$ 18,836.29	\$ 21,953.69	\$ 17,361.52
Simple Payback	0	71.5	58.1	n/a

- Regardless of energy savings the chilled beam system is not more economical solution than the VAV system due to drastic initial cost differences





1050 K Street

Building Introduction

Chilled Beam Analysis

Solar Shading Analysis

Daylighting Analysis

Conclusions

# Thank You

- All AE Faculty and Staff
- My classmates, especially Erin & Patrick
- My family and friends
- Professionals at Vanderweil Engineers, especially Brandon Harwick and Sam Bohsali



1050 K Street

Building Introduction

Chilled Beam Analysis

Solar Shading Analysis

Daylighting Analysis

Conclusions

# Questions

