Patrick B. Murphy

Penn State Architectural Engineering **Mechanical Option Senior Thesis**

Sustainable Solutions for Energy Efficiency and Acoustics

Study Building:

Name: James Lee Soreson Language and Communication Center (SLCC)

Location: Washington, DC (NE)
Owner: Gallaudet University

Architect: SmithGroup

Engineers: SmithGroup (MEP, Structural)

Floor Area: 87,000SF \$24,054,000

LEED Rating: Certified

vis·u·cen·tric (vĭzh'ōō-sĕn'trĭk) adj.:


- 1. The design of a destinctive structure that clearly and unmistakably says "this is a space for deaf people."
- A design for the deaf "way of being" based on visual communication.



Rendering of the main entrance to the SLCC (SmithGroup)


Green Roof:

HVAC Energy Savings: 256.5 MMBTU/yr



The green roof energy savings were based on an energy balance of all modes of heat flux and average ambient monthly conditions.

The energy profile shows the sinusoidal nature of heat gain through the different roof types over 24 hours.



400,000 gallons held back **Stormwater runoff:** Anacostia River annually.

Minimizes Urban Heat Island Effect


Acoustic Insulation: Dampens traffic noise of downtown Washington, DC.


Acoustic Analysis:


The SLCC contains several Audiology Labs, Therapy Rooms, and a Hearing Aid Fitting Center. These spaces require NC-25 or quieter conditions.

Green Roof: Mass dampens lower frequency noise. allows mechanical noise to govern.

DOAS System: Less air movement and elimination of VAV boxes also reduces noise in occupied spaces.







The proposed DOAS System and Green Roof provide optimal conditions in a typical classroom for three cases of outdoor noise: average conditions (blue), car traffic (purple), and large truck driving by (green)

LEGEND AHU-1 AHU-2 AHU-3 AHU-4 AHU-5 AHU-6

Mechanical system zones are based on occupancy

PRV to LPS (15psig) to HHW (180F)

Six (6) Trane M-Series AHUs

Original Design

Air-side Economizer with Enthalpy Ctrl.

Remote CHW (43F) and HPS (100psig)

Variable Air Volume with Terminal Reheat

30x8

72,875 CFM

21,630 CFM

2,167 MMBH

\$153,000

Mechanical System

Proposed Design

Туре

Dedicated Outdoor Air System (DOAS)

Equipment

Merge AHUs 4,6 for total of five (5) AHUs

Plants

Remote CHW (43F) and HPS (100psig) PRV to LPS (15psig) to HHW (180F)

Energy Saving Strategies

Plate ERV Enthalpy Exchanger

Outdoor Air Supply

17,835 CFM

Total Supply Air

17,835 CFM

Annual Cooling Energy Use

Annual Operating Cost

\$128,600

1,746 MMBH

Special Thanks to:

schedule and special loads.





48×18



