

INDIVIDUAL TRANSFORMER SCHEDULE

TAG	PRIMARY VOLTAGE	SECONDARY VOLTAGE	SIZE	TYPE	MOUNTING	REMARKS
1-T01	480V,3PH,3W.	208Y/120V,3PH,4W	30	GENERAL DUTY DRY	TRAPEZE NOUNTED	K-1 RATED
1T02	480V,3PH,3W.	208Y/120V,3PH,4W	150	ISOLATION DRY	PAD MOUNTED ON FLOOR	K-1 RATED
2-T01	480V,3PH,3W.	208Y/120V,3PH,4W	15	GENERAL DUTY DRY	TRAPEZE NOUNTED	K-1 RATED
2-T02	480V,3PH,3W.	208Y/120V,3PH,4W	15	GENERAL DUTY DRY	TRAPEZE NOUNTED	K-1 RATED
2-T03	480V,3PH,3W.	208Y/120V,3PH,4W	112	GENERAL DUTY DRY	PAD MOUNTED ON FLOOR	K-1 RATED

NOTES:

1. REFER TO SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS